

June

17  
TH

Daily Record of Events

NOTE. - M. FERDA (2004)

Plant Status

100% GREEN NO CO's

▶ Mtg: @ Discuss EOC/SCWE Public Meeting  
@ SCWE - Regular "Fast Print" + Follow-up Actions.  
M. Lof, Blay, Guy, Milon, Lisa Zerk., J. Clifford.  
ASM → (A. S. hos)

▶ RCIC Oil Issue. Identified  
- IN 81-24 Max. Feed Pump Turbine Bearing Failures  
\* Discussed 2 turbine journal bearing failures due to  
failure to maintain oil level within narrow range.  
→ CA included clearly marky MAX + MIN allowed  
oil levels.  
- ~~RCIC~~ HCOP-30.BD-0001 states 3.2.3 "...oil  
level sensor should be filled to between MAX + MIN  
marks on level gauge." NCA address IN 81-24.  
Ⓢ → Swr. Test inadequate states a general level bad.  
(711122)

PS - 1

COU - 5

711122-1

BIP - 1

ASM - 45

8:30 - 5:30 pm 8/1

B-26