

Jeffrey B. Archie  
Vice President, Nuclear Operations  
803.345.4214



February 28, 2006

Document Control Desk  
U. S. Nuclear Regulatory Commission  
Washington, DC 20555

Dear Sir or Madam:


Subject: VIRGIL C. SUMMER NUCLEAR STATION  
DOCKET NO. 50/395  
OPERATING LICENSE NO. NPF-12  
SPECIAL REPORT (SPR) 2006-001

South Carolina Electric & Gas Company (SCE&G) is submitting this report pursuant to the requirements of Technical Specification 3.3.3.1.b. This report addresses the inoperability of the Main Plant Vent and Reactor Building Purge Supply and Exhaust System radiation monitors (RMA-13 and RMA-14) for greater than 72 hours. During the inoperable period of 90 hours and 45 minutes, V. C. Summer Nuclear Station (VCSNS) implemented a preplanned alternate monitoring in accordance with the requirements of Action 30 of the Technical Specification.

The radiation monitors were removed from service on February 11, 2006 at 1625 hours in order to replace the Victoreen Model 845 series radiation monitors with a new Victoreen Model 945A series to improve equipment reliability. The modifications were completed and the equipment returned to operability on February 15, 2006 at 1110 hours.

Should you have any questions, please call Mr. Robert Sweet at (803) 345-4080 at your convenience.

Very truly yours,



Jeffrey B. Archie

CJM/JBA/cm

c: N. O. Lorick  
S. A. Byrne  
N. S. Cams  
J. H. Hamilton  
R. J. White  
W. D. Travers  
R. E. Martin  
K. M. Sutton  
NRC Resident Inspector  
INPO Records Center  
NSRC  
CER (C-06-0572)  
File (818.08)  
DMS (RC-06-0042)

IE22