

3.3 INSTRUMENTATION

3.3.1.1 Reactor Protection System (RPS) Instrumentation

LCO 3.3.1.1 The RPS instrumentation for each Function in Table 3.3.1.1-1 shall be OPERABLE.

APPLICABILITY: According to Table 3.3.1.1-1.

ACTIONS

-----NOTE-----
Separate Condition entry is allowed for each channel.

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more required channels inoperable.	A.1 Place channel in trip. <u>OR</u> A.2 -----NOTE----- Not applicable for Functions 2.a, 2.b, 2.c, 2.d, or 2.f. ----- Place associated trip system in trip	12 hours 12 hours
B. -----NOTE----- Not applicable for Functions 2.a, 2.b, 2.c, 2.d, or 2.f. ----- One or more Functions with one or more required channels inoperable in both trip systems.	B.1 Place channel in one trip system in trip. <u>OR</u> B.2 Place one trip system in trip	6 hours 6 hours
C. One or more Functions with RPS trip capability not maintained.	C.1 Restore RPS trip capability.	1 hour

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
D. Required Action and associated Completion Time of Condition A, B, or C not met.	D.1 Enter the Condition referenced in Table 3.3.1.1-1 for the channels.	Immediately
E. As required by Required Action D.1 and referenced in Table 3.3.1.1-1.	E.1 Reduce THERMAL POWER to < 30% RTP.	4 hours
F. As required by Required Action D.1 and referenced in Table 3.3.1.1-1.	F.1 Be in MODE 2.	6 hours
G. As required by Required Action D.1 and referenced in Table 3.3.1.1-1.	G.1 Be in MODE 3.	12 hours
H. As required by Required Action D.1 and referenced in Table 3.3.1.1-1.	H.1 Initiate action to fully insert all insertable control rods in core cells containing one or more fuel assemblies.	Immediately
I. As required by Required Action D.1 and referenced in Table 3.3.1.1-1.	I.1 Initiate alternate method to detect and suppress thermal hydraulic instability oscillations. <u>AND</u> I.2 Restore required channels to OPERABLE.	12 hours 120 days
J. Required Action and associated Completion Time of Condition I not met.	J.1 Reduce THERMAL POWER to <25% RTP.	4 hours

SURVEILLANCE REQUIREMENTS

-----NOTES-----

1. Refer to Table 3.3.1.1-1 to determine which SRs apply for each RPS Function.
 2. When a channel is placed in an inoperable status solely for performance of required Surveillances, entry into associated Conditions and Required Actions may be delayed for up to 6 hours provided the associated Function maintains RPS trip capability.
-

SURVEILLANCE		FREQUENCY
SR 3.3.1.1.1	Perform CHANNEL CHECK.	12 hours
SR 3.3.1.1.2	Perform CHANNEL CHECK	24 hours
SR 3.3.1.1.3	<p>-----NOTE-----</p> <p>Not required to be performed until 12 hours after THERMAL POWER \geq 25% RTP.</p> <p>-----</p> <p>Verify the absolute difference between the average power range monitor (APRM) channels and the calculated power is \leq 2% RTP plus any gain adjustment required by LCO 3.2.4, "Average Power Range Monitor (APRM) Setpoints" while operating at \geq 25% RTP.</p>	7 days
SR 3.3.1.1.4	<p>-----NOTE-----</p> <p>Not required to be performed when entering MODE 2 from MODE 1 until 12 hours after entering MODE 2.</p> <p>-----</p> <p>Perform CHANNEL FUNCTIONAL TEST.</p>	7 days

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.3.1.1.11	<p>-----NOTES-----</p> <ol style="list-style-type: none"> 1. Neutron detectors are excluded. 2. For Function 1.a, not required to be performed when entering MODE 2 from MODE 1 until 12 hours after entering MODE 2. <p>-----</p> <p>Perform CHANNEL CALIBRATION.</p>	184 days
SR 3.3.1.1.12	<p>-----NOTES-----</p> <ol style="list-style-type: none"> 1. For Function 2.a, not required to be performed when entering MODE 2 from MODE 1 until 12 hours after entering MODE 2. 2. For Functions 2.b and 2.f, the CHANNEL FUNCTIONAL TEST includes the recirculation flow input processing, excluding the flow transmitters. <p>-----</p> <p>Perform CHANNEL FUNCTIONAL TEST</p>	184 days
SR 3.3.1.1.13	Perform CHANNEL CALIBRATION.	24 months
SR 3.3.1.1.14	Perform CHANNEL FUNCTIONAL TEST.	24 months
SR 3.3.1.1.15	Perform LOGIC SYSTEM FUNCTIONAL TEST.	24 months
SR 3.3.1.1.16	Verify Turbine Stop Valve—Closure and Turbine Control Valve Fast Closure, Trip Oil Pressure—Low Functions are not bypassed when THERMAL POWER is \geq 30% RTP.	24 months

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.3.1.1.17	<p>-----NOTES-----</p> <ol style="list-style-type: none"> 1. Neutron detectors are excluded. 2. For Function 5 "n" equals 4 channels for the purpose of determining the STAGGERED TEST BASIS Frequency 3. For Function 2.e, "n" equals 8 channels for the purpose of determining the STAGGERED TEST BASIS Frequency. Testing of APRM and OPRM outputs shall alternate. <p>-----</p> <p>Verify the RPS RESPONSE TIME is within limits.</p>	24 months on a STAGGERED TEST BASIS
SR 3.3.1.1.18	<p>-----NOTES-----</p> <ol style="list-style-type: none"> 1. Neutron detectors are excluded. 2. For Functions 2.b and 2.f, the recirculation flow transmitters that feed the APRMs are included. <p>-----</p> <p>Perform CHANNEL CALIBRATION</p>	24 months
SR 3.3.1.1.19	Verify OPRM is not bypassed when APRM Simulated Thermal Power is $\geq 30\%$ and recirculation drive flow is \leq value equivalent to the core flow value defined in the COLR.	24 months
SR 3.3.1.1.20	Adjust recirculation drive flow to conform to reactor core flow.	24 months

Table 3.3.1.1-1 (page 1 of 3)
Reactor Protection System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER TRIP SYSTEM	CONDITIONS REFERENCED FROM REQUIRED ACTION D.1	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
1. Intermediate Range Monitors					
a. Neutron Flux-High	2	3	G	SR 3.3.1.1.1 SR 3.3.1.1.4 SR 3.3.1.1.6 SR 3.3.1.1.7 SR 3.3.1.1.11 SR 3.3.1.1.15	≤ 122/125 divisions of full scale
	5 ^(a)	3	H	SR 3.3.1.1.1 SR 3.3.1.1.5 SR 3.3.1.1.11 SR 3.3.1.1.15	≤ 122/125 divisions of full scale
b. Inop	2	3	G	SR 3.3.1.1.4 SR 3.3.1.1.15	NA
	5 ^(a)	3	H	SR 3.3.1.1.5 SR 3.3.1.1.15	NA
2. Average Power Range Monitors					
a. Neutron Flux-High (Setdown)	2	3 ^(c)	G	SR 3.3.1.1.2 SR 3.3.1.1.7 SR 3.3.1.1.8 SR 3.3.1.1.12 SR 3.3.1.1.18	≤ 20% RTP
b. Simulated Thermal Power-High	1	3 ^(c)	F	SR 3.3.1.1.2 SR 3.3.1.1.3 SR 3.3.1.1.8 SR 3.3.1.1.12 SR 3.3.1.1.18 SR 3.3.1.1.20	≤ 0.58 W + 62% RTP ^(b) and ≤ 115.5% RTP

(continued)

- (a) With any control rod withdrawn from a core cell containing one or more fuel assemblies.
- (b) $0.58(W-\Delta W) + 62\% \text{ RTP}$ when reset for single loop operation per LCO 3.4.1, "Recirculation Loops Operating." For single loop operation the value of $\Delta W = 5\%/0.58$. For two loop operation, the value of $\Delta W = 0$.
- (c) Each APRM channel provides inputs to both trip systems.

Table 3.3.1.1-1 (page 2 of 3)
Reactor Protection System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER TRIP SYSTEM	CONDITIONS REFERENCED FROM REQUIRED ACTION D.1	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
2. Average Power Range Monitors (continued)					
c. Neutron Flux—High	1	3 ^(c)	F	SR 3.3.1.1.2 SR 3.3.1.1.3 SR 3.3.1.1.8 SR 3.3.1.1.12 SR 3.3.1.1.18	≤ 120% RTP
d. Inop	1,2	3 ^(c)	G	SR 3.3.1.1.12	NA
e. 2-Out-Of-4 Voter	1,2	2	G	SR 3.3.1.1.2 SR 3.3.1.1.12 SR 3.3.1.1.15 SR 3.3.1.1.17	NA
f. OPRM Trip	≥25% RTP	3 ^(c)	I	SR 3.3.1.1.2 SR 3.3.1.1.8 SR 3.3.1.1.12 SR 3.3.1.1.18 SR 3.3.1.1.19 SR 3.3.1.1.20	(d)
3. Reactor Vessel Steam Dome Pressure—High	1,2	2	G	SR 3.3.1.1.9 SR 3.3.1.1.10 SR 3.3.1.1.15	≤ 1093 psig
4. Reactor Vessel Water Level—Low, Level 3	1,2	2	G	SR 3.3.1.1.1 SR 3.3.1.1.9 SR 3.3.1.1.10 SR 3.3.1.1.15	≥ 11.5 inches
5. Main Steam Isolation Valve— Closure	1	8	F	SR 3.3.1.1.9 SR 3.3.1.1.13 SR 3.3.1.1.15 SR 3.3.1.1.17	≤ 11% closed
6. Drywell Pressure— High	1,2	2	G	SR 3.3.1.1.9 SR 3.3.1.1.10 SR 3.3.1.1.15	≤ 1.88 psig

(continued)

(c) Each APRM channel provides inputs to both trip systems.

(d) See COLR for OPRM period based detection algorithm (PBDA) setpoint limits.

Table 3.3.1.1-1 (page 3 of 3)
Reactor Protection System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER TRIP SYSTEM	CONDITIONS REFERENCED FROM REQUIRED ACTION D.1	SURVEILLANCE REQUIREMENTS:	ALLOWABLE VALUE
7. Scram Discharge Volume Water Level—High					
a. Level Transmitter	1,2	2	G	SR 3.3.1.1.9 SR 3.3.1.1.13 SR 3.3.1.1.15	≤ 66 gallons
	5 ^(a)	2	H	SR 3.3.1.1.9 SR 3.3.1.1.13 SR 3.3.1.1.15	≤ 66 gallons
b. Float Switch	1,2	2	G	SR 3.3.1.1.9 SR 3.3.1.1.13 SR 3.3.1.1.15	≤ 62 gallons
	5 ^(a)	2	H	SR 3.3.1.1.9 SR 3.3.1.1.13 SR 3.3.1.1.15	≤ 62 gallons
8. Turbine Stop Valve—Closure	≥ 30% RTP	4	E	SR 3.3.1.1.9 SR 3.3.1.1.13 SR 3.3.1.1.15 SR 3.3.1.1.16 SR 3.3.1.1.17	≤ 7% closed
9. Turbine Control Valve Fast Closure, Trip Oil Pressure— Low	≥ 30% RTP	2	E	SR 3.3.1.1.9 SR 3.3.1.1.13 SR 3.3.1.1.15 SR 3.3.1.1.16 SR 3.3.1.1.17	≥ 460 psig
10 Reactor Mode Switch—Shutdown Position	1,2	2	G	SR 3.3.1.1.14 SR 3.3.1.1.15	NA
	5 ^(a)	2	H	SR 3.3.1.1.14 SR 3.3.1.1.15	NA
11. Manual Scram	1,2	2	G	SR 3.3.1.1.5 SR 3.3.1.1.15	NA
	5 ^(a)	2	H	SR 3.3.1.1.5 SR 3.3.1.1.15	NA

(a) With any control rod withdrawn from a core cell containing one or more fuel assemblies.

SURVEILLANCE REQUIREMENTS

-----NOTES-----

1. Refer to Table 3.3.2.1-1 to determine which SRs apply for each Control Rod Block Function.
2. When an RBM channel is placed in an inoperable status solely for performance of required Surveillances, entry into associated Conditions and Required Actions may be delayed for up to 6 hours provided the associated Function maintains control rod block capability.

SURVEILLANCE	FREQUENCY
SR 3.3.2.1.1 Perform CHANNEL FUNCTIONAL TEST.	184 days
SR 3.3.2.1.2 -----NOTE----- Not required to be performed until 1 hour after any control rod is withdrawn at $\leq 10\%$ RTP in MODE 2. ----- Perform CHANNEL FUNCTIONAL TEST.	92 days
SR 3.3.2.1.3 -----NOTE----- Not required to be performed until 1 hour after THERMAL POWER is $\leq 10\%$ RTP in MODE 1. ----- Perform CHANNEL FUNCTIONAL TEST.	92 days
SR 3.3.2.1.4 -----NOTE----- Neutron detectors are excluded. ----- Verify the RBM Trip Functions are not bypassed when THERMAL POWER is $\geq 30\%$ RTP.	24 months
SR 3.3.2.1.5 Verify the RWM is not bypassed when THERMAL POWER is $\leq 10\%$ RTP.	24 months

(continued)

Table 3.3.2.1-1 (page 1 of 1)
Control Rod Block Instrumentation

FUNCTION		APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
1.	Rod Block Monitor				
	a. Low Power Range-Upscale	1 ^(a)	2	SR 3.3.2.1.1 SR 3.3.2.1.4 SR 3.3.2.1.7	$\leq 0.58W+55\%$ ^(b)
	b. Inop	1 ^(a)	2	SR 3.3.2.1.1 SR 3.3.2.1.4	NA
	c. Downscale	1 ^(a)	2	SR 3.3.2.1.1 SR 3.3.2.1.4 SR 3.3.2.1.7	$\geq 3/125$ divisions of full scale
2.	Rod Worth Minimizer	1 ^(c) , 2 ^(c)	1	SR 3.3.2.1.2 SR 3.3.2.1.3 SR 3.3.2.1.5 SR 3.3.2.1.8	NA
3.	Reactor Mode Switch—Shutdown Position	(d)	2	SR 3.3.2.1.6	NA

(a) When THERMAL POWER is $\geq 30\%$ RTP

(b) $0.58(W-\Delta W) + 55\%$ RTP when reset for single-loop operation per LCO 3.4.1, "Recirculation Loops Operating." For single-loop operation, the value of $\Delta W = 5\%/0.58$. For two-loop operation, the value of $\Delta W = 0$.

(c) With THERMAL POWER $\leq 10\%$ RTP.

(d) Reactor mode switch in the shutdown position.

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.1 Recirculation Loops Operating

LCO 3.4.1 Two recirculation loops with matched flows shall be in operation.

OR

One recirculation loop may be in operation provided the following limits are applied when the associated LCO is applicable:

- a. LCO 3.2.1, "AVERAGE PLANAR LINEAR HEAT GENERATION RATE (APLHGR)," single loop operation limits specified in the COLR;
- b. LCO 3.2.2, "MINIMUM CRITICAL POWER RATIO (MCPR)," single loop operation limits specified in the COLR;
- c. LCO 3.2.3, "LINEAR HEAT GENERATION RATE (LHGR)," single loop operation limits specified in the COLR, and
- d. LCO 3.3.1.1, "Reactor Protection System (RPS) Instrumentation," Function 2.b (Average Power Range Monitors Simulated Thermal Power-High), Allowable Value of Table 3.3.1.1-1 is reset for single loop operation.
- e. Recirculation pump speed is $\leq 80\%$.

-----Note-----

Required limit and setpoint resets for single recirculation loop operation may be delayed for up to 12 hours after transition from two recirculation loop operation to single recirculation loop operation.

APPLICABILITY: MODES 1 and 2.

3.10 SPECIAL OPERATIONS

3.10.8 SHUTDOWN MARGIN (SDM) Test - Refueling

LCO 3.10.8 The reactor mode switch position specified in Table 1.1-1 for MODE 5 may be changed to include the startup/hot standby position, and operation considered not to be in MODE 2, to allow SDM testing, provided the following requirements are met:

- a. LCO 3.3.1.1, "Reactor Protection System Instrumentation," MODE 2 requirements for Functions 2.a, 2.d, and 2.e of Table 3.3.1.1-1;
- b. 1. LCO 3.3.2.1, "Control Rod Block Instrumentation," MODE 2 requirements for Function 2 of Table 3.3.2.1-1, with the banked position withdrawal sequence requirements of SR 3.3.2.1.8 changed to require the control rod sequence to conform to the SDM test sequence.

OR

2. Conformance to the approved control rod sequence for the SDM test is verified by a second licensed operator or other qualified member of the technical staff;
- c. Each withdrawn control rod shall be coupled to the associated CRD;
- d. All control rod withdrawals that are not in conformance with the BPWS shall be made in notch out mode;
- e. No other CORE ALTERATIONS are in progress; and
- f. CFD charging water header pressure ≥ 940 psig.

APPLICABILITY: MODE 5 with the reactor mode switch in startup/hot standby position.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>A. -----NOTE----- Separate Condition entry is allowed for each control rod. ----- One or more control rods not coupled to its associated CRD.</p>	<p>-----NOTE----- Rod worth minimizer may be bypassed as allowed by LCO 3.3.2.1, "Control Rod Block Instrumentation," if required, to allow insertion of inoperable control rod and continued operation. ----- A.1 Fully insert inoperable control rod. <u>AND</u> A.2 Disarm the associated CRD.</p>	<p>3 hours 4 hours</p>
<p>B. One or more of the above requirements not met for reasons other than Condition A.</p>	<p>B.1 Place the reactor mode switch in the shutdown or refuel position.</p>	<p>Immediately</p>

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.10.8.1 Perform the MODE 2 applicable SRs for LCO 3.3.1.1, Functions 2.a, 2.d, and 2.e of Table 3.3.1.1-1.</p>	<p>According to the applicable SRs</p>

(continued)

5.6 Reporting Requirements (continued)

5.6.4 Monthly Operating Reports

Routine reports of operating statistics and shutdown experience, including documentation of all challenges to the main steam safety/relief valves, shall be submitted on a monthly basis no later than the 15th of each month following the calendar month covered by the report.

5.6.5 CORE OPERATING LIMITS REPORT (COLR)

- a. Core operating limits shall be established prior to each reload cycle, or prior to any remaining portion of a reload cycle, and shall be documented in the COLR for the following:
1. The Average Planar Linear Heat Generation Rate for Specification 3.2.1;
 2. The Minimum Critical Power Ratio for Specification 3.2.2;
 3. The Linear Heat Generation Rate for Specification 3.2.3;
 4. The Average Power Range Monitor (APRM) Gain and Setpoints for Specification 3.2.4;
 5. The Shutdown Margin for Specification 3.1.1; and
 6. Oscillation Power Range Monitor (OPRM) Trip Setpoints for Specification 3.3.1.1.
- b. The analytical methods used to determine the core operating limits shall be those previously reviewed and approved by the NRC.

When an initial assumed power level of 102 percent of rated power is specified in a previously approved method, this refers to the power level associated with the design basis analyses, or 3510 MWt. The power level of 3510 MWt is 100.6% of the rated thermal power level of 3489 MWt. The RTP of 3489 MWt may only be used when feedwater flow measurement (used as input to the reactor thermal power measurement) is provided by the Leading Edge Flow Meter (LEFM[✓]™) as described in the LEFM[✓]™ Topical Report and supplement referenced below. When feedwater flow measurements from the LEFM[✓]™ system are not available, the core thermal power level may not exceed the originally approved RTP of 3441 MWt, but the value of 3510 MWt

(continued)

3.3 INSTRUMENTATION

3.3.1.1 Reactor Protection System (RPS) Instrumentation

LCO 3.3.1.1 The RPS instrumentation for each Function in Table 3.3.1.1-1 shall be OPERABLE.

APPLICABILITY: According to Table 3.3.1,1-1.

ACTIONS

-----NOTE-----
Separate Condition entry is allowed for each channel.

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more required channels inoperable.	A.1 Place channel in trip.	12 hours
	<u>OR</u> A.2 -----NOTE----- Not applicable for Functions 2.a, 2.b, 2.c, 2.d, or 2.f. ----- Place associated trip system in trip.	12 hours
B. -----NOTE----- Not applicable for Functions 2.a, 2.b, 2.c, 2.d, or 2.f. ----- One or more Functions with one or more required channels inoperable in both trip systems.	B.1 Place channel in one trip system in trip.	6 hours
	<u>OR</u> B.2 Place one trip system in trip.	6 hours
C. One or more Functions with RPS trip capability not maintained.	C.1 Restore RPS trip capability.	1 hour

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
D. Required Action and associated Completion Time of Condition A, B, or C not met.	D.1 Enter the Condition referenced in Table 3.3.1.1-1 for the channels.	Immediately
E. As required by Required Action D.1 and referenced in Table 3.3.1.1-1.	E.1 Reduce THERMAL POWER to < 30% RTP.	4 hours
F. As required by Required Action D.1 and referenced in Table 3.3.1.1-1.	F.1 Be in MODE 2.	6 hours
G. As required by Required Action D.1 and referenced in Table 3.3.1.1-1.	G.1 Be in MODE 3.	12 hours
H. As required by Required Action D.1 and referenced in Table 3.3.1.1-1.	H.1 Initiate action to fully insert all insertable control rods in core cells containing one or more fuel assemblies.	Immediately
I. As required by Required Action D.1 and referenced in Table 3.3.1.1-1.	I.1 Initiate alternate method to detect and suppress thermal hydraulic instability oscillations.	12 hours
	<u>AND</u> I.2 Restore required channels to OPERABLE.	120 days
J. Required Action and associated Completion Time of Condition I not met.	J.1 Reduce THERMAL POWER to <25% RTP.	4 hours

SURVEILLANCE REQUIREMENTS

-----NOTES-----

1. Refer to Table 3.3.1.1-1 to determine which SRs apply for each RPS Function.
 2. When a channel is placed in an inoperable status solely for performance of required Surveillances, entry into associated Conditions and Required Actions may be delayed for up to 6 hours provided the associated Function maintains RPS trip capability.
-

SURVEILLANCE		FREQUENCY
SR 3.3.1.1.1	Perform CHANNEL CHECK.	12 hours
SR 3.3.1.1.2	Perform CHANNEL CHECK.	24 hours
SR 3.3.1.1.3	<p>-----NOTE-----</p> <p>Not required to be performed until 12 hours after THERMAL POWER \geq 25% RTP.</p> <p>-----</p> <p>Verify the absolute difference between the average power range monitor (APRM) channels and the calculated power is \leq 2% RTP plus any gain adjustment required by LCO 3.2.4, "Average Power Range Monitor (APRM) Setpoints" while operating at \geq 25% RTP.</p>	7 days
SR 3.3.1.1.4	<p>-----NOTE-----</p> <p>Not required to be performed when entering MODE 2 from MODE 1 until 12 hours after entering MODE 2.</p> <p>-----</p> <p>Perform CHANNEL FUNCTIONAL TEST.</p>	7 days

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.3.1.1.11	<p>-----NOTES-----</p> <ol style="list-style-type: none"> 1. Neutron detectors are excluded. 2. For Function 1.a, not required to be performed when entering MODE 2 from MODE 1 until 12 hours after entering MODE 2. <p>-----</p> <p>Perform CHANNEL CALIBRATION.</p>	184 days
SR 3.3.1.1.12	<p>-----NOTES-----</p> <ol style="list-style-type: none"> 1. For Function 2.a, not required to be performed when entering MODE 2 from MODE 1 until 12 hours after entering MODE 2. 2. For Functions 2.b and 2.f, the CHANNEL FUNCTIONAL TEST includes the recirculation flow input processing, excluding the flow transmitters. <p>-----</p> <p>Perform CHANNEL FUNCTIONAL TEST</p>	184 days
SR 3.3.1.1.13	Perform CHANNEL CALIBRATION.	24 months
SR 3.3.1.1.14	Perform CHANNEL FUNCTIONAL TEST.	24 months
SR 3.3.1.1.15	Perform LOGIC SYSTEM FUNCTIONAL TEST.	24 months
SR 3.3.1.1.16	Verify Turbine Stop Valve—Closure and Turbine Control Valve Fast Closure, Trip Oil Pressure—Low Functions are not bypassed when THERMAL POWER is $\geq 30\%$ RTP.	24 months

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.3.1.1.17	<p>-----NOTES-----</p> <ol style="list-style-type: none"> 1. Neutron detectors are excluded. 2. For Function 5, "n" equals 4 channels for the purpose of determining the STAGGERED TEST BASIS Frequency. 3. For Function 2.e, "n" equals 8 channels for the purpose of determining the STAGGERED TEST BASIS Frequency. Testing of APRM and OPRM outputs shall alternate. <p>-----</p> <p>Verify the RPS RESPONSE TIME is within limits.</p>	24 months on a STAGGERED TEST BASIS
SR 3.3.1.1.18	<p>-----NOTES-----</p> <ol style="list-style-type: none"> 1. Neutron detectors are excluded. 2. For Functions 2 b and 2.f, the recirculation flow transmitters that feed the APRMs are included. <p>-----</p> <p>Perform CHANNEL CALIBRATION</p>	24 months
SR 3.3.1.1.19	Verify OPRM is not bypassed when APRM Simulated Thermal Power is $\geq 30\%$ and recirculation drive flow is \leq value equivalent to the core flow value defined in the COLR.	24 months
SR 3.3.1.1.20	Adjust recirculation drive flow to conform to reactor core flow.	24 months

Table 3.3.1.1-1 (page 1 of 3)
Reactor Protection System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER TRIP SYSTEM	CONDITIONS REFERENCED FROM REQUIRED ACTION D.1	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
1. Intermediate Range Monitors					
a. Neutron Flux—High	2	3	G	SR 3.3.1.1.1 SR 3.3.1.1.4 SR 3.3.1.1.6 SR 3.3.1.1.7 SR 3.3.1.1.11 SR 3.3.1.1.15	≤ 122/125 divisions of full scale
	5 ^(a)	3	H	SR 3.3.1.1.1 SR 3.3.1.1.5 SR 3.3.1.1.11 SR 3.3.1.1.15	≤ 122/125 divisions of full scale
b. Inop	2	3	G	SR 3.3.1.1.4 SR 3.3.1.1.15	NA
	5 ^(a)	3	H	SR 3.3.1.1.5 SR 3.3.1.1.15	NA
2. Average Power Range Monitors					
a. Neutron Flux—High (Setdown)	2	3 ^(c)	G	SR 3.3.1.1.2 SR 3.3.1.1.7 SR 3.3.1.1.8 SR 3.3.1.1.12 SR 3.3.1.1.18	≤ 20% RTP
b. Simulated Thermal Power—High	1	3 ^(c)	F	SR 3.3.1.1.2 SR 3.3.1.1.3 SR 3.3.1.1.8 SR 3.3.1.1.12 SR 3.3.1.1.18 SR 3.3.1.1.20	≤ 0.58 W + 62% RTP ^(b) and ≤ 115.5% RTP
(continued)					

(a) With any control rod withdrawn from a core cell containing one or more fuel assemblies.

(b) $0.58(W-\Delta W) + 62\% \text{ RTP}$ when reset for single loop operation per LCO 3.4.1, "Recirculation Loops Operating." For single-loop operation, the value of $\Delta W = 5\%/0.58$. For two-loop operation, the value of $\Delta W = 0$.

(c) Each APRM channel provides inputs to both trip systems.

Table 3.3.1.1-1 (page 2 of 3)
Reactor Protection System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER TRIP SYSTEM	CONDITIONS REFERENCED FROM REQUIRED ACTION D.1	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
2. Average Power Range Monitors (continued)					
c. Neutron Flux—High	1	3 ^(c)	F	SR 3.3.1.1.2 SR 3.3.1.1.3 SR 3.3.1.1.8 SR 3.3.1.1.12 SR 3.3.1.1.18	≤ 120% RTP
d. Inop	1,2	3 ^(c)	G	SR 3.3.1.1.12	NA
e. 2-Out-Of-4 Voter	1,2	2	G	SR 3.3.1.1.2 SR 3.3.1.1.12 SR 3.3.1.1.15 SR 3.3.1.1.17	NA
f. OPRM Trip	≥25% RTP	3 ^(c)	I	SR 3.3.1.1.2 SR 3.3.1.1.8 SR 3.3.1.1.12 SR 3.3.1.1.18 SR 3.3.1.1.19 SR 3.3.1.1.20	^(d)
3. Reactor Vessel Steam Dome Pressure—High	1,2	2	G	SR 3.3.1.1.9 SR 3.3.1.1.10 SR 3.3.1.1.15	≤ 1093 psig
4. Reactor Vessel Water Level—Low, Level 3	1,2	2	G	SR 3.3.1.1.1 SR 3.3.1.1.9 SR 3.3.1.1.10 SR 3.3.1.1.15	≥ 11.5 inches
5. Main Steam Isolation Valve—Closure	1	8	F	SR 3.3.1.1.9 SR 3.3.1.1.13 SR 3.3.1.1.15 SR 3.3.1.1.17	≤ 11% closed
6. Drywell Pressure—High	1,2	2	G	SR 3.3.1.1.9 SR 3.3.1.1.10 SR 3.3.1.1.15	≤ 1.88 psig

(continued)

(c) Each APRM channel provides inputs to both trip systems.

(d) See COLR for OPRM period based detection algorithm (PBDA) setpoint limits.

Table 3.3.1.1-1 (page 3 of 3)
Reactor Protection System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER TRIP SYSTEM	CONDITIONS REFERENCED FROM REQUIRED ACTION D.1	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
7. Scram Discharge Volume Water Level—High					
a. Level Transmitter	1,2	2	G	SR 3.3.1.1.9 SR 3.3.1.1.13 SR 3.3.1.1.15	≤ 66 gallons
	5 ^(a)	2	H	SR 3.3.1.1.9 SR 3.3.1.1.13 SR 3.3.1.1.15	≤ 66 gallons
b. Float Switch	1,2	2	G	SR 3.3.1.1.9 SR 3.3.1.1.13 SR 3.3.1.1.15	≤ 62 gallons
	5 ^(a)	2	H	SR 3.3.1.1.9 SR 3.3.1.1.13 SR 3.3.1.1.15	≤ 62 gallons
8. Turbine Stop Valve—Closure	≥ 30% RTP	4	E	SR 3.3.1.1.9 SR 3.3.1.1.13 SR 3.3.1.1.15 SR 3.3.1.1.16 SR 3.3.1.1.17	≤ 7% closed
9. Turbine Control Valve Fast Closure, Trip Oil Pressure— Low	≥ 30% RTP	2	E	SR 3.3.1.1.9 SR 3.3.1.1.13 SR 3.3.1.1.15 SR 3.3.1.1.16 SR 3.3.1.1.17	≥ 460 psig
10. Reactor Mode Switch— Shutdown Position	1,2	2	G	SR 3.3.1.1.14 SR 3.3.1.1.15	NA
	5 ^(a)	2	H	SR 3.3.1.1.14 SR 3.3.1.1.15	NA
11. Manual Scram	1,2	2	G	SR 3.3.1.1.5 SR 3.3.1.1.15	NA
	5 ^(a)	2	H	SR 3.3.1.1.5 SR 3.3.1.1.15	NA

(a) With any control rod withdrawn from a core cell containing one or more fuel assemblies.

SURVEILLANCE REQUIREMENTS

-----NOTES-----

1. Refer to Table 3.3.2.1-1 to determine which SRs apply for each Control Rod Block Function.
2. When an RBM channel is placed in an inoperable status solely for performance of required Surveillances, entry into associated Conditions and Required Actions may be delayed for up to 6 hours provided the associated Function maintains control rod block capability.

SURVEILLANCE	FREQUENCY
SR 3.3.2.1.1 Perform CHANNEL FUNCTIONAL TEST.	134 days
SR 3.3.2.1.2 -----NOTE----- Not required to be performed until 1 hour after any control rod is withdrawn at $\leq 10\%$ RTP in MODE 2. ----- Perform CHANNEL FUNCTIONAL TEST.	92 days
SR 3.3.2.1.3 -----NOTE----- Not required to be performed until 1 hour after THERMAL POWER is $\leq 10\%$ RTP in MODE 1. ----- Perform CHANNEL FUNCTIONAL TEST.	92 days
SR 3.3.2.1.4 -----NOTE----- Neutron detectors are excluded. ----- Verify the RBM trip functions are not bypassed when THERMAL POWER is $\geq 30\%$ RTP.	24 months
SR 3.3.2.1.5 Verify the RWM is not bypassed when THERMAL POWER is $\leq 10\%$ RTP.	24 months

Table 3.3.2.1-1 (page 1 of 1)
Control Rod Block Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
1. Rod Block Monitor				
a. Low Power Range-Upscale	1 ^(a)	2	SR 3.3.2.1.1 SR 3.3.2.1.4 SR 3.3.2.1.7	$\leq 0.58W+55\%$ ^(b)
b. Inop	1 ^(a)	2	SR 3.3.2.1.1 SR 3.3.2.1.4	NA
c. Downscale	1 ^(a)	2	SR 3.3.2.1.1 SR 3.3.2.1.4 SR 3.3.2.1.7	$\geq 3/125$ divisions of full scale
2. Rod Worth Minimizer	1 ^(c) , 2 ^(c)	1	SR 3.3.2.1.2 SR 3.3.2.1.3 SR 3.3.2.1.5 SR 3.3.2.1.8	NA
3. Reactor Mode Switch—Shutdown Position	(d)	2	SR 3.3.2.1.6	NA

(a) When THERMAL POWER is $\geq 30\%$ RTP

(b) $0.58(W-\Delta W) + 55\%$ RTP when reset for single-loop operation per LCO 3.4.1, "Recirculation Loops Operating". For single-loop operation, the value of $\Delta W = 5\%/0.5\%$. For two-loop operation, the value of $\Delta W = 0$.

(c) With THERMAL POWER $\leq 10\%$ RTP.

(d) Reactor mode switch in the shutdown position.

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.1 Recirculation Loops Operating

LCO 3.4.1 Two recirculation loops with matched flows shall be in operation.

OR

One recirculation loop may be in operation provided the following limits are applied when the associated LCO is applicable:

- a. LCO 3.2.1, "AVERAGE PLANAR LINEAR HEAT GENERATION RATE (APLHGR)," single loop operation limits specified in the COLR;
- b. LCO 3.2.2, "MINIMUM CRITICAL POWER RATIO (MCPR)," single loop operation limits specified in the COLR;
- c. LCO 3.2.3, "LINEAR HEAT GENERATION RATE (LHGR)," single loop operation limits specified in the COLR, and
- d. LCO 3.3.1.1, "Reactor Protection System (RPS) Instrumentation," Function 2.b (Average Power Range Monitors Simulated Thermal Power—High), Allowable Value of Table 3.3.1.1-1 is reset for single loop operation.
- e. Recirculation pump speed is $\leq 80\%$.

Note

Required limit and setpoint resets for single recirculation loop operation may be delayed for up to 12 hours after transition from two recirculation loop operation to single recirculation loop operation.

APPLICABILITY: MODES 1 and 2.

3.10 SPECIAL OPERATIONS

3.10.8 SHUTDOWN MARGIN (SDM) Test - Refueling

LCO 3.10.8 The reactor mode switch position specified in Table 1.1-1 for MODE 5 may be changed to include the startup/hot standby position, and operation considered not to be in MODE 2, to allow SDM testing, provided the following requirements are met:

- a. LCO 3.3.1.1, "Reactor Protection System Instrumentation," MODE 2 requirements for Functions 2.a, 2.d and 2.e of Table 3.3.1.1-1;
- b. 1. LCO 3.3.2.1, "Control Rod Block Instrumentation," MODE 2 requirements for Function 2 of Table 3.3.2.1-1, with the banked position withdrawal sequence requirements of SR 3.3.2.1.8 changed to require the control rod sequence to conform to the SDM test sequence.

OR

- 2. Conformance to the approved rod sequence for the SDM test is verified by a second licensed operator or other qualified member of the technical staff;
- c. Each withdrawn control rod shall be coupled to the associated CRD;
- d. All control rod withdrawals that are not in conformance with the BPWS shall be made in notch out mode;
- e. No other CORE ALTERATIONS are in progress; and
- f. CFD charging water header pressure ≥ 940 psig.

APPLICABILITY: MODE 5 with the reactor mode switch in startup/hot standby position.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>A. -----NOTE----- Separate Condition entry is allowed for each control rod. ----- One or more control rods not coupled to its associated CRD.</p>	<p>-----NOTE----- Rod worth minimizer may be bypassed as allowed by LCO 3.3.2.1, "Control Rod Block Instrumentation," if required, to allow insertion of inoperable control rod and continued operation. -----</p> <p>A.1 Fully insert inoperable control rod.</p> <p><u>AND</u></p> <p>A.2 Disarm the associated CRD.</p>	<p>3 hours</p> <p>4 hours</p>
<p>B. One or more of the above requirements not met for reasons other than Condition A.</p>	<p>B.1 Place the reactor mode switch in the shutdown or refuel position.</p>	<p>Immediately</p>

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.10.8.1 Perform the MODE 2 applicable SRs for LCO 3.3.1.1, Functions 2.a, 2.d and 2.e of Table 3.3.1.1-1.</p>	<p>According to the applicable SRs</p>

(continued)

5.6 Reporting Requirements (continued)

5.6.4 Monthly Operating Reports

Routine reports of operating statistics and shutdown experience, including documentation of all challenges to the main steam safety/relief valves, shall be submitted on a monthly basis no later than the 15th of each month following the calendar month covered by the report.

5.6.5 CORE OPERATING LIMITS REPORT (COLR)

- a. Core operating limits shall be established prior to each reload cycle, or prior to any remaining portion of a reload cycle, and shall be documented in the COLR for the following:
1. The Average Planar Linear Heat Generation Rate for Specification 3.2.1;
 2. The Minimum Critical Power Ratio for Specification 3.2.2;
 3. The Linear Heat Generation Rate for Specification 3.2.3;
 4. The Average Power Range Monitor (APRM) Gain and Setpoints for Specification 3.2.4;
 5. The Shutdown Margin for Specification 3.1.1; and
 6. Oscillation Power Range Monitor (OPRM) Trip setpoints, for Specification 3.3.1.1.
- b. The analytical methods used to determine the core operating limits shall be those previously reviewed and approved by the NRC.

When an initial assumed power level of 102 percent of rated power is specified in a previously approved method, this refers to the power level associated with the design basis analyses, or 3510 MWt. The power level of 3510 MWt is 100.6% of the rated thermal power level of 3489 MWt. The RTP of 3489 MWt may only be used when feedwater flow measurement (used as input to the reactor thermal power measurement) is provided by the Leading Edge Flow Meter (LEFM[✓]™) as described in the LEFM[✓]™ Topical Report and supplement referenced below. When feedwater flow measurements from the LEFM[✓]™ system are not available, the

(continued)