

March 10, 2006

Mrs. Mary G. Korsnick  
Vice President R.E. Ginna Nuclear Power Plant  
R.E. Ginna Nuclear Power Plant, LLC  
1503 Lake Road  
Ontario, NY 14519

SUBJECT: R.E. GINNA NUCLEAR POWER PLANT - FINAL ACCIDENT SEQUENCE  
PRECURSOR ANALYSIS REPORT REGARDING ELECTRIC GRID EVENT ON  
AUGUST 14, 2003

Dear Mrs. Korsnick:

Enclosed for your use and information is a copy of the Nuclear Regulatory Commission (NRC) Final Accident Sequence Precursor (ASP) Analysis Report for the R.E. Ginna Nuclear Power Plant regarding the grid disturbance event on August 14, 2003 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML050960036). This event was described in Licensee Event Report 50-244/03-002, "Major Power Grid Disturbance Causes Loss of Electrical Load and Reactor Trip" (ADAMS No. ML0328904410). Although offsite power was never completely lost to the buses supplying the power block area, the plant operators determined that the offsite power supply was unreliable and manually started and loaded the emergency diesel generators (EDGs) onto the emergency buses. The EDGs supplied power to safety-related plant loads until offsite power was deemed stable.

If you have any questions about the analysis, please contact me at 301-415-1457 or Christopher Hunter of the NRC's Office of Research at 301-415-4127.

Sincerely,

*/RA/*

Patrick D. Milano, Senior Project Manager  
Plant Licensing Branch I-1  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket Nos. 50-244

Enclosure:  
Final ASP Analysis Report

cc w/encl: See next page

March 10, 2006

Mrs. Mary G. Korsnick  
Vice President R.E. Ginna Nuclear Power Plant  
R.E. Ginna Nuclear Power Plant, LLC  
1503 Lake Road  
Ontario, NY 14519

SUBJECT: R.E. GINNA NUCLEAR POWER PLANT - FINAL ACCIDENT SEQUENCE  
PRECURSOR ANALYSIS REPORT REGARDING ELECTRIC GRID EVENT ON  
AUGUST 14, 2003

Dear Mrs. Korsnick:

Enclosed for your use and information is a copy of the Nuclear Regulatory Commission (NRC) Final Accident Sequence Precursor (ASP) Analysis Report for the R.E. Ginna Nuclear Power Plant regarding the grid disturbance event on August 14, 2003 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML050960036). This event was described in Licensee Event Report 50-244/03-002, "Major Power Grid Disturbance Causes Loss of Electrical Load and Reactor Trip" (ADAMS No. ML0328904410). Although offsite power was never completely lost to the buses supplying the power block area, the plant operators determined that the offsite power supply was unreliable and manually started and loaded the emergency diesel generators (EDGs) onto the emergency buses. The EDGs supplied power to safety-related plant loads until offsite power was deemed stable.

If you have any questions about the analysis, please contact me at 301-415-1457 or Christopher Hunter of the NRC's Office of Research at 301-415-4127.

Sincerely,

/RA/

Patrick D. Milano, Senior Project Manager  
Plant Licensing Branch I-1  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket Nos. 50-244

Enclosure:  
Final ASP Analysis Report

cc w/encl: See next page

ACCESSION NUMBER: ML060660379

OFFICE	LPLI-1/PM	LPLI-1/LA	RES/DRAA/D	LPLI-1/BC
NAME	PMilano	SLittle	CAder	RLaufer
DATE	03/09/06	03/09/06	02/17/06	03/10/06

**OFFICIAL RECORD COPY**

DISTRIBUTION:

PUBLIC

LPLI-1 Reading File

R. Laufer

P. Milano

S. Little

E. Brown

C. Ader

C. Hunter

B. McDermott, RGN-I

OGC

ACRS

RidsNrrDorlLpII-1

RidsNrrPMPMilano

RidsNrrLASLittle

RidsNrrDeEeeb

RidsResDraa

RidsRgn1MailCenter

RidsOgcRp

RidsAcrsAcnwMailCenter

R.E. Ginna Nuclear Power Plant

cc:

Mr. Michael J. Wallace  
President  
R.E. Ginna Nuclear Power Plant, LLC  
c/o Constellation Energy  
750 East Pratt Street  
Baltimore, MD 21202

Mr. John M. Heffley  
Senior Vice President and  
Chief Nuclear Officer  
Constellation Generation Group  
1997 Annapolis Exchange Parkway  
Suite 500  
Annapolis, MD 21401

Kenneth Kolaczyk, Sr. Resident Inspector  
R.E. Ginna Nuclear Power Plant  
U.S. Nuclear Regulatory Commission  
1503 Lake Road  
Ontario, NY 14519

Regional Administrator, Region I  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

Mr. Peter R. Smith, President  
New York State Energy, Research,  
and Development Authority  
17 Columbia Circle  
Albany, NY 12203-6399

Mr. Carey W. Fleming, Esquire  
Senior Counsel - Nuclear Generation  
Constellation Generation Group, LLC  
750 East Pratt Street, 17th Floor  
Baltimore, MD 21202

Mr. Charles Donaldson, Esquire  
Assistant Attorney General  
New York Department of Law  
120 Broadway  
New York, NY 10271

Ms. Thelma Wideman, Director  
Wayne County Emergency Management  
Office  
Wayne County Emergency Operations  
Center  
7336 Route 31  
Lyons, NY 14489

Ms. Mary Louise Meisenzahl  
Administrator, Monroe County  
Office of Emergency Preparedness  
1190 Scottsville Road, Suite 200  
Rochester, NY 14624

Mr. Paul Eddy  
New York State Department of  
Public Service  
3 Empire State Plaza, 10th Floor  
Albany, NY 12223