

March 21, 2006

LICENSEE: Nuclear Management Company, LLC

FACILITY: Monticello Nuclear Generating Station

SUBJECT: SUMMARY OF MARCH 6, 2006, MEETING TO DISCUSS FULL-SCOPE
APPLICATION OF ALTERNATIVE SOURCE TERM (AST) METHODOLOGY

On March 6, 2006, the Nuclear Regulatory Commission (NRC) staff met with Nuclear Management Company (the licensee) staff to discuss its full-scope application of AST methodology for the Monticello Nuclear Generating Plant. The licensee provided details regarding the application to aid the staff in its technical review.

The meeting adjourned with three action items. NRC staff requested, and the licensee agreed to provide, the following information: 1) hourly meteorological data measured at the 100 meter level from 1998 through 2002; 2) supporting calculations for the standby liquid control system maintaining suppression pool pH level; and 3) additional information on the impact of removing from technical specifications the radiation monitor actuation of the control room emergency filtration system.

The enclosure is a list of the attendees and meeting agenda. Handouts were provided by the licensee during the meeting and are available in the Agencywide Documents Access and Management System (see ADAMS Accession No. ML060670337).

/RA/

Terry A. Beltz, Project Manager
Plant Licensing Branch III-1
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-263

Enclosure:
List of Attendees and Meeting Agenda

cc w/encl: See next page

March 21, 2006

LICENSEE: Nuclear Management Company, LLC
FACILITY: Monticello Nuclear Generating Station
SUBJECT: SUMMARY OF MARCH 6, 2006, MEETING TO DISCUSS FULL-SCOPE APPLICATION OF ALTERNATIVE SOURCE TERM (AST) METHODOLOGY

On March 6, 2006, the Nuclear Regulatory Commission (NRC) met with Nuclear Management Company (the licensee) staff to discuss its full-scope application of AST methodology for the Monticello Nuclear Generating Plant. The licensee provided details regarding the application to aid the staff in its technical review.

The meeting adjourned with three action items. NRC staff requested, and the licensee agreed to provide, the following information: 1) hourly meteorological data measured at the 100 meter level from 1998 through 2002; 2) supporting calculations for the standby liquid control system maintaining suppression pool pH level; and 3) additional information on the impact of removing from technical specifications the radiation monitor actuation of the control room emergency filtration system.

The enclosure is a list of the attendees and meeting agenda. Handouts were provided by the licensee during the meeting and are available in the Agencywide Documents Access and Management System (see ADAMS Accession No. ML060670337).

/RA/

Terry A. Beltz, Project Manager
Plant Licensing Branch III-1
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-263

Enclosure:
List of Attendees and Meeting Agenda

cc w/encl: See next page

DISTRIBUTION:

PUBLIC	LPL3-1 R/F	RidsNrrDorlLple
RidsNrrPMPTam	RidsNrrPMTBeltz	RidsNrrLATHarris
RidsRgn3MailCenter	RidsAcrsAcnwMailCenter	RidsNrrDorl
RJasinski, NRR	JDixon-Herrity, RIII	RidsOGCRp

ADAMS Accession Number: **ML060670035** (Package)
ADAMS Accession Number: **ML060670037** (Meeting Summary & Enclosure)
ADAMS Accession Number: **ML060670337** (Licensees' Handout)

OFFICE	LPL3-1/PM	LPL3-1/PM	LPL3-1/LA	DRA/AADB/BC	DRA/ACVB/BC	DCI/CSGB/BC	LPL3-1/BC
NAME	TBeltz	PTam	THarris	MKotzalas	RDennig	EMurphy for AHiser	LRaghavan
DATE	03/14/06	03/21/06	03/21/06	03/14/06	03/14/06	03/19/06	03/21/06

OFFICIAL RECORD COPY

Monticello Nuclear Generating Plant

cc:

Jonathan Rogoff, Esquire
Vice President, Counsel & Secretary
Nuclear Management Company, LLC
700 First Street
Hudson, WI 54016

U.S. Nuclear Regulatory Commission
Resident Inspector's Office
2807 W. County Road 75
Monticello, MN 55362

Manager, Regulatory Affairs
Monticello Nuclear Generating Plant
Nuclear Management Company, LLC
2807 West County Road 75
Monticello, MN 55362-9637

Robert Nelson, President
Minnesota Environmental Control
Citizens Association (MECCA)
1051 South McKnight Road
St. Paul, MN 55119

Commissioner
Minnesota Pollution Control Agency
520 Lafayette Road
St. Paul, MN 55155-4194

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
Suite 210
2443 Warrenville Road
Lisle, IL 60532-4351

Commissioner
Minnesota Department of Health
717 Delaware Street, S. E.
Minneapolis, MN 55440

Douglas M. Gruber, Auditor/Treasurer
Wright County Government Center
10 NW Second Street
Buffalo, MN 55313

Commissioner
Minnesota Department of Commerce
85 7th Place East, Suite 500
St. Paul, MN 55101-2198

Manager - Environmental Protection Division
Minnesota Attorney General's Office
445 Minnesota St., Suite 900
St. Paul, MN 55101-2127

Michael B. Sellman
President and Chief Executive Officer
Nuclear Management Company, LLC
700 First Street
Hudson, MI 54016

Nuclear Asset Manager
Xcel Energy, Inc.
414 Nicollet Mall, R.S. 8
Minneapolis, MN 55401

Mr. John T. Conway
Site Vice President
Monticello Nuclear Generating Plant
Nuclear Management Company, LLC
2807 West County Road 75
Monticello, MN 55362-9637

November 2005

LIST OF ATTENDEES

**MEETING TO DISCUSS MONTICELLO NUCLEAR GENERATING PLANT
FULL-SCOPE APPLICATION OF ALTERNATIVE SOURCE TERM METHODOLOGY**

MARCH 6, 2006

NRC

T. Beltz
L. Brown
K. Feintuch
E. Forrest
M. Hart
M. Kotzalas
R. Lobel
K. Parczewski
L. Raghavan
H. Scott

NUCLEAR MANAGEMENT COMPANY

B. Brown
P. Burke
M. Limbeck
R. Loeffler
G. Salamon
K. Schriver

ENCLOSURE

AGENDA

MEETING WITH NUCLEAR MANAGEMENT COMPANY, LLC TO DISCUSS MONTICELLO NUCLEAR GENERATING PLANT FULL-SCOPE APPLICATION OF ALTERNATIVE SOURCE TERM METHODOLOGY

March 6, 2006

- INTRODUCTION
- FULL-SCOPE ALTERNATIVE SOURCE TERM ACCIDENT ANALYSIS REVIEW
 - Atmospheric Dispersion Factors
 - Assumptions, Results
 - Additional Dispersion Factors
 - Loss-of-Coolant Accident
 - Assumptions, Results
 - Consideration of Current Issues
 - Technical Support Center Design Considerations
 - Main Steam Line Break Accident
 - Assumptions, Results
 - Control Rod Drop Accident
 - Assumptions, Results
 - Fuel Handling Accidents
 - Assumptions, Results
 - Re-evaluation of Accident With Revised Source Term and Dispersion Factors
- CONTROL ROOM CONFIGURATION
- TECHNICAL SPECIFICATION CHANGES
- DISCUSSION OF PROPRIETARY MATERIAL (CALCULATIONS, Q&A)
 - This portion of the meeting is closed to the public.
- NRC STAFF CAUCUS (IF NEEDED)
- COMMENTS FROM MEMBERS OF THE PUBLIC (IF ANY)
- CLOSING REMARKS BY LICENSEE PERSONNEL AND NRC STAFF

ENCLOSURE