

TABLE 3.4-2
REACTOR COOLANT SYSTEM
CHEMISTRY LIMITS

<u>PARAMETER</u>	<u>STEADY-STATE LIMIT</u>	<u>TRANSIENT LIMIT</u>
Dissolved Oxygen*	≤ 0.10 ppm	≤ 1.00 ppm
Chloride	≤ 0.15 ppm	≤ 1.50 ppm
Fluoride	≤ 0.15 ppm	≤ 1.50 ppm

*Limit not applicable with T_{avg} less than or equal to 250°F.

TABLE 4.4-3
REACTOR COOLANT SYSTEM
CHEMISTRY LIMITS SURVEILLANCE REQUIREMENTS

<u>PARAMETER</u>	<u>SAMPLE AND ANALYSIS FREQUENCY</u>
Dissolved Oxygen*	At least once per 72 hours
Chloride	At least once per 72 hours
Fluoride	At least once per 72 hours

*Not required with T_{avg} less than or equal to 250°F