

March 9, 2006

LICENSEE: SOUTHERN CALIFORNIA EDISON (SCE)

FACILITIES: SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3
(SONGS 2 AND 3)

SUBJECT: MEETING WITH REPRESENTATIVES OF SCE FOR SONGS 2 AND 3

A meeting was held on Thursday, March 2, 2006, between the Nuclear Regulatory Commission (NRC) staff and SCE, the licensee for SONGS 2 and 3. The meeting was held at the request of the licensee for it to present to the NRC staff its evaluation of the indications in the Unit 3 Control Element Drive Mechanism (CEDM) penetration 56 and repair alternatives. The notice for the meeting was issued on February 13, 2006.

During the Unit 3 outage in 2003, the inspection of the Unit 3 reactor vessel head (RVH) identified an indication on CEDM penetration 56 that was assumed to be a crack. Although SCE had approval to perform a weld overlay repair of RVH penetrations (ISI-3-8), this particular indication exceeded the generic 75 percent through-wall crack limit. Therefore, SCE submitted a specific relief request for CEDM penetration 56 (ISI-3-13). The NRC granted approval of this relief request for one cycle. SCE committed to evaluate repair alternatives for the long term.

With the Unit 3 refueling outage scheduled for October 2006, the licensee proposed its long-term disposition of penetration 56 by discussing repair alternatives, criteria for a contingency repair, appropriate contingency repair, planned actions, and implementation schedules. The NRC staff was appreciative of the presentation and stated it will perform a quick review on the general acceptability of SCE's approach and techniques and inform SCE of the staff's findings.

Enclosure 1 is the list of attendees. Enclosure 2 is the material handed out by the licensee. There was no handout from the NRC staff.

/RA/

N. Kalyanam, Project Manager
Plant Licensing Branch IV
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No.: 50-362

Enclosures: 1. List of Attendees
2. Licensee's Handout

cc w/encls: See next page

LICENSEE: SOUTHERN CALIFORNIA EDISON (SCE)

March 9, 2006

FACILITIES: SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3
(SONGS 2 AND 3)

SUBJECT: MEETING WITH REPRESENTATIVES OF SCE FOR SONGS 2 AND 3

A meeting was held on Thursday, March 2, 2006, between the Nuclear Regulatory Commission (NRC) staff and SCE, the licensee for SONGS 2 and 3. The meeting was held at the request of the licensee for it to present to the NRC staff its evaluation of the indications in the Unit 3 Control Element Drive Mechanism (CEDM) penetration 56 and repair alternatives. The notice for the meeting was issued on February 13, 2006.

During the Unit 3 outage in 2003, the inspection of the Unit 3 reactor vessel head (RVH) identified an indication on CEDM penetration 56 that was assumed to be a crack. Although SCE had approval to perform a weld overlay repair of RVH penetrations (ISI-3-8), this particular indication exceeded the generic 75 percent through-wall crack limit. Therefore, SCE submitted a specific relief request for CEDM penetration 56 (ISI-3-13). The NRC granted approval of this relief request for one cycle. SCE committed to evaluate repair alternatives for the long term.

With the Unit 3 refueling outage scheduled for October 2006, the licensee proposed its long-term disposition of penetration 56 by discussing repair alternatives, criteria for a contingency repair, appropriate contingency repair, planned actions, and implementation schedules. The NRC staff was appreciative of the presentation and stated it will perform a quick review on the general acceptability of SCE's approach and techniques and inform SCE of the staff's findings.

Enclosure 1 is the list of attendees. Enclosure 2 is the material handed out by the licensee. There was no handout from the NRC staff.

/RA/

N. Kalyanam, Project Manager
Plant Licensing Branch IV
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No.: 50-362

Enclosures: 1. List of Attendees
2. Licensee's Handout

cc w/encls: See next page

DISTRIBUTION:

PUBLIC	LPLIV Reading	RidsNrrDorl (CHaney/CHolden)
RidsNrrDorlLplg (DTerao)	RidsNrrLALFeizollahi	KGruss
RidsNrrDciCpnb (TChan)	JCollins	JTsao
RidsNrrPMNKalyanam	RidsOgcRp	RidsRgn4MailCenter (TPruett)
RidsAcrsAcnwMailCenter	RJasinski (Comm. Analyst)	JDixon-Herrity, RIV

ADAMS ACCESSION NO. **ML060690154**

OFFICE	LPL4/PM	LPL4/LA	LPL4/BC
NAME	NKalyanam	LFeizollahi	DTerao
DATE	3/8/06	3/8/06	3/9/06

DOCUMENT NAME: E:\Filenet\ML060690154.wpd

OFFICIAL RECORD COPY

LIST OF ATTENDEES AT THE MARCH 2, 2006, MEETING

<u>NAME</u>	<u>AFFILIATION</u>
M. Short	SCE
A.E. Scherer	SCE
J. Rainsberry	SCE
T. Raidy	SCE
M. Devitt	SCE
W. Bramford	Westinghouse
J. Lareau	Westinghouse
D. Terao	NRR/DORL/LPLIV
K. Gruss	NRR/DCI/CFEB
T. Chan	NRR/DCI/CPNB
J. Collins	NRR/DCI/CPNB
J. Tsao	NRR/DCI/CFEB
N. Kalyanam	NRR/DORL/LPLIV

Where:

SCE	=	Southern California Edison
NRR	=	Office of Nuclear Reactor Regulation
DORL	=	Division of Operating Reactor Licensing
LPLIV	=	Plant Licensing Branch IV
DCI	=	Division of Component Integrity
CFNB	=	Piping & NDE Branch
CFEB	=	Flaw Evaluation & Welding Branch

ENCLOSURE 1

LICENSEE'S HANDOUT FOR MARCH 2, 2006, MEETING

LONG-TERM DISPOSITION OF
CONTROL ELEMENT DRIVE MOTOR PENETRATION # 56
SAN ONOFRE NUCLEAR GENERATING STATION, UNIT 3
SOUTHERN CALIFORNIA EDISON

ENCLOSURE 2

San Onofre Nuclear Generating Station
Units 2 and 3

cc:

Mr. Daniel P. Breig
Southern California Edison Company
San Onofre Nuclear Generating Station
P. O. Box 128
San Clemente, CA 92674-0128

Mr. Douglas K. Porter, Esquire
Southern California Edison Company
2244 Walnut Grove Avenue
Rosemead, CA 91770

Mr. David Spath, Chief
Division of Drinking Water and
Environmental Management
P. O. Box 942732
Sacramento, CA 94234-7320

Chairman, Board of Supervisors
County of San Diego
1600 Pacific Highway, Room 335
San Diego, CA 92101

Mark L. Parsons
Deputy City Attorney
City of Riverside
3900 Main Street
Riverside, CA 92522

Mr. Gary L. Nolff
Assistant Director - Resources
City of Riverside
3900 Main Street
Riverside, CA 92522

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011-8064

Mr. Michael Olson
San Diego Gas & Electric Company
P.O. Box 1831
San Diego, CA 92112-4150

Mr. Ed Bailey, Chief
Radiologic Health Branch
State Department of Health Services
Post Office Box 997414 (MS7610)
Sacramento, CA 95899-7414

Resident Inspector/San Onofre NPS
c/o U.S. Nuclear Regulatory Commission
Post Office Box 4329
San Clemente, CA 92674

Mayor
City of San Clemente
100 Avenida Presidio
San Clemente, CA 92672

Mr. James T. Reilly
Southern California Edison Company
San Onofre Nuclear Generating Station
P.O. Box 128
San Clemente, CA 92674-0128

Mr. James D. Boyd, Commissioner
California Energy Commission
1516 Ninth Street (MS 31)
Sacramento, CA 95814

Mr. Ray Waldo, Vice President
Southern California Edison Company
San Onofre Nuclear Generating Station
P.O. Box 128
San Clemente, CA 92764-0128

Mr. Brian Katz
Southern California Edison Company
San Onofre Nuclear Generating Station
P.O. Box 128
San Clemente, CA 92764-0128

February 2006

San Onofre Nuclear Generating Station
Units 2 and 3

- 2-

cc:

Mr. Steve Hsu
Department of Health Services
Radiologic Health Branch
MS 7610, P.O. Box 997414
Sacramento, CA 95899

Mr. A. Edward Scherer
Southern California Edison Company
San Onofre Nuclear Generating Station
P.O. Box 128
San Clemente, CA 92674-0128

February 2006