

From: D. Ashley
To: John Hufnagel
Date: Tue, Sep 13, 2005 12:41 PM
Subject: draft RAIs

John,

Per our discussions.

Bear in mind that this is RAI is in the draft stage and is being provided to clarify our phone conversations. It should not be used to finalize any formal response or licensing position. The discussion of draft RAIs is a necessary part of the license renewal process and will be provided as needed for your use.

The final RAI will be issued under docketed correspondence.

The combustion turbine power plant was determined to be in-scope for the purposes of license renewal. Table 2.5.1.19 refers to section 3.6.2.1.2 for the purpose of Aging Management Evaluation. We cannot evaluate the breakdown of subcomponents in the Combustion Turbine Power Plant section. We need additional information to evaluate the long lived passive components and any aging management program and aging management reviews conducted. The level of detail should be in the format and depth used to describe the diesel generator section of your application.

Please let me know if you need additional information.

=====
regards,

Donnie Ashley
NRR/DRIP/RLEP
Oyster Creek
License Renewal Project Manger
301-415-3191
dja1@nrc.gov

Mail Envelope Properties (4327014C.36D : 9 : 10848)

Subject: draft RAIs
Creation Date: Tue, Sep 13, 2005 12:41 PM
From: D. Ashley

Created By: DJA1@nrc.gov

Recipients	Action	Date & Time
exeloncorp.com	Transferred	09/13 12:42 PM
john.hufnagel (John Hufnagel)		

Post Office	Delivered	Route
		exeloncorp.com

Files	Size	Date & Time
MESSAGE	2300	Tuesday, September 13, 2005 12:41 PM

Options

Auto Delete: No
Expiration Date: None
Notify Recipients: No
Priority: Standard
Reply Requested: No
Return Notification: None

Concealed Subject: No
Security: Standard

To Be Delivered: Immediate
Status Tracking: Delivered & Opened