



A subsidiary of Pinnacle West Capital Corporation

Palo Verde Nuclear
Generating Station

Cliff Eubanks
Vice President
Nuclear Operations

Tel (623) 393-6116
Fax (623) 393-6077

Mall Station 7802
PO Box 52034
Phoenix, Arizona 85072-2034

102-05434-CE/SAB/RKR
March 07, 2006

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555-0001

Dear Sirs:

**Subject: Palo Verde Nuclear Generating Station (PVNGS)
Unit 2
Docket No. STN 50-529
Withdrawal of Request for Emergency Amendment to Technical
Specifications 3.7.8, "Essential Spray Pond System (ESPS)" and
3.8.1, "AC Sources – Operating"**

In letter number 102-05420, dated February 23, 2006, supplemented by letter number 102-05421, dated February 23, 2006, Arizona Public Service Company (APS) requested an emergency Technical Specification (TS) amendment that would allow a one-time extension of the 72-hour allowed outage times (AOTs) of TS 3.7.8, Essential Spray Pond System (ESPS), Required Action A.1, and TS 3.8.1, AC Sources – Operating, Required Action B.4, due to suspected ESPS train B pipe leakage. Subsequent to submitting the emergency TS amendment request, APS completed excavation and examination of the areas of the ESPS train B supply and discharge piping that were suspected to be leaking and concluded that the ESPS train B piping is not leaking, and is intact and functional. APS restored the ESPS to operable status at 0246 on February 24, 2006, prior to expiration of the 72 hour AOT. Based on this, NRC approval of the AOT extension is no longer required and APS withdraws the emergency TS amendment. It should be noted that APS verbally notified the NRC at approximately 0305 on February 24, 2006, that the emergency TS amendment was no longer required.

No commitments are being made in this letter. If you have any questions, please contact Thomas N. Weber at (623) 393-5764.

Sincerely,

A member of the **STARS** (Strategic Teaming and Resource Sharing) Alliance

Callaway • Comanche Peak • Diablo Canyon • Palo Verde • South Texas Project • Wolf Creek

A001

U. S. Nuclear Regulatory Commission

ATTN: Document Control Desk

Withdrawal of Request for Emergency Amendment to Technical Specifications 3.7.8,
"Essential Spray Pond System (ESPS)" and 3.8.1, "AC Sources – Operating"

Page 2

CE/SAB/RKR/gt

cc: B. S. Mallett NRC Region IV Regional Administrator
M. B. Fields NRC NRR Project Manager
G. G. Warnick NRC Senior Resident Inspector for PVNGS
A. V. Godwin Arizona Radiation Regulatory Agency (ARRA)