

March 15, 2006

10 CFR 50.55a(g)(5)(iii)

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Mail Stop: OWFN P1-35
Washington, D.C. 20555-001

Gentlemen:

In the Matter of) Docket No. 50-259
Tennessee Valley Authority)

**BROWNS FERRY NUCLEAR PLANT (BFN) - UNIT 1 - AMERICAN SOCIETY OF
MECHANICAL ENGINEERS (ASME) SECTION XI, INSERVICE INSPECTION
(ISI) PROGRAM - FIRST TEN-YEAR INSPECTION INTERVAL, REQUEST FOR
RELIEF 1-ISI-20**

Pursuant to 10 CFR 50.55a(g)(ii)(A)(5), TVA requests relief from certain inservice inspection requirements in Section XI of the ASME Boiler and Pressure Vessel Code.

TVA has determined that three of the fifteen longitudinal shell welds in the BFN Unit 1 reactor pressure vessel have nondestructive examination (NDE) coverage limitations (less than 90 percent coverage completed) because of obstructions from other components, which exceeds that specified in Table IWB-2500-1 of ASME Section XI. Compliance with the extent of the examination which includes essentially 100 percent of the weld length is impractical and will result in unusual difficulty and unnecessary radiation exposure to various plant personnel without any compensating increase in the level of quality or safety. In lieu of the required essentially 100 or greater than 90 percent coverage, BFN Unit 1 proposes an examination of the accessible areas to the maximum extent practical given the components design, and configuration. TVA considers that the obtained coverage to the maximum extent practical will provide an acceptable level of quality and safety. Therefore, pursuant to 10 CFR 50.55a(a)(3)(i), TVA requests that relief be granted.

U.S. Nuclear Regulatory Commission
Page 2
March 15, 2006

BFN Unit 1 is currently in a recovery outage, and TVA is in the process of completing the BFN Unit 1 first Ten-Year Inspection Interval NDE examinations. The second Ten-Year Inspection Interval will begin one year after restart from the recovery outage. Accordingly, TVA requests NRC approval of the enclosed BFN Unit 1 Relief Request 1-ISI-20 by January 31, 2007.

There are no new commitments contained in this letter. If you have any questions, please telephone me at (256) 729-2636.

Sincerely,

Original signed by:

William D. Crouch
Manager of Licensing
and Industry Affairs

cc: See Page 3

U.S. Nuclear Regulatory Commission
Page 3
March 15, 2006

Enclosure
cc (Enclosure):

(Via NRC Electronic Distribution)
U.S. Nuclear Regulatory Commission
Region II
Sam Nunn Atlanta Federal Center
61 Forsyth Street, SW, Suite 23T85
Atlanta, Georgia 30303-3415

Mr. Malcolm T. Widmann, Branch Chief
U.S. Nuclear Regulatory Commission
Region II
Sam Nunn Atlanta Federal Center
61 Forsyth Street, SW, Suite 23T85
Atlanta, Georgia 30303-8931

NRC Senior Resident Inspector
Browns Ferry Nuclear Plant
10833 Shaw Road
Athens, Alabama 35611-6970

Margaret Chernoff, Senior Project Manager
U.S. Nuclear Regulatory Commission
(MS 08G9)
One White Flint, North
11555 Rockville Pike
Rockville, Maryland 20852-2739

U.S. Nuclear Regulatory Commission
Page 4
March 15, 2006

WDC:SMK:BAB

Enclosure

cc (Enclosure):

B. M. Aukland, POB 2C-BFN
M. Bajestani, NAB 1A-BFN
A. S. Bhatnagar, LP 6A-C
J. C. Fornicola, LP 6A-C
R. G. Jones, POB 2C-BFN
R. F. Marks, PAB 1C-BFN
G. W. Morris, BR 4X-C
B. J. O'Grady, PAB 1E-BFN
K. W. Singer, LP 6A-C
E. J. Vigluicci, ET 11A-K
NSRB Support, LP 5M-C
EDMS WT CA-K

S:\lic\submit\subs\ISI Relief Request.doc

**TENNESSEE VALLEY AUTHORITY
BROWNS FERRY NUCLEAR PLANT (BFN) UNIT 1
AMERICAN SOCIETY OF MECHANICAL ENGINEERS (ASME) SECTION XI
INSERVICE INSPECTION (ISI) PROGRAM
(FIRST TEN-YEAR INSPECTION INTERVAL)
REQUEST FOR RELIEF 1-ISI-20**

Executive Summary: The augmented examination requirements of the reactor vessel are included in 10 CFR 50.55a(g)(6)(ii)(A)(2) and performed in accordance with Section XI of the ASME Boiler and Pressure Vessel Code, 1995 Edition through the 1996 Addenda, the examination code of record for BFN Unit 1.

TVA is requesting relief from the specified inservice inspection requirements. ASME Section XI Examination Category B-A, Pressure Retaining Welds in Reactor Vessel, Item Number B1.12, Longitudinal Shell Welds, requires the extent of the examination to include essentially 100% of the weld length, as documented in Table IWB-2500-1 (note 2) of ASME Section XI. 10 CFR 50.55a(g)(6)(ii)(A)(2) states "essentially 100% as used in Table IWB-2500-1 means more than 90 percent of the examination volume of each weld, where the reduction in coverage is due to interference by another component, or part geometry." The configuration of the BFN Unit 1 Reactor Pressure Vessel (RPV) and vessel internals prevents 100% examination coverage of the longitudinal shell welds. BFN Unit 1 has a total of fifteen longitudinal shell welds in the RPV. Three of the fifteen welds did not receive more than 90% coverage because of obstructions from other components. The physical examination limitations occur when the ASME Section XI Code examination requirements are applied in areas of components constructed and fabricated to early plant designs, which were not required to be "designed for access." The BFN Unit 1

construction permit was issued prior to January 1, 1971, and is therefore exempt from complying with certain provisions of the Code requirements for examination access pursuant to 10 CFR 50.55a(g)(4). Compliance with the extent of the examination which includes essentially 100 percent of the weld length is impractical and will result in unusual difficulty and unnecessary radiation exposure to various plant personnel without any compensating increase in the level of quality or safety.

Therefore, in lieu of the required essentially 100 or greater than 90% coverage, BFN Unit 1 proposes an examination of the accessible areas to the maximum extent practical given the components design, and configuration. TVA considers that the obtained coverage to the maximum extent practical will provide an acceptable level of quality and safety. Therefore, pursuant to 10 CFR 50.55a(a)(3)(i), TVA requests that relief be granted.

This request for relief is consistent with one submitted by TVA for BFN Unit 2, third period, second interval by letter dated May 24, 2002. The request was approved by NRC letter dated April 03, 2003.

<u>Unit:</u>	One (1)
<u>ISI Interval:</u>	ASME Section XI, First Ten-Year ISI Interval
<u>System(s):</u>	Reactor Pressure Vessel (RPV)
<u>Components:</u>	RPV Longitudinal Welds
<u>ASME Code Class:</u>	ASME Code Class 1
<u>ASME Section XI Code Edition:</u>	1995 Edition, 1996 Addenda

Code Table: IWB-2500-1

Examination Category: B-A, Pressure Retaining Welds in Reactor Vessels

Examination Item Number: B1.12 Longitudinal Shell Welds

Code Requirement: The 1995 Edition, 1996 Addenda, ASME Section XI, Table IWB-2500-1, Examination Category B-A, Item Numbers B1.12 requires a volumetric examination method that includes essentially 100 percent of the weld length.

Code Requirements From Which Relief Is Requested: Relief is requested from the requirement to perform a volumetric examination of essentially 100 percent of the three RPV longitudinal shell welds.

List Of Items Associated With The Relief Request:

Component	Percentage Coverage	Limitation
V-3-A	77.7%	Core Spray Piping and Feedwater Spargers
V-3-B	77.4%	Core Spray Piping and Feedwater Spargers
V-3-C	76.6%	Core Spray Piping and Feedwater Spargers

Basis For Relief Request: Areas of the V-3-A, V-3-B, and V-3-C welds are inaccessible for ultrasonic examination due to the design configuration of the RPV and vessel internals. The examinations were performed with automated ultrasonic equipment from the vessel inside surface. The V-3-A, V-3-B, and V-3-C RPV

longitudinal shell weld scans were obstructed by the core spray piping and feedwater spargers.

Alternative Examination:

In lieu of the Code required essentially 100 percent volume ultrasonic examination, BFN Unit 1 proposes an ultrasonic examination of accessible areas to the maximum extent practical given the component design, and configuration of the subject welds.

Justification for The Granting of Relief:

The configuration of BFN Unit 1 RPV and vessel internals prevents essentially 100 percent examination coverage of the three RPV longitudinal shell welds (V-3-A, V-3-B, and V-3-C). The examinations were performed with automated ultrasonic equipment from the vessel inside surface. BFN Unit 1 has fifteen longitudinal welds in the RPV shell courses. Twelve of these welds received essentially 100 percent coverage. Three of the fifteen welds did not receive essentially 100 percent coverage due to obstructions from the vessel internal components.

The V-3-A, V-3-B, and V-3-C longitudinal shell weld scans were obstructed by the core spray piping and feedwater sparger and received 77.7%, 77.4% and 76.6% examination coverage respectively. The outside surfaces of these welds are inaccessible due to RPV outside insulation design and proximity of bio-shield wall.

The ultrasonic examinations of the longitudinal shell welds were performed to the maximum extent practical for maximum coverage. The ultrasonic examinations of the longitudinal shell welds were performed with equipment, personnel, and procedures qualified to the Performance Demonstration Initiative (PDI) Program in accordance with

the requirements of the 1995 Edition, 1996 Addenda of ASME Section XI, Division 1, Appendix VIII as mandated by 10 CFR 50.55a(g) (6) (ii) (c).

Because BFN's construction permit was issued prior to January 1, 1971, BFN is exempt from complying with certain provisions of the Code requirements for examination access as granted by 10 CFR 50.55a(g) (4).


Compliance with the 1995 Edition, 1996 Addenda of ASME Section XI is not practical and will result in unusual difficulty and unnecessary radiation exposure to various plant personnel without any compensating increase in the level of quality or safety. TVA considers that the obtained coverage to the maximum extent practical will provide an acceptable level of quality and safety. Therefore, pursuant to 10 CFR 50.55a(a) (3) (i), TVA requests that relief be granted.

**Implementation
Schedule:**

This request for relief is applicable to the BFN Unit 1, ASME Section XI, First Ten-Year Inservice Inspection Interval, which ends one year following Unit 1 restart.

Attachments:
Drawing/Sketch

1-ISI-0992-C-01
BFN-1 RPV ID Coverage Map



NOZZLE GROUP | DISTANCE TO MATING SURFACE

- N12X - 146.5"
- N11X - 228"
- N4X - 246.5"
- N9 - 226.5"
- N16X - 379.5"
- N2X - 564"
- N3X - 503.5"
- N4X - 610"

REFERENCE DRAWINGS (CE):
 SKETCHES - RPV EXAMINATION PLAN (CE)
 SK-B1001
 SK-B1002
 SK-B1004
 SK-B1006
 SK-B1010

LEGEND:
 ○ VESSEL NOZZLE
 ⊙ FULL PENETRATION NOZZLE WELD
 ASME CC-1 (EQUIVALENT)

OLD WELD NO.	NEW WELD NO.
N1A-SE	RRR-1-W001-071
N1B-SE	RRR-1-W002-031
N2A-SE	RRR-1-W002-026
N2B-SE	RRR-1-W002-027
N2C-SE	RRR-1-W002-028
N2D-SE	RRR-1-W002-029
N2E-SE	RRR-1-W002-030
N2F-SE	RRR-1-W002-070
N2G-SE	RRR-1-W002-069
N2H-SE	RRR-1-W002-087
N2J-SE	RRR-1-W002-087
N2K-SE	RRR-1-W002-086
N2A-SE	CS-1-W002-020
N2B-SE	CS-1-W002-021
N2A-SE	RRR-1-W003-001
N2B-SE	RRR-1-W003-050

- NOTES:
 1. REFER TO RPV MANUAL FOR MATERIAL SPECIFICATIONS AND MATERIAL
 2. NOZZLES N-11A, N-11B, N-12A, N-12B, N-16A AND N-16B ARE CODE
 3. EACH NOZZLE IS DENOTED BY 'IR' FOR THE INNER RADIUS SECTION AND 'SE' FOR THE SWE-END WELDS

DATE: 07/02/2010
 TIME: 10:52:30
 USER: CDD

APP: 2.7.2.10
 PROJECT: RPV EXAMINATION PLAN
 SHEET: 01 OF 01
 TITLE: RPV EXAMINATION PLAN

DESIGNED BY: CDD
 CHECKED BY: CDD
 APPROVED BY: CDD

DATE: 07/02/2010
 TIME: 10:52:30
 USER: CDD

APP: 2.7.2.10
 PROJECT: RPV EXAMINATION PLAN
 SHEET: 01 OF 01
 TITLE: RPV EXAMINATION PLAN

DESIGNED BY: CDD
 CHECKED BY: CDD
 APPROVED BY: CDD

ALL W/P HISTORY REPRODUCED AT FOOT

Elev. 745.00' -
 Elev. 739.00'
 (Top of
 Guide Rod BKH)

