

March 22, 2006

Mr. David H. Hinds, Manager, ESBWR
General Electric Company
P.O. Box 780, M/C L60
Wilmington, NC 28402-0780

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION LETTER NO. 12 RELATED TO
ESBWR DESIGN CERTIFICATION APPLICATION

Dear Mr. Hinds:

By letter dated August 24, 2005, General Electric Company (GE) submitted an application for final design approval and standard design certification of the economic simplified boiling water reactor (ESBWR) standard plant design pursuant to 10 CFR Part 52. The Nuclear Regulatory Commission (NRC) staff is performing a detailed review of this application to enable the staff to reach a conclusion on the safety of the proposed design.

The NRC staff has identified that additional information is needed to continue portions of the review. The staff's request for additional information (RAI) is contained in the attachment to this letter. This RAI concerns missile protection, Section 3.5 of the ESBWR design control document. Questions 3.5-1 through 9 of this RAI were sent to you via electronic mail on February 1, 2006, and were discussed with you during a telecon on March 3, 2006. Questions 3.5-10 through 14 of this RAI were sent to you via electronic mail on February 19, 2006, and were discussed with you during a telecon on March 7, 2006. You agreed to respond to this RAI by April 14, 2006.

If you have any questions or comments concerning this matter, you may contact me at (301) 415-2863 or lwr@nrc.gov or you may contact Amy Cubbage at (301) 415-2875 or aec@nrc.gov.

Sincerely,

/RA/

Lawrence Rossbach, Project Manager
New Reactor Licensing Branch
Division of New Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 52-010

Enclosure: As stated

cc: See next page

Mr. David H. Hinds, Manager, ESBWR
General Electric Company
P.O. Box 780, M/C L60
Wilmington, NC 28402-0780

March 22, 2006

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION LETTER NO. 12 RELATED TO
ESBWR DESIGN CERTIFICATION APPLICATION

Dear Mr. Hinds:

By letter dated August 24, 2005, General Electric Company (GE) submitted an application for final design approval and standard design certification of the economic simplified boiling water reactor (ESBWR) standard plant design pursuant to 10 CFR Part 52. The Nuclear Regulatory Commission (NRC) staff is performing a detailed review of this application to enable the staff to reach a conclusion on the safety of the proposed design.

The NRC staff has identified that additional information is needed to continue portions of the review. The staff's request for additional information (RAI) is contained in the enclosure to this letter. This RAI concerns missile protection, Section 3.5 of the ESBWR design control document. Questions 3.5-1 through 9 of this RAI were sent to you via electronic mail on February 1, 2006, and were discussed with you during a telecon on March 3, 2006. Questions 3.5-10 through 14 of this RAI were sent to you via electronic mail on February 19, 2006, and were discussed with you during a telecon on March 7, 2006. You agreed to respond to this RAI by April 14, 2006.

If you have any questions or comments concerning this matter, you may contact me at (301) 415-2863 or lwr@nrc.gov or you may contact Amy Cubbage at (301) 415-2875 or aec@nrc.gov.

Sincerely,

/RA/

Lawrence Rossbach, Project Manager
New Reactor Licensing Branch
Division of New Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 52-010

Enclosure: As stated

cc: See next page

ACCESSION NO. ML060750246

OFFICE	NRBA/PM	NRBA/BC
NAME	LRossbach	LDudes
DATE	03/17/2006	03/21/2006

OFFICIAL RECORD COPY

Distribution for DCD RAI Letter No. 12 dated March 22, 2006

Hard Copy

PUBLIC
NRBA R/F
ACabbage
LRossbach

E-Mail

LDudes
JHan
JDanna
ACRS
OGC
ACabbage
LRossbach
LQuinones
JGuo
DSolorio
JTsao
KGruss

Request for Additional Information - Chapter 3.5 of the ESBWR Design Control Document (DCD)

RAI Number	Reviewer	Question Summary	Full Text
3.5-1	Guo J	Provide additional information on missile selection criteria.	DCD Section 3.5.1 describes the criteria for missile protection inside the reactor building and lists systems requiring missile protection. However, the information provided is not sufficient for the staff to determine their acceptability. Please (1) provide information on missile protection for the systems classified under regulatory treatment of non-safety systems (RTNSS), such as fuel and auxiliary pool cooling system, (2) explain why the reactor water cleanup system (RWCU) is not listed as requiring missile protection for its reactor coolant pressure boundary and shutdown cooling functions, and (3) confirm that a single active failure concurrent with postulated internally generated missiles has been properly assumed in the selections.
3.5-2	Guo J	Provide design information on how the various pipe fittings were screened.	DCD Section 3.5.1.1.2.2 analyzed the remaining pressurized components considered to be potentially capable of producing missiles. However, the information is not sufficient to determine their acceptability. Please provide information on how the various pipe fittings were screened to determine those that could credibly become missiles.
3.5-3	Guo J	Discuss the potential for a guillotine break of a high-energy line outside containment to become a missile source.	DCD Section 3.5.1.1.2.2 states that piping failures do not form missiles because the whipping section remains attached to the remainder of the pipe. However, a guillotine break of a high-energy line could cause the pipe attachments to become a missile source. DCD Section 3.6 discusses the dynamic effects related to jet impingement forces and pipe whipping, but missile generation was not considered. Discuss the potential for a guillotine break of a high-energy line outside containment to become a missile source.

3.5-4	Guo J	Provide an assessment of potential gravitational missiles generated outside the containment.	DCD Section 3.5.1.1.1.3 discusses other missile analyses. However, gravitational missiles are not addressed in this section. Provide an assessment of potential gravitational missiles generated outside containment and explain plant design features that could prevent the impact of a falling object on safety-related equipment necessary to achieve a safe shutdown.
3.5-5	Guo J	Explain how protection from external missiles is provided for the blowout panel openings.	DCD Section 3.5.1.1.2.2.6 states that blowout panels are hinged to prevent them from becoming missiles. Explain how protection from external missiles is provided for safety-related components located near the openings of the swing-type blowout panels.
3.5-6	Guo J	Discuss how the failure of explosive squib valve were evaluated and provide design information to show that this type of valve will not become a credible missile source.	Squib valves are seldom used in operating nuclear plants such that the reliability of the valve is not traceable through plant operating experience. Discuss how the failure of explosive squib valves were evaluated, both an initiating event and at time of actuation demand, to verify that potential missiles could not damage surrounding safety-related components such that a safety function would not be threatened. If used as a basis for the evaluation, provide design information to show that this type of valve will not become a credible missile source.
3.5-7	Guo J	Discuss the possibility of the safety-relief valves becoming internally generated missiles.	Safety-relief valves (SRVs) used in ESBWR design function as safety valves and open to prevent nuclear system over-pressurization and are self-actuating by inlet steam pressure. Discuss the possibility of the safety-relief valves becoming internally generated missiles, and provide basis to determine that these components will not credibly affect safety-related equipment needed for safe shutdown.
3.5-8	Guo J	Explain whether the tornado missile threat is considered concurrent with a loss-of-offsite-power.	DCD Section 3.5.1.4 states that the design basis tornado and tornado missile spectrum are defined in DCD Sections 2.3.1, 2.3.2, and Table 2.0-1 in the design of Seismic Category I buildings. In considering tornado-generated missile threat to plant safety-related SSCs, explain whether the missile threat is considered concurrent with a loss-of-offsite-power.

3.5-9	Guo J	In addition to tornado missiles, please address the potential for other extreme winds.	DCD Section 3.5.1.4 states “because tornado missiles are used in the design basis, it is not necessary to consider missile generated from other natural phenomena.” This statement may not be true. Wind driven missiles generated by other site specific extreme winds should be considered on a case by case basis if they are considered credible. Please address the potential for other extreme winds more fully.
3.5-10	Tsao J	Submit the turbine system maintenance program with the COL application.	In DCD Section 3.5.1.1.1.2, it is stated that the COL holder shall submit for NRC approval, within three years of obtaining an operating license, a turbine system maintenance program including probability calculations of turbine missile generation based on the NRC-approved methodology such as Reference 3.5-1, or volumetrically inspect all low pressure turbine rotors at the second refueling outage and every other (alternate) refueling outage thereafter until a maintenance program is approved by the staff. (A) The staff requests that the COL applicant include the turbine system maintenance program for NRC approval as part of the COL application. Turbine integrity plays an important role in ensuring public health and safety. Therefore, the staff needs to review and approve the turbine system maintenance program to confirm that the turbine will be adequately maintained under the program before the operating license is granted. (B) The “COL holder” implies that the utility company has obtained the operating license whereas the “COL applicant” implies that the utility company has not obtained the operating licensee. Therefore, in the context of the turbine maintenance program submittal, the COL “holder” in DCD Section 3.5.1.1.1.2 should be changed to the COL “applicant”.
3.5-11	Tsao J	Explain the inspection frequency.	Provide the technical basis for volumetrically inspecting all low pressure turbine rotors at the second refueling outage and every other refueling outage, and not at every refueling outage.

3.5-12	Tsao J	Submit the probability of turbine missile generation.	DCD Section 3.5.4.4 requires that “The COL holder shall provide a turbine system maintenance program to the NRC or alternative volumetric inspection as described in Subsection 3.5.1.1.” Depending on resolution of RAI 3.5-10, the commitment in Section 3.5.4.4 may need to be revised. As written, DCD Section 3.5.4.4 is inadequate because it does not require the COL holder to submit, for staff review, the probability of turbine missile generation which is a commitment in DCD Section 3.5.1.1.1.2.
3.5-13	Tsao J	Modify Sections 3.5.1.1.1.2 and 3.5.4 to include criteria for the probability of turbine missile generation.	<p>In DCD Section 3.5.1.1.1.2, it is stated that “...the COL holder shall meet the minimum requirement for the probability of turbine missile generation given in Table 3.5-1 at COL...” This commitment is not shown in DCD Section 3.5.4, COL Information. This commitment needs to be added to DCD Section 3.5.4 as follows:</p> <p>3.5.4.5 Probability of Turbine Missile Generation</p> <p>The COL applicant shall meet the minimum requirement for the probability of turbine missile generation provided in Table 3.5-1.</p>
3.5-14	Tsao J	Explain how the turbine system is monitored to meet the probability criteria.	In DCD Table 3.5-1, it is required that if the probability of missile generation, P_1 , exceeds 10^{-4} , the COL applicant is required to take action to reduce P_1 to less than 10^{-4} before returning the turbine to service. Discuss how the COL applicant would monitor the turbine system to ensure that the probability of missile generation satisfies the acceptance criteria in DCD Table 3.5-1 during the life of the plant.

ESBWR

cc:

Mr. David H. Hinds, Manager
ESBWR
P.O. Box 780, M/C L60
Wilmington, NC 28402-0780

Mr. George B. Stramback
Manager, Regulatory Services
GE Nuclear Energy
1989 Little Orchard Street, M/C 747
San Jose, CA 95125

Mr. David Lochbaum, Nuclear Safety Engineer
Union of Concerned Scientists
1707 H Street, NW., Suite 600
Washington, DC 20006-3919

Mr. Paul Gunter
Nuclear Information & Resource Service
1424 16th Street, NW, Suite 404
Washington, DC 20036

Mr. James Riccio
Greenpeace
702 H Street, Suite 300
Washington, DC 20001

Mr. Adrian Heymer
Nuclear Energy Institute
Suite 400
1776 I Street, NW
Washington, DC 20006-3708

Mr. Paul Leventhal
Nuclear Control Institute
1000 Connecticut Avenue, NW
Suite 410
Washington, DC 20036

Dr. Jack W. Roe
Nuclear Energy Institute
1776 I Street, NW
Washington, DC 20006-3708

Mr. Ron Simard
6170 Masters Club Drive
Suwanee, GA 30024

Mr. Brendan Hoffman
Research Associate on Nuclear Energy
and Environmental Program
215 Pennsylvania Avenue, SE
Washington, DC 20003

Ms. Patricia Campbell
Morgan, Lewis & Bockius, LLP
1111 Pennsylvania Avenue, NW
Washington, DC 20004

Mr. Glenn H. Archinoff
AECL Technologies
481 North Frederick Avenue
Suite 405
Gaithersburg, MD. 20877

Mr. Gary Wright, Director
Division of Nuclear Facility Safety
Illinois Emergency Management Agency
1035 Outer Park Drive
Springfield, IL 62704

Mr. Charles Brinkman
Westinghouse Electric Co.
Washington Operations
12300 Twinbrook Pkwy., Suite 330
Rockville, MD 20852

Mr. Ronald P. Vijuk
Manager of Passive Plant Engineering
AP1000 Project
Westinghouse Electric Company
P. O. Box 355
Pittsburgh, PA 15230-0355

Mr. Ed Wallace, General Manager
Projects
PBMR Pty LTD
PO Box 9396
Centurion 0046
Republic of South Africa

Mr. Russell Bell
Nuclear Energy Institute
Suite 400
1776 I Street, NW
Washington, DC 20006-3708

Ms. Sandra Sloan
Areva NP, Inc.
3315 Old Forest Road
P.O. Box 10935
Lynchburg, VA 24506-0935

Ms. Kathryn Sutton, Esq.
Morgan, Lewis & Bockius, LLP
1111 Pennsylvania Avenue, NW
Washington, DC 20004

Mr. Robert E. Sweeney
IBEX ESI
4641 Montgomery Avenue
Suite 350
Bethesda, MD 20814

Mr. Eugene S. Grecheck
Vice President, Nuclear Support Services
Dominion Energy, Inc.
5000 Dominion Blvd.
Glen Allen, VA 23060

Mr. George A. Zinke
Manager, Project Management
Nuclear Business Development
Entergy Nuclear, M-ECH-683
1340 Echelon Parkway
Jackson, MS 39213

E-Mail:
tom.miller@hq.doe.gov or
tom.miller@nuclear.energy.gov
mwetterhahn@winston.com
whorin@winston.com
gcesare@enercon.com
jerald.holm@framatome-anp.com
eddie.grant@exeloncorp.com
joseph_hegner@dom.com
steven.hucik@ge.com
david.hinds@ge.com
chris.maslak@ge.com
james1beard@ge.com
louis.quintana@gene.ge.com
wayne.massie@ge.com
kathy.sedney@ge.com
george.stramback@gene.ge.com