Please do NOT remove

This material from the

Public Document Room

Plant NAME



Metropolitan Edison Company Post Office Box 480 Middletown, Pennsylvania 17057 717 944-4041

6161

HAY 24 FH 3:

April 12, 1979 GOL 0509

Mr. Denwood Ross Assistant Director Division of Reactor Safety U. S. Nuclear Regulatory Commission Washington, D.C. 20555

Dear Sir:

Three Mile Island Nuclear Station Unit 2 (TMI-2)) License No. DPR-73 Docket No. 50-320

Safety Analysis Report for Transition to Natural Circulation (C-D)

Enclosed please find the Safety Analysis Report and preliminary information for the proposed transition to long term natural circulation at TMI-2, as requested at the Commission Meeting of April 9, 1979. This report is current as of approximately April 9. The analysis is significant in that it suggests a great deal of flexibility in placing the TMI-2 reactor in a natural circulation mode. Additional analyses are continuing to be performed which will define more specifically the proposed final end point temperature and pressure conditions as well as state points in the various supporting plant systems. Detail analyses and procedures on the exact methods for achieving natural circulation are also in work. As additional information becomes available, we will supplement the attachment as necessary.

It is our conclusion, from the data in the attachment, that long term natural circulation is a viable way for placing the TMI-2 reactor into a long term stable condition, and the safest of the various options available. OFFINE OF THE SECRETA

Sincerely, Original signed/ J. G. Herbein J. G. Herbein Vice President Generation

JGH:LWH:al Enclosure

cc: Harley Silver (NRC)

Metropolitan Edison Company is a Member of the General Public Utilities System

79051 90236

CORE THERMAL BEHAVIOR

CONTENTS

Evel To 7905190236 DTD 4/12/79

- 1) "3.7 CORE THERMAL BEHAVIOR", G. A. MEYER/A. B. JACKSON, APRIL 10, 1979.
- 2) "CRITERIA DURING ESTABLISHMENT OF NATURAL CIRCULATION," L. L. LOSH/ J. F. BURROW, APRIL 10, 1979.
- 3) "RELIABILITY AND UNCERTAINTY OF THERMOCOUPLES FOLLOWING LOSS OF FEEDWATER TRANSIENT," T. L. WILSON, APRIL 5, 1979.
- 4) "ACTION ITEM 143," J. T. WILLSE, APRIL 6, 1979.
 - 5) "RESPONSE TO THERMOCOUPLE REQUEST," J. A. WEIMER, APRIL 5, 1979.
 - 6) "REQUIRED FLOW FOR CORE COOLING," A. B. JACKSON, APRIL 10, 1979.
 - 7) "COOLDOWN PRESSURE," J. R. GLOUDEMANS, APRIL 10, 1979.
 - 8) "ADIABATIC HEATUP RATES," J. H. JONES, APRIL 10, 1979.
 - 9) "INCREASED T.C. READINGS DUE TO PROXIMITY OF FUEL PARTICULATES,"
 P. J. HENNINGSON, APRIL 10, 1979.
- 10) "BOILING CONDITIONS IN CORE," J. A. WEIMER/R. L. HARNE," APRIL 1, 1979.

11) "MINIMUM CORE FLOW - LONG TERM COOLING," G. A. MEYER, APRIL 4, 1979.

12) "CORE FLOW DISTRIBUTIN FOR ONE PUMP AND TWO PUMP OPERATION,"

• R. M. HIATT, APRIL 10, 1979.

20)

- 13) "CORE BYPASS FLOW FOR CORE BLOCKED AT TOP ONLY," R. M. GRIBBLE, APRIL 8, 1979.
- 14) "INCORE THERMOCOUPLE ERROR EVALUATION," J. A. WEIMER, APRIL 10, 1979.
- 15) "DISCREPANCY BETWEEN THERMOCOUPLES AND OUTLET RTD TEMPERATURE MEASUREMENTS," T. L. WILSON, APRIL 9, 1979.
- 16) "LYNXI MODEL FOR TMI-2 BLOCKAGE STUDY," R. M. HIATT, APRIL 10, 1979.
- 17) "DAMAGE MODEL FLUIDIZED BED," P. J. HENNINGSON, APRIL 10, 1979.
- 18) "ESTIMATE OF LOOSE CORE DEBRIS VOLUME (4/9/79 2000)," CORE CONDITION TASK FORCE, APRIL 9, 1979.

CORE PRESSURE DROP FOR NATURAL CIRCULATION. CALCULATION" P.S. BARTELLS, APRIL 9, 1979

CONTENTS

- 3. SAFETY EVALUATION INFORMATION FOR TRANSITION TO NATURAL CIRCULATION COOLING
- 3.1 DESCRIPTION OF COOLING MODE
- 3.2 CONTINGENCY PROCEDURES
- 3.3 SYSTEM PERFORMANCE ANALYSIS IN NATURAL CIRCULATION
- 3.4 CHECKPOINTS DURING THE TRANSITION OPERATION TO NATURAL CIRCULATION
- 3.5 HYDROGEN GAS CONSIDERATIONS
- 3.6 PRESSURE TEMPERATURE CONSIDERATIONS
- 3.7 CORE MELT CONSIDERATIONS
- 3.8 CORE THERMAL BEHAVIOR
- 3.9 CRITICALITY CONSIDERATIONS

3.0 SAFETY EVALUATION INFORMATION FOR TRANSITION TO NATURAL CIRCULATION COOLING

METROPOLITAN EDISON CO. HAS EVALUATED THE VARIOUS STATES FOR MAINTAINING THE TMI 2 REACTOR A LONG TERM COOLING MODE. WE HAVE PREPARED THE FOLLOWING EVALUATIONS WHICH DEMONSTRATE THAT THE REACTOR AND ASSOCIATED SYSTEMS CAN SAFELY UTILIZE RCS NATURAL CIRCULATION CORE COOLING WITH THE STEAM GENERATOR SECONDARY SIDE IN A SOLID FLOWING WATER CONDITIONS FOR HEAT REMOVAL. 3.1 DESCRIPTION OF COOLING MODE

ATTACHMENT 1 TO THIS REPORT ENTITLED "A SUMMARY OF NATURAL CIRCULATION ALTERNATIVES FOR LONG-TERM CORE COOLING AT TMI-2 "DESCRIBES THE PROPOSED METHOD FOR LONG TERM COOLING. THE DOCUMENT CONTAINS DETAILED INFORMATION ON THE RECOMMENDED COOLING METHOD ALONG WITH DISCUSSIONS DOCUMENTING THE SUPERIORITY OF THE RECOMMENDED METHOD OVER ALTERNATIVE CONSIDERATIONS.

BACKUP CONSIDERATIONS 3.2

METROPOLITAN EDISON CO. HAS PREPARED DETAILED OPERATING INSTRUCTIONS IN THE EVENT OF EQUIPMENT MALFUNCTION. A LIST OF THESE PROCEDURES IS PROVIDED IN ATTACHMENT 2. THE BACKUP CONTINGENCIES PROVIDED BY THESE PROCEDURES ASSURES RAPID AND ACCURATE RESPONSE TO EMERGENCY OR OFF NORMAL PLANT CONDITIONS.

3.3 SYSTEM PERFORMANCE ANALYSIS IN NATURAL CIRCULATION

B&W HAS PERFORMED DETAILED ANALYSES OF THE NATURAL CIRCULATION CONDITION FOR THE RECOMMENDED MODE OF COOLING. THESE CALCULATIONS INCLUDE BOTH HAND CALCULATIONS AND THE DEVELOPMENT OF COMPUTER CODES TO PREDICT TRANSITION SYSTEM RESPONSES. THE ANALYTICAL TECHNIQUES USED ARE DESCRIBED IN ATTACHMENT 3. THESE TECHNIQUES HAVE BEEN BENCHMARKED AGAINST NATURAL CIRCULATION DATA OBTAINED AT DAVIS-BESSE 1. IN ADDITION, TESTS WERE PERFORMED AT B&W'S ALLIANCE RESEARCH CENTER WHICH DEMONSTRATE THE EXCELLENT COOLING CAPABILITIES USING THE OTSG'S IN THE RECOMMENDED COOLING MODE. THE RESULTS OF THE ALLIANCE TESTING ARE DISCUSSED IN DETAIL IN ATTACHMENT 1.

ATTACHMENTS 1, Z AND 4 DISCUSS THE POTENTIAL FOR CORE BLOCKAGE. AS SHOWN IN FIGURE 2 OF ATTACHMENT 1, MORE THAN ADEQUATE CORE FLOW WILL EXIST FOR THE RANGE OF ESTIMATED BLOCKAGE. IN ADDITION, ACCEPTANCE CRITERIA HAVE BEEN PREPARED WHICH WILL BE USED TO SAFELY TERMINATE THE TRANSITION TO THE NATURAL CIRCULATION MODE IF NEEDED.

IT IS THEREFORE METROPOLITAN EDISON COMPANY'S VIEW THAT DETAILED ANALYSES OF THE TRANSITION TO THE NATURAL CIRCULATION MODE OF COOLING DEMONSTRATE THAT THE RECOMMENDED COOLING MODE CAN MAINTAIN THE CORE IN A SAFE CONDITION. IN ADDITION, IN THE UNLIKELY EVENT THAT PROBLEMS DO ARISE, ACCEPTANCE CRITERIA WILL ASSURE THAT THE TRANSITION OPERATION CAN BE SAFELY TERMINATED AND THE PLANT RETURNED TO ITS ORIGINAL COOLING MODE. CHECKPOINTS DURING THE TRANSITION OPERATION TO NATURAL CIRCULATION. THE ACCEPTANCE CRITERIA FOR THE TRNASITION OPERATION ARE INCLUDED IN ATTACHMENT 1 AND THE THERMOCOUPLE CRITERIA ARE INCLUDED IN ATTACHMENT 4

3.5 HYDROGEN EVALUATION

METAL-WATER REACTION DURING THE INITIAL PHASES OF THE TMI-2 INCIDENT GENERATED LARGE QUANTITIES OF HYDROGEN ON MARCH 28, 1979. THIS HYDROGEN FORMED A BUBBLE WHICH BECAME TRAPPED IN THE HEAD OF THE REACTOR VESSEL. THE PARTIAL PRESSURE OF HYDROGEN IN THIS BUBBLE CAUSED THE REACTOR COOLANT TO BECOME SATURATED WITH HYDROGEN. AFTER THE BULK OF THE BUBBLE WAS REMOVED ON APRIL 1. THE COOLANT REMAINED SATURATED WITH 1300 TO 1400 STD. CC OF HYDROGEN PER KILO-GRAM OF COOLANT. EXTENSIVE DEGASSING OF THE REACTOR COOLANT DURING THE TIME PERIOD FROM APRIL 2 THROUGH APRIL 8 IS BELIEVED TO HAVE SIGNIFICANTLY REDUCED THE CONCENTRATION OF DISSOLVED HYDROGEN. HOWEVER, SOME HYDROGEN GAS WAS BELIEVED TO HAVE BEEN TRAPPED IN THE CONTROL ROD DRIVE MECHANISMS (CRDMs) AND HAS NOT READILY DISSOLVED INTO THE REACTOR COOLANT. SO, ON APRIL 9TH, THE REACTOR COOLANT SYSTEM PRESSURE WAS CYCLED TO PROGRESSIVELY LOWER PRESSURES, REACHING A MINIMUM PRESSURE OF 411 PSIG. THIS EXPANDED THE GAS TRAPPED IN THE CONTROL ROD DRIVES AND ALLOWED IT TO BE ENTRAINED IN THE RC FLOW. THE AC NOISE SIGNALS ON THE REACTOR COOLANT PRESSURE TRANSMITTER CONFIRMED THAT BUBBLES WERE RELEASED EACH TIME THE PRESSURE REACHED A NEW LOW. (BUBBLES APPARENTLY ALTERNATE THE NOISE SIGNAL AND REDUCE THE PEAK-TO-PEAK FLUCTUATION). THEREFORE, IT IS CLEAR THAT, AT PRESSURES ABOVE 411 PSIG, THE GAS WILL BE COMPRESSED FAR BACK INTO THE CROMS AND THAT. THE REACTOR COOLANT SATURATION PRESSURE IS BELOW 411 PSIG. SINCE THE SOLUBILITY OF HYDROGEN WILL DECREASE AS THE TEMPERATURE DECREASES, NATURAL CIRCULATION MUST BE PERFORMED AT A PRESSURE SUFFICIENTLY ABOVE 411 PSIG TO ASSURE THAT ANY DECREASE IN SOLUBILITY DUE TO TEMPERATURE IS OFFSET BY THE SOLUBILITY INCREASE DUE TO PRESSURE. IF THE MINIMUM TEMPERATURE EXPECTED DURING NATURAL CIRCULATION IS 140°F, AN OPERATING PRESSURE OF 600 PSIG OR GREATER WILL ASSURE THAT NO BUBBLES

ARE FORMED, EVEN IF IT IS ASSUMED THAT REACTOR COOLANT IS PRESENTLY SATURATED AT 411 PSIG. ACTUALLY, THE REACTOR COOLANTS HYDROGEN SATURATION PRESSURE IS EXPECTED TO BE SIGNIFICANTLY BELOW 411 PSIG, BUT THIS WILL NOT BE ABLE TO BE PROVEN BY PRESSURE REDUCTIONS DUE TO NPSH LIMITATIONS ON THE RC PUMPS. IN ORDER TO DETERMINE THE ACTUAL SATURATION LIMIT, PRESSURIZED REACTOR COOLANT SAMPLES WILL HAVE TO BE ANALYZED FOR DISSOLVED HYDROGEN.

THE NET PRODUCTION OF RADIOLYTIC HYDROGEN OR OXYGEN IS EXPECTED TO BE ZERO AS LONG AS THE PARTIAL PRESSURE OF HYDROGEN IN THE REACTOR COOLANT SYSTEM IS KEPT IN THE RANGE OF 5 TO 15 PSI (REF. 1).

ADDITIONAL EQUIPMENT IS NEEDED TO ASSURE ADEQUATE RCS DEGASSING CAPABILITY TO REMOVE ENOUGH GAS FROM THE SYSTEM TO ASSURE EVENTUAL DEPRESSURIZA-TION FROM 600 PSIG TO ATMOSPHERIC PRESSURE WITHOUT INTERRUPTING COOLANT FLOW.

REFERENCES

1. WATER COOLANT TECHNOLOGY OF POWER REACTORS, BY PAUL COHEN, GORDON AND BREACH SCIENCE PUBLISHERS OF NEW YORK, 1969 3.6 PRESSURE-TEMPERATURE CONSIDERATIONS

FERENCES: 1) J.H. TAYLOR TO DISTRIBUTION, SAME SUBJECT, 4/9/79, 8:53 P.M.

2) C.E. HARRIS TO C.W. PRYOR, "P.T. LIMITS FOR LONG TERM COOLING," 4/10/79, 5:50 P.M.

IN RESPONSE TO REFERENCE 1), THE FOLLOWING STATEMENT IS PROVIDED AS INPUT TO SECTION 3.8 OF THE SUBJECT SER. THIS INPUT IS BASED ON THE ANALYSIS RESULTS DOCUMENTED IN REFERENCE 2).

"BASED ON FRACTURE MECHANICS ANALYSES OF THE TMI-2 REACTOR VESSEL, PRESSURE-TEMPERATURE LIMITS FOR LONG TERM COOLING OPERATION HAVE BEEN ESTABLISHED. THE ANALYSES WERE CONDUCTED IN ACCORDANCE WITH APPENDIX G TO SECTION III OF ASME CODE FOR ACCIDENT CONDITIONS. THE CALCULATIONS ARE APPLICABLE FOR FLAW DEPTHS UP TO ONE QUARTER OF THE REACTOR VESSEL THICKNESS AND SHOULD CONSERVATIVELY BOUND ANY FLAWS WHICH MIGHT EXIST IN SERVICE.

THESE ANALYSES CONSIDERED A WORST CASE TRANSIENT ASSOCIATED WITH HPI SYSTEM OPERATION BY CONSERVATIVELY ASSUMING THAT NO MIXING OF HPI AND REACTOR COOLANT WATER OCCURS IN THE INLET PIPING. FOR THIS CASE, THE REACTOR VESSEL INLET NOZZLE IS THE GOVERNING WELD.

A PLOT OF THE ALLOWABLE PRESSURE-TEMPERATURE ENVELOPE IS ATTACHED. THE SYSTEM WILL BE CONTROLLED DURING LONG TERM COOLING OPERATION TO ENSURE THAT THE PRESSURE-TEMPERATURE RESTRICTIONS ARE NOT VIOLATED."

lun Bu

FRB: nw ATTACHMENT

C.E. Harris 4/10/79 PREPARED BY : nil, 2600 2400 2200 Zoco CUR VE APPLICA BLE TO STERDY STATE 1800 PST CONDITIONS, 1600 THERMAL CURVE APPLICABLE STRESSES NOT PRESENT DURING HPL TRANSIENT, W 1400 CONSIDERS THERMAL STRESSES PRESS U 0001 800 THE REACTOR COOLANT TEMPERATURI 600 May DE CONSERVATIVELY TAKEN TO BE EQUAL TO THE METAL 400 TEMAERATURE 200

· 3.7 CORE MELT CONSIDERATIONS

UNDER THE CONDITIONS OF NATURAL CIRCULATION, THE CORE WILL BE SURROUNDED BY COLD WATER NEAR 100[°]F. THE POSSIBILITY OF CORE MELT IS CONSIDERED TO BE REMOTE UNDER THESE CONDITIONS. WITH THE CURRENT LOW DECAY HEAT RATE AND WITH APPROPRIATE MONITORING OF INCORE THERMOCOUPLES, THERE WILL BE SUFFICIENT EARLY WARNING SIGNALS TO PREVENT CORE DAMAGE.

A DETAILED DISCUSSION OF CORE MELTING POINT, ASSESSMENT OF ORIGINAL FUEL DAMAGE CONDITIONS AND EARLY WARNING SIGNALS IS PROVIDED IN ATTACHMENT 5. BASED UPON THIS ASSESSEMENT AND THE USE OF DETAILED ACCEPTANCE CRITERIA FOR THE TRANSITION TO NATURAL CIRCULATION, IT IS METROPOLITAN EDISON COMPANY'S VIEW THAT NO PROBLEMS EXIST WITH RESPECT TO THE POTENTIAL FOR CORE MELT.

3.8 CORE THERMAL BEHAVIOR

THE CORE THERMAL BEHAVIOR FOR VARIOUS POTENTIAL MODES OF OPERATION IS DISCUSSED IN ATTACHMENT 4. ATTACHMENT 4 ALSO DISCUSSES THE USE OF INCORE THERMOCOUPLES, CORE BLOCKAGE CONSIDERATIONS, THERMAL HYDRAULIC EVALUATION OF NATURAL CIRCULATION AND ANALYSIS OF VARIOUS ALTERNATIVES. BASED UPON THE INFORMATION IN ATTACHMENT 4, METROPOLITAN EDISON COMPANY CONCLUDES THAT THE PLANT CAN BE SAFELY OPERATED IN THE RECOMMENDED LONG TERM COOLING MODE.

TMI-2 CRITICALITY EVALUATION

Introduction

3.9

Evaluations of core subcriticality and potentially critical fuel configurations were begun soon after the TMI-2 incident. The analysis covered a broad spectrum of fuel configurations, ranging from the intact core to homogeneous solutions of uranium and water. Boron concentrations necessary to maintain subcriticality for the various postulated configurations were determined. The following is a description of the methods of analysis and results from the criticality evaluations.

1. Fuel in Core Region

The analysis for the various possible configurations of fuel in the core region was divided into two areas (1) fuel rods intact and (2) successive "slumping" of fuel pellets to an ultimate slab of pellets.

1.1 Fuel Rods Intact

PDQ-07 calculations were performed for the TMI-2 core at the core burnup on March 28, 1979 (88.3 EFPD) for several assumptions at cold conditions. The results are summarized in Table 1.

TABLE 1

Boron Requirements for TMI-2 Core for Cold (70°F) Shutdown

Temperature, ^O F	Control Rods	<u>Keff</u> <u>F</u>	oron, ppm
70	All Rods Out	.95	2155
70	All Rods Out	.99	1795
70	All Rods In	•95	1705
70	All Rods In	•99	1385

The boron concentrations listed above are based upon the following assumptions:

a. Guide tubes, spacer grids and cladding remain intact. The fuel is the basic structure as originally loaded into the core region.

b. No credit taken for Lumped Burnable Poison (LBP).

c. Xenon fully decayed.

d. No credit taken for Samarium buildup since shutdown; equilibrium Samarium at hot full power was assumed.

e. An additional 1% ΔK/K was included to provide a conservative prediction at 70°F. The values in Table 1 are possibly non-conservative for higher temperatures because the core has a positive moderator coefficient of \sim +.8 x 10⁻⁴ $\Delta K/K/^{O}F$ at 2100 ppm boron, for an intact core.

Predicted keff values for the present temperature and boron conditions based on the above assumptions are shown in Table 2.

TABLE 2

Core Keff Values for Present Conditions, 280°F and 2100 ppm

Temperature, ^o F Boron,	<u>, ppm</u> <u>Control Rods</u> <u>Keff*</u>
280 210	00 All Rods Out .97
280 210	0 All Rods In .92

* Predicted values from Table 1 using a +.8 x 10^{-4} $\dot{\Delta}$ K/K/^OF moderator coefficient at 2100 ppm boron.

1.2 Fuel Pellets Slumping

Criticality studies were performed for fuel pellets free from the cladding dropping onto the spacer grids. The grids were successively assumed to fail resulting in various slabs of "slumped" fuel atop the lower fuel segments until ultimately one large slab of all the fuel pellets rested atop the lower grid.

KENO-IV version 2 utilizing 123 g XSDRN cross-section sets were used for all calculations.

The core was modeled in seven symmetric planes with top and bottom reflector, but infinite in x,y. Thus, a slab reactor was calculated for 160° F moderator temperature, 900 psi. (An extra conservatism was the top plane having 21 inches of fuel as opposed to the 16 inch actual). The initial axial geometry assumed full (21") pellet stack heights surrounded by borated water. This condition represented a $U0_2/H_20$ volume ratio of .307. Subsequent calculations assumed that as the fuel slumped into each of the seven planes, defined by the spacer grid, a $U0_2/H_20$ volume ratio of 0.63 occurred within the fuel water mixture. The assumed volume fraction of .63 is based on measured packing fraction data at CNFP. The calculations assumed BOL isotopics; no control rods, no LBPs, no fission products, no structural material, only borated water and fuel pellets. A calculation was also made assuming that all seven planes had slumped into one slab. Fuel enrichment for all cases was assumed to be the average of the three fuel batches, ie 2.60 w/o U-235.

For those conditions which produced a critical system at the initial boron concentration of 2100 ppm (approximate level in RC system), the boron was increased until a subcritical array could be predicted. The fuel arrangement for the various cases is shown in Figure 1 and the results are summarized in Table 3.

riticality C	Calculations for	Four "Slu	mped" Fuel	Configurations	in Core Region

Boron, ppm	<u>Case 1</u> (Grids Intact)	<u>Keff</u> <u>Case 2</u> (2 Grids Fail)	<u>Case 3</u> (5 Grids Fail)	<u>Case 4</u> (Total Slump)
2100	0.824 ± .004	1.016 ± .005	$1.062 \pm .004$	$1.078 \pm .004$
4000	•••• ••••	.990 ± .004	.992 ± .003	$1.038 \pm .004$ $1.003 \pm .005$

An additional KENO calculation was made for the more credible situation of the upper 3 grids failing and the fuel slumping atop the fourth grid. For this situation the fuel below the fourth grid was assumed to be standing in its basic configuration. The array was assumed infinite in x-y direction. The slumped fuel pellets in the upper region was assumed to be packed in the most optimum fuel/water ratio of fuel volume fraction = 0.55. Whereas, the standing fuel pellets were assumed to be at their initial volume fraction of 0.307. Since the KENO code cannot calculate two mixtures of fuel with different cell pitch the above scenario was bounded by two KENO cases. The first case assumed normal cell pitch (1.44 cm) but had to use a larger pellet O.D. in the slumped region to produce the 0.55 volume fraction fuel. Case 2 assumed the normal pellet O.D in the slumped region with a cell pitch of 1.12 cm and a correspondingly smaller pellet 0.D. in the lower intact fuel rods. Figure 2 shows the fuel configuration and Table 4 summarizes the results.

TABLE 4

Criticality Calculations for 3 Grids Failing

<u>_</u>	ase	<u>Cell Pitch</u>	Boron, ppm	<u>Temp</u> , ^O F	<u>K∞</u>
	1	1.44 cm	3000	280	1.000
	2	1.12 cm	3000	280	1.019

Comparing Case 2 above with the total slump Case 4 from Table 1, the single slab is slightly more reactive.

An assessment of the inherent conservatism and nonconservatism of the KENO studies (Tables 3 & 4) is presented below:

1.

2.

No fuel depletion considered. Fuel depletion will reduce K∞ by 2 -2.5% ΔK/K No radial leakage considered. Radial leakage will reduce K^{∞} by $\frac{1}{2}$ -3.0% $\Delta K/K$ 3. No credit taken for Ag-In-Cd Control Rods.

The total slump case (slab) assumed a Volume Fraction of fuel equal to 0.63, the packing fraction. However, this is not necessarily the optimum configuration for criticality (Section). If the most optimum fuel/water ratio is formed, the configuration may be more reactive by $\sim +2.5\%$ $\Delta K/K$.

TABLE.

1.3 Fuel Pellets - Sphere

Calculations were performed to predict the criticality for the assumption that all the fuel pellets collapse to form an optimum spherical configuration in the reactor vessel plenum. The multiplication factor for an infinite array of non-depleted fuel pellets in the optimum water ratio for the core average enrichment 2.6 w/o U-235 is presented in Table 5. Also shown in Table 5 is the expected leakage reactivity for the hypothetical sphere.

Enrichment Temp, ^O F	Boron, ppm	Optimum VF Fuel	K∞ ρ Leakage
w/o U235			
2.6 280	2100	0.52	1.091 -1.4% AK/K
2.6 280	3000	0.63	1.028 -1.6% AK/K

These data demonstrate that after subtracting the fuel depletion reactivity $(-2.5\% \ \Delta K/K)$ and the expected leakage, a hypothetical sphere can be critical at 2100 ppm but will be subcritical at a boron concentration of 3000 ppm.

Parameter Study - Infinite Media

Heterogeneous mixtures of fuel and water in an infinite array were analyzed with the NULIF code. The volume fraction of fuel, fuel particle size, boron concentration, and temperature were varied. The calculations were performed for a fuel enrichment of 2.6 w/o U-235, corresponding to the average fuel enrichment in the core. No credit was taken for fuel burnup or fission product buildup.

Figure 3 shows reactivity as a function of the uranium volume fraction for several boron concentrations and 2 different temperatures. The optimum fuel/ water ratio increases with increasing boron concentration. The most likely fuel volume fraction for intact fuel pellets settling in a system cavity has been experimentally determined to be .63. Figure 4 shows reactivity as a function of fuel particle size for a fuel volume fraction of .63. As can be seen by comparing Figures 3 and 4, reactivity is much more sensitive to the volume fraction of uranium in the system than to particle size. For fuel volume fractions in the range where Ko can be greater than 1.0 with 2100 ppm boron in the system, intact fuel pellets uniformly distributed in the system were found to be more reactive than an equal amount of fuel dispersed in smaller sized particles or honogeneously mixed with the coolant. Figure 5 shows reactivity as a function of boron concentration for uranium volume fractions of .52 and .63 at 280°F. At lower boron concentrations, the lower uranium volume fractions are nore reactive, at higher boron concentrations, the larger uranium volume fractions are more reactive. Figure 6 shows reactivity as a function of boron concentration for a uranium volume fraction of :63 and 3 different particle sizes.

All the above calculations were performed at 1000 psia. A drop in system pressure to 300 psia would be equivalent to a 10° F rise in the moderator temperature. For intact pellets at a volume fraction of .63 the temperature coefficient varies from -.8 x $10^{-4} \Delta \rho / ^{\circ}$ F at 2100 ppm to -.5 x $10^{-4} \Delta \rho / ^{\circ}$ F at 4000 ppm. Thus a drop in system pressure from 1000 psia to 300 psia would result in a slight decrease (<0.1% in reactivity.



Figure 2 CONFIGURATION FOR THREE (3) GRID COLLAPSE KENO CASE 2 CASE1 SLUMPED SIUMPED FUEL , FUEL 1.12 cm CELL PITCH 1.44cm Cell Pitch FUEL VF= .55 Fuel VF= .55 INTACT INTACT FUEL FUEL 1,44 cm CELL PITCH 1.12 cm CELL PITCH $\rightarrow \infty$ 700 004 ∞ < FUEL VF=,307 FUEL VF=,307 K= 1.019 K= 1,000

				7-1					7.72																	
				7-17- 7-17-					1.7																	
				7 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1					7.72																	
		ле- Ке- К- К-							7:7																	
		2 2 2 2 2 2 2																								
		<i>се</i> ,		7-1-7- 7-1-7- 7-1-7- 1-7- 1-7- 1-7- 1-7																						
		се., К.С.,		7-1-7- 7-1-7-1-					7.7	77	, <u>-</u>															
		RE-2		7-17, 7 <u>7</u> 2		/ / / /			F.					-				E				:=:	1			==::
		RE- 2.7		7-1-7 - 1 <u>7-</u> -		, -7 , -7	2.7 2.7		<i>F</i>	+				=	=											
						/ //	2.7																			=-1
						· • · · ·			==	1 4- 5- 			ا بو مر: ا 	<u>1-k=</u>												
										1/- 1	1711	1		، رسلم، ا ۱۰۰۰۰		[-	<u>جر ،</u>			, <u>(</u> , , , , , , , , , , , , , , , , , , ,						
								Ê		****	15-1	(<u>1)</u> -		<u>/-/1</u>	<i>•••=</i>											
										; ;		+		=				_							1	
		=1=																								
									1			+) <u> </u>									
							2			\geq																
		i				17				<u></u>	<u> ``\</u> 	ŧ								2		2				
						1/==		<u> </u>			×						<u>}</u>			2	27	<u>, </u>	=			
						(<u></u>						\equiv						44			<u></u>	<u>F</u> E				
					12																					=
														Ϋ́Ē												
																				\equiv				-		
																			===	<u>. </u>				_		
																=-										
	=1-			:1::::										<u> </u>									<u> </u>			
=						==				==	-	1														
					<u> </u>	==												_								
	<u> </u>		2			7.7					-							ź							ΞĒ	
	<u> </u>	<u> </u>	17	R	iv.	7.14	11	101	1)	15	:- <i>;</i> ¢	X	ic.	;- <u>-</u> -	,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,						===		===			
						==		=																		
	- /									=				\equiv									===			
						===	==		==					=									=			
			:																							
													-													
:	::																									
:: ::				-:::									• • • • •													





	•								<u> </u>			· · ·	<u>.</u>						<u>i</u>		<u> </u>	·	<u> </u>	-,,-,-,-,-,-,-,-,-,-,-,-,-,-,-,-,-,	 			
•											Ì				T													
, >																												
				1									,,	12.11														
(`,)0																2.									 		===	
				=											=								*****	===	 		==1	
		=													-77				=						 			
		=				: <u></u>			==		=				2.5				7.27	1	,				5			
1,08			==		XE		=		==	==																		
			=		\sum															=		=			=	1		
021						1×	-																					
214				<u> </u>	X		X															=						
5-9					X	ì						_				==		=										
				 		\leq	X							ļ	7-77												;	
Koo			=			\equiv	Ì	١.		ΣĘ.			=									=			_	=		
								Ê																	=			
1.04								Ē				<u> </u>									;							
				==	\equiv				È																			
							=																					
											X	Ż								,, ,								
1,02							ļ						X															
Contraction of the second seco														X								_						
24 2 2															X										=			
2 5																X												
100 250 250																									 		=;	
0										=								<u> </u>		`		Ж						
101	=					=			===	=		===			-		::::	=		$\overline{\langle}$			=		 			
410 X 10				==:					=							=		==			\leq	Ż			 =			
198 198		<u></u>	Ξ							==					=							\geq		=	 =			
															==										 			
											=							:==				==			 			
C								=::	==																 			
9%				.z.	20.1							<u></u>	2								<u></u> د		::::		 			
					37																				 			
)															<u></u>													
N27																												
		•		<u> 1</u>		<u> </u>	·· · ·		·····	<u> </u>		····1		<u></u>		<u>1</u>			<u> </u>			<u> </u>			 <u></u> i			<u></u>

Attachment 1

Babcock & Wilcox

April 10, 1979

A SUMMARY OF NATURAL CIRCULATION ALTERNATIVES FOR LONG-TERM CORE COOLING AT TMI-2

prepared by

B. A. Karrasch

. . . .

TABLE OF CONTENTS

ACCEPTANCE CRITERIA DURING OPERATION

INTRODUCTION

SUMMARY

DISCUSSION

RECOMMENDATION

REFERENCES

APPENDICES

STEADY STATE RESULTS TRANSIENT ANALYSES OTSG TEST PROGRAM

REQUIRED INSTRUMENTATION

INTRODUCTION:

The TMI-2 long-term cooling mode proposed by B&W utilizes RCS natural circulation core cooling with the steam generator secondary side in a solid flowing water condition for heat removal. This ultimate decay heat removal mode is a key feature of the following proposed sequence of events to achieve a stable, cold safe shutdown condition at TMI-2.

Phase I:

Reduce RCS temperature to approximately 230[°]F by steaming the A OTSG through the turbine bypass system with one RC pump running and RC pressure controlled to a value greater than the pump NPSH using the pressurizer in a normal mode.

Phase II:

With the A OTSG steaming, the \cancel{B} OTSG (and closed secondary system yet to be installed) will be slowly filled solid with water and a transition will be made to remove RCS decay heat with the \cancel{B} OTSG solid. The \cancel{K} OTSG will be isolated and the RCS temperature will be reduced to approximately 100°F with the \cancel{B} OTSG. Reactor coolant flow and pressure conditions will remain the same as Phase I.

Phase III:

The *A* OTSG (and closed secondary system to be installed) will be filled solid with water and a transition made to remove RCS decay heat with both A and B steam generators flowing solid with 100[°]F feedwater. Reactor coolant flow and pressure conditions will remain the same as Phase I. Alternate to Phases II and III:

The B OTSG will remain isolated and the A OTSG will continue to remove RCS decay heat during the transition from a steaming secondary at 230° F to a solid water Chingsecondary at 100° F. This scheme would not utilize the B OTSG; however, the transition operation is more difficult with respect to steam line water hammer and maintenance of a stable RCS temperature and pressure.

Phase IV:

With the reactor coolant system at approximately $100^{\circ}F$ using normal RC pressure control and secondary side heat removal with a solid system (between 3000 and 5000 gpm at $100^{\circ}F$), the reactor coolant pump will be tripped and natural circulation core cooling will commence. Acceptance criteria for core cooling will be established and long-term cooling of the core will be maintained with natural circulation.

Phase V:

With natural circulation for core cooling and a solid secondary system for OTSG heat removal, RC pressure can be reduced to a minimum value required to maintain the RCS in a sub-cooled condition. Our plan is to fill the primary system solid, including the pressurizer, and maintain pressure control with a <u>makeup pump</u> designed for such an application. To maintain a stable sub-cooled margin, we envision a long-term RCS pressure between 20 and 50 psia.

During the past week, analysis and testing has been underway at NPGD and the Alliance Research Center to define and understand the various alternatives available for core heat removal with natural circulation. The analyses were directed toward obtaining data to define an optimum long-term cooling mode. Several of the important considerations include:

- Core natural circulation cooling, for various core ΔP configurations, with one or two OTSG's in service.
- OTSG natural circulation cooling performance with various secondary side water flowrates to the unit through the main or auxiliary feedwater nozzles.
- 3. Expected transient performance during the transition from forced to natural circulation including specific acceptance criteria for the operator to determine if adequate core cooling is achieved.

SUMMARY

The preferred mode for natural circulation core cooling is to use both OTSG's solid on the secondary side, with a flowrate of 3000 gpm entering the OTSG through the main feedwater nozzles and exiting the unit through the steam outlet nozzles. This mode will provide a maximum core flowrate (> 800,000 lb/hr), a minimum core ΔT (< 30° F), and a minimum reactor coolant average temperature (< 120° F for a 100° F OTSG feedwater temperature). The secondary side OTSG cooling is a stable, forced convection mode, which transfers all the primary system energy above a tube elevation of 30 feet, thereby providing a high column of cold water for enhancing the primary side natural circulation. This mode provides a driving head similar to that obtained with the OTSG steaming with a secondary side level at 30 feet.

The solid secondary side mode of operation has a distinct advantage over a steaming mode in that a much lower reactor coolant system temperature can be achieved. The solid configuration will result in an RCS temperature very close to the OTSG feedwater temperature (approximately 100°F); the steaming mode of operation can only obtain RCS conditions equivalent to the saturation temperature at the lowest achievable steam pressure (approximately 230°F). In addition, the use of the main nozzles for OTSG feedwater addition has been shown to yield a predictable and uniform primary system heat removal suitable for natural circulation. The use of the auxiliary nozzles for OTSG feedwater addition, with water exiting the main nozzles, should also remove the primary heat at an elevated point in the unit. However, the flow distribution and uniformity of cooling is uncertain and the feedwater flowrates are limited by system design and OTSG tube crossflow velocity concerns. In addition, major secondary plant modification would be required to implement reverse flow through the OTSG main feedwater nozzles. Testing

performed on the 19-tube steam generator at the Alliance Research Center confirms that feedwater addition through the main nozzles with water exiting the steam outlet nozzles is the preferable mode for natural circulation.

The advantage of using both steam generators instead of only one is an increase in the core natural circulation core flowrate of 10 to 20 percent and a decrease in the core outlet temperature of about 5°F. Extensive analysis has been independently performed at NPGD to confirm that the difference between using one or two OTSG's is not significant from a natural circulation standpoint; one OTSG in service will provide adequate core cooling. We believe, however, that the uncertainty in local core conditions and cooling requirements, the need for heat exchanger redundancy in the long-term cooling mode, and the ease of transition and operation with a solid water secondary for two OTSG's versus one, makes operation with two loops a superior mode.

The effect of a greater core resistance on the natural circulation cooling capability has been evaluated and deemed acceptable. A core resistance of 60 times the normal value has been assumed in the calculations, and the reported results are acceptable for either one or two steam generators in operation. The difference between a normal core resistance and a core resistance 60 times normal (indicating a significant blockage) is a factor of two in core flow and ΔT . This favorable result is due to the offsetting effects of system resistance, flowrate, and temperature difference to sustain a stable natural circulation condition.

Expected transient performance during the transition from forced primary system flow to natural circulation is predictable and stable. From an initial condition with the RC pump running and primary and secondary temperature approximately 100° F, a stable natural circulation condition will be achieved within a half hour following the pump trip. The cold leg temperature will decrease slightly (due to the pump power loss) and remain stable at about

 100° F. The core outlet temperature will increase by about $20-30^{\circ}$ F within 10 minutes and be observed on the hot leg RTD in less than 20 minutes. During the first hour after the pump trip, the reactor vessel heatup with <u>no primary system flow</u> would only be 100° F. Acceptance criteria during the first hour of natural circulation will be provided to the operator and primary system pressure will be maintained to assure that the reactor core outlet temperature remains 100° F sub-cooled at all times. When the operator observes the increase in hot leg temperature indication, a stable natural circulation condition will be confirmed.

DISCUSSION

A. Steady State Analysis

The results of the steady state natural circulation analyses performed to date are presented in Table 1. Four different reactor configurations were evaluated to determine the sensitivity of various conditions and assumptions on the natural circulation core flowrate and core temperature drop. The configurations studied include:

Two loop operation with both steam generators steaming at 230°F (20 psia) at a 30-foot secondary side level (95% on operate range). This configuration is similar to that which has been tested on the Oconee Units and forms the basis for a considerable amount of analysis at NPGD. These cases have been used to provide a benchmark on the OTSG heat transfer characteristics for development of a driving head and for confirming RCS loop ΔP characteristics. Figure 1 illustrates the sensitivity of the core natural circulation flowrate with loop ΔT (the driving head gain) and loop pressure drop (the driving head loss). The flowrate will seek a stable natural circulation condition based upon the loop ΔP and the resultant core AT. The key to obtaining a maximum flowrate is to remove the primary system heat (i.e., change t to T cold) at as high an elevation as possible in the steam generator. Our testing and analysis confirms that the primary heat is all transferred above the liquid/steam interface (i.e., the level) on the secondary side of the OTSG. The calculational results presented conservatively assume that the primary system temperature change occurs as a step change at the height of the OTSG operate range level.

The effect of increased core AP has also been evaluated to determine the core flowrate and temperature drop sensitivity. The following types of analyses have been performed at NPGD to conclude that the TMI-2 core resistance in its current configuration could be as high as 60 times the nominal value, indicating a high degree of core blockage:

a. Core ΔP calculations based upon a postulated core configuration.

- b. A comparison of RCS flow meter readings, with one pump running, before and after the TMI-2 incident.
- c. A conservative estimate of core flowrate and pressure drop in the current TMI-2 core configuration using the actual decay heat level and the difference between the cold leg temperature and the core outlet temperature as determined by the core outlet thermocouples [i.e., core flow = $\frac{Q_{decay}}{2}$ and ΔP = (core flow)²].

These analyses have provided a range of core ΔP values which have been included in the evaluations described in Table 1. The effect of increased core ΔP on the natural circulation flowrate is illustrated on Figure 2. The analyses have shown that the natural circulation flowrates are adequate with the core in its current configuration.

2. Single loop operation with OTSG A steaming at 230°F (20 psia) at a 30-foot secondary side level-OTSG B isolated. This configuration has been evaluated to provide a comparison of two loop versus single loop operation. The single loop calculations confirm that the net core flow will be 10 to 20% less in this configuration than with both steam generators in service. The resultant core ΔT will increase about 5°F (depending upon the decay heat level) and is still acceptable for core cooling. These analyses were performed to confirm an acceptable condition should an emergency situation require an immediate transition to natural circulation prior to the planned sequence to a solid steam generator secondary side.

Single loop operation with OTSG A in a solid secondary side mode with water addition through the main feedwater nozzles. Steam generator heat transfer analyses and testing have confirmed that a 3000 gpm feedwater flowrate to the main feedwater nozzles will provide a primary to secondary heat transfer characteristic similar to that achieved with the OTSG steaming with a 30-foot water level. The majority of the heat removal occurs above the 30-foot level in the OTSG with a 3000 gpm flowrate. If the flowrate is increased to 5000 gpm, the driving head for natural circulation is further improved to about 35 feet. The calculational results confirm that adequate natural circulation flow and core AT can be obtained with a single steam generator operating in a solid condition.

Additional analyses were performed in this configuration to determine the effect of reduced core decay heat levels. These cases were run at 2 and 3 MW to provide a comparison with values of core flow and ΔT at 5 MW. As can be seen from Table 1, natural circulation core flowrate and core ΔT are both reduced for lower decay heat values, and core cooling remains acceptable.

Two loop operation with both steam generators in a solid secondary mode with feedwater addition through main nozzles at 3000 gpm. This is the preferred mode for long-term cooling at TMI-2 and the results are very similar to the two OTSG's steaming case. Again, the solid flowing water secondary system at 3000 gpm induces
a high heat transfer interface in the OTSG's and acceptable core natural circulation cooling is achieved.

The steady state natural circulation analysis has resulted in the following conclusions with regard to long-term cooling at TMI-2:

- 1. Adequate core cooling with natural circulation can be achieved with either one or two steam generators in service.
- 2. An increased core resistance due to blockage decreases the natural circulation flowrate and increases the core ΔT . However, it has been shown that acceptable core flow and ΔT can be maintained with significant increases in the core resistance due to blockage.
- 3. Adequate natural circulation flowrate can be achieved with the steam generator(s) in a steaming or solid mode if the effective heat transfer height is maintained at 30 feet or greater using a high level for steaming (30 feet) or a high flowrate for solid (3000 gpm).

Adequate natural circulation cooling can be maintained at reduced core decay heat levels.

-10-

. Transient Analysis

The results of the forced flow transition to natural circulation cooling are presented in Figures 3 and 4. Transient analyses were performed at core decay heat levels of 2 and 3 megawatts to better understand the time dependent responses of core flowrate and temperature change following the loss of forced cooling. The bases for the analyses are as follows:

Core Power - 2 and 3 Megawatts Reactor Coolant Pump Trip at Time O OTSG A Solid with 100[°]F Feedwater into the Main Nozzles at 3000 gpm OTSG B Isolated Core Resistance Factor - 60

The transient responses of core flow and temperature confirm that a smooth transition to natural circulation is achievable. Following the loss of forced flow, the reactor vessel heatup slowly induces a temperature gradient between the reactor vessel and upper OTSG and natural circulation occurs with no operator action. The core flowrate reaches a minimum about 1 minute into the transient and reaches a stable condition between 10 and 20 minutes. The core outlet temperature begins to increase and reaches a maximum value 4 to 5 minutes into the transient and a stable condition at about 10 minutes. There is about a four minute time delay in the response of the hot leg temperature ature measurement due to the approximately 1000 feet³ in the reactor vessel upper plenum and hot leg piping. The cold leg temperature due to the loss of the approximately 5 megawatts of pumping power.

The transient natural circulation analyses have resulted in the following conclusions with regard to long-term cooling at TMI-2:

-11-

- A smooth transition from forced flow cooling to natural circulation can be achieved by tripping the reactor coolant pump and observing core outlet temperature. There is no reason to slowly reduce the . RC pump speed for a more gradual transition to natural circulation.
- 2. The reactor coolant system flow and temperature will reach an equilibrium value within the first 1/2 hour of the transient; the response of the hot leg temperature measurement occurs within 5 minutes after the core outlet temperature changes.

-12-

OTSG Test Program

The ability to achieve and maintain a stable natural circulation flowrate is dependent upon the elevation difference between the heated core outlet temperature and the transition to cold leg temperature in the OTSG tubes. This transition point in the OTSG is in turn dependent upon the heat transfer characteristics of the unit. If the primary to secondary heat transfer can be obtained at a high elevation in the OTSG, the driving head from the density difference will be improved and natural circulation flowrate will increase.

The primary to secondary OTSG heat transfer mechanism, while in a steaming mode is boiling at or about the level of the secondary side water. Extensive analysis and testing of the OTSG in the "pot boiling" mode has confirmed that the primary system temperature transition occurs above the level of the "boiling pot." All calculations performed with the OTSG in a steaming mode conservatively assume that the primary system cold leg temperature is available for driving the natural circulation flow at the 30 foot level.

Use of the steam generator as a water to water counter flow heat exchanger is a more desirable condition to obtain during a long-term decay heat cooling mode. The primary temperatures can be maintained much nearer the temperature of the incoming feedwater to the OTSG. In order to determine OTSG characteristics in a solid mode, a test program was conducted at the Alliance Research Center on a 19-tube, full-length, steam generator. A natural circulation flowrate of 700,000 lb/hr was simulated on the primary side and forced secondary side cooling was injected into the main feedwater nozzles; flow exited the unit through the steam outlet nozzles. Feedwater flowrates were varied from a scaled value of 100 gpm up to 5000 gpm. The results of this test program are presented on Figure 5, a plot of feedwater flowrate versus the OTSG heat transfer elevation. Heat transfer elevation is defined as that level above which all primary system heat is transferred to the secondary system fluid. That is, the height at which one can assume the primary cold leg temperature is available for driving natural circulation. The figure shows that a heat transfer elevation of 30 feet can be obtained if the feedwater flowrate is at 3000 gpm or higher. A 30 foot elevation head in the OTSG primary is adequate to achieve natural circulation as demonstrated by the calculations in the previous section.

Acceptance Criteria During Operation

The success or failure of natural circulation as a core cooling mode depends upon the value of the core ΔT that can be maintained. The key objective during plant operation in this mode is to maintain a primary cold leg temperature as low as possible and observe the resultant hot leg temperature. The acceptance criteria for success of the natural circulation mode is to maintain the hot leg temperature below the saturation temperature which would cause bulk boiling. Figure 6 illustrates the proposed NPGD criteria for natural circulation: to maintain a 100°F sub-cooled margin to bulk boiling using the plant instrumentation in its current degraded state. The large errors which have been imposed on the pressure and temperature instrumentation make it imperative to keep the RC pressure as high as possible at the time of pump trip. This will allow a large hot leg temperature increase to occur before boiling and assure a reasonable time period to achieve a stable natural circulation. If the RC pressure is maintained at 500 psia, the hot leg temperature can reach 340°F (from its initial condition of 110°F) before action must be taken.

An analysis of the reactor vessel was performed to determine the potential heatup rate with zero flow into the vessel. This analysis provides a bounding bulk fluid heatup rate to indicate the amount of time available to the operator to take action before a boiling condition could occur. The high probability of achieving a stable natural circulation condition indicates that such a reactor vessel heatup could never occur. The analysis is provided to show that the operator has at least one hour to confirm natural circulation before any action must be taken.

-15-

RECOMMENDATION:

Natural circulation has been shown to be an acceptable means of heat removal for long-term cooling at TMI-2 with the core in its current configuration. Use of either one or two steam generators is feasible if the proper. secondary side heat transfer characteristics are established and maintained to remove the primary energy near the top of the OTSG. In addition, the expected transition process from forced cooling to natural circulation will provide a continuous and stable core cooling condition which can be monitored and controlled by the plant operator.

B&W, therefore recommends that a planned transition to natural circulation core cooling be implemented at TMI-2 as soon as the degassing process is completed. Both steam generators should be utilized in a solid flowing water condition with approximately 100° F feedwater at 3000 to 5000 gpm entering through the main feedwater nozzles. The sequence of events for this transition, as described in the Introduction of this report should be as follows:

1. Reduce RCS temperature to 230[°]F with a OTSG steaming.

2. Slowly fill OTSG B solid with water and begin removing primary system energy with the B OTSG by gradually increasing feedwater flow until a stable condition is reached at 200-230°F. When a stable condition has been established, isolate OTSG A.

3. Reduce the RCS temperature to approximately 100°F by increasing the feedwater flowrate to OTSG B. Fill OTSG A solid with water and prepare for operation.

-16-

- Slowly begin feeding OTSG A with 100[°]F feedwater and establish a stable condition with both steam generators removing decay heat with a 3000 gpm feedwater flowrate.
- 5. Establish RCS natural circulation as follows:
 - a. Throttle feedwater flow to both steam generators to establish approximately $25^{\circ}F$ ΔT between feedwater temperature and OTSG secondary outlet temperature.
 - b. When a stable condition has been established, trip the running reactor coolant pump and increase feedwater flowrate to both OTSG's to 5000 gpm within 3 minutes. Maintain at 5000 gpm.
 - c. Maintain RC pressure at the initial condition value and observe both A and B hot leg temperatures.
 - d. Compare the hot leg temperatures to the acceptance criteria on Figure 6. If the temperature exceeds the limiting value, start a reactor coolant pump.
 - e. When stable natural circulation conditions have been achieved, reduce RC pressure to the proposed long-term cooling value between 20 and 50 psia.

The above sequence of events will establish a stable and safe natural circulation condition for long-term cooling at TMI-2. All starting or stopping of reactor coolant pumps should be avoided until the pump is tripped to induce natural circulation. In addition, B&W recommends that the sequence of events be implemented in a planned and controlled manner, i.e., we should not wait for a complete failure of all four RCP's before establishing natural circulation. We should, however, have an alternate decay heat removal system installed and ready for operation prior to the transition to natural circulation.

·17

APPENDIX A

INSTRUMENTATION REQUIRED TO ACHIEVE AND MAINTAIN LONG TERM COOLING

INSTRUMENTATION REQUIRED TO ACHIEVE AND MAINTAIN LONG TERM COOLING

PAGE

I. REQUIRED TO CONFIRM THE INITIATION OF NATURAL CIRCULATION

Primary System <u>ITEM</u>	MEASUREMENT	RANGE OF INTEREST	DESIRED	BACK-UP MEASUREMENT	<u>COMMENTS</u>
1	Reactor Core Outlet Temperature (Incore TC's)	0-700F	<u>+</u> 10F	Item I.2; I.3	•
2	Loop A Reactor Hot Leg Temperature	0-550F	<u>+</u> 10F	Item I.3	
3	Loop B Reactor Hot Leg Temperature	0-550F	<u>+</u> 10F	Item I.2	
4	Loop Al or A2 Cold Leg Temperature	0-350F	<u>+</u> 10F	Item I.5	
5	Loop B1 or B2 Cold Leg Temperature	0-350F	<u>+</u> 10F	Item I.4	• •
	•	•	· · ·	÷	•

II. REQUIRED TO MONITOR LONG TERM NATURAL CIRCULATION

(IN ADDITION TO ITEMS IN I. ABOVE)

A. Primary System		. ·			·
ITEM	MEASUREMENT	RANGE OF INTEREST	DESIRED	BACK-UP MEASUREMENT	COMMENTS
1	Pressurizer Level	0-400"	<u>+</u> 40"		Comp. I.D. 0387, 0388 (Not required for solid primary.)
2	Pressurizer Temperature	0-500F	<u>+</u> 10F	Item II.A.3	Comp. I.D. 0389 (Not required for solid primary.)
3	Loop A Reactor Coolant Pressure	0-1000 psig	<u>+</u> 50 pst	Item II.A.4	Comp. I.D.0398, 0399
4	Loop B Reactor Coolant Pressure	0-1000 psig	<u>+</u> 50 psi	Item II.A.3	Comp. I.D. 0400
4	Loop B Reactor Coolant Pressure	0-1000 psig	<u>+</u> 50 psi	Item II.A.3	Comp. I.D. 0400

INSTRUMENTATION REQUIRED TO ACHIEVE AND MAINTAIN LUNG TERM COOLING

PAGE 2 of 3

Β.	·	Secondary	System

ITEM

3

5

6

7

q

10

.11

12

13

14

MEASUREMENT		RANGE OF INTEREST	DESIRED ACCURACY	BACK-UP MEASUREMENT	COMMENTS
Steam Generato	or A Level	0-600"	<u>+</u> 30"		Comp. I.D. 0009 (Required only if steaming.)
Steam Generat	or B Level	0-600"	<u>+</u> 30"	• • •	Comp. I.D. 0001 (Required only if
Steam Generat Pressure	or A Outlet	0-300 psig	<u>+</u> 15 psi	Item I.4	steaming.)
Steam Generat Pressure	or B Outlet	0-300 psig	<u>+</u> 15 psi	Item I.5	
Steam Generat Feedwater F	or A Main Iow	0-7000 gpm	<u>+</u> 50 gpm	Item II.B.1	· · · · · · · · · · · · · · · · · · ·
Steam Generat Feedwater F	or B Main Iow	0-7000 gpm	<u>+</u> 50 gpm	Item II.B.2	
Steam Generat Feedwater F	or A Start-Up low	0-500 gpm	<u>+</u> 10 gpm	•	(Required only if steaming.)
Steam Generat Feedwater F	or B Start-Up low	0-500 gpm	<u>+</u> 10 gpm		(Required only if steaming.)
Steam Generat Temperature	or A Outlet	0-250 F	<u>+</u> 2 F		(Required only for solid secondary.)
Steam Generat Temperature	or B Outlet	0-250 F	<u>+</u> 2 F		(Required only for solid secondary.)
Steam Generat	or A Feed Temperature	0-150 F	<u>+</u> 2 F	Item II.B.10	Comp. I.D. 0491
Steam Generat	or B Feed Temperature	0-150 F	<u>+</u> 2 F	Item II.B.9	Comp. I.D. 0492
. Steam Generat Temperature	or A Downcomer	0-150 F	<u>+</u> 2 F	• • • • • •	Comp. I.D. 0469
Steam Generat Temperature	or B Downcomer	0-150 F	<u>+</u> 2 F	•	Comp. I.D. 0470

INSTRUCTION REQUIREMENTS TO ACHIEVE & MAINTAIN LONG TERM COUCTIN	INSTRUCTION	REQUIREMENTS	TQ	ACHIEVE 8	ŝ	MAINTAIN	LONG	TERM	COOLING
--	-------------	--------------	----	-----------	---	----------	------	------	---------

. :

Page 3 of 3

III. Additional Required Measurements

ITEM

1.

.7

11.

MEASUREMENT	RANGE OF INTEREST	DESIRED ACCURACY	BACKUP MEASUREMENTS	COMMENTS
Pressurizer Heater Status (Banks 1,2,3,4,5)	0-540KW Per Bank	-	-	Not required for solid primary
Electromatic Relief Block Valve Position Status	Open; Closed	-	-	
Pressurizer Vent (EMO to Quench Tank) Valve Position Stat	Open; Closed us	•	• • • •	
Reactor Vessel Boron Con- centration	0-5000ppm	<u>+</u> 100ppm	Sample	· ·
Makeup Flow	0-200gpm	<u>+</u> 5gpm	None	
Makeup Tank Level	0-100"	<u>+</u> 10"	None	
Makeup Boron Con- centration	0-12000ppm	<u>+</u> 200ppm	Sample	÷
Letdown Flow	0-100gpm	<u>+</u> 10gpm	Item III.9	Comp. I.D. 0346
Letdown Temperature	0-200F	<u>+</u> 20F	None	•
Borated Water Storage Tank Level	0-100'	-	Redundant Sensor	
Borated Water Storage Tank Temperature	0-200F	<u>+</u> 20F	, -	•
Borated Water Storage Tank Concentration	0-5000ppm	<u>+</u> 100ppm	Sample	
Steam Generator A Activity Level		•	Sample	
Steam Generator B Activity Level			Sample	
Heat Sink Temperature	0-200F	<u>+</u> 10F		
Heat Sink Pressure	0-5psi 0-300psi	<u>+</u> 0.5psi <u>+</u> 20psi		
Heat Sink Level (If Applicable)	•		•	· ·

APPENDIX B

LIST OF REFERENCES

This Appendix will be included in the final report and include a complete list of all calculations and related test data and backup material for the information contained in this report.

SUMMARY OF NATURAL CIRCULATION ALTERNATIVES

Reactor Configuration	Core Flow	Core ∆T	^T cold	T _{hot}
Two OTSG's Steaming at 230 ⁰ F With a 30' Secondary Level	0.8x10 ⁶ - 1.2x10 ⁶ 1b/hr	15-25 ⁰ f	230 ⁰ f	245–255 ⁰ F
60 Times Normal Core Resistance 10 Times Normal Core Resistance Normal Core Resistance	$\begin{array}{r} 0.8 - 1.2 \times 10_{6}^{6} 1 \text{b/hr} \\ 1.1 - 1.6 \times 10_{6}^{6} 1 \text{b/hr} \\ 1.5 - 2.3 \times 10^{6} 1 \text{b/hr} \end{array}$	15-25 [°] F 11-19°F 8-13 [°] F	230 [°] F 230 [°] F 230 [°] F	245–255 [°] F 241–249 [°] F 238–243 [°] F
One OTSG Steaming at 230 ⁰ F With a 30' Secondary Level (60 Times Normal Core Resistance)	0.7 - 1.1x10 ⁶ 1b/hr	20-30 ⁰ F	230 ⁰ F	250–260 ⁰ F
Two OTSG's Solid With 100 ⁰ F Feedwater at 3000 gpm (60 Times Normal Core Resistance)	0.8 - 1.2x10 ⁶ 1b/hr	15-25 ⁰ F	105 ⁰ f	120–125 ⁰ F
One OTSG Solid With 100 ⁰ F Feedwater at 3000 gpm (60 Times Normal Core Resistance)	0.7 - 1.1x10 ⁶ 1b/hr	20-30 ⁰ F	105 ⁰ F	125-135 ⁰ F
3 MW Decay Heat 2 MW Decay Heat	$0.7 - 1.1 \times 10^{6}_{6}$ 1b/hr $0.6 - 1.0 \times 10^{6}$ 1b/hr	10-20 ⁰ F 8-15 ⁰ F	103 ⁰ F 101 ⁰ F	113-123 ⁰ F 109-116 ⁰ F

5 MW With reduced M& slight reduction in DT



					ť	D			₭•ᢄ	10) Keu	ί 10 Τ FFEL	ro 14 A ess	INCH ER CO	• 735	X 10 C 14 U S	INCHE	:s	=72	i U	RE		2	-			6 14	170	:					•	-	 •	•
	VA	172		<i>AL</i>	. ∠		? 	00	. Р .		※	ک اللہ		∕`S ∏∏	<u>/</u> 7					っ。	公司	ICR		99. 	EL	>` <i>∠</i> Ⅲ	01	28	\mathcal{R}	<i>es</i> 111	<u>/51</u>		<u>E</u>			
																					1117 1141															
	C-41											H H																								
	2.2																			:::: ::::::																
	20																									ン									2	
البلا	 																			0																
27																																				
0	1:6																								+++++ +++++ +++++ ++++										2	
<u>、</u>	1.4	2				编制													닄井		레뷔															
-1-0	1.2	· · · · · · · · · · · · · · · · · · ·	/																																	
202		I			$\left \right\rangle$	X	<u>/#</u>																													
 	-1.0		•••••										1.11																							1.6
	ъ																									5∦									- 12	
0	-6																	// </th <th></th> <th>N N</th>																		N N
<u>-</u> V 																																				Ŭ
	-4-																																		E	3
	2																		1 1 1 1 1 1																	
	ſ					<u> </u>																														
													<u>)</u>				4					5			9											

. .

ŀ

•

•

•

.

· ·









•	•	1		27) برسر			₹ ~∑		(10 T FFEL	o ji a ess	1 • 734 ۱۸۱	X 10 of IN U	INCH		-/:	y JI	ee ee	- 7					61	470		 • .	:		<u>(</u>)	•	-	:	
• •																																		
•																																		
ų																																		
U U								┿┿╌╎┸╎┰┿ ╾╾┥┱╽┍╾																										
1110		500															2	<i>4C</i> /	22		上	197		5	10									
V Q y	ì														1. P				21															
000																																		
ł		400										0			X																			
											些不																							
U U					· · · · · · · · · · · · · · · · · · ·	 																												
		300						2																										
- +							Z																											
		71				加以																												
Ø																																		
· · ·		00	1																			////												
				3	ر انا	6			19					Ľ	150 01		222	80 17		2	10 9.5.	5	121 07			70 1. 1.		30	10	225 225	<u>s</u> ;			

CHMENT 3

3.3. SYSTEM PERFORMANCE ON NATURAL CIRCULATION

3.3.1. DESCRIPTION OF CADDS NATURAL CIRCULATION MODEL

THE CADDS DIGITAL COMPUTER CODE¹ IS DESIGNED TO ANALYZE REACTOR TRANSIENTS, WITH OR WITHOUT SCRAM, IN A HETEROGENEOUS PRESSURIZED WATER REACTOR. IT SOLVES THE TIME DEPENDENT NEUTRON KINETICS EQUATIONS IN CONJUNCTION WITH A THERMAL HYDRAULIC SOLUTION FOR AN AVERAGE FUEL PIN DURING A REACTIVITY TRANSIENT. THE SIMULATION INCLUDES THE MAJOR FEEDBACK MECHANISMS AS WELL AS DETAILED SINGLE-PHASE NUCLEATE BOILING, TRANSITION, AND STABLE FILM BOILING CORE HEAT TRANSFER MODELS. THE ENTIRE REACTOR COOLANT LOOP, INCLUDING THE PRESSURIZER, IS SIMULATED. THE STEAM GENERATOR MODEL IS INCLUDED TO EVALUATE THE EFFECT OF FEEDWATER VARIATIONS ON THE STEAM GENERATOR AS WELL AS THE PRIMARY SYSTEM RESPONSE.

THE CADDS COMPUTER CODE DESCRIBED ABOVE NORMALLY REQUIRES THAT THE REACTOR COOLANT LOOP FLOW HISTORY BE SPECIFIED AS PART OF THE CODE INPUT. HOWEVER, A RECENTLY COMPLETED MODIFICATION TO CADD ALLOWS FLOW COASTDOWN AND NATURAL CIRCULATION TO BE CALCULATED WITHIN THE PROGRAM. THE DEVELOPMENT OF THIS MODIFICATION FOLLOWS

A SCHEMATIC DIAGRAM OF THE PRIMARY LOOP IS SHOWN IN FIGURE 1. CONSIDERING THE FLOW AS ONE-DIMENSIONAL, THE MOMENTUM EQUATION IN THE AXIAL DIRECTION x IS

 $\frac{\partial}{\partial t}(pu) = -\frac{\partial}{\partial x}(pu^2) - \frac{\partial P}{\partial x} - \frac{\partial F}{\partial x} + F_g$ (1)

+ $\frac{W|W|}{2g_0} \sum_{i}^{CV} \frac{1}{\rho_{i}A_{i}^2} (K_{i} + F_{i} \frac{L_{i}}{D_{i}})$

 $\Delta P_{\text{pump}} = \frac{W^2}{g_o} \left[\frac{1}{\rho A^2} \right]_1^6 + \frac{dw}{dt} \sum_{i}^{cv} \frac{L_i}{A_i g_o} + \sum_{i}^{cv} \rho_i \frac{g}{g_o} \Delta Z_i$

VOLUMES YIELDS

WHERE cv is the total number of control volumes. Considering the flow RATE to be spatially independent, expressing velocity (u) in terms of system FLOW RATE (W), AREAS (A_i), AND DENSITIES (ρ_i), AND SUMMING OVER ALL CONTROL

$$\sum_{i}^{cv} (k_{i} + f_{i} \frac{L_{i}}{D_{i}}) \frac{1}{2g_{o}} \rho_{i} u_{i} |u_{i}|$$
(3)

(4)

$$\Delta P_{pump} = \int_{1}^{6} \frac{\partial}{\partial x} \left(\frac{\rho u^{2}}{g_{0}}\right) dx + \int_{1}^{6} \frac{\partial}{\partial t} \left(\frac{\rho u}{g_{0}}\right) dx + \int_{1}^{6} \rho \frac{g}{g_{0}} \frac{\partial z}{\partial x} dx$$

OBTAINS

(2)
SUBSTITUTING FOR F AND F AND EQUATING THE PRESSURE INTEGRAL TO
$$\Delta P_{\text{plump}}$$

 $\int_{1}^{6} -\frac{\partial P}{\partial x} dx = \int_{1}^{6} \frac{\partial}{\partial x} \left(\frac{\rho u^{2}}{g_{o}}\right) dx + \int_{1}^{6} \frac{\partial}{\partial t} \left(\frac{\rho u}{g_{o}}\right) dx + \int_{1}^{6} \frac{\partial F}{\partial x} dx + \int_{1}^{6} F_{g} dx$

WHERE F REPRESENTS FRICTION/FORM LOSS FORCES AND F IS THE GRAVITY FORCE. B INTEGRATING EQUATION (1) ALONG THE PRIMARY SYSTEM IN THE DIRECTION OF FLOW FROM THE PUMP DISCHARGE TO THE PUMP SUCTION YIELDS

TWO SPECIAL CASES WERE USED TO VERIFY THE CALCULATIONS OF THE NATURAL SUB-ROUTINE. EACH CASE MADE USE OF ENOUGH SIMPLIFYING ASSUMPTIONS TO ALLOW THE HAND CALCULATION OF FLOW (OR FLOW VERSUS TIME) WHICH COULD THEN BE COMPARED TO NATURAL PREDICTIONS.

3.3.1.1. COMPARISON OF NATURAL CIRCULATION MODEL PREDICTIONS TO ANALYTICAL RESULTS

THEREFORE, THE SYSTEM FLOW RATE CAN BE DETERMINED BY EQUATION 6 AT ANY TIME STEP DURING THE TRANSIENT. THE MOMENTUM EQUATION IS COUPLED TO THE CADDS ENERGY EQUATION THROUGH THE FLUID PROPERTIES WHICH ARE FUNCTIONS OF THE SYSTEM PRESSURE AND THE ENTHALPY. THE CALCULATION OF FLOW RATE IS CON-TAINED IN THE CADDS SUBROUTINE, NATURAL.

$$= \frac{\frac{W^{n}}{\delta t} \sum_{i}^{CV} \frac{L_{i}}{A_{i}g_{o}} + \Delta P_{pump} - \sum_{i}^{CV} \rho_{i} \frac{g}{g_{o}} \Delta Z_{i}}{\frac{1}{\delta t} \sum_{i}^{CV} \frac{L_{i}}{A_{i}g_{o}} + \frac{|W^{n}|}{2g_{o}} \sum_{i}^{CV} \frac{1}{\rho_{i}A_{i}} (K_{i} + f_{i} \frac{L_{i}}{D_{i}})}$$

REARRANGING AND NEGLECTING THE ACCELERATION TERM PRODUCES

wn+1

$$\sum_{i}^{cv} \rho_{i} \frac{g}{g_{o}} \Delta Z_{i} - \frac{|W^{n}|W^{n+1}}{2g_{o}} \sum_{i}^{cv} \frac{1}{\rho_{i}A_{i}^{2}} (K_{i} + f_{i}\frac{L_{i}}{D_{i}})$$
(5)

(6)

$$\frac{w^{n+1} - w^n}{\delta t} \sum_{i}^{cv} \frac{L_i}{A_i g_o} = \Delta P_{pump}^n - \frac{2}{g_o} \frac{w^n |w^n|}{g_o} \left[\frac{1}{\rho A^2} \right]^{\frac{1}{2}}$$

USING A SEMI-IMPLICIT SOLUTION TECHNIQUE, EQUATION 4 CAN BE WRITTEN AS

3.3.1.2. COMPARISON OF CADDS WITH NATURAL TO DAVIS-BESSE DATA

BOTH OF THE ABOVE COMPARISONS SHOW EXCELLENT AGREEMENT BETWEEN THE ANALYTICAL VALUES AND NATURAL SUBROUTINE PREDICTIONS, THUS VERIFYING THE PROGRAMMING AND THE NUMERICAL SCHEME OF THE NATURAL SUBROUTINE.

THE SECOND CASE USED THE SAME PRIMARY LOOP AS THE FIRST CASE AND ASSUMED A LINEAR DISTRIBUTION OF DENSITY IN THE CORE AND STEAM GENERATOR. THE STEADY STATE NATURAL CIRCULATION FLOW WAS CALCULATED AND COMPARED TO TRANSIENT NATURAL PREDICTIONS. THIS COMPARISON IS SHOWN IN FIGURE 2.

THE FIRST CASE SIMULATED THE FLOW COASTDOWN OF AN NSS PRIMARY LOOP. IT WAS ASSUMED THAT THE PUMP SEIZED AT THE BEGINNING OF THE TRANSIENT $(\Delta P_{pump} = 0)$ AND THAT THE GRAVITY TERM COULD BE NEGLECTED SINCE INERTIA TERMS DOMINATE IN THE INITIAL STAGES OF A COASTDOWN TRANSIENT. THE NATURAL SUBROUTINE RESULTS ARE COMPARED TO ANALYTICAL VALUES IN TABLE 1.

TABLE 1. COM	PARISON OF NATURAL PREDICTIO	NS TO ANALYTICAL
	UES FOR A FLOW COASTDOWN	
	1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1	
TIME (sec)	"o analytical	<u> </u>
n an		
n	1.0	1.0
05	0.7881	0.7882
1.0	0.6452	0.6454
2.0	0.4667	0.4669
3 0	0.3610	0.3611
	0.2917	0.2919
4.0 5.0	0.2432	0.2433
10.0	0.1274	0.1275
15.0	0.08336	0.08341
20.0	0.06077	0.06081
25 0	0.04723	0.04726
30.0	0.03830	0.03832
40.0	0.02736	0.02738
	0.02099	0.02101
50.0		
50.0 60.0	0.01688	0.01689
50.0 60.0 70.0	0.01688 0.01401	0.01689 0.01402

•

• • •

•

. .

 $\sum_{i=1}^{n}$





3.2.2. MODELLING ASSUMPTIONS

THE NATURAL CIRCULATION RESULTS WHICH ARE SUBSEQUENTLY REPORTED WERE OBTAINED USING A ONE (1) LOOP CADDS/NATURAL MODEL. THE ASSUMPTION OF ONE LOOP MEANS THAT ALL DECAY HEAT REMOVAL OCCURS THROUGH ONE ACTIVE STEAM GENERATOR AND THAT THE STEADY STATE NATURAL CIRCULATION IN THE IDLE LOOP IS ZERO. THE CADDS MODEL ALSO ASSUMES THAT ALL FLOW FROM THE OPERATING PUMP GOES THROUGH THE CORE PRIOR TO PUMP TRIP. WHILE THIS ASSUMPTION IS NOT ENTIRELY ACCURATE UNDER FORCED FLOW CONDITIONS (BECAUSE OF REVERSE FLOW IN THE IDLE LOOP), IT DOES NOT PREVENT THE OBTAINING OF A VALID STEADY STATE NATURAL CIRCULATION SOLUTION UNDER CONDITIONS CONSIDERED HEREIN.

ANOTHER ANALYSIS ASSUMPTION IS THAT THE PUMP ROTOR LOCKS AT TIME OF TRIP AND A LOCKED ROTOR PUMP RESISTANCE IS USED FROM THEN ON. THIS RESULTS IN THE MAXIMUM FLOW COASTDOWN AND MAXIMUM TRANSIENT CORE TEMPERATURE WHILE NATURAL CIRCULATION IS BEING ESTABLISHED.

THE PRINCIPAL VALUE USED FOR CORE FORM LOSS HAS BEEN CALCULATED FROM CORE FLOW AND PRESSURE DROP INFERRED FROM TMI-2 HOT LEG FLOW MEASUREMENTS. GIVEN THAT THE CORE PRESSURE DROP IS APPROXIMATELY 18 PSI AT A CORE FLOW OF ABOUT 4500 lbm/sec AND THAT THE PRESSURE DROP IS ENTIRELY FORM LOSS, A FORM LOSS FACTOR (K) OF 1100 CAN BE CALCULATED, WHICH IS ABOUT 200 TIMES THE NORMAL CORE FORM LOSS. OTHER CORE FORM LOSS FACTORS USED IN THE NATURAL CIRCULATION ANALYSIS ARE 5.5 (NORMAL), 330 (60 TIMES NORMAL), AND 5500 (1000 TIMES NORMAL).

ADDITIONAL MODELLING ASSUMPTIONS CONCERN THE CORE BYPASS FLOW AND VENT VALVE FLOW. MOST OF THE ANALYSIS ASSUMES A CORE BYPASS FLOW OF 4.6%, BUT ONE CASE CONSIDERS A 30% BYPASS FLOW. IN ALL CASES VENT VALVE FLOWS ARE NEGLECTED.

3.3.3 RESULTS

IN ORDER TO INVESTIGATE THE FEASIBILITY OF COOLING THE CORE WITH NATURAL CIRCULATION USING WATER TO WATER HEAT TRANSFER IN THE STEAM GENERATOR, A STUDY WAS PERFORMED USING THE FOLLOWING MATRIX:

CORE POWER5 MWFEEDWATER TEMPERATURE100°FONLY A STEAM GENERATOR OPERATINGCORE PRESSURE DROP 60 TIMES NOMINALFEEDWATER FLOW1100, 3000, 5000 GPMCORE BYPASS5%

THE STEADY STATE RESULTS OF THIS STUDY ARE SHOWN IN TABLE 2.

TABLE 2

FEE	DWATER GPM	FLOW	CC TEME	RE INLET PERATURE °F	CO TEM	RE OUTLI	ET E°F	PRIMA FLOW	RY SYSTEM LEM/SEC.
;	1100			123		151			210
	3000	•		103	•	118		• •	325
. <i>'</i>	5000			101		116			338

FROM THE ABOVE TABLE, WE SEE THAT IF THE FEEDWATER FLOW EXCEEDS THE PRIMARY SYSTEM FLOW, THE COOLING WILL OCCUR HIGH ENOUGH IN THE OTSG TO DEVELOP REASONABLE NATURAL CIRCULATION FLOW RATES. BASED ON THESE RESULTS, A FEEDWATER FLOW RATE OF 3000 GPM AT 100°F WAS CHOSEN AS THE MODE FOR REMOVING THE DECAY HEAT AND FURTHER PARAMETER STUDIES WERE PERFORMED. TABLE 3 SHOWS THE STEADY STATE RESULTS FOR THE CASES RUN.

CASE NO.	CORE POWE	CORE F R LOSS C <u>X NC</u>	RESSURE HARACTER MINAL	DROP ISTRICS	% BYPASS FLOW	CORE INLET TEMP. °F	CORE OUTLET TEMP. °F	SYSTEM FLOW <u>LEM/SEC.</u>
1	3		1	1. 2. 1. 1. 1. 1.	5	101.9	109.7	380
2	3		60		5	101.3	111.1	305
3	. 3		200		5	100.8	113.7	231
.4	3		1000		5	100.4	121.3	142
5	3		200		30	100.9	118.2	235
6	. 2		60		5	100.9	107.7	292

TABLE 3

CASE NUMBER FIVE IS THE BEST ESTIMATE OF THE EXPECTED CORE BEHAVIOR IF NATURAL CIRCULATION IS INITIATED WHEN THE DECAY HEAT LEVEL IS 3 MW. A CORE PRESSURE DROP LOSS CHARACTERISTIC OF 200 TIMES NOMINAL IS SLIGHTLY LARGER THAN THAT REQUIRED TO PRODUCE AGREEMENT WITH CURRENT MEASUREMENTS OF REACTOR COOLANT FLOW SPLITS. (SEE P. S. BARTELLS, "CORE PRESSURE DROP FOR NATURAL CIRCULATION CALCULATION", APRIL 9, 1979). THE BEST ESTIMATE FOR CORE BYPASS FLOW IS BETWEEN 22 AND 27 PERCENT. (R. M. GRIBBLE, "CORE BYPASS FLOW FOR CORE BLOCKED AT TOP ONLY", APRIL 8, 1979.)

FIGURE 3 SHOWS A PLOT OF CORE FLOW VERSUS TIME AND FIGURE 4 SHOWS A PLOT OF TEMPERATURE AT THE HOT LEG RESISTANCE THERMOMETER VERSUS TIME FOR CASE FIVE. NOTE THE TIME DELAY BETWEEN THE START OF NATURAL CIRCULATION AND THE INCREASED HOT LEG TEMPERATURE. THIS IS DUE TO THE LOW VELOCITIES DURING NATURAL CIRCU-LATION.

THE STEADY STATE NATURAL CIRCULATION FLOW OF 235 LBM/SEC FOR CASE FIVE PROVIDES AMPLE COOLING FOR THE CORE. IN FACT, IF THE HOT BUNDLE ONLY RECEIVED 10% OF THE NOMINAL FLOW DUE TO BLOCKAGES, A CORE FLOW of 235 LBM/SEC WOULD BE ENOUGH TO PREVENT BOILING IN THE BLOCKED BUNDLE. (D. A. FARNSWORTH, "REQUIRED FLOW VERSUS COOLING EFFICIENCY", APRIL 10, 1979). COMPARISON OF CASES THREE AND FIVE SHOWS THE EFFECT OF CORE BYPASS FLOW ON SYSTEM FLOW AND CORE COOLANT TEMPERATURE INCREASE. AS EXPECTED, THERE IS VERY LITTLE INFLUENCE ON SYSTEM FLOW. AS THE CORE BYPASS FLOW INCREASES THE FLUID GOING THROUGH THE CORE IS HEATED MORE AND WHEN THE TWO STREAMS MEET AND ARE MIXED THE TEMPERATURE IN THE UPPER PLENUM IS NEARLY THE SAME; THUS THE DENSITY DISTRIBUTIONS ARE NEARLY THE SAME FOR BOTH RUNS AND THUS THE FLOWS ARE NEARLY EQUAL. SINCE THE CORE COOLANT TEMPERATURE RISE IS QUITE SMALL, SUBSTANTIAL BYPASS CAN OCCUR AND STILL HAVE ACCEPTABLE CORE COOLING.

COMPARISON OF CASES TWO, THREE AND FOUR SHOWS THE EFFECT OF INCREASING THE EFFECTIVE CORE RESISTANCE TO FLOW. AS EXPECTED, THE FLOW DECREASES AND THE TEMPERATURE RISE ACROSS THE CORE INCREASES; HOWEVER, EVEN FOR PRESSURE DROPS 1000 TIMES NOMINAL (ABOUT FIVE TIMES WHAT WE ESTIMATE) THE CORE FLOW IS ADE-QUATE TO COOL THE CORE.

<u> 1997 - 19</u>

_____400

310

200

Ē d

٦. \propto 3

100

÷ -

0

UNE FLOW VS. TIME

::**i**.: <u>|</u>

.....

400

÷

..... -----17

800

, - **1**., <u>F</u>.

.

• • •

-......

1...

12200 T= 2400

1600

FW=417

3 MW BY PASS = 0.3 3000 GPM .

2400 2000

.

TIME (see)

1200



TIME (sec)

REFERENCES

 Y. H. Hsii et.al., CADDS - Computer Application to Direct Digital Simulation of Transients in PWRs with or without SCRAM, Revision 1, <u>BAW-10098P, Rev. 1</u>, December 1977.

. . t .

3.3.5 COMPARISON WITH ALTERNATE CALCULATIONS

A COMPUTER PROGRAM HAS BEEN WRITTEN TO PERFORM THE SAME TYPE OF STEADY STATE ANALYSIS AS HAS BEEN DONE BY HAND. THIS PROGRAM INCLUDES A FORCE BALANCE ON THE VENT VALVES AND WILL TREAT THE RECIRCULATION FLOW IF THE VENT VALVE OPENS. THE PROGRAM ALSO CONSIDERS THE IDLE LOOP AS A FLOW PATH. FOR A RUN WHERE THE CONDITIONS WERE SIMILAR TO CASE 1 OF TABLE 3 (POWER = 3 MW, CORE PRESSURE DROP AT ITS NOMINAL CONDITION, FEEDWATER FLOW OF 3000 GPM), THIS PROGRAM COMPUTED A CORE FLOW OF 313 LBM/SEC WHERE CADDS/NATURAL PREDICTED 380. THIS IS GOOD AGREEMENT CONSIDERING THE SMALL DIFFERENCIES IN DENSITY AND PRESSURE DROP WHICH OCCUR, AND THERE WAS A DIFFERENCE IN PRIMARY COOLANT TEMPERATURE WHICH WOULD ACCOUNT FOR PART OF THE DIFFERENCE. THE STEADY STATE CODE PREDICTED A CORE AT OF 9 DEGREES VERSUS CADDS-NATURAL'S PREDICTION OF 7.8. THE STEADY STATE CODE COMPUTED THAT THE PRESSURE DIFFERENCE WAS NOT SUFFICIENT TO OPEN THE VENT VALVES AND THE IDLE LOOP FLOW WAS ONLY 32 LBS; THUS, THE SIMPLIFICATIONS USED IN THE CADDS-NATURAL PROGRAM ARE REASONABLE.
3.2.1.2. <u>COMPARISON OF CADDS WITH NATURAL CIRCULATION CALCULATION TO</u> DAVIS-BESSE <u>EXPERIMENT</u>

IN ORDER TO VERIFY THE VALIDITY OF THE CADDS/NATURAL CALCULATIONAL RESULTS, A SPECIAL CASE SIMULATING THE DAVIS-BESSE PLANT WAS RUN AND THE RESULTS COMPARED WITH THE REPORTED EXPERIMENTAL MEASUREMENTS. THE FOLLOWING TEST CONDITIONS WERE USED IN THE CADDS/NATURAL INPUT.

- 1) 2-LOOP CONFIGURATION
- 2) FEEDWATER FROM THE AUXILIARY FEEDWATER SYSTEM
- 3) REACTOR POWER WAS CONSTANT AT 3.85% OF 2772 MWth
- 4) TWO DIFFERENT FEEDWATER RATES (46 AND 460 LBM/SEC) WERE USED.

THE RESULTS ARE SHOWN IN FIG. _____. AS SHOWN BY THE FIGURE, THE SYSTEM FLOW RATES DO NOT REALLY STABILIZE IN 1800 SEC AND SMALL OSCILLA-TIONS STILL CAN BE SEEN: HOWEVER, IT APPEARS THAT THE PRIMARY SYSTEM FLOW RATES ARE APPROACHING A STEADY STATE NATURAL CIRCULATION FLOW RATE OF 6.0% FOR THE LOW FEEDWATER RATE AND 4.4% FOR THE HIGHER FEEDWATER RATE. THE REASON FOR THIS IS THAT THE HIGHER FEEDWATER RESULTS IN LOWER PRIMARY SYSTEM TEMPERATURE, WHICH IMPLIES HIGHER DENSITY AND VISCOSITY AND CONSEQUENTLY, HIGHER FRICTION.

THE DAVIS-BESSE EXPERIMENT REPORTED THAT THE NATURAL CIRCULATION FLOW RATE RANGES FROM 4.6 TO 5.1%, DEPENDING ON THE WATER LEVEL OF THE STEAM GENERATOR. IT APPEARS THAT THE CADDS/NATURAL PROGRAM WITH THE TWO EXTREMES IN FEEDWATER FLOW PREDICTS NATURAL CIRCULATION FROM RATES THAT BRACKET THE EXPERIMENTAL RESULTS. THE DIFFICULTY IN COMPARING CADDS/NATURAL DIRECTLY TO THE DAVIS-BESSE DATA IS DUE TO THE FOLLOWING:

- 1) THE OPERATOR VARIED AUXILIARY FEED PUMP SPEEDS SO MUCH THAT THE FLOW RATES RANGED FROM 200 TO 1400 GPM AND THAT <u>NO AVERAGE STEADY STATE FLOW</u> RATE
 - COULD BE DISCERNED FROM THE DATA.

DURING THE EXPERIMENT, THE MAIN FEEDWATER WAS TURNED OFF AND ONLY THE AUXILIARY FEEDWATER WAS USED. AT PRESENT, CADDS DOES NOT HAVE THE CAPABILITY OF MODELLING THE AUXILIARY FEEDWATER PROPERLY.

2)

3.7 CORE THERMAL BEHAVIOR

Attachment 4.

A. ANALYSIS OF CURRENT OPERATING CONDITION

CORE BLOCKAGE STUDY

TWO METHODS HAVE BEEN USED TO ESTIANTE THE EXTENT OF THE CORE BLOCKAGE. THE FIRST METHOD INVOLVES THE USE OF THE INCORE THERMOCOUPLES TO DETERMINE THE CORE OUTLET TEMPERATURE. THIS METHOD PREDICTS A CORE FLOW OF LESS THAN 1 X 10⁶ LB/HR.¹

WINDE

APRIL 10, 1979 TIME: 1630

THE SECOND METHOD INVOLVES MATCHING THE PUMP CODE TO THE DATA FORM THE PLANT. THE PUMP CODE CALCULATES FLOW SPLITS FOR DIFFERENT PUMP CONFIGURATIONS. THE CODE WAS MODELED TO MATCH THE PRE-INCIDENT CONDITIONS. THE CORE RESISTANCE WAS INCREASED UNTIL THE CODE PREDICTED THE SAME HOT LEG FLOWS THAT ARE BEING MEASURED BY THE TWO GENTILLE DELTA P'S.

THIS CALCULATION PREDICTS A CORE FLOW OF 13 \times 10⁶ LBM/HR AND A CORE PRESSURE DROP OF 18 PSI. THESE CONDITIONS ARE CALCULATED WITH A CORE RESISTANCE APPROXIMATELY 200 TIMES THE NORMAL RESISTANCE^{2,3,8} OR A FORMLOSS RESISTANCE OF 1650.

TO DETERMINE IF A CORE RESISTANCE OF THAT MAGNITUDE IS FEASIBLE AN ESTIMATE OF THE CORE DAMAGE WAS DEVELOPED. A CURRENT ESTIMATE OF THE MATERIAL AVAILABLE FOR CORE BLOCKAGE IS :

G. A. MEYER APRIL 10, 1979 TIME: 1630



THIS DEBRIS IF SPREAD EVENLY ACROSS THE CORE COULD FORM A PACKED BED OF DEBRIS THREE FEET THICK.⁴ THE RESISTANCE (FORMLOSS COEFFICIENT) FOR THIS BED HAS BEEN CALCULATED AT APPROXIMATELY 1700⁵ WHICH IS IN GOOD AGREEMENT WITH THE TOTAL CORE RESISTANCE CALCULATED USING THE MEASURED FLOW SPLITS. THE METHOD TWO CALCULATION OF A ONE PUMP CORE FLOW OF 13 \times 10⁶ LB/HR AND THE ASSOCIATED BLOCKAGE IS THE BEST ESTIMATE OF THE CURRENT CORE CONDITIONS FOR THE FOLLOWING REASONS. 1) CALCULATIONS HAVE SHOWN THAT SUFFICIENT UO, COULD BE "PACKED" AROUND THE THERMOCOUPLE TO GET A TEMPERATURE READING 35⁰ HIGHER THAN THE FUEL ASSEMBLY BULK EXIT TEMPERATURE. CALCULATION INDICATE THAT ON THE AVERAGE THE THERMO 2) COUPLE WERE READING 5°F TOO HIGH BEFORE THE ING IT SEEMS IMPROBABLE THAT SUFFICIENT BLOCKAGE 3) COULD EXIST TO REDUCE THE CORE FLOW TO THE 1 \times 10^{\circ} LB/HR PREDICTED IN METHOD ONE. 4)

THE SHIFT IN THE THERMOCOUPLE READING BEFORE, DURING, AND AFTER THE SWITCH FROM PUMP A1 TO A2 INDICATE THAT THE CHANGE IN THE FLOW DISTRIBUTION IS CAUSING

G, A. MEYER APRIL 10, 1979 TIME: 1630

THE DEBRIS TO SHIFT WHICH IS AFFECTING THE THERMOCOUPLE READINGS. THE SHIFTING DEBRIS MAKE THE METHOD ONE ANALYSIS MORE SUSPECT AND LENDS CREDENCE TO THE HYPOTHESIZED LARGE BED OF DEBRIS CALCULATED IN METHOD TWO.

3.7 A⁻(‡) REFERENCES

- 1. JH Jones to GA Meyer "Estimate of Core Flow"
- 2. PS Bartells to Distribution, "Core Pressure Drop for Natural Circulation Calculation", 4/9/79

2215

- 3. R. M. Hiatt to G. A. Meyer, "LYNXL Model for TMI-2 Blockage Study", 4/10/79
- Core Condition Task Force, "Estimate of Loose Core Debris Volume (4/9/79 2000),
 4/9/79
- 5. P. J. Henningson to G. A. Meyer, "Damage Model Fluidized Bed", 4/10/79
- 6. P. J. Henningson to G. A. Meyer, "Increased T.C. Readings Due to Proximitty
 - of Fuel Particulates"
- 7) T. L. Wilson to J. T. Willse, "Discripancy between Thermocouples and Outlet RTD Temperature Measurements", 4/9/79
- R. M. Gribble to J. D. Carlton, "Core Bypass Flow For Core Blocked at Top Only", 4/8/79
- 9) J. A. Weimer to G. A. Meyer, "Incore Thermocouple Error Evaluation", 4/10/79

OTHER INFORMATION

1) R. M. Hiatt to G. A. Meyer, "Core Flow Distribution for One Pump and two Pump Operation". 4/10/79 DESCRIPTION

6.

The incore thermocouple design for TMI-2 is a grounded junction chromel-Alumel detector. The location of the detector in relation to the fuel assembly upper end fitting is shown on Figure 1. The thermocouple wire diameters are approximately 10 mils, the sheath is 62 mils OD Inconel tubing, and the insulation material is Al_2O_3 . The location of the thermocouple within the instrument tube is shown in Figure 2. There are 50 thermocouples at locations in the core shown on Figure

THERMOCOUPLE READINGS

The highest temperature readings of the thermocouples are plotted from 0400, 3/28 to 1300, 4/6 on Figure 3. at about 1300 on 4/6 a RC pump switch from 1A to 2A occurred which caused a redistribution of thermocouple readings. The change in thermocouple readings as a result of the pump switch is shown on Figure 4. The highest thermocouple readings after the pump switch are shown on Figure 5. Complete sets of thermocouple readings at selected times of each day are given on Figure 6.

The major point addressed in this section is to evaluate the thermocouple readings to determine the validity of the temperatures. This was done by examining detector accuracy and by evaluating fuel pellet debris accumulated around the thermocouple. The results of this evaluation are that the thermocouples are reasonably accurate and that the high temperatures are a result of fuel particles in the upper end fitting. DETECTOR ACCURACY

PAST EXPERIENCE WITH THERMOCOUPLES INSTALLED IN B&W PLANTS SHOW TWO BASIC TRAITS. THEY TRACK FAIRLY STEADY WHEN THE CORE IS AT STEADY STATE AND THEY RESPOND TO LOCAL CHANGES RELATIVELY ACCURATELY. A ONE TO TWO DEGREE CHANGE IN THERMOCOUPLE READING HAS OCCURRED MANY TIMES WITHOUT ANY OBVIOUS CHANGE IN CORE CONDITIONS. THERMOCOUPLE READING CHANGES GREATER THEN 2[°]F ARE REFLECTED IN OTHER MEASUREABLE LOCAL OR CORE CHANGES.

THE THERMOCOUPLES WERE EXPOSED TO TEMPERATURES GREATER THAN (1800°F) DURING THE INCIDENT AT TMI-2. TO DETERMINE IF THESE ELEVATED TEMPERATURES WOULD PRODUCE INACCURATE THERMOCOUPLE READINGS, TESTS WERE CONDUCTED AT THE BÆLFAB SUBSIDIARY OF B&W. IN THESE TESTS, 4 THERMOCOUPLES WERE RAISED TO 2000°F FOR FOUR HOURS. THE THERMOCOUPLE READINGS WERE THEN CHECKED AGAINST KNOWN READINGS OVER THE RANGE OF 200 TO 1000°F. ALL TEST THERMOCOUPLES READ WITHIN 5% OF THE CALIBRATION VALUE. IT WAS CONCLUDED THAT THE HIGH TEMPERATURE EXPOSURE WOULD NOT SIGNIFICANT ALTER THE THERMOCOUPLE READING.

THERMOCOUPLE DATA FROM TMI-2 DURING NORMAL OPERATION BEFORE THE LOFW TRANSIENT WAS EXAMINED TO DETERMINE IF A SYSTEMATIC BIAS EXISTED. NO DATA WAS AVAILABLE AT ZERO POWER CONDITIONS, THEREFORE DATA FROM SEVERAL POWER LEVELS WAS EXTRAPOLATED DOWN TO ZERO POWER. THE RESULTS OF THIS ANALYSIS SHOW THAT A + 5°F BIAS IS POSSIBLE ON THE THERMOCOUPLE READINGS.

.

THE POSSIBLILITY OF DE-CALIBRATION SINCE THE INCIDENT HAS ALSO BEEN EVALUATED. SIX THERMOCOUPLES WHICH HAD A TEMPERATURE RISE OF 7 to 33^{0} F OVER A 5 DAY PERIOD WERE EXAMINED. NO MECHANISM COULD BE POSTULATED WHICH WOULD CAUSE DECALIE ARTION TO THE EXTENT SHOWN BY THE DATA. IT WAS CONCLUDED THAT THE THERMOCOUPLE READINGS WERE ACCURATE AND THAT TRUE TEMPERATURES WERE BEING MONITORED TO $\pm 5^{\circ}$ F.

THE RESULTS OF THE THERMOCOUPLE TESTS AND EVALUATIONS INDICATE THAT THE TEMPERATURE READINGS ARE GENERALLY ACCURATE WITH A POSSIBLE + 5°F BIAS.

3.7A (3) HEAT CONDUCTION FROM FUEL PELLET DEBRIS

An evaluation was performed to determine if the quasi steady thermocouple readings of 100 to 240° F above coolant temperature could be caused by fuel pellet agglomerates located on spacer grids or in end fittings.

One evaluation was performed assuming all the pellets from one grid span were caross the opstream grid. Exocut heat is generated evenly distributed in this mass to produce boiling in the annulus between the instrument string and the guide tube. The steam would be vented out of the guide tube below the upper end fitting. Heat transfer to the thermocouple would be from axial conduction along the instrument string. Due to the large amounts of fuel debris required and the fact that the instrument guide tube would be cooled above the fuel mass, it is concluded that this mechanism is not the most likely reason for the high thermocouple readings.

It is more likely that fuel pellets and pellet fragments have collected in the upper end fitting and/or the mixing cup. Reactor coolant flow is sufficient to carry fuel pellet fragments above the upper end fitting where they would settle out in this stagment region. An analysis was performed which assumed various widths of fuel assumulation in the upper end fitting around and in the mixing cup. The results of this analysis is shown on Figures 7 and 8. The case with fuel particles inside the mixing cup (T.C. Well) shows a small (10° F) increase in temperature which is insignificant. Fuel debris to a width of 3 to 4 inches in the upper end fitting itself does produce the magnitude at Δ T's which are seen on the readings. This amount of fuel could easily fit within the upper end fitting which has an interiour width of 7 inches.

Bibliograph for 3.7A(2) and (3)

For A.B. Jackson 3217

- 1. Memo, T.L. Wilson to E. Oelkers, "Reliability and Uncertainty of Thermocouples Following Loss of Feedwater Transient", April 5, 1979.
- Memo, J.A. Weimer to G.A. Meyer, "Response to Thermocouple Request", April 5, 1979.
- Memo, J.A. Weimer to G.A. Meyer, "Incore Thermocouple Error Evaluation", April 10, 1979.
- Memo, T.L. Wilson to J.T. Willse, "Discrepancy Between Thermocouples and Outlet RTD Temperature Measurements", April 9, 1979.
- Memo, J.T. Willse to Engineering Operations Manager, "Action Item 143", April 6, 1979.
- 6. Memo, P.J. Henningson to G.A. Meyer "Increased T.C. Readings Due to Proximity of Fuel Particulates", April 10, 1979.





SPECIFICATION NO. 1014/1269 SPECIFICATION NO. 1134/1169 DRAWING NO. 136010E - REV. 6 Figure 2.

.

(I-11)	F-7 \	6-9 - E-11	
		1)=-9	
		1	
		5501	P-10
		560	
		1 -522-	
		500	
		430- 462	
		440	
		420-470-	
		3\$D-	
		360	
		320	
		300	
		260	
		240-	
Orico 03co	1700 1600	2000 0000 (2400 0500 1000 1600 2400
	- 3/28		3 23
			Figure 3a

· · · · · · · · · · · · · · · · · · ·		
	λ	
•	H-8 \	
	D_{-1}	-60
1		-610
		-620
		V-PM-
		580
	Tely I I I I I I I I I I I I I I I I I I I	-504
		-540
		- 530
• • .		300
		-180
		460
•		
•		440-E
		Ara
:		-400
		202-
٠. ١		
	G-II	-300
		220
•		370
••		200
		-280
• •		
• •		
•		240
		-170
•		200
•		
	00. 0400	1200
	TIME	
İ		- 3/31

	میں میں میں ہیں۔ میں ایر		ومتعارية الشاد وساوي المريب وساور المريد بالا
· ······		·	•
b80			
1-620-			
The second secon			
Veso en			
50			
1517			
212			
520			
		in diata a second	
460			
440-E-9-			
B-11			
E-11			
400 K-11			
6-9			
3.0			
free and the second construction of the second s			
20			
320			
- 220			
320			
370 			
320 320 			
320 320 320 			
320 320 200 C-13 200 F-7 1 210 F-7			
320 320 320 200 C-13 1 200 F-1 20 340			
320 320 320 			
220 			
320 320 320 			
$ \frac{320}{320} \\ -320 \\ -320 \\ -210 \\ -210 \\ -220 \\ -220 \\ -200 \\$			
$ \frac{320}{320} - \frac{1}{200} - \frac{1}{5-3} - \frac{1}{1-3} - \frac$			
$ \frac{320}{320} \\ \frac{320}{210} \\ \frac{320}{210} \\ \frac{720}{5-1} \\ \frac{340}{210} \\ \frac{340}{5-1} \\$			
$ \frac{320}{320} $ $ \frac{320}{-320} $ $ \frac{210}{-13} $ $ \frac{1200}{-13} $ $ \frac{11200}{-15} $ $ \frac{11200}{-15} $ $ \frac{2000}{-7} $	2010 2010		и
$ \frac{320}{320} - \frac{320}{500} - \frac{1}{500} -$			

₽.

Figure 3c

1 62D • :• **:**. 1. . 1 660. ÷ Fi - [.... ::::: 1. . **i** 540 ÷. . · • 630 . ,...**;**.... :::1.: 600 <u>. </u> iir: ÷ 580 560-. . 540 13**.** 520 500 ÷..... -480 D-10 460--::i G = 11 - ------:13 440 470 1..... - - - -Щ. Ц 400 3S0 H-8 K-11 EAJ • •:• ₹.**.**, 360 ::.. :f:::::::... in the second ani in the state 1. • 1 E F -i--• منبح... تفتقل بيانيد -. 570-..... · · · · · · 1 300 1.1 13 <u>...</u> :: 280 .1 :: 260 240 220-···. ----- 117 ÷:Ľ - 1 -------200 <u>. i</u> 1**.** 1 -1200 0800 1620 2400 2000 0400 Dogo 0400 0500 1200 10-2000 2-4 :1 . 1 1 ::**:**: . . . ••• **:**. 4|3 ------|... <u>)</u>. : ÷ 1 · · · : ‡

Figure 3d

		:		•	:	· · ·	1. 1	· ·	1 • • •					1			• • • •		;	
•				1	<u> </u>	<u>† 77</u>	j 			<u> </u> :									j. , \$	89
		5. E.A													. :		<u> </u>			
					<u> </u> -						<u> </u>					1 T			b	69 -
						·							 							
					<u> </u>	.										1-1		<u> </u>		
														-						
•				1																79
•				1			<u> </u>			1										
. •• •				1																99
•																				
										1										20
•				T	AT-	1	1												<u></u>	<i>Ъ</i> р
					171	1				<u></u>		~~~	~~						<u> </u>	
					<u> </u>	+								F		1 · · · · · · · · · · · · · · · · · · ·			S	40-
					<u></u>														<u> </u>	~~~~~
			····																	<u> </u>
					<u> </u>		L	1.2.1	1	1									5	00
																	1 1 1 1 1 1			
							1												<u></u>	80
				D-10	0			<u> </u>												
				1		. <u>.</u>	1	\rightarrow	\leq	1									<u></u>	; <u>,,,</u>
· .	<u></u>			G-H			<u> </u>			i			<u></u>	<u> </u>					<u></u>	
							<u></u>	1	1	<u> </u>	1			···::	<u> </u>		1;			40
· .							<u> </u>					· ::!·:::		<u> </u>						
				1 E-1		<u></u>	1										<u> </u>			20
-									<u> </u>	<u> </u>	i		-		<u> </u>			<u> </u>	<u> </u>	<u> </u>
· .				<u> </u>		. <u> -::-1:-</u> .:		<u>1</u>		<u> </u>			<u></u>					<u> </u>	-4	67
								\sim		1.1211.				<u> </u>						
				13	<u></u>	<u></u>	<u></u>	<u> </u>			<u></u>							<u> </u> -	1	\$0
						E	9—-	<u> </u>	<u> </u>	 -				·				<u> </u>	ŀ,≓='	·
÷.,,	1			<u> </u>					~				سمس						3	60 <u> </u>
			<u></u>	00			(-11									<u></u>		- <u></u> -	 -	
•				107		· <u>···</u>	<u> </u>	<u> </u>	<u> </u>										<u> </u>	42-
			<u> </u>	<u> </u>		1	<u> </u>	<u> </u>					(****i.: 							<u></u>
•						: <u> :::</u>	<u> </u>			<u> </u>				<u></u>				1		20
												*****							<u></u>	
				<u></u>	C-13.			<u></u>											3	00
)											1				<u></u>	<u></u>		<u> -</u> ∔	<u>)</u>	- <u>-</u>
·					-p	- <u>-</u> -												<u>-</u>	1	80
· ·				<u>.</u>	1	1.1.1.		<u></u>	· · · · ·	<u>.</u>								<u> </u>		
		<u></u>									<u> : . !: </u>							· · · · · · · · · · · · · · · · · · ·	- 7	b0
						+											<u> </u>		[::-	
					<u></u>					<u></u> -		· · ·	<u> </u>			· · · · · · ·	<u> :</u> .: .: .			40
												·						 ::	 -	
					<u> </u>	<u></u>	<u>r</u>			1		•				·····	<u> </u>	<u> </u>		20
· ·						-		<u> </u>												
		╞╼╧				<u> </u>		<u> iiii</u>							···· •···			<u> </u>	├ •	00
1. • y				 		-					<u> </u>									
	<u> </u>		<u> </u>		1	- <u> </u>			 					<u> </u>				<u> </u>	<u> </u>	
					 	- 														
	L		<u> </u>		_ن_ب	_ن_ا	<u></u>		<u> </u>	<u>i</u>	للنعب		أسياسا	لنسب		نسب		İ		بالسنساب
•	·· \$	400	0	400	0	500	- 17	00	1	00	30	00.	.24	00	04	00	D	200 .	13	00
		<u>.</u>		.	<u> </u>		<u>L.</u>	<u> ÷-</u> .		<u> </u>	., 					[;i]		·	<u>-</u>	
			<u> </u>	<u></u>				41	·	<u> </u>	··					j	••	· · · ·		15 -
• • •				·		4		Ļ	• •;		ļ	·			·····					
		ŧ.		.				•				·;; ·					• •••			
1														•						

Figure 3e

		••••••••••••••••••••••••••••••••••••••		
680-			<u> </u>	<u>. </u>
660				
110				
600				
550				
		<u></u>		
520				
500				
480				
		H-	δ	
Ab0				
G-11				
100				
E-1				
400				
380 118				
Kaller and a second				
340-6-9				
			1	
200 Cal3		- A-		
			· · · · · · · · · · · ·	
280				
260				
220				
- 2 p0				
1200 1600 2000 24	00	12-00	00 2000	2400
- 4/5		-4/6		

•

. .

Figure 3f

'ORM 146'	No				the e	NBCO	CK &	WILCO	х со.	•	T RC RC	ime Temp. Press.		
		SP	DND DCA	STR	- ING 15 -	NUM 177	BE R FA	S A COF	N D RE	•	[XXX K	STRIN - TIC	g NO. Read
·(A)2	S RC	Pump	S										
3						+1	50						/	
•					32			29 +1	6.5			52		
)				33					21 -119				51	
:			34			+7		-10		-105		-		
-		ي ي ال				+4	+7			-33	2.4	23 -19		·*·**
:	+1	•		+35	+7		•	-3		25 -105		-34		
F 216				10 +42			+66	-112				21	•	
(11				~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~		19 -42	20		₩.212. PT. 4" +PT. 4. ²⁷⁹ -	
	36	29 +1			12					-46		50		
1.20		મંડ				13		+32	זיו +10		•		-3	
			મ્હ				14 +5	15						
1	م با بر الربن الربي الربي الربي الربي الربي الربي الربي الربي الربي الربي الربي الربي الربي الربي الربي الربي			42	43				17		48			•
, (E		No.		1947 - FOCTA 42377	44 +2			*****	•					AN
						45	*5	TOT ROOT	46	Taurranananananananananananananananananan			B.	
1	2	3	4	5	6	7 ΔT	1 8 After	9 Pumi	10 5 Swit	11 Tch -	12 Figur	13 24.	14	15
USTOMER	GPI	12	. 1)L	DB 110.			

•••• .::I :: 680 <u>....</u> 660 ÷. 640 ··... 620 -11 ii. E 600 - **i** --580 . ::i:· 560 540 1111 TSAT ::4: · 1. Ē . . 520 : **|****.**: : l: ..i• Ŧ ::l: :: 500 #† ; ; 480 •••• 460 148 ___ <u>.</u> 1..... 440 i i :::iii 420 ____G 400 • ::i::: 380 :#: • le de la compañía de la compañía de la compañía de la compañía de la compañía de la compañía de la compañía de 11 ------...... •••• e de la calendaria de la calendaria de la calendaria de la calendaria de la calendaria de la calendaria de la c .:: : :* 360 . . H5 1 : ei in Mg 340 32*0* 300 E9 .:. GT -L6 9.H 1. - (i :: 280 :: -..... 260 -1. ÷ 240[:#: 1 1... $\cdot | \cdot |$ 220 22 .<u>.</u>.... <u>il:</u> -÷ H. 3.17 `...†· 1.5 :.i. 200 ----. · • 1 2400 1600 2000 0300 2400 0400 0800 1200 0400 1200 · ÷ ÷ ÷ .. •• • • 4/8-7 : : :

Figure 5

.

1 .							
					650-		
					660		
· · ·					640		
ʻ.					620		
					600-		
•							
,							
					520		
•			$\sum =$				
			$- \chi +$		180		
					160		
					440-		
					~		
							118
2							<u>#5</u>
					960-		G5
					310-		
····					320		<u>G</u> 6
1					300		
					280		
•							
					240		
					220		
•							
	.1200	1600 .20	2400.	0400	0800 1200	1600 20	00 2400
•	- 4/8 —	. <u></u>			4/9	· · · · · · · · · · · · · · · · · · ·	
1	• 1			•			

Figure S

•

			,-,			เงคตา	CK Ft	WII CO	ox co.		TIME		1035	
•	•	•	•••		2 4 1 km pr						RC	Press	·	
•		SF	<u>200</u> 4	STR	HNG 15 -	NUM	BE R FA	S A COF	N D RE			к	STRIN	G NO.
	•												•	•
•••••		••				31 289	30 293						1	
ſ	•				293			29	294	. 1		289	contraction of the second	
	•			292					21 579				283	
ISCHIES CO.			34 290		af an interest of the second	596		5		26				
		288	 			345	226				290	23		
1	36 293			422	в З6З			3 558		25		22 301		
284			1	[0	•		7900	363				282		
01111-C			•	11 291			• • •			19 580	20 304			
	38 2 <i>8</i> 7	39 288			12					ເຮ	-	50		
		287				13 299		492	378				49	
			304		·	•	399	- 15 2,90						
•			• •	42 296	43 291			•	47		48 290			
					292				8. Jacob - po prove					
		•			•	45 290	+5		46 7.90	•		Figur	-e 6	a
l	2	3	4	5	6	7	8	9	10	11	12	13]4 <u>+</u>	15

(.140 - ° -	12 a - a - A.	•			THE L	ODRAG	CK &	WILCO	x co.	· - · · · · · ·	TIME	IEMD	1345	
		•		•			• •		•	•	RC	Press		
	•	SF	ND DCA	STR	<u>ING</u> 15 -	NUM 177	BE R FA	S A COF	N D RE	-		ĸ	STRIN	G NO.
	•												· · · · · · · · · · · · · · · · · · ·	•
•		••				31 2,93	30 296						/	
	•				32 297			319	28	1		295	errer year	•
	•			296					586				292	
			34 2,93			359		465		25				- Carlos - Carlos - Carlos - Carlos - Carlos - Carlos - Carlos - Carlos - Carlos - Carlos - Carlos - Carlos - C
- - 	•	35 29 <u>2</u>				295	42,33				24 310	23 305		
	3% 296		s.	9 336	8 316			385	· .	25 420		22 333		
293				299	•		895	322				21 307		
				" 296			••••			19 447	20 325			
	38	39 293			12 2,96					18 302	•	50		
		298				13 299		16 350	12 326		-		300	
			41 289				14 348	15 295						
•				42 296	43 294				47 297		48 294			•
. :					44 293								>	· · · ·
··· · ·	i . J					45 283 6183	45		193			Fi	qure	6b
1	2	3	4	5	6	7	8	9	10	11	12	13	J 14	15

ŀ

M. 140. A			•		THE L	N9CO	CK &	WILCO	х со.		Time RC T RC	iemp_ Press	0845 280 978	5
		SE L	<u>ND</u> OCA	-STR TION	171G 15 -	NUM 177	BE R FA	S A COF	N D \E			ĸ	STRIN	G NO.
•	•												•	•
		•				31 289	30 291			1			/	• ••
	•				32 292			29 3/1	. 28 291			52 290		
				33 2,89					११ 507	• •			51 287	
			34 2,88			356		5 442		-26 417			-	
	والمراجع المراجع	289				6 293	2.42				303	23	•	
	36 290			330	8 319			392		427		22 330		
243				294			678	2 314			•	310		
			-	۰۱۱ 291						19 421	20 32,7			~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~
aller The	38 289	39 287			290			a		18 302	•	50		
	=14 3= [295				13 29.4		16 344	17 3:30				294	
			291				341	15 291						•
	•			42 292	43 288				47 293		48 288			•
	/				286									
	,	· ·		-		45 287	215		46			F	Flaure	6c
1	2	3	4	5	6	7	8	9	10	11	12	13	J 14	15

•	· · · · · · · · · · · · · · · · · · ·	•	•••		THE E	VECO	CK Ei	WILCO	x co.	• • • • • • • • • • • • • • • • • • •	RC T RC	iemp_ Press	279 970	.7
		SE	OCA	-5TR TION	179G 95 -	NUM 177	BE R FA	S A COF	N D RE			ĸ	STRIN	G NO.
												•	•	•
		••				288	30 290			1			1	
	•			<u></u>	32			305	289			52 290	FURNELLYCA	•
				288					27 49.2				31 285	
Northeast			34 287			340		407		416		•	-	weither and
		35 285				283	234				24 311	23 299		
13101-01-01-01-01-01-01-01-01-01-01-01-01-	36 289			322	315		•	350		25 438		22. 331		
200				290			393	2 311			•	21 312		
		•	-	" 289		•	•			19 3.76	20 330			
	38 287	39 286			12 2.89				•	18 308	•	50		
•		2.90				13 292		323	317				49 295	
			41 292				14 327	15 2,90				•		
•				42 287	43 281				117 293		48 288			
					14									
			• . •			286	: ۲۰ ۲۰		16	•			Fiaur	e 6d
1	2	3	4	5	6	7	8	9	10	11	12]3	5 ‡	15

DECR .

4M 140 ---

THE BABCOCK & WILCOX CO. RC TEMP 277.9 RC PRESS 910

		SF	ND OCA	STR	ING 15 -	NUM 177	BE R FA	S A COF	N D RE		• [к	STRIN	G NO.
•										•			•	•
		••				31 286	30 287						1	
	•				32. 287			29 300	287			52 288		
				33					27 473	•			278	
			34 2,84			32,5		384		26 :410			-	
	•	283 283		•		6 2,75	227			•	317	23 299	•	
3624	36 285			320	3/3			339 339		25 432		22 330		
284				287	•		376	г 303			-	310		
BADIN'S MAN				2,86	· .	•				360	20 326			
1.5 4720004701	38 286	39 284			12 286			#797389720794	•	18 312	•	50		
	-	40 285				13 286		16 318	17 312				19 291	
•			41 288				306	15 288				• 		•
•	•			42 284	43 285				47 290		48 286			•
	1	J			44 279									
	· · · · · · · · · · · · · · · · · · ·		•			45 284	ن ۲۰. ۱۰.		283	•			Figure	,6e
1	2	3	4	5	6	7	8	9	10	11	12	13) 4	15



MER

.

4 1 43		• • •	•••		THE I	OOBAG	CK &	WILCO	»х со.	•	Time RC T RC	TEMP_ Press	<u>0532</u> 283 105	، <u>، (،</u> ک <u>ی</u>
	· · .	S L	24-D=	STR	ING 15 -	NUM 177	BE R FA	S A COF	N D RE			×	STRIN	G NO
	•	•											•	· · · · · · · · · · · · · · · · · · ·
•		••				31 293	30 293			1			1	
	•		•		32 300			29 309	28 294			57. 295		-
				293					211 466				288	
-			34 292			309		5. 364		26			-	
	Strategy (Jacob	35			·	272	234				329	308		
s.a	36			322	8 312			339 339		25		333		
240				292			372	2 3/1				320		
			· .	293						19	20 338			
	38 291	39 290			301					329	•	50		
	Nonestrane	289				294		32,1	310				2,97	
	and the second		293				311	296						•
	•			42 2,88	43 290				.47 298		48 293			•
· · ·	/				44 285				•				``	, ,
}	•		,	,		45 290	45		290			F	iqure	69
1	2	3	4	5	6	7	8	9	10	11	12	13	。 [华]5



NM 140	. <u></u>			•	THE L		LIME RC T	EMP_	254A	6				
•		•	•		•	•			•••••••••••••••••••••••••••••••••••••••		RC	Press		<u>\</u>
		SF	ND OCA	STR	<u>ING</u> 15 -	NUM 177	BE R FA	S A COF	N D RE			к	STRIN	G NO.
	•	•		•							:			•
•		•••				31 291	30						/	
	•				32			29 307	83			52 298		•
				33					2.7 445				51	• • •
			과			304		.351		26 409				
		35				267	213			•	24 3,25	23 309		
State Press	36 292			320	6			331 331		25		22 318		
240				292	•		372	2 307			-	319		
				11						19 357	20			
	38	39 290	- Kanta 1941		12					18 335	•	50		
		16				13		323	17 314				297	
			41				308	15	•					
	•			42	43				47		48			•
					285									
	• • • •		•		1070mm211_	45	215		46	6 	**************************************	-	Figure	-6i
) 	2	3	4	5	6	7	8	1	10	- 11	12	13	J /4	15
	·								•			•	•	

RH 142		<u>.</u>						· · · · · · · · · · · · · · · · · · ·			TIME		500	<u>}</u>
•		•			THE L	179CO	CK &	WILCO	ox co.	,	RC	PRESS	97	8
•	-				· · · · ·			•						
•	· · ·	SF L	OND OCA	SIR	171G 15 -	NUM 177	IBE R FA	S A COF	N D RE	•		к	STRIN	IG NO.
	•	•					1		<u> </u>				•	
						31 1Q1	30 202						•	•
) 		32 295	010	a D	29 301	28			52 201		
	•			33					29,1 29,1				51 291	
			³⁴ 291			300		. 5 326		26				•
EDECOURTS		298				6 272.	3.13				24 291	23 290		STRATISTICS IN THE REAL
100000000	3% 2,92			376	в 333			3 333		2.5 31.4		293		
293				10			451	298			•	· 21 290		-
and the				" 300			• • • •			19 315	20 290			
	38 J.GJ	39 2,95			12 312,		********			18 293	•	50		
	910 97 Januar	293				13 295		16 33%	313				294	•
			297				308	300				•		
				42 297	43 303				117		48			•
	/				307									
· · ·)	•	•			45 2,8%	-15		292	•		· · · ·	Figure	26j
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15

onet 140		•			THE L	SABCO	CK &	WILCO	x co.		Time RC T RC	EIIIP_ Press	<u>2517</u> 2.70 	<u>15</u> 16
	SPND-STRTNG NUMBERS AND LOCATIONS - 177 FA CORE											к	STRIN	G NO.
•	•	•										· · ·		
	\	••				31 286	30 288			••			1	
	•				32 289			: 29 298	28 287			52 2,88		
				33					27	•			31 286	
			34 293			298		5 317		26 285			-	
		35 2195		·		266	207				24 286	23 201		
	36 287			370	в ЗЗ.7.			323 323		25		22 2,89		
288				10 341	•		440	29:1		#3787.5.78%		285		
57435-12745-44				295						19 3/3	20 285			
	38 288	39			12 309					18 288	•	50		-
¥.	*****	288				291		333	309				289	
			41 291				303	295					· · · ·	
				, 42 291	43 297				47 288		287		· ·	•
	1				44 300									
•)					293	÷5)		16 201 01010			f	-īgure	GK
1	S	3	4	5	6	7	8	9	10]/	12	13	14	15

			TIME UDU											
• •		• •				JABCO		MILCO	λ 00.	•	RC	PRESS	시7.	3
	. <u>.</u>	· · · · · · · · · · · · · · · · · · ·	••••		· · · · · ·		•				· · · · · · · · · · · · · · · · · · ·			
•	•	SF	РND	STR	ING	NUM	BER	S A	ND			К	STRIN	G NO.
•														
	•	•							•				•	
•••		••				31 2,87	30 289						1	
	•			}	32 290			299	28			52 291		
				33 290		•			27				51 2,88	
			34 291			296		313		26			-	
C. D. D. K.		35 298				6 262	2.01				288	23 285		
	36 284			367	323	ч		3 3/5		25		22 290		
340				375	•		429	2 395				2.86		
		•		.11 296	·		• •			19 3/4	20 287			
B (2 4 9 george	38 289	39			12 322					18 2,90	•	50		
		289				13 293		349	17 307				49 291	
			295				14 304	15 297						
	•			42 2.91.1	13 296				117 290		48 288			
	/	C	`	-3 + 45 - 12 - 2	44 302									•
	1					15 298	5		281		₩₩₩₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽	i. T	-igura	e 64
1	2	3	4	5	6	7	8	9	10]]	12	13	14	15

DHER

.

11 67D 11 DO 1			•					•			IIME			<u>></u>
•					THE E	NDCO	CK & 1	WILCO	х со.		RCT	EMP_ Porce	94	1
•		•	•		•		•		: •	•	. 17	14655		
		SF	N D	STR	ING	NŲM	BER	SĂ	N D	•		к	STRIN	G NO.
		L	OCA.	TION	15 -	177	FA	COF	₹E					•
									-				•	•
•		••				31 283	30 285				· · ·		. .	
					32			293	28 284	,		52 2,86		
				33					27				283	
••			34 286			286		300		26		·		•
*****************		392				253	4		<u> </u>		283	23 279		
547 20 404-444-4	34 285			9 352	в 309			3 301		25		- 22 285		
226				376	•		398	286				21 281		
*				.11 294			••••			. 19 302	20 2.82			
	38 285	39	ric commente 4		51 818				•	18 2,84	•	50		
		286				13 2,87		16 335	17 2.99				49 2,86	
			41 289				14 298	15 29/						•
_ ^	•.			42 Z90	43 29.4				47 286		18			•
					44 29:4									
•						45 291	45		16 1600 1600		}	F	iqure	Gm
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15

OLICE .




3.7 B

OPERATION OF THE TMI-2 CORE WITH NATURAL CIRCULATION HAS BEEN EVALUATED AND JUDGED ACCEPTABLE ON A LONG TERM COOLING BASIS. CORE MINIMUM FLOW REQUIREMENTS AS A FUNCTION OF TIME AND OPERATING CONDITIONS HAVE BEEN DETERMINED. CRITERIA HAVE BEEN ESTABLISHED FOR THE ACCEPTABILITY AND ESTABLISHMENT OF NATURAL CIRCULATION. THE EFFECTS OF LOCALIZED HEATING HAVE BEEN EVALUATED AND LIMITS HAVE BEEN ESTABLISHED FOR THE INCORE THERMOCOUPLES AND HOT LEG RTD'S.

THE MINIMUM CORE FLOW REQUIREMENTS FOR LONG TERM COOLING ARE GIVEN IN REFERENCE 1. THE BASIS FOR THIS MINIMUM REQUIRED FLOW IS NO BULK COOLANT TEMPERATURE ABOVE SATURATION TEMPERATURE. THE CURVES PRESENTED IN REFERENCE 1 INCLUDE A SAFETY MARGIN OF 300% AND ARE COMPLETELY BOUNDED BY PREDICTIONS OF ACTUAL NATURAL CIRCULATION CORE FLOW ASSUMING CORE RESISTANCES 200 TO 1000 TIMES THE RESISTANCE OF A NORMAL 177 CORE.

CRITERIA FOR THE INCORE THERMOCOUPLES AND HOT LEG RTD'S ARE DESCRIBED IN REFERENCE 3. THESE CRITERIA ARE DESIGNED TO ALLOW ADEQUATE TIME FOR THE ESTABLISHMENT OF NATURAL CIRCULATION FLOW WHILE STILL ALLOWING FOR ADEQUATE SAFETY MARGIN AND TIME FOR TRANSITION TO ONE OF THE ALTERNATIVE COOLING SYSTEMS. THE DEGREE OF CONSERVATISM IN THE CRITERIA IS DEMONSTRATED BY ANALYSIS RESULTS PRESENTED IN REFERENCES 2, 3, & 4. THE REFERENCE 2 RESULTS DEMONSTRATE THAT TIMES IN ACCESS OF ONE HOUR ARE REQUIRED TO HEAT THE WATER CONTAINED ONLY IN THE CORE REGION TO SATURATION UNDER

4/10/79 7:50 pm Page 2

NO-FLOW CONDITIONS AND POWER LEVELS BELOW 3 MWT. REFERENCE 3 DEMONSTRATES THAT AN ADDITIONAL HOUR WOULD BE REQUIRED (@3 MWT) TO BOIL OUT COOLANT FROM THE OUTLET NOZZLE LEVEL TO THE TOP OF THE CORE. REFERENCE 4 DEMONSTRATES THAT MORE THAN ONE HOUR IS REQUIRED (@3 MWT) FOR THE ADIABATIC HEAT-UP OF THE CORE FROM 200°F TO 2000°F ASSUMING INSTANTANEOUS CORE UNCOVERAGE.

NATURAL CIRCULATION RESPONDS TO HIGHER FLOW RESISTANCE BY GOING FURTHER INTO TWO-PHASE FLOW UNTIL THE VAPORIZED DENSITY CHANGE IS SUFFICIENT TO OVERCOME SYSTEM RESISTANCE. WITH DEBRIS BLOCKING A GRID, FLOW WILL PASS LATERALLY AROUND THE BLOCKAGE AND ADEQUATELY IMMERSE THE FUEL BEFORE AND AFTER THE BLOCKAGE. IF THE BLOCKAGE DEBRIS ALSO CONTAINS FUEL, THE MAXIMUM TEMPERATURE AT THE BLOCKAGE CENTER WILL BE CONDUCTION LIMITED AND RELATIVELY INSENSITIVE TO THE MODE OF SURFACE HEAT TRANSFER. THE FLOW PATTERNS IN NATURAL CIRCULATION ARE DIRECTLY RESPONSIVE TO RESTRICTIONS, AND MAY WELL SHOW LOCAL TWO-PHASE TRANSITIONS AND RELATIVELY HIGH VELOCITIES AT PARTIALLY-BLOCKED HOTTER REGIONS.

REDISTRIBUTION OF CORE DEBRIS IS ANTICIPATED WHEN THE PUMPED FLOW IS TERMINATED. CHANGES IN THERMOCOUPLE INCORE TEMPERATURE DISTRIBUTIONS SHOULD BE EXPECTED. NOT ALL THERMOCOUPLE READINGS CAN BE EXPLAINED BY HYDRAULIC PHENOMENA. SOME THERMOCOUPLES, PARTICULARLY NEAR THE CENTER, ARE CURRENTLY INDICATING LOCALIZED HEATING EFFECTS AND ARE NOT MEASURING BULK FLUID TEMPERATURES. HENCE, IT IS NOT REALISTIC TO REQUIRE ALL INCORE THERMOCOUPLE MEASUREMENT BE BELOW SATURATION TEMPERATURE, NOR IS IT NECESSARY.

4/10/79 7:50 pm Page 3

REFERENCE 5 DISCUSSES THE ADVANTAGES AND DISADVANTAGES OF CORE COOLING AND NATURAL CIRCULATION AT VARIOUS PRESSURES. IT IS DESIRABLE AND PRUDENT TO ACCOMPLISH THE INITIAL COOLING EXOMPLISH PRESSURE (TP-TO-1800 FSIA) AND THEM MAINTAIN LONG TERM COOLING AND NATURAL CIRCULATION AT EXAMPLE PRESSURES IN THE RANGE OF 500-600 PSIA.

REFERENCES:

- MEMO, G.A. MEYER TO J.D. CARLTON, PLANT DESIGN, "MINIMUM CORE FLOW-LONG TERM COOLING", APRIL 4, 1979.
- 2) MEMO, L.L. LOSH/J.F. BURROW TO G.A. MEYER, THERMAL-HYDRAULICS, "CRITERIA DURING ESTABLISHMENT OF NATURAL CIRCULATION",

APRIL 10, 1979.

- 3) MEMO, J.A. WEIMER, R.L. HARNE TO DISTRIBUTION, "BOILING CONDITIONS IN CORE", APRIL 1, 1979.
- 4) MEMO, J.H. JONES TO G.A. MEYER, THERMAL-HYDRAULICS,
 - "ADIABATIC CORE HEATUP RATES", APRIL 10, 1979.
- 5) MEMO, J.R. GLOUDEMANS TO G.A. MEYER, THERMAL-HYDRAULICS, "COOLDOWN PRESSURE", APRIL 10, 1979.

G. A. MEYER -APRIL 10, 1979 TIME: 1520

3.7 CORE THERMAL BEHAVIOR

2)

C: ANALYSIS OF ALTERNATIVES

THE PLANNED MODE OF OPERATION, DISCUSSED IN SUB-SECTION B, IS TO ESTABLISH NATURAL CIRCULATION FOR THE LONG-TERM COOLDOWN. IF THE SYSTEM RESPONSE AFTER THE REACTOR COOLANT PUMP IS TRIPPED INDICATES THAT NATURAL CIRCULATION HAS NOT BEEN ESTABLISHED, THEN THE FOLLOWING ALTERNATIVE MODES OF OPERATION WOULD BE CONSIDERED:

1) RESTART ONE REACTOR COOLANT PUMP

THIS WOULD RESULT IN CORE CONDITIONS ESSENTIALLY THE SAME AS THOSE EXISTING NOW AND DISCUSSED IN SECTION A. IT IS ANTICIPATED THAT SOME SHIFTING OF DEBRIS WITHIN THE CORE WOULD OCCUR, RESULTING IN A NUMBER OF FAIRLY RAPID CHANGES IN INCORE THERMOCOUPLE READINGS, SIMILAR TO THE CHANGES WHICH OCCURRED ON APRIL 6, 1979 WHEN THE A1 PUMP TRIPPED AND THE A2 PUMP WAS STARTED.

DECAY HEAT SYSTEM (OR MODIFIED DECAY HEAT SYSTEM) THE COOLING FLOW RATE AVAILABLE FROM THIS SYSTEM IS SIMILAR IN MAGNITUDE TO THAT AVAILABLE WHEN NATURAL CIRCULATION IS SUCCESSFULLY ESTABLISHED, THEREFORE THE ANALYSES OF SUBSECTION B APPLY. THE MINIMUM REQUIRED FLOWRATE, PROVIDED IN REFERENCE (C.1) INCLUDES A FACTOR OF 5.8 ON THE FLOW CALCULATED AS THAT REQUIRED TO AVOID BULK BOILING WITHIN THE CORE. LOCALIZED BOILING IS EXPECTED TO OCCUR, AND THIS COULD CAUSE SOME OF THE INCORE THERMOCOUPLES, SUCH AS THOSE LOCATED IN CORE LOCATIONS H8 AND H5, TO INDICATE TEMPERATURES SOMEWHAT HIGHER THAN THE AVERAGE AND POTENTIALLY HIGHER THAN THE SATURATION TEMPERATURE (ASSUMING THAT THESE THERMOCOUPLES ARE IN CONTACT WITH AGGLOMERATIONS OF FUEL FRAGMENTS). THE FACTOR OF 5.8 ACCOUNTS FOR A 27% CORE BYPASS FLOW RATE WHICH, IN TURN, REFLECTS AN EXTREMELY HIGH CORE FLOW RESISTANCE RESULTING FROM THE POSTUALTED CORE BLOCKAGE.

3) HIGH PRESSURE INJECTION SYSTEM

THE MINIMUM FLOW RATE SPECIFIED FOR THIS MODE OF OPERATION IS BASED UPON THE SAME EVALUATION AS THAT FOR THE DECAY HEAT SYSTEM, AND REPRESENTS THAT FLOW RATE NECESSARY TO AVOID BULK BOILING. THE AVOIDANCE OF BULK BOILING, ALTHOUGH NOT CONSIDERED TO BE ABSOLUTELY NECESSARY, IS DESIRABLE TO MINIMIZE HOT SPOT TEMPERATURES IN CORE LOCATIONS SUBJECTED TO SEVERE BLOCKAGE. THE FLOW REQUIREMENT SPECIFIED IS CONSERVATIVELY BASED UPON A DECAY HEAT VALUE OF 4 MWT. FOR LOWER POWER LEVELS THE MINIMUM REQUIRED FLOW DECREASES IN DIRECT PROPORTION TO THE DECAY HEAT LEVEL.

REFERENCE C.1

A. B. JACKSON TO C. C. ENGLAND, "REQUIRED FLOW FOR CORE COOLING," APRIL 10, 1979.

THE B POWER	GENERATION GROUP PRELIMINARY	
To	G. A. MEYER	
òm	L. L. LOSH/J. F. BURROW	BDS 663-5
Cust.	TMI-2	File No. or Ref.
Subj.	CRITERIA DURING ESTABLISHMENT OF NATURAL CIRCULATION	Date 5:40 P.M. APRIL 10, 1979

THE TRANSITION FROM FORCED CORE COOLING USING ONE REACTOR COOLANT PUMP TO NATURAL CIRCULATION WILL BE ACCOMPLISHED OVER A PERIOD OF TIME. HEATUP OF THE CORE COOLANT WILL GENERATE A DENSITY GRADIENT AXIALLY IN THE CORE WHICH WILL PRODUCE THE DRIVING FORCE FOR THE CIRCULATION FLOW. THE TIME REQUIRED TO ESTABLISH NATURAL CIRCULATION IS THEN DIRECTLY RELATED TO THE HEATUP RATE OF THE CORE WHICH GENERATES THE DRIVING FORCE. TO ESTIMATE THIS HEATUP TIME THE FOLLOWING ANALYSIS WAS PERFORMED: (1) IT WAS ASSUMED THAT THERE WAS NO CORE FLOW, (2) THE ENTIRE CORE COOLANT INVENTORY WAS RAISED FROM T_{IN} TO T_{SAT}, (3) NO NET STEAM QUALITY WAS GENERATED, (4) CALCULATIONS WERE BASED ON GROSS CORE AVERAGE CONDITIONS.

FIGURE 1 DEPICTS THE CORE DECAY HEAT GENERATION AS A FUNCTION OF TIME. THE RESULTS OF THIS ANALYSIS ARE SHOWN IN FIGURE 2-4 FOR VARIOUS ASSUMPTIONS ON T_{IN} , SYSTEM PRESSURE AND CORE POWER (TIME AFTER SHUTDOWN). THESE CURVES WERE USED TO ESTABLISH A MAXIMUM TIME REQUIRED TO ESTABLISH NATURAL CIRCULATION.

NATURAL_CIRCULATION RESPONDS TO HIGHER FLOW RESISTANCE BY GOING FURTHER INTO TWO-PHASE FLOW UNTIL THE VAPORIZED DENSITY CHANGE IS SUFFICIENT TO OVERCOME SYSTEM RESISTANCE. WITH DEBRIS BLOCKING A GRID, FLOW WILL PASS LATERALLY AROUND THE BLOCKAGE AND ADEQUATELY INMERSE THE FUEL BEFORE AND AFTER THE BLOCKAGE. IF THE BLOCKAGE DEBRIS ALSO CONTAINS FUEL; THE MAXIMUM TEMPERATURE AT THE BLOCKAGE CENTER WILL BE CONDUCTION LIMITED AND RELATIVELY INSENSITIVE TO THE G. A. MEYER

5:40 P.M. APRIL 10, 1979

MODE OF SURFACE HEAT TRANSFER. THE FLOW PATTERNS IN NATURAL CIRCULATION ARE _____ DIRECTLY RESPONSIVE TO RESTRICTIONS, AND MAY WELL SHOW LOCAL TWO-PHASE TRANSITIONS AND RELATIVELY HIGH VELOCITIES AT PARTIALLY-BLOCKED HOTTER REGIONS.

REDISTRIBUTION OF CORE DEBRIS IS ANTICIPATED WHEN THE PUMPED FLOW IS TERMINATED. CHANGES IN THERMOCOUPLE INCORE TEMPERATURE DISTRIBUTIONS SHOULD BE EXPECTED. NOT ALL THERMOCOUPLE READINGS CAN BE EXPLAINED BY HYDRAULIC PHENOMENA. SOME THERMOCOUPLES, PARTICULARLY NEAR THE CENTER, ARE CURRENTLY INDICATING LOCALIZED HEATING EFFECTS AND ARE NOT MEASURING BULK FLUID TEMPERATURES. SINCE THE PRIMARY CONCERNS DURING THE TRANSITION FROM PUMPED FLOW TO NATURAL CIRCULATION ARE ADEQUATE COVERAGE OF THE CORE AND BULK COOLANT TEMPERATURES BELOW SATURATION TEMPERATURE, IT IS REQUIRED THAT AT LEAST 10 (TEN) INCORE THERMOCOUPLES HAVE READINGS BELOW SATURATION TEMPERATURE FOR THE SYSTEM PRESSURE (FIGURE 5). ADDITIONALLY, NO TWO INCORE THERMOCOUPLES SHOULD EXCEED 800°F. ANTICIPATED CORE TRANSIENTS ARE VERY SLOW. FIGURE 4 SHOWS THAT IT WILL REQUIRE AT LEAST 45 MINUTES TO ONE HOUR TO RAISE THE WATER TEMPERATURE IN THE CORE FROM 200°F TO SATURATION TEMPERATURE FOR DATES BETWEEN 4/10/79 AND 4/17/79. ADDITIONALLY, THE CORE ADIABATIC HEATUP FROM 200°F TO 1000°F EXCEEDS ONE HOUR FOR DATES AFTER 4/12/79. HENCE, NO CORE COOLING PROBLEMS EXIST FOR AT LEAST THE FIRST HOUR OF TRANSITION TO NATURAL CIRCULATION.

THE "HOT-LEG" THERMOCOUPLE SHOULD SHOW A TEMPERATURE INCREASE AS NATURAL CIRCULATION IS ESTABLISHED. TEMPERATURE INCREASES IN THE T_H RESISTANCE TEMPERATURE DETECTOR (RTD) SHOULD BE OBSERVED WITHIN THE BOUNDS OF THE TIME TO SATURATE THE CORE AS SHOWN IN FIGURE 4 (I.E., 45 MINUTES ON 4/10/79; 2.5 HOURS ON 6/6/79). G. A. MEYER

ADDITIONALLY, THE MAXIMUM TEMPERATURE OF THE HOT LEG_RTD_SHOULD NOT EXCEED 250° F FOR PRESSURES ABOVE 500 PSIA AND 180° F FOR PRESSURES NEAR ATMOSPHERIC. THE CORE Δ T SHOULD BE LIMITED TO 150° F.

SUMMARY:

REQUIREMENTS FOR TRANSITION TO NATURAL CIRCULATION:

- INCORE THERMOCOUPLES -- AT LEAST 10 (TEN) THERMOCOUPLES MUST READ BELOW THE SATURATION TEMPERATURE CORRESPONDING TO SYSTEM PRESSURE (FIGURE 5).
 NO TWO INCORE THERMOCOUPLES MAY EXCEED 800°F.
- 2) HOT LET RTD'S -- THE HOT LEG RTD'S MUST INDICATE A TEMPERATURE RISE WITHIN THE TIME REQUIRED TO SATURATE THE CORE (FIGURE 4) AND THE MAXIMUM TEMPERATURE SHOULD NOT EXCEED 250°F FOR SYSTEM PRESSURES ABOVE 500 PSIA AND 180°F FOR PRESSURES NEAR ATMOSPHERIC. THE CORE ΔT SHOULD BE LIMITED TO 150°F.

LLL: JFB:nw

cc: J. S. TULENKO FUEL ENG. UNIT MANAGERS CORE HOT SPOT TASK FORCE

ATTACHMENTS (5 FIGURES)



KEUFFEL & ESSER CO. HADE IN U.S.A.

46 1320

		-
	FIGURE Z	
	SYSTEM PRESSING = 500 pVA	
8	Core	
	1.0 mil 6-6-79 Calendor Doke	
	5510-29	
3		
2	5mw/9-22-79	
1º 10-1-12-	22	
×.		
100	200 300	700
	CORE INIST TEMPERATURE OF	

3.388.000

KEUFFEL & ESSER CO. MAINE IN U.S.A

N. 1

401010

1

.::																	1.	1	17									जन	<u></u>	6	<u></u>	<u> </u>					1.11				
																		F	10	SUR	E	3														-			-		-
								-				<u> </u>	_										_																		
																	-	17										-													1
																												-						T							
																																									1
	+	-5	_م																																						
ī	47																							<u></u>							H										
	11																																								
.,	2	4																				LN	iiii C-1		m	C.R.A	TUR		i Zc	so!	F										
																													/ /												1
	ΪF																	<u> :</u> C	-lC	ĥΞ	160	JER					NV.	6/	417	9											-
	F												i																												-
	1		Ĭ.																																						-
																												1.	2M	51	5/1	17									
	S																																								
		2	0												-				T] 																			
1	Ċ	2								:::!									İİ												lie E	5.	ţ		/22	179					i
					1										1						<u> : i</u>							1 -1-											1.	1	
:1:		1	μo-	-		<u></u>						,																							35	2 1/1	Ŷ	7/		<i>17</i>	
	f																		li																						
	1								liii																																
<u></u>	IF				2														<u>!</u> i																						H
																		ļ																							
					30		₹				5)	<u>5</u>		6	00			7	þ			80	×5			962			10	201			35		1117	200:			135	0	
															S.	246			23																						
																			11				Ī																		
																li i i j												<u>]</u>					iii.								

3

.

KET IN X IN TO THE CENTIMETER IN A MICH.

0

÷

: •

(m)

461510

•

 \bigcirc \bigcirc

	FIGURE 4		
-TIME TE PAIR		- Flaglas	
	E CORE DATER VOLUME 10 1	SAT (NO FLOW)	
$\mathcal{L}_{\mathcal{O}}$			
3			
2			
- <u>-</u>			
155			
8 I I I I I I I I I I I I I I I I I I I			
	DO 1514 203 F TA		
500 20			
230°ETT			
С —			
200			
X			
£ 1.0			
1.0	2.0	3.0	40
	CORE POWER MANYE		
		200/00	alia la
· Carendar Dores 6/6/19	4/39/19	<i>TITI79</i>	4/10/17

•. .

.

KE 10 X 10 TO THE CENTIMETER 10 X 25 CM. REUFFEL & ESSER CO. MANCIN U SA

 \mathbb{C}^{n}

i.

-

0

46 15 10

.

 \mathbf{O}

.

 \bigcirc



cc: J. R. Gloudemans G. A. Meyer P. F. Mamola
J. A. Weimer H. D. Warren C. T. Bembough
R. V. DeMars BDS 663-5
File No. or Ref.
IG Date APRIL 5, 1979
-

Acknowledgement:

I have gathered the following information through conversations with several individuals having experience with thermocouples that have been subjected to extremely high temperatures. I am indebted to P. E. Mamola, R. H. Stoudt, a and Tom Kollie of ORNL for their help and cooperation.

Description of the Problem:

The incore thermocouple design at the TMI-2 core is a grounded junction Chromel-Alumel detector. The wire diameters are approximately 10 mils, the sheath is 62 mils OD Inconel tubing, and the insulation material is Al_2O_3 . I have gathered information on reliability and uncertainty of this type of thermocouple after being subjected to extremely high temperatures (> 2000°F). The problem of gross failure (open circuit, sheath failure, new junction or other failure) would be indicated by no reading or extremely low, erratic reading. No detectors are giving indication of gross failure. Given the survival at present conditions, the prospect for continued operation is excellent. The primary questions are the following:

1. Are the readings accurate?

2. Are the errors in the readings consistent with the hypothesized scenario of the transient?

Decalibration Phenomenon:

A phenomenon observed by Dr. Kollie in thermocouples having experienced extremely high temperatures is a deteriorated state in which the thermocouple gives a stable but inaccurate reading. The effect is called decalibration.

The decalibration error is random but does follow some trends. The primary dependencies are the following:

1.	Sheath diameter	The larger the detector, the less susceptible to decalibration.
2.	Sheath material	Inconel is better than stainless. The decalibration

E. OELKERS

error for Inconel is usually negative. Measured temperature is lower than actual.

3. Temperature,

4.

Decalibration error increases with temperature. (10°C roughly doubles the reaction rate of the mechanism.)

Decalibration error is roughly linear with exposure time.

5. Temperature profile

Time of exposure

Decalibration occurs along the length of the thermocouple. Hence, the error depends on the profile of the elevated temperature and on the profile of a subsequent measurement with the thermocouple.

Other dependencies which are not known specifically but are expected to be small are insulation material, length of detector, and wire diameter.

Experience with smaller diameter detectors (20 mils OD) but similar in other characteristics (grounded junction Chromel/Alumel thermocouple with Inconel sheath) show essentially zero probability of survival at 1100°C for 10 to 100 hrs. without a measurable decalibration. The decalibration error tends to be negative (reading lower than actual) for this test; however, one sample gave a positive error. The magnitude for worst case error (remembered) was -50°C. Larger decalibration errors would be expected for higher temperatures.

The primary mechanism for decalibration is migration of constituents primarily chromium in the detector through vapor phase transfer. The chromel lead loses chromium and the alumel lead gains chromium. Belfab tests indicating little decalibration for 4 hour period at 7000°F are not necessarily conclusive since the temperature gradient of the high temperature state does not simulate the transient environment nor did the test condition simulate the present environment.

Conclusions:

If it can be determined that the thermocouple is reading accurately now (for example, if it agrees with outlet RTD's), this implies that its readings are believable throughout the transient.

If thre is reason to believe a thermocouple is decalibrated, there is a high probability that actual temperature is greater than its indication. Hence, the cluster of high readings should not be disregarded.

Since a high percentage of detectors survived the transient, the maximum temperature did not attain a level for widespread failure.

Recommendations:

- 1. Perform testing simulating transient conditions to determine the temperature threshold for gross failure in TMI-2 design detectors.
- 2. Perform testing to quantify magnitude and direction of decalibration errors for a range of temperatures simulating reactor environment.

TLW:ae

2

THE BABCOCK & WILCOX COMPANY POWER GENERATION GROUP	(4)
To Engineering Operations Manager	
irom J. T. Willse Arapan for TVW	THE-79-179 BDS 662.5
Cust.	File No. or Ref.
Subj. Action Item 143	Date April 6, 1979

This letter to cover one customer and one subject only.

Reference: C. T. Rombough to Engineering Operations Manager, Action Item 143, 4/5/79.

The purpose of this memo is to elaborate on conclusions no. 3 and 4 in the referenced memo. The increase in selected thermocouple readings is no cause for concern. The temperature is still 200°F below saturation temperature. The increased readings are caused by two factors. The first and smallest effect is a 4° increase in the core inlet temperature. The primary cause for the change in thermocouple readings is the change in the flow distribution caused by the shifting debris in the core. This was vividly demonstrated when the Al pump tripped and the A2 pump was started. I would anticipate that some thermocouples would continue to change for several days until the debris redistributes into a stable configuration reflecting the change of coolant pumps.

Conclusion number 4 is inaccurate since resistance readings will show wide variations from thermocouple to thermocouple and also the readings will depend on whether the chromel or alumel wire resistance is being measured. However, if needed, we can state the following:

A test can be performed to determine whether a gross failure of a thermocouple has occurred. For a good thermocouple the resistance between one T/C lead and ground should be approximately 750 ohms while the other lead to ground should measure approximately 300 ohms to ground.

JTW:mp

cc:

F. E. Unit Managers J. S. Tulenko Kululu Shift Technical Header

T A		•	
10 I		· •	
5.90, <u> </u>	Engineering Operations Manager		
rom			ns A
	C.T. Rombough, Fuel Management & Development	Eile Ne	
Cust.		or Ref.	038
<u> </u>	GPU		
	B&W's View of Increasing Incore Thermocouple Readings (Instruction 143)	April 5, 1979	
	This letter to cover one customer and one subject only.		
· • •	As requested in Action Item 143, the increasing thermocoup been reviewed by both NPGD and LRC personnel. These perso included J.B. Andrews, G.A. Meyer, J.A. Weimer, J.T. Mayer E.T. Chulick, P.E. Mamola, R.A. Copeland, J.W. Ewing, H.D. J.G. Brown.	nel have , T.L. Wilson, Warren, and	
	A summary of the pertinent data and their conclusions is a D.H. Roy's response to Bill Lowe.	ttached for	
		· /	
	CTR/dlw (1 1	A . A	
ڊ. • • • •	Bot	lon / m	
<i>€</i> €} :		. 🕻	
•		· · · · ·	
		• •	
			•
			•
		÷	
· · · · · · · · · · · · · · · · · · ·			· · ·
·			
			•
			•

Incore thermocouple data from TMI-2 have been evaluated. As shown below, six of the thirty thermocouples for which we have data have shown a temperature rise of $7 - 33^{\circ}$ F over the past 5 days (117 hours) or 1.4 - 6.8° F per day.

Location	T/C at 0845,3/31	T/C at 0542,4/5	Net Increase (^o F)	Increase Per Day (°F)
130	290	297 . •	7	1.4
13F	298	307 .	9 .	1.8
13H	. 310	320	10	2.1
11G -	· 427	445	. 18	3.7
12F	303	327	. 24	4.9
11L	302	335	33	6.8

Temperature vs time for locations 13F, 12F, and 11L are shown in the attached figure.

The following conclusions have been reached based on this data.

- There is no mechanism which has been postulated that would cause decalibration to the extent shown by the data. Therefore, it is concluded that the thermocouple readings are accurate and that true temperatures are being monitored to ±5°.
 - 2. There is nothing in the fuel, structural materials, or fission products which would cause a chemical reaction that would result in the observed rate of temperature rise.
 - 3. As indicated in the attached map of temperature changes for 30 selected locations, the increasing readings are located preferentially in the core (in the center of the right half). This leads to the most probable explanation that a very gradual flow redistribution is occurring; either increased flow blockage in this region or decreased flow blockage in another region causing temperature increases in this region.
 - . If Met Ed questions the thermocouple readings, a simple test can be performed. The resistance between the T/C lead and ground should be approximately 750 ohms.

C :ATION	. 12/2								<u>)</u>
LOCATION	13 F								
	• • • • • •					A real is a final of the	<u>у</u>		
·····		·····							
····						[- V			
				····					
	······	· · · · · · · · · · · · · · · · · · ·		V				1.	
	· · · · · · · · · · · · · · · · · · ·		N					····	
	12F/								
	2F1		····						
<u> </u>		است. مراجع							
\\	- / , """								
	ļ//								
		• • • • • • • • • •						·	
									· · · · · · · · · · · · · · · · · · ·
<u> </u>		· · · · ·							
								· · · · · · · · · · · ·	
, in 210 	-03/30			نی 	04/03		1211 2400 	1000 -04/26	سنز
		••	•			•	•	•	
			•	•		:			
•	•	•			3		•	. (
		•	,		ð · .		•		

CHANGE IN T/C READING FOR 0845, 3/31 TO 0512, 4/5 0) 2807 8 9 10 11 12 13 14 15 3 5. 2 4 6 289 .A : В +2. +7 -1 D -53 E . -47 -87 -6 F -+24 +9 -20 -18 G +2 -45 -8 -6 +/8 +1 Η -2 0 -302 -/ +10 • K -59 • +4 -133 . Μ -20 -3 +3 Ν • -30 ۰. .::: • Ο 0

POWER GENERATION GROUP	- (5) .
G. A. MEYER, MANAGER, T-H ENGINEERING UNIT	THE-79-171
. TOM I A WEIMER T-H ENGINEERING UNIT EXT 3236	BDS 663-5
Cust.	File Ho. or Ref.
Subj.	Date
RESPONSE TO THERMOCOUPLE REQUEST	APRIL 5, 1979

Past experience with thermocouples show two basic things. First, they track fairly steady when core condition are not changing (ie. 100% steady state conditions). Secondly, they respond to local changes relatively accurate. A one to two degree change in thermocouple reading has occurred many times without any obvious core change (or local change) conditions. Greater deltas than 2°F usually indicate another measurable local or core change.

The two mechanisms for thermocouple changes are obviously power distribution or flow distribution. A few random local changes are usually due to local power changes. A large area group change indicate flow redistribution.

Assuming local flow blockages (in the center of the core a decrease in thermocouple reading would occur if and when the blockage was decreased and if the "hot" conditions were due to local heat sources (ie. fuel pellets) the temperature would decrease as the source burned out. Furthermore, as blockage decreases in one region of the core the outlet flow distribution would tend to flatten causing temperature increases in other portions of the core.

JAW/sgh

cc: J. S. Tulenko FE Unit Managers J. F. Burrow

liction Stim. 143 DISTRIBUTION . С. Т. Комволан (х 3748) ROM FILE NO. OR REF. EASON DATE FOR INCRUASING 4/5/79 10:30 AM I/C THERMICOUPLE READINGS DISTRIBUTION G.A. Meyor J.T. MAYER T.L. WILSON E. T. CHULICK R. N. KUBIK requested_ Don iled response. B+W a de as oconple. The for an I +tached loca read as been Satt that ored record no t Please review this quickly. to at_ day. my desk y you lee -you for you h. , 2

 D. H. ROY D. H. ROY Cust. File No. File No. Subj. REQUEST FOR ESM'S VIEN OF INCREASING INCORE THERMOCUPLE READINGS Date APRIL 5, 1979 THE HAR AND OUR CONCERNS REGARDING SOME THERMOCUPLES SUGALY INCREASING IN TEMPERATURE The responses provided is inadequate for transmission to GPU. We should take the following steps: (1) Report the increases as we see them in the data - assembly location, temperature change per unit time over some time interval. (2) Provide the uncertainty value which we would assign for these loca- tions. (3) Have our radiochemists get in touch with expert fuel material people to determine if there are any break away chemical reactions or any other explanation which might be provided to explain the temperature behavior which is observed. It is not necessary to state that we will continue to monitor thermocouple changes and report them promptly as GPU is also tracking them routinely. D. H. Roy DHR: dmd 	WHITE	R GENERATION GROUP	• • •
D. H. ROY PD5 463 Dust. File No. or Ref. SubJ. REQUEST FOR EAM'S VIEW OF INCREASING INCORE THERMOCOUPLE READINGS Date APRIL 5, 1979 The new or or order of worker of the state	To	ATTINE PRYOR CT	
Eust. File No. or Ref. Subj. REQUEST FOR BAM'S VIEW OF INCREASING INCREASING Date APRIL 5, 1979 Date NOTES TO ANSMER TO BILL LOWE'S REQUEST TO D. H. ROY AT 0735 ON APRIL 4 REGARDING BAM'S IDEAS AND OUR CONCERNS REGARDING SOME THERMOCOUPLES SLOWLY INCREASING IN TEMPERATURE The responses provided is inadequate for transmission to GPU. We should take the following steps: (i) Report the increases as we see them in the data - assembly location, temperature change per unit time over some time interval. (2) Provide the uncertainty value which we would assign for these loca- tions. (3) Have our radiochemists get in touch with expert fuel material people to determine if there are any break away chemical reactions or any other explanation which might be provided to explain the temperature behavior which is observed. It is not necessary to state that we will continue to monifor thermocouple changes and report them promptly as GPU is also tracking them routinely. D. H. Roy No.35 DHR:dmd	· .	D. H. ROY	BDS 663
Subj. REQUEST FOR BAM'S VIEW OF INCREASING INCORE THERMOCOUPLE READINGS Pate APRIL 5, 1979 The number of BILL LOWE'S REQUEST TO D. H. ROY AT 0735 ON APRIL 4 REGARDING BAM'S IDEAS AND OUR CONCERNS REGARDING SOME THERMOCOUPLES SLOWLY INCREASING IN TEMPERATURE The responses provided is inadequate for transmission to GPU. We should take the following steps: (1) Report the increases as we see them in the data - assembly location, temperature change per unit time over some time interval. (2) Provide the uncertainty value which we would assign for these loca- tions. (3) Have our radiochemists get in touch with expert fuel material people to determine if there are any break away chemical reactions or any other explanation which might be provided to explain the temperature behavior which is observed. It is not necessary to state that we will continue to monitor thermocouple changes and report them promptly as GPU is also tracking them routinely. D. H. Roy No SS	Cust.	• • • • • • • • • • • • • • • • • • • •	File No. or Ref.
 NOTES TO ANSHER TO BILL LOME'S REQUEST TO D. H. ROY AT 0735 ON APRIL 4 REGARDING BAM'S IDEAS AND OUR CONCERNS REGARDING SOME THERMOCOUPLES SLOWLY INCREASING IN TEMPERATURE The responses provided is inadequate for transmission to GPU. We should take the following steps: (1) Report the increases as we see them in the data - assembly location, temperature change per unit time over some time interval. (2) Provide the uncertainty value which we would assign for these locations. (3) Have our radiochemists get in touch with expert fuel material people to determine if there are any break away chemical reactions or any other explanation which might be provided to explain the temperature behavior which is observed. It is not necessary to state that we will continue to monitor thermocouple changes and report them promptly as GPU is also tracking them routinely. 	Subj.	REQUEST FOR B3W'S VIEW OF INCREASING INCORE THERMOCOUPLE READINGS	Date APRIL 5, 1979
 NOTES TO ANSWER TO BILL LOME'S REQUEST TO D. H. ROY AT 0735 ON APRIL 4 REGARDING BRM'S IDEAS AND OUR CONCERNS REGARDING SOME THERMOCOUPLES SLOWLY INCREASING IN TEMPERATURE The responses provided is inadequate for transmission to GPU. We should take the following steps: (1) Report the increases as we see them in the data - assembly location, temperature change per unit time over some time interval. (2) Provide the uncertainty value which we would assign for these loca- tions. (3) Have our radiochemists get in touch with expert fuel material people to determine if there are any break away chemical reactions or any other explanation which might be provided to explain the temperature behavior which is observed. It is not necessary to state that we will continue to monitor thermocouple changes and report them promptly as GPU is also tracking them routinely. 	.	This latter to cover and custamer and one subject unly,	• •
 BAM'S IDEAS AND OUR CONCERNS REGARDING SOME THERMOCOUPLES SLOWLY INCREASING IN THEMPERATURE The responses provided is inadequate for transmission to GPU. We should take the following steps: Report the increases as we see them in the data - assembly location, temperature change per unit time over some time interval. Provide the uncertainty value which we would assign for these locations. Have our radiochemists get in touch with expert fuel material people to determine if there are any break away chemical reactions or any other explanation which might be provided to explain the temperature behavior which is observed. It is not necessary to state that we will continue to monitor thermocouple changes and report them promptly as GPU is also tracking them routinely. 	· ·	NOTES TO ANSWED TO BILL LOVE'S DECUEST TO D H POY AT 0735	ON APRIL A REGARDING
 <u>TEMPERATURE</u> The responses provided is inadequate for transmission to GPU. We should take the following steps: Report the increases as we see them in the data - assembly location, temperature change per unit time over some time interval. Provide the uncertainty value which we would assign for these locations. Have our radiochemists get in touch with expert fuel material people to determine if there are any break away chemical reactions or any other explanation which might be provided to explain the temperature behavior which is observed. It is not necessary to state that we will continue to monitor thermocouple changes and report them promptly as GPU is also tracking them routinely. 	•	BAN'S THEAS AND OUR CONCEPNS REGARDING SOME THERMOCOUPLES SI	OWLY INCREASING IN
 The responses provided is inadequate for transmission to GPU. We should take the following steps: Report the increases as we see them in the data - assembly location, temperature change per unit time over some time interval. Provide the uncertainty value which we would assign for these locations. Have our radiochemists get in touch with expert fuel material people to determine if there are any break away chemical reactions or any other explanation which might be provided to explain the temperature behavior which is observed. It is not necessary to state that we will continue to monitor thermocouple changes and report them promptly as GPU is also tracking them routinely. 	, .	TEMPERATURE	
 The responses provided is inadequate for transmission to GPU. We should take the following steps: (1). Report the increases as we see them in the data - assembly location, temperature change per unit time over some time interval. (2) Provide the uncertainty value which we would assign for these locations. (3) Have our radiochemists get in touch with expert fuel material people to determine if there are any break away chemical reactions or any other explanation which might be provided to explain the temperature behavior which is observed. It is not necessary to state that we will continue to monitor thermocouple changes and report them promptly as GPU is also tracking them routinely. 		<u></u>	
 Inc responds provide is indecedent for the transmission to the order in the share take the following steps: (1) Report the increases as we see them in the data - assembly location, temperature change per unit time over some time interval. (2) Provide the uncertainty value which we would assign for these locations. (3) Have our radiochemists get in touch with expert fuel material people to determine if there are any break away chemical reactions or any other explanation which might be provided to explain the temperature behavior which is observed. It is not necessary to state that we will continue to monitor thermocouple changes and report them promptly as GPU is also tracking them routinely. D. H. Roy DHR:dmd 	•	The responses provided is inadequate for transmission to GPI	I. We should take the
 (1) Report the increases as we see them in the data - assembly location, temperature change per unit time over some time interval. (2) Provide the uncertainty value which we would assign for these locations. (3) Have our radiochemists get in touch with expert fuel material people to determine if there are any break away chemical reactions or any other explanation which might be provided to explain the temperature behavior which is observed. It is not necessary to state that we will continue to monitor thermocouple changes and report them promptly as GPU is also tracking them routinely. D. H. Roy DHR:dmd 	•	following stons:	·
 (1) Report the increases as we see them in the data - assembly location, temperature change per unit time over some time interval. (2) Provide the uncertainty value which we would assign for these locations. (3) Have our radiochemists get in touch with expert fuel material people to determine if there are any break away chemical reactions or any other explanation which might be provided to explain the temperature behavior which is observed. It is not necessary to state that we will continue to monitor thermocouple changes and report them promptly as GPU is also tracking them routinely. D. H. Roy DHR:dmd 	• • •	(2) Depart the improvement of the data	
 temperature change per unit time over some time interval. (2) Provide the uncertainty value which we would assign for these locations. (3) Have our radiochemists get in touch with expert fuel material people to determine if there are any break away chemical reactions or any other explanation which might be provided to explain the temperature behavior which is observed. It is not necessary to state that we will continue to monitor thermocouple changes and report them promptly as GPU is also tracking them routinely. D. H. Roy DHR:dmd 	•	(1) Report the increases as we see them in the data - a	assembly location,
 (2) Provide the uncertainty value which we would assign for these locations. (3) Have our radiochemists get in touch with expert fuel material people to determine if there are any break away chemical reactions or any other explanation which might be provided to explain the temperature behavior which is observed. It is not necessary to state that we will continue to monitor thermocouple changes and report them promptly as GPU is also tracking them routinely. D. H. Roy DHR:dmd 	•	temperature change per unit time over some time int	terval.
 tions. (3) Have our radiochemists get in touch with expert fuel material people to determine if there are any break away chemical reactions or any other explanation which might be provided to explain the temperature behavior which is observed. It is not necessary to state that we will continue to monitor thermocouple changes and report them promptly as GPU is also tracking them routinely. D. H. Roy D. H. Roy D. H. Roy 	_	(2) Provide the uncertainty value which we would assign	, for these less.
 (3) Have our radiochemists get in touch with expert fuel material people to determine if there are any break away chemical reactions or any other explanation which might be provided to explain the temperature behavior which is observed. It is not necessary to state that we will continue to monitor thermocouple changes and report them promptly as GPU is also tracking them routinely. D. H. Roy DU35 		(2) Howide the uncertainty value which we would assign	i for chese foca-
<pre>to determine if there are any break away chemical reactions or any other explanation which might be provided to explain the temperature behavior which is observed. It is not necessary to state that we will continue to monitor thermocouple changes and report them promptly as GPU is also tracking them routinely. D. H. Roy DHR:dmd</pre>	9	tions.	
<pre>other explanation which might be provided to explain the temperature behavior which is observed. It is not necessary to state that we will continue to monitor thermocouple changes and report them promptly as GPU is also tracking them routinely. D. H. Roy N635 DHR:dmd</pre>	3	(2) How de the uncertainty value which we would assign tions.(3) Have our radiochemists get in touch with expert fue	el material people
behavior which is observed. It is not necessary to state that we will continue to monitor thermocouple changes and report them promptly as GPU is also tracking them routinely. D. H. Roy N.35 DHR:dmd)	 (2) How de ene uncertainty value which we would assign tions. (3) Have our radiochemists get in touch with expert fue to determine if there are any break away chemical in the second secon	el material people reactions or any
It is not necessary to state that we will continue to monitor thermocouple changes and report them promptly as GPU is also tracking them routinely. D. H. Roy NG35 DHR:dmd)	 (2) However the uncertainty value which we would using tions. (3) Have our radiochemists get in touch with expert fue to determine if there are any break away chemical mother explanation which might be provided to explain 	el material people reactions or any in the temperature
and report them promptly as GPU is also tracking them routinely. D. H. Roy N635 DHR:dmd	3	 (2) Provide the uncertainty value which we would using tions. (3) Have our radiochemists get in touch with expert fue to determine if there are any break away chemical mother explanation which might be provided to explain behavior which is observed. 	el material people reactions or any • in the temperature
DHR: dmd		 (2) Provide the uncertainty value which we would using tions. (3) Have our radiochemists get in touch with expert fue to determine if there are any break away chemical is other explanation which might be provided to explain behavior which is observed. It is not necessary to state that we will continue to monitor. 	el material people reactions or any in the temperature
DHR: dmd		 (2) Provide the uncertainty value which we would using tions. (3) Have our radiochemists get in touch with expert fue to determine if there are any break away chemical mother explanation which might be provided to explain behavior which is observed. It is not necessary to state that we will continue to monite and report them promptly as GPU is also tracking them routing them. 	el material people reactions or any in the temperature or thermocouple changes
D. H. Roy D635	3	 (2) Provide the uncertainty value which we would ussign tions. (3) Have our radiochemists get in touch with expert fue to determine if there are any break away chemical mother explanation which might be provided to explain behavior which is observed. It is not necessary to state that we will continue to monite and report them promptly as GPU is also tracking them routing them to the state that we will contain the state them promptly as GPU is also tracking them routing them to the state that we will contain the state them promptly as GPU is also tracking them routing them to the state that we will contain the state them promptly as GPU is also tracking them routing the state the state the state them promptly as GPU is also tracking them routing the state the state that we will contain the state them promptly as GPU is also tracking them routing the state	el material people reactions or any in the temperature or thermocouple changes hely.
DHR:dmd	3	 (2) Provide the uncertainty value which we would ussign tions. (3) Have our radiochemists get in touch with expert fue to determine if there are any break away chemical mother explanation which might be provided to explain behavior which is observed. It is not necessary to state that we will continue to monite and report them promptly as GPU is also tracking them routing them to the state of	el material people reactions or any in the temperature or thermocouple changes hely.
DHR:dmd		 (2) Provide the uncertainty value which we would ussign tions. (3) Have our radiochemists get in touch with expert fue to determine if there are any break away chemical mother explanation which might be provided to explain behavior which is observed. It is not necessary to state that we will continue to monitor and report them promptly as GPU is also tracking them routing them to the state that we will contain the state them promptly as GPU is also tracking them routing the state that we will contain the state the state the state the state the state the state them promptly as GPU is also tracking them routing the state th	al material people reactions or any in the temperature or thermocouple changes hely.
		 (2) How the the uncertainty value which we would ussign tions. (3) Have our radiochemists get in touch with expert fue to determine if there are any break away chemical mother explanation which might be provided to explain behavior which is observed. It is not necessary to state that we will continue to monite and report them promptly as GPU is also tracking them routine. 	el material people reactions or any in the temperature or thermocouple changes hely.
		 (2) How detend under tarmety value with the world assignations. (3) Have our radiochemists get in touch with expert fuer to determine if there are any break away chemical mother explanation which might be provided to explain behavior which is observed. It is not necessary to state that we will continue to monitor and report them promptly as GPU is also tracking them routing them to the provided to explain th	el material people reactions or any in the temperature or thermocouple changes hely.
		 (2) Horde the uncertainty value which we would assign tions. (3) Have our radiochemists get in touch with expert fue to determine if there are any break away chemical mother explanation which might be provided to explain behavior which is observed. It is not necessary to state that we will continue to monite and report them promptly as GPU is also tracking them routin D. H. Roy DHR:dmd 	al material people reactions or any in the temperature or thermocouple changes hely.
		 (2) Frontide the uncertainty value which we would ussign tions. (3) Have our radiochemists get in touch with expert fue to determine if there are any break away chemical mother explanation which might be provided to explain behavior which is observed. It is not necessary to state that we will continue to monite and report them promptly as GPU is also tracking them routin D. H. Roy 	el material people reactions or any in the temperature or thermocouple changes hely.
		 (2) Horide the uncertainty value which we would ussign tions. (3) Have our radiochemists get in touch with expert fue to determine if there are any break away chemical mother explanation which might be provided to explain behavior which is observed. It is not necessary to state that we will continue to monite and report them promptly as GPU is also tracking them routin D. H. Roy DHR:dmd 	el material people reactions or any in the temperature or thermocouple changes hely.
		 (2) How determine under damer vande winder design tions. (3) Have our radiochemists get in touch with expert fue to determine if there are any break away chemical mother explanation which might be provided to explain behavior which is observed. It is not necessary to state that we will continue to monite and report them promptly as GPU is also tracking them routin D. H. Roy DHR:dmd 	el material people reactions or any in the temperature or thermocouple changes hely.
		 (2) Howard the uncertainty value which we would ussign tions. (3) Have our radiochemists get in touch with expert fue to determine if there are any break away chemical mother explanation which might be provided to explain behavior which is observed. It is not necessary to state that we will continue to monite and report them promptly as GPU is also tracking them routin DHR:dmd 	el material people reactions or any in the temperature or thermocouple changes hely.
		 (2) How determine the under carliery while which we would assign tions. (3) Have our radiochemists get in touch with expert fue to determine if there are any break away chemical mother explanation which might be provided to explain behavior which is observed. It is not necessary to state that we will continue to monite and report them promptly as GPU is also tracking them routine. D. H. Roy 	el material people reactions or any in the temperature or thermocouple changes hely.
		 (2) How determent of the ender carliery while which we would assign tions. (3) Have our radiochemists get in touch with expert fue to determine if there are any break away chemical mother explanation which might be provided to explain behavior which is observed. It is not necessary to state that we will continue to monite and report them promptly as GPU is also tracking them routine. D. H. Roy DHR:dmd 	el material people reactions or any in the temperature or thermocouple changes hely.
•		 (2) Howard one uncertainty while which we would assign tions. (3) Have our radiochemists get in touch with expert fue to determine if there are any break away chemical mother explanation which might be provided to explain behavior which is observed. It is not necessary to state that we will continue to monitor and report them promptly as GPU is also tracking them routine. D. H. Roy DHR:dmd 	el material people reactions or any in the temperature or thermocouple changes hely.

Telecon from Bill Love to D. H. Roy April 4, 1979 Aut 0735

Telecon from Bill Lowe at 0735 informed us that over the past 36 hours some trace in thermocouple readings have been observed, it varies from assembly to assembly with some going up by as much as 9°F. The absolute temperature still is o.k. but they do not like the trend. It could be associated with changes in coolant temperature and or pressurizer level. He requested that we consider various possibilities for this behavior including a break away chemical reaction. We told him that our data for thermocouple readings at the 0523 hour measurement was just coming in, we will take action to determine whether there is a chemical reaction which can account for this and try to corelate with changes in the state of the reactor.

- Signed D. H. Roy

FROM FILE NO. OR REF. ø SUBJ. DATE increace pleady_ pllowin detec 0900 0500 116 3 3 rē. Net T/C_at T/C at LOCATION increace 0500 415 °F) 0900, 3/31 327 24 IZF. 303 445 18 116 427 10 13 H 310 320 NU 33 335 302 13F 9 298 307 297 290 7 13C • . 30 /c c locat ma zous le f 09 4 atta 00 3/31 0500, 50 ween 4 be havior 1. car 917 of the 'n ; ÷ • ÷ . . • .







Evaluate fuel pin contact with Incore thermal couples

The evaluation was performed assuming all the pellets from one grid span are evenly distributed across the upstream grid. Average temperature of the UO_2 mass is $-1500^{\circ}F$. Enough heat is generated to produce boiling in the annulus between the instrument string and the guide tube and possibly some superheat. Heat would be transferred to the instrument string which could be transferred axially by conduction to the thermal couple. This would produce a T-C reading higher than the surrounding coolant. This indicates that it is possible that a conglomerate of pellets with the proper size and location could produce T-C readings in the range of temperatures which are being recorded (100-600°F above coolant temperature).

> C. D. Morgan M. Montgomery Min Street, ' G. A. Meyer Milleyer

To	C. C. ENGLAND	
From	A. B. JACKSON	BDS (
Cust.	TMI-2	File No. or Ref.
Subj.	REQUIRED FLOW FOR CORE COOLING	Date 12:40 A.M. APRIL 10, 1979
Ī	This letter to cover one customer and one subject only.	· · · · · · · · · · · · · · · · · · ·
•	REFERENCES: (1) MEMO, C. C. ENGLAND TO R. B. DAVIS, "ALTE SYSTEM REQUIREMENTS," 7:22 A.M., APRIL 9,	RNATE DECAY HEAT 1979.
	(2) MEMO, G. A. MEYER TO J. D. CARLTON, "MINI LONG TERM COOLING," 1200, APRIL 4, 1979	MUM CORE FLOW -
•	(3) MEMO, A. B. JACKSON TO C. C. ENGLAND, "CO FROM HPI SYSTEM." APRIL 8, 1979	RE FLOW REQUIRED

AS REQUESTED IN REFERENCE (1), THE UNCERTAINTIES INCLUDED IN THE CORE FLOW REQUIRE-MENTS BY T-H HAVE BEEN RE-EVALUATED BASED ON UNCERTAINTIES PROVIDED BY CENTRAL ANALYSIS. UNCERTAINTY DUE TO CORE BYPASS HAS BEEN REMOVED AND THE CORE FLOW REQUIP MENTS FROM REFERENCES (2) AND (3) ARE REPLOTTED ON FIGURES 1 AND 2. THE CONTROL ANALYSIS UNCERTAINTY OF 5.8 TIMES THE CORE FLOW REQUIRED MUST BE APPLIED TO THESE CURVES.

A. B. JACKSON

ABJ:dmd CC: JS TULENKO FEUM





700 600 500 65 Psia, Tc=300 F 200 12510; 220 17 1000 2010, 23001 100 0., 0 20 = 40 60 80 100 170 140 160 160 200 200 200 200 200 200 200 Minamory Core Flore Rayured Jon Low, Term Cooling Decay Heat System 1-100 Reguired = 518 Times Core-Flow

7101 94

Not to X to 10 Int V Tot merel a

46 1512 psia, Tc=3005F 200 6519, 220 4 -1000 0000 23091-WT 12 X 10 TO THE C IMETER 13 X 23 CM 100 0 20 40 60 80 100 120 140 160 180 240 200 240 200 200 Minimum Core Flew Required Decay Heat System Flow Required = Si 8: Times Core Flow 15/70
THE BABCOCK & WILCOX COMPANY POWER GENERATION GROUP		INSI	RUCTION #310
To R. B. DAVIS, CONTROL ANALYSIS, A. L. J.	ACKSON, THERMAL, HYD	RAULICS	
From C. C. ENGLAND, LONG TERM COOLING CCC	fand		8D5 663.
Cust.		File I or Re	io. f.
Subj. ALTERNATE DECAY HEAT SYSTEM REQUIREMENT	TS	Date	TIME: 7:22 P.M. APRIL 9, 1979

R. B. DAVIS' MEMO OF APRIL 8, 1979 RECOMMENDS THAT DECAY HEAT SYSTEM FLOW REQUIREMENTS BE SET AT 5.8 TIMES THE CORE FLOW REQUIREMENT.

I UNDERSTAND THAT THE ATTACHED CURVE FROM THERMAL HYDRAULICS ALREADY CONTAINS. SOME CONSERVATISM (ON THE ORDER OF A FACTOR OF 3) TO ACCOUNT FOR UNKNOWNS IN THE CORE.

I REQUEST THAT YOU REVIEW YOUR CALCULATIONS WITH THERMAL HYDRAULICS TO ASSURE THAT THE "CONSERVATISMS" AREN'T BEING ADDED TWICE.

A D.H. FLOW RATE MUTUALLY AGREED UP ON BETWEEN CONTROL ANALYSIS AND T.H.E. SHOULD BE ESTABLISHED.

PLEASE PROVIDE THIS BY 0800 ON 4/9/79.

CCE/CMW

ATTACHMENT

- / DABCOCK & WILCOX	COMPANY JUN GA	AD/I-S
To		- Ula - Atra
CC ENGLAND	1 Nor or still	in st in
From RB DAVIS	2. M. D. Kuin	120086m 21
Cust. TMI-2	Ner Ner 7.	File Ko. or Ref.
Subj.		Date
. DEALL REMENTS FOR	ALTERNATE DECAY HEAT SYSTEM	APRIL 8 1979 233

REFERENCE: CC ENGLAND, RB DAVIS, SAME SUBJECT, APRIL 5, 1979

IN THE REFERENCE, I RECOMMENDED THE DECAY HEAT SYSTEM FLOW REQUIREMENT BE 3 TIMES THE CORE DECAY HEAT FLOW REQUIREMENT. THIS MEMO REVISES THIS REQUIREMENT TO 5.8 TIMES THE CORE FLOW REQUIREMENT.

IN HY LATEST ANALYSIS, I IMPROVED ON MY CALCULATION TO INCLUDE (1) A BETTER HYDRAULICS MODEL, (2) A HIGHER CORE RESISTANCE (83 $\times 10^8$ psi/(1bs/sec)²) PROVIDED BY PS BARTELLS, AND (3) A CORE BYPASS FLOW OF 27%. THIS NEW DATA RAISED THE REQUIREMENT TO 5.8 TIMES THE CORE FLOW REQUIREMENT. ATTACHED IS GEORGE MEYER'S CORE FLOW REQUIREMENT ON WHICH I ADDED A NOTE ON THE DECAY HEAT SYSTEM FLOW REQUIREMENT.

THE DELTA P (FROM THE CORE FLOOD NOZZLE ACROSS THE REACTOR VESSEL AND UP TO THE DECAY HEAT DROP LINE) IS STILL NEGLIGIBLE (APPROXIMATELY .02 PSIA)

;js

Reference 5	$(\overline{7})$
THE BABCOCK & WILCOX COMPANY	cc: D. A. Farnsworth
POWER GENERATION GROUP	R. H. Stoudt
G. A. MEYER, FUEL ENGINEERING	RECEIVED.
From	APR101979
J. R. GLOUDEMANS, THERMODYNAMICS UNIT, TECHNICAL STAFF	S. A. MEYER BDS 663.5
Cust.	File No. or Ref. 845-7952-01
Subj.	Date
COOLDOWN PRESSURE	APRIL 10, 1979

COOLDOWN PRESSURES FROM ATMOSPHERIC PRESSURE TO \sim 1800 PSIA HAVE BEEN CONSIDERED. THERE ARE MANY SYSTEM RESPONSES RELATED TO PRESSURE, THE ADVANTAGES OF COOLING AT HIGHER (UP TO \sim 1800 PSIA) OR LOWER (DOWN TO \sim 15 PSIA) PRESSURES ARE:

1. ADVANTAGES OF COOLING AT HIGHER PRESSURE

- a. GREATER MARGIN TO SATURATION TEMPERATURE.
- b. LESS STRAIN ON (OPERATING) RCP's.
- c. BECAUSE OF DECREASED EXPANSION OF FLUID DURING VAPORIZATION (SEE ATTACHED FIGURE), DECREASED FUEL OR FUEL-DEBRIS DISLOCATION DUE TO THE HEATING AND VAPORIZATION OF TRAPPED WATER.

2. ADVANTAGES OF COOLING AT LOWER PRESSURE

- a. BECAUSE NATURAL CIRCULATION IN RESTRICTIONS AND/OR AT "HOT SPOTS" MAY REQUIRE VAPORIZATION TO ACHIEVE THE NECESSARY STEADY-STATE DRIVING HEAD, AND VAPORIZATION EXPANSION INCREASES WITH DECREASING PRESSURE (SEE ATTACHED FIGURE), LOWER PRESSURE INFERS MORE ADEQUATE COOLING OF THE MORE-RESTRICTED FLOW REGIONS IN THE CORE.
- b. POSTULATING NATURAL CIRCULATION AND VOIDING AT CORE-FLOW RESTRICTIONS AS IN
 "2.a", AND NOTING THE DECREASE IN SATURATION TEMPERATURE WITH PRESSURE,

THE (FUEL) DEBRIS OR FUEL IN THE STARVED REGION IS AFFORDED A LOWER SURFACE TEMPERATURE (WITH LOWER PRESSURE).

c. LESS PRESSURE-INDUCED STRESS ON BOUNDARY COMPONENTS.

d. LESS BLOWDOWN (TO ATMOSPHERIC) LIKELIHOOD AND STRESS.

c. FACILITATED SHIFT TO THE LOWER-PRESSURE DECAY-HEAT-REMOVAL SYSTEM.

I AM CERTAIN THAT LONG-TERM COOLING SHOULD <u>NOT</u> BE ACCOMPLISHED AT THE HIGHER PRESSURES CONTEMPLATED, 1000 to 1800 PSIA. THE ONLY SIGNIFICANT ADVANTAGE (1a), IS OUT-WEIGHED BY ITS COUNTERPART (2b); i.e., RAISING PRESSURE RAISES T_{SAT} AND DIRECTLY RAISES THE SURFACE TEMPERATURE OF THOSE FLOW-RESTRICTED DECAY-HEAT REGIONS WHICH REQUIRE BOILING FOR THEIR HEAT TRANSFER MECHANISM.

WHILE RCP'S ARE OPERATING, I RECOMMEND THE LOWER EAND OF THE CURRENT PRESSURE RANGE, i.e., $\sim 550 \pm 50$ PSIA. PRESSURE SWINGS SEDULD BE AVOIDED. (COOLDOWN SHOULD BE VERY GRADUAL). WHEN "COOLED DOWN" (TO APPROXIMATELY 100-200 F), AND WHEN RCP'S ARE NO LONGER AVAILABLE OR ARE NOT DESIRED FOR BACKUP, SYSTEM PRESSURE SHOULD BE SLOWLY REDUCED TO APPROXIMATELY 100 PSIA ($T_{SAT} \sim 328$ F). THIS LOWER PRESSURE INCREASES THE DRIVING HEAT AT VOIDING LOCATIONS AND DECREASES THE SURFACE TEMPERATURE OF BOILING-LIMITED FUEL, WHILE MAINTAINING MORE THAN 100F "MARGIN" TO SATURATION.

S. R. Gloudemans

VERIFIED 4/10/79 by

D. A. Farnsworth pereres Herdeaus for DISF



้ โHE BA POWER	BCOCK-& WILCOX COMPANY GENERATION GROUP	B
To	G. A. MEYER, MANAGER, THERMAL HYDRAULIC ENGINEERING UNIT	THE-79-193
From	J. H. J. J. H. SONES, THE UNIT, EXT. 3239	BDS 66:
Cust.	TMI2	File No. or Ref.
Subj.	ADIABATIC HEATUP RATES	Date APRIL 10, 1979

This letter to cover one customer and one subject only.

FIGURE 1 SHOWS THE ADIABATIC HEATUP RATE AS A FUNCTION OF TIME IN DAYS AFTER THE LOSS OF FEEDWATER EVENT. THIS CURVE ASSUMES INSTANTANEOUS CORE UNCOVERAGE (NO HEAT REMOVAL FROM THE FUEL). THE CALCULATION WAS PERFORMED FOR A FUEL ROD ASSUMED TO BE INTACT.

FIGURE 2 SHOWS THE TIME IN HOURS TO HEAT THE FUEL FROM 200°F TO 1000°F USING THE HEATUP RATES FROM FIGURE 1.

FIGURE 3 SHOWS THE DECAY HEAT (CORE POWER) AS A FUNCTION OF TIME (SEE REFERENCE).

REFERENCE: MEMO, J. R. BURRIS TO J. D. CARLTON, "DECAY HEAT CURVE," APRIL, 2, 1979, NSS-6.

JHJ/CDB

CC: J. S. TULENKO F.E. UNIT MANAGERS CORE HOT SPOT/FLOW BLOCKAGE TASK FORCE Q/A Both method and calculations have been independently checked and found to be correct. SThur T. Chain 4/10/79



-1.8 1.6 461510 10 60 HOE 10 X 10 TO THE ENTIMETER 18 X 25 CM -----30 10 daus 4/22 4/27 Calendar time (month/day) 4/17 \bigcirc Time to heat up trom 200°F to 1000°F (Asiabatic) jure 12 C;

V.H.J.

ł

	د_؟	د یا دوروند در از میرو در از میرو مراجع از میرو در میرو از میرو در میرو میرو میرو میرو میرو میرو میرو میر	, ιως mantip v an γ	• • •		· . · ·	a jara	
		•		·····			·	· •
			TmT-5 G	IGURE 3	HEAT IS. TI	715		·ð
6	0							
		V						
	D-							
- T MV								
5-4-	0							
nod								
203	0							
	0.							
1,	0							
0,	.0							
	0		20	30	40	60 Time do	70 6 ^S	30
		4/7	1/17 4	127	5/7 5/17	5/27	culto la	/13

THE BABCOCK & WILCOX COMPANY POWER GENERATION GROUP PRELIMINARY	
To G. A. MEYER	$\left[\begin{array}{c} 0\\ 0\end{array}\right]$
From P. J. HENNINGSON Faul & Deringer	BDS 663.5
Cust.	File No. or Ref.
Subj. INCREASED T.C. READINGS DUE TO PROXIMITY OF FUEL PARTICULATES	Date 5:30 P.M. APRIL 10, 1979
This later a constant and an utility all	

REFERENCE: CORE CONDITION TASK FORCE TO J.S. TULENKO, "CURRENT ASSESSMENT OF CORE CONDITION, 4/7/79 (1800)," 4/7/79 - 7:48 P.M.

ONE POSSIBLE EXPLANATION OF THE INCREASED T.C. (LOCATED IN UEF'S) READINGS IS THE ACCUMULATION OF UO₂ FRAGMENTS IN AND AROUND THE MIXING CUP. THESE ELEVATED TEMPERATURES, RANGING FROM $\sim 100^{\circ}$ F TO $\sim 190^{\circ}$ F ABOVE THE COOLANT TEMPERATURE, ARE IN THE CENTRAL PORTION OF THE CORE. ACCORDING TO THE REFERENCE, THIS IS THE POSITION OF THE CORE ASSUMED TO HAVE THE GREATEST DAMAGE.

THIS POSSIBILITY WAS INVESTIGATED ASSUMING UO₂ PARTICULATES WERE WITHIN THE MIXING CUP AND AT RADII OF 1/2 IN, 1 IN, 2 IN, 3 IN, AND 4 IN. AXIAL CONDUCTION AND CONVECTION WERE NEGLECTED (GROSS FAILURE).

THE RESULTS ARE SHOWN IN THE ATTACHED FIGURES. FIGURE 1 SHOWS THE TEMPERATURE DIFFERENCE (ΔT (F°)) EXISTING BETWEEN THE I.D. OF THE MIXING CUP AND THE O.D. OF THE INSTRUMENT STRING ASSUMING ENTRAINED UO₂. THE TEMPERATURE RISE THROUGH THE UO₂ IS SMALL FOR ALL TIMES. FIGURE 2 SHOWS THE AFFECT OF VARYING AMOUNTS OF FAILED FUEL OUTSIDE THE MIXING CUP. THE TEMPERATURE DIFFERENCE (ΔT (F°)) IS FROM THE SURFACE TO THE T.C. WELL SURFACE. (THE ONE INCH WIDTH OF UO₂ OUTSIDE THE T.C. WELL IS SHOWN ON FIGURE 1 FOR COMPARATIVE PURPOSES.)

IT IS POSSIBLE FOR THE ELEVATED T.C. READINGS TO BE SOLELY DUE TO LARGE AGGLOMERATES OF FUEL PARTICULATES SURROUNDING THE MIXING CUP. FURTHER CREDENCE TO THIS THEORY ARISES FROM THE CHANGE IN T.C. READINGS WHEN THE A-1 PUMP TRIPPED. THEREFORE, ANY DECISIONS UPON CHANGES IN CORE CONFIGURATION SHOULD NOT BE MADE SOLELY ON THE BASIS OF INCORE THERMOCOUPLE READINGS.

PJH:nw

CC: J. S. TULENKO FUEL ENG. UNIT MANAGERS CORE HOT SPOT TASK FORCE

57-9
UD2 WILDE TIC, WELL
EZ 105 7
the second

.

40 14/U

- <u>-</u>

2

a,

ניא 🛶 אנוטו וצבר א באבולי 🗤 אמניא שאז

.

.

.

. .

AT THORSE AND RELATED	170
between the op. or	A ID
4 width	
Ζ' ω: τ	H-102
2.0. 9. 6.2 2.0 1.0 2.0 1.0 2.0 1.0 2.0 1.0 2.0 1.0 2.0 1.0 2.0 1.0 2.0 1.0 2.0 1.0 2.0 1.0 2.0 1.0 2.0 1.0 2.0 2.0 2.0 2.0 2.0 2.0 2.0 2.0 2.0 2	
-Time /Free StritDon's COAPES	
	· · · · · · · · · · · ·
	•
Le le le le le le le le le le le le le le	

•••

.

• •

1014104

ج • .

a sum heat fan is securit. Fân is ein

HE BABC	OCK & WILCOX COMPANY	
POWER GEI	NERATION GROUP PRELIMINARY	(10)
DIS DIS	STRIBUTION	
rrom J.	A. WEIMER/R. L. HARNE	BDS 663-5
Cust. TMI	1-2	File No. or Ref.
Subj. BOI	ILING CONDITIONS IN CORE	Date APRIL 1, 1979
This	letter to cover one customer and one subject only.	1 <u></u>

The following curve (and attached calculations) shows estimated time required to bring the water in the core to saturation temperature at 300, 600 and 1000 psia from its present 280°F energy level. This calculation assumes a no-flow condition with 161" of stagnant coolant available for heat transfer. A second calculation was made to determine additional time required to vaporize the coolant such that active fuel will be exposed to steam.

JAW/RLH:cmw *Attachment

625



46 1510

Kot Wall N Inte Manual an 10 A 41

-NIE BABCOCK 8 POWER GENERAT	WILCOX COMPANY	Netconce 2		
To J. D. C.	ARLTON, PLANT DESIGN		*. .*	THE-79-162
-om G. A. M	EYER, MANAGER, T-H E	NGINEERING UNIT	(3218)	BDS 663-5
Cust.				File No. or Ref.
Subj. MININUM	CORE FLOW - LONG TE	RM COOLING		Date Time 1200 APRIL 4, 1979

Reference:

86-1100401-00, "Minimum Core Flow - Long Term," April 2, 1979, L. L. Losh.

The attached figure expands upon the information provided in the reference to provide minimum long term cooling flow requirements for various proposed operating conditions. Each of the curves presented accounts for core blockage by the application of a safety factor of 3.0 to the calculated flow requirement. The curves provided are essentially the same as those determined this morning by L. L. Losh and J. R. Bohart, thus providing a QA verification of their analysis.

10 Mar

GAM/sgh

cc: J. S. Tulenko⁹⁶²⁷ FE Unit Managers C. Parks

Reference 1

1400 1360 12:00 1100 THE BOOKE MAX Pare 200 prio His 80 00=45iA; ?2= 0 PTIA 27.0 .10 50 4:11-7-20 Te 30 70 00 40 60 80 100 120 140 160 180 200 220 240 200 200 Minimum Core Flow Required Ler Licing Lerin Ccoling

B

D. WADE IN

M"LE KEUFFEL & ESS

Figure 1.

THE BABCOCK & WILCOX COMPANY POWER GENERATION GROUP PRELIMINARY	
To de contraction de la contra	(12).
From R.M. HIATT - THERMAL HYDRAULIC ENGINEERING	THE-79-195 BDS 663.5
Cust. TMI-2	File No. or Ref.
Subj.	Date ·
CORE FLOW DISTRIBUTION FOR ONE PUMP AND TWO PUMP OPERATION	APRIL 10, 1979
This letter to cover and customer and one subject only.	

ONE OF THE IMPORTANT CONSIDERATIONS IN ANALYZING THE TMI-2 CORE BLOCKAGE IMPACT ON CORE COOLING IS THE FLOW DISTRIBUTION IN THE CORE. A DETERMINATION OF CORE INLET FLOW DISTRIBUTION FOR ONE PUMP OPERATION WITHOUT BLOCKAGE WAS BASED ON A REVIEW OF THE VESSEL MODEL FLOW TEST (VMFT) DATA AND ENGINEERING JUDGEMENT AS FOLLOWS:

THE TRANSFER OF MASS CAN BE MODELED SIMILAR TO ELECTRIC CIRCUITRY. THE FLOW PATHS CAN BE REPRESENTED BY A SYSTEM OF RESISTANCES AND THE FLOW WILL SELECT THE FLOW PATH IN SUCH A WAY TO EQUALIZE THE PRESSURE DROP ACROSS THE SYSTEM. THUS, FLOW HAS A "LOOK AHEAD" CAPABILITY THAT TENDS TO EQUALIZE THE POTENTIAL (Δ P) ACROSS A SYSTEM OF RESISTANCE. THE FLOW CHANNELS THROUGH THE CORE CAN BE VIEWED AS A SYSTEM OF RESISTANCES. BASED ON THIS PRINCIPLE, ASSUMING THAT RATE OF CHANGE OF MOMENTUM FROM COLD LEG INLET TO HOT LEG OUTLET 'IS THE SAME, AND AN INSPECTION OF THE VNFT INLET FLOW FACTORS CAN BE USED TO IDENTIFY THE FLOW DISTRIBUTION AT THE CORE INLET FOR ONE PUMP OPERATION.

FIGURE 1 ILLUSTRATES THE CORE INLET FLOW FACTORS FOR 4 PUMP OPERATION FOR THE 177 FA PLANT. SUMMARIZED ON FIGURE 1 ARE THE AVERAGE FLOW FACTORS FOR EACH QUADRANT. THE OUTLET PIPE IS LOCATED BETWEEN QUADRANTS A1 AND A2 G.A. MEYER

AND BETWEEN B1 AND B2. THUS, WITH BOTH LOOPS OPERATING THE RESISTANCES ACROSS THE CORE FOR EACH QUADRANT WOULD BE EXPECTED TO BE ABOUT THE SAME. FIGURE 1 ILLUSTRATES A SLIGHT BIAS TOWARDS QUADRANTS A1, A2, AND B2... THIS BIAS IS PROBABLY DUE TO FABRICATION TOLERANCES.

FIGURE 2 ILLUSTRATES THE CORE INLET FLOW FACTORS FOR TWO PUMP OPERATION. NOTE THAT THE OPERATING PUMPS AL AND BL ARE ARRANGED IN OPPOSITE QUADRANTS. THE SUMMARY FLOW FACTOR FOR EACH QUADRANT AGAIN ILLUSTRATES A RELATIVELY. UNIFORM FLOW FOR THE QUADRANTS WITH A SLIGHT BIAS TOWARDS THE QUADRANTS CON-TAINING THE OPERATING PUMPS. NOTE THAT THE OPERATING PUMP COMBINATION IS A TWO LOOP OPERATION. THEREFORE, THE RESISTANCE ACROSS EACH QUADRANT SHOULD BE ABOUT THE SAME WITH THE RESISTANCES HIGHER FOR THOSE CHANNELS FARTHEST FROM THE PUMP AND FARTHEST FROM THE OUTLET PIPING. HOWEVER, THE MOMENTUM OF THE FLOW DISCHARGED INTO THE CORE MAY BE SUFFICIENT TO OVERCOME LATERAL CORE RESISTANCES IN THE LOWER PLENUM. THIS IS ILLUSTRATED IN FIGURE 3.

FIGURE 3 SHOWS THE CORE INLET FLOW DISTRIBUTION FOR A TWO PUMP OPERATION A2, AND B2. IN THIS INSTANCE THE TWO PUMPS ARE NOT OPPOSING. NOTE THAT BOTH LOOPS ARE OPERATING. THUS, THE RESISTANCE ACROSS EACH QUADRANT ARE ABOUT THE SAME. HOWEVER, AS MENTIONED PREVIOUSLY, THE LATERAL MOMENTUM OF THE FLOW DISCHARGED INTO THE LOWER PLENUM FORCES FLOW TO THE ADJACENT QUADRANT WITH A2 AND B2 HIGHER IN INLET FLOW THAN A2 AND B2 CONTAINING THE PUMPS.

FIGURE 4 ILLUSTRATES THE CORE INLET FLOW DISTRIBUTION FOR A 1 LOOP 2 PUMP OPERATION (A1 AND A2). THE INLET FLOW FACTORS SHOW A BIAS WITH QUADRANTS A1 AND A2 HIGHER IN FLOW. THIS SUGGESTS THAT THE RESISTANCE OF THE CORE QUADRANTS FOR THE CLOSED LOOP IS HIGH OVERCOMING THE LATERAL MOMENTUM OF THE G.A. MEYER

DISCHARGED FLUID AND RECEIVES LESS FLOW. FIGURE 4 SHOWS THAT ABOUT 4% MORE FLOW ENTERS LOOP A CORE QUADRANTS THAN ENTERS LOOP B QUADRANTS. WHEN VIEWED WITH THE INFORMATION OF FIGURE 3, IT IS BELIEVED THAT THE QUADRANTS B1 AND B2 HAVE A HIGHER RESISTANCE OVER THE COMPLETE LENGTH OF THE CORE. THIS OCCURS DUE TO THE "LOOK AHEAD" CAPABILITY OF THE COOLANT WHICH SEES THE CLOSED LOOP AND THE LATERAL RESISTANCE BETWEEN QUADRANTS B1 AND B2 AND THE OUTLET PIPING OF LOOP A. THEREFORE, IT IS CONCLUDED THAT A COMBINATION OF FIGURE 3 AND FIGURE 4 IS THE MOST REPRESENTATIVE OF ONE PUMP OPERATION. FROM FIGURE 3, THE QUADRANT ADJACENT AND IN THE SAME LOOP WILL BE BIASED ABOUT (1.5 - 2.5%) HIGH IN CORE INLET FLOW. THE FLOW FACTORS SHOWN IN FIGURE 5 ARE RECOMMENDED FOR ANALYZING THI-2 ONE PUMP CORE INLET FLOW CONDITION.

RMH/FFA

CC: F.E. UNIT MGRS. J.S. TULENKO CORE HOT SPOT TASK FORCE

ste °

-	•	 			· ·	•			7-	F · ·	ন্দ	TRESS	·	
•	••	•	F	ig 1		•	•	•	• •				•	
	•	SI L	PND OCA	STR TLOI	ING 45 -	NUM 177	IBE F FA	S A COI	ND RE	· · ·		. ¥	STRIN	ig ric
•	Az	Ave=1	.0/03		.937	.890	.943	.967	.970		• •	•	AL.	Loui-
·		••	.963	1.05	.983	31 .967	30 .983	.977	.993	.960	.960		////	כסייייו
	•	.953	1.017	1.0/0	.977	1.04	.983	.997	1.073	1.000	1.010	57. 987.	1111	•
•	.980	1.020	.990	33 1.120	1.027	1.017	1:040	1.037	27 1.030	1.000	1.080	1.013	-98 7	
ser sources	.987	1.0/0	34	1.097	1.080	1.040	1.027	5 1.070	1.037	26 1.070	.987	.993	1.043	
.410	.940	=5 .033	1.067	1.140	1.043	1.000	1.023	.970	1.140	.990	2.4 1.04 <u>3</u>	1.000	1.023	.95:
.950	.990	.957	1.083	.973	ь 1.037	1.017	1.007	3 1.017	1.093	25 .11 7	1.010	.993	.973	.98:
893	.963	1.120	.930	10 1.057	<i>.</i>	1.083	1-107	2.	1.053	.920	.987	. 980	.970	.96:
91.7	.963	1.000	1.120	۱۱ 1.143	1:000	1.097	.997	1.033	1.037	۱۹ 38.3.1	20 1.033	.923	1.017	1.0/:
883	38 .940	39 .980	1.063	1.040	12 1.070	1.027	1.070	.977	.957	18 1.000	983	50 -967	1.007	.883
	.940	415 .977	1.110	1.170	1.057	13 1.073	1.010	16 .950	17 1.037	.930	1.000	1.000	.960	
•	.900	.957	41 993	1.117	.1/0	1.033	14 .947	15 .973	1.000	.970	.970	.933	.900	•
		.9.77	.930	112 .980	43 .913	1.050	1.070	1.017	47 .923	.933	48 .89 <u>.</u> 3	.947		•
	1		.900	.990	.940	.957	.980	.970	.94D	.937	.907			•
	Br	Ave=1.0	0597		.910	45 957	.9/0	.920	46 897	•	•	ļ	Br.	7244
۰	2	3	4	5.	6	7	8	9	10	11	12	, 13	14	15
DARR		· · · · · · · · · · · · · · · · · · ·		* *					•	JJ)11 Ho.			

	• ••		•1 	· · · ·	· ·-	·	• •• • • • • • •	• • • •	· - ·		570	Poses	<u></u>	
. 5	•	• •	••••	•	Fig.	· · 2	· •.•	`````		•		116255	· ·	
•	•	S L	PND .OCA	ST R T I O	ING NS -	NUM 177	IBE F	RS A	ND RE	•	· ·	к 	STRIN	IG NO.
•.	Az	•	•		.920	.907	.970	1.06	1.070] .	•		, A'z	•
Av	le=_99	62	.933	1.020	.973	31 .907	30 .987	.993	1.007	1.020	1.037		A	le=1.01?
:		.960	.987	.980	32. 943	1.040	1.003	24 1.030	28 1.033	1.043	1.090	52 1.050	*****	-
	.940	.997	.930	33 1.097	1.023	.997	1.047	1.037	27	.957	1.170	1.093	51 .987	•
· · ·	.94	.983	34 1.043	1.063	1.067	1.067	1.040	1.083	1.017	26 1./0 _. 7	.990	1.023	1.037	accesor,
723	.92	1.003	1.050	1.097	1.067	.983	.973	.967	1.02.0	1.000	1.033	.980	.99.0	.923
780	.97	.967	1:053	.970	.987	1.047	1.040	1.017	1.087	1-137	1.007	.94.0	.967	.933
	.930	1.067	.893	1.070	1.1.03	1.113	1.097	1.017	1.023	9/0	.970	.933	.950	.595.
397	.953	.960	1.123	.11 1.083	.993	1.127	1.077	1.053	1.057	19 .103	20 1.023	.953	.960	.910
34.3	30 .930	.950	1.057	1.037	12 ./37	1.033	1.090	1.04-3	.993	18 1.037	1.040	50 .923	.950	.837
•	.923	1.013	1.097	1.153	1.040	. 13 1.087	1.023	.970	1.057	.943	1.063	1.003	.920	-
•	.910	.963	41 1.0/0	1.073	1.090	1.037	.963	.990	1.043	.497	.993	.890	.863	•
	•	.973	.937	42 .983	43 .927	1.033	1.083	1.023	47 .9/0	.970	40 .870	:933		•
	2		.920	1.017	.960	.943	.960	.963	.9.27	.920	.897	~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~	` В.	
Av	12 e= . 00	6333			.953	.980	.933	.930	46 883.	•		Ave = .97277		
1	• 2	3	Ļ	5	6	7	8	9	10	11	12	13	14	15

`:

RC PRESS Fig. 3 STRING NO. NUMBERS AND X SPND STRING 177. FA CORE LOCAT.IONS . Ave = 1.04098 Ave = .983 .977 1.000 1.077 1.063 1.040 Az AI 1.023 1.140 1.050 1.017 1.047 .980 .930 .960 .967 1.023 1.103 1.060 1.020 1.040 1.000 1.057 1.043 1.003 .977 .943 1.013 1.097 .980 1.163 1.033 1.000 1:080 1.010 1.000 .953 1.077 1.017 .910 1.0/0 1.027 1.133 1.080 1.077 1.070 1.060 1.040 .960 1.033 .933 .960 .970 990 1.033 1.057 1.103 1.130 1.010 .950 .953 1.123 .953 .957 .967 .980 .893 963 1.007 1.030 1.047 1.000 1.003 1.053 .993 .947 1.037 1.073 .960 .913 .910 .897 000 37 .993 1.087 1.107 1.120 1.070 .973 .960 .890 .940 .913 .950 .94-7 1.097 263 7 1.120 .983 1.153 1.047 1.030 1.047 1.070 1.013 .937 .94.0 .935 710 .953 .977 1.143 20 50 .950 1.093 1.060 1.153 1.003 1.080 .980 .983 1.033 1.013 .920 .937 823 11.2 .930 .997 1.060 1.153 1.023 1.087 1.027 .967 1.073 .943 1.043 .990 .917 .913 .950 .983 1.127 1.103 1.057 .963 1.003 1.057 1.003 1.000 .883 .857 .897 42 47 .930 .963 .940 1.063 1.103 1.037 .913 .977 .887 .943 .927 .910 1.017 .953 .977 .983 .980 .930 .907 .907 13, Β, Ave = . 91:53 Ave = 1.00856 .910 .960 .920 .923 .850 4 5 7 3 6 · 2 8 9 10 14 15 13 11 12 OBER

	CI	•		4		• •		•	1				
		PND OCA	57 R T-1-0	1NG <u>NS</u> -	NUN177	1BE F	RS A	ND RE		•••		STRIE	IG NC
Ave	=1.048	39		.950	.953	.963	1.010	1.020		•	•	Av	e=1.0
AZ	• ••	.977	1.040	1.023	31 .963	30 .020	.997	.993	1.007	1.027		A	1
•	1.0/0	1.053	1.040	32 1.0/3	1.050	1.020	1.050	28 1.040	1.030	1.050	57. .033		
1.033	1.060	1.023	33 1.170	1.077	1.027	1.070	1.057	2'' 1.040	1.003	1.157	1.100	51 1.027	
1.0/0	1.063	34 1.090	1.100	1.09.7	1.090	1.063	5	1.030	26 . 23	1.017	1.040	1.030	
1.037	25 .0/3	1.080	1.120	1.147	6	1.043	1.073	1.087	1.083	2.4 1.05D	23 1.080	1.1.2.0	1.07
3:5 1.090	1.077	1.093	1.030	ь 1.053	1.077	1.037	1.003	1.043	25 1.093	1.017	ег 1.047	1.047	1.04
1.013	1.040	.983	.997	1.040	1.027	1-060	?. 1.0/3	.867	.877	.817	. 910	.953	.9\$3
1.053	1.000	1.140	۱۱ 7 20.1	1-030	1.070	1.033	1.033	1.040	19 1./00	20 1.037	1.050	1.033	1.07
1.013	1.013	1.073	1.073	12 .11 7	1.083	1.077	1.027	1.007	18 1.043	1.087	50 1.043	1.057	1.00
1.0/3	1.060	1.067	1.067	1.037	13 1.043	1.043	16	17 1.049	.477	1.010	1.013.	49 .997	
.997	1.020	1.003	1.050	1.053	.950	.877	.863	.950	.853	.877	-833	.830	•
	.8/3	.827	-817	.770	.840	.873	.857	47 •757	-683	48 • 7! 7	. 78 7		• -
- Br		.730	.793	.777	.770	.8/0	.863	.827	.853	-867		·Bz	
=.97	314	· · · ·		.8:3	15 900	.837	.837	"16 -797	····			Ave =	.9385
2	3	<u>ц</u> г.	5	6	7	8	9	10	11	12	13	14	15
	AP 1.033 1.0/0 1.0/0 1.0/3 1.0/3 1.0/3 1.0/3 1.0/3 1.0/3 .997 .977 .2	AP 1.0/0 1.033 1.060 1.0/0 1.063 1.0/0 1.063 1.0/0 1.063 1.0/3 1.0/3 1.0/3 1.0/0 1.0/3 1.000 30 39 1.0/3 1.000 30 39 1.0/3 1.000 30 39 1.0/3 1.000 30 39 1.0/3 1.000 30 39 1.0/3 1.000 30 39 1.0/3 1.000 39 39 1.0/3 1.020 .8/3 32 =.97314 2 3	AP2	Ap .977 1.040 \cdot 1.0/0 1.053 1.040 \cdot 1.0/0 1.053 1.040 \cdot 1.0/0 1.053 1.040 \cdot 1.0/0 1.053 1.040 \cdot 1.0/0 1.073 \cdot 1.0/3 1.070 \cdot 1.0/3 1.070 \cdot \cdot 1.0/3 1.070 \cdot \cdot 1.077 1.073 1.030 \cdot	AP .977 1.040 1.023 $1.0/0$ 1.053 1.040 1.023 1.033 1.060 1.023 1.170 1.077 1.070 1.063 1.23 1.170 1.077 1.070 1.063 1.23 1.170 1.077 1.070 1.063 1.260 1.100 1.097 1.070 1.063 1.20 1.147 335 1.070 1.030 1.053 1.070 1.073 1.030 1.053 1.070 1.073 1.030 1.053 1.073 1.073 1.073 1.040 1.053 1.000 1.140 1.057 1.030 1.073 1.073 1.073 1.073 1.177 1.073 1.060 1.067 1.057 1.037 1.073 1.060 1.067 1.057 1.037 1.073 1.073 1.073 1.057 1.053 1.073 1.060 1	App .977 1.040 $(.023)$.963 1.010 1.053 1.040 $(.023)$ $.963$ 1.033 1.060 1.023 1.040 1.073 1.050 1.033 1.060 1.023 1.170 1.077 1.027 1.010 1.063 1.070 1.077 1.027 1.010 1.063 1.070 1.0977 1.027 1.010 1.063 1.070 1.0977 1.027 1.070 1.073 1.050 1.120 1.147 1.060 1.073 1.073 1.030 1.077 1.027 1.070 1.077 1.073 1.073 1.073 1.077 1.073 1.073 1.073 1.073 1.070 1.027 1.053 1.000 1.140 1.057 1.020 1.027 1.073 1.073 1.073 1.073 1.070 1.070 1.073 1.073 1.073 1.073 1.073 1.073	App .977 1.040 (.023 .963 1.020 1.0/0 1.053 1.040 1.013 1.050 1.020 1.033 1.060 1.023 1.170 1.077 1.027 1.020 1.033 1.060 1.023 1.170 1.077 1.027 1.070 1.010 1.063 1.070 1.070 1.077 1.027 1.070 1.010 1.063 1.070 1.100 1.0977 1.027 1.070 1.010 1.063 1.070 1.120 1.147 1.060 1.043 1.070 1.073 1.080 1.120 1.147 1.060 1.043 1.073 1.073 1.030 1.077 1.037 1.037 1.013 1.040 .983 .997 1.040 1.027 1.060 1.053 1.000 1.140 1.057 1.030 1.070 1.033 1.053 1.060 1.067 1.057 1.037 1.043 1.043 1.073 1.060 1.067 1.057 1.037<	Ap .977 1.040 $(.023)$.963 1.020 .977 1.0/0 1.053 1.040 $(.073)$ $(.057)$ $(.020)$ $(.977)$ 1.033 1.060 $(.023)$ 1.040 $(.073)$ $(.057)$ $(.020)$ $(.977)$ 1.033 1.060 $(.023)$ (1.70) $(.077)$ $(.027)$ $(.057)$ 1.010 1.063 $(.023)$ (1.70) $(.077)$ $(.063)$ $(.063)$ 1.010 1.063 $(.077)$ $(.070)$ $(.063)$ $(.063)$ 1.070 1.073 $(.060)$ $(.147)$ $(.060)$ $(.043)$ $(.073)$ 1.070 1.073 $(.073)$ $(.053)$ $(.077)$ 1.073 $(.073)$ 1.013 $(.040)$ 983 $.997$ 1.040 1.027 1.037 1.033 1.073 1.073 1.073 1.070 1.070 1.033 1.033 1.053 1.073 1.073 1.073 1.070 1.027 1.033 1.053 <	Ap .977 1.040 1.023 .963 1.020 .997 .993 1.0/0 1.053 1.040 1.073 1.050 1.020 $.977$ $.973$ $.22$ 1.0/0 1.053 1.040 1.073 1.050 1.020 1.050 1.040 1.033 1.060 1.023 1.170 1.077 1.027 1.070 1.057 1.040 1.0/0 1.063 1.070 1.077 1.027 1.070 1.053 1.040 1.0/1 1.063 1.070 1.077 1.073 1.063 1.077 1.073 1.073 1.077 1.073 1.073 1.030 1.077 1.037 1.073 1.073 1.073 1.073 1.073 1.073 1.077 1.033 1.077 1.033 1.073 1.073 1.073 1.073 1.073 1.073 1.073 1.073 1.073 1.073 1.073 1.073 1.077 1.027 1.007 1.043 1.073 </td <td>$\begin{array}{c ccccccccccccccccccccccccccccccccccc$</td> <td>$\begin{array}{c ccccccccccccccccccccccccccccccccccc$</td> <td>$\begin{array}{c ccccccccccccccccccccccccccccccccccc$</td> <td>$\begin{array}{c ccccccccccccccccccccccccccccccccccc$</td>	$\begin{array}{c ccccccccccccccccccccccccccccccccccc$	$\begin{array}{c ccccccccccccccccccccccccccccccccccc$	$\begin{array}{c ccccccccccccccccccccccccccccccccccc$	$\begin{array}{c ccccccccccccccccccccccccccccccccccc$

RC PRESS : F19.5 BEST ESTIMATE OF CORE INLET Flow Factors STRING NO. for 1 pump operation 177 FA plants Ave = 1.05: Ave = 1. 795 939 963 1.025 1.035 936 31 . A2 Az 949 1.020 1.012 1.008 1.022 1.042 1.075 1.008 963 29 5% 25 9 1.038 1.025 998 1.035 1.020 1.065 1.055 1.045 1.065 1.048 1.153 1.061 1.012 1.070 1.073 1.055 1.018 1.174 1.116 1.018 1.008 1.04-2 20 1.074 1.063 1.079 1.045 1.140 1.032 1.055 1.045 995 1.074 1.084 1.081 11.0 1.064 1.104 1.130 1.044 1.043 1.089 1.103 1.079 1.065 0/2 1.022 <u>;</u>;. 1.096 1.137 1.109 22 25 1.015 1.038 1.061 1.037 1.018 1.058 1.109 1.032 1.062 1.062 1.055 150 1.074 1.1 1.077 31 ופ .9/0 .997 1.040 1.027 1.060 1.013 .967 .877 .983 .8/7 1.13 1.... 953 953 3 1.057 1.030 1.070 1.033 1.033 1.040 1.100 1.037 1.050 1.033 1.077 990 1.053 1.140 1.: 30 Sc 1.073 1.117 1.083 1.077 1.027 1.007 1.043 1.087 1.043 1.057 1.007 003 1.013 1. .073 1.067 1.037 1.043 1.043 1.013 1.040 .977 1.010 1.013 .997 :.067 1.013 1. 北 14 .877 .863 .950 .853 .877 .833 997 .003 1.050 1.053 .950 .830 1.1 43 48 42 17 .770 .840 .757 .683 .7/7 .787 <u>, </u> .873 .857 . 927 .817 .777 Bz .8/0 .863 .827 .853 .867 .793 .770 730 BZ 45 .837 .717 .853 900 .837 Ave = .97: Ave = .9385 · 2 6 . 8 9 10 14 15 7 11 12 13

THE BABLUL & WILCOX COMPANY S. BARTELLS . R. BURRIS J. M. KNOLL To 1 1 A. TREVENTI J. D. CARLTON R. GLOUDEMAS . E. PARKS From M DUNN (EXT. 2584) GKIBBLY D W LLEELLE BOS 65 File No. Cust. TMI or Ref. Date Subj. . CORE BYPASS FLOW FOR CORE BLOCKED AT TOP ONLY APRIL 8, 1979 This fatter to cover one customer and one subject only. REFERENCE: MEMO, R. M. GRIBBLE TO J. D. CARLTON, "CORE BYPASS FLOW . THROUGH CORE BASKET (UNIFORM BLOCKAGE)," 4/8/79. THE REFERENCED MEMO REPORTS CORE BYPASS FLOW FOR A UNIFORMLY BLOCKED CORE. FOR THIS CONDITION, 22% OF THE VESSEL FLOW BYPASSES THE CORE THROUGH THE CORE BASKET. ANOTHER CASE HAS BEEN CONSIDERED AND IS REPORTED HEREIN. CORE BLOCKAGE AT ONLY THE TOP OF THE CORE HAS BEEN ANALYZED TO DETERMINE CORE BYPASS FLOW FOR THIS MORE LIMITING SITUATION. RESULTS OF THIS ANALYSIS INDICATED THAT CORE BYPASS FLOW FOR THE CORE BLOCKED ABOVE THE UPPERMOST INTERMEDIATE SPACER GRID WILL BE APPROXIMATELY 27% LEAVING 73% AVAILABLE FOR CORE HEAT REMOVAL. MAJOR ANALYSIS ASSUMPTIONS FOLLOW: 1. MAXIMUM RESISTANCE OF THE CORE AND CORE BASKET = 83 X 10^{-8} PSI/(LB/SEC)², 17.7 PSI AT 4600 LB/SEC NOMINAL CORE BASKET RESISTANCES • LOCA HOLES (CROSSFLOW) $R = 7.64 \times 10^{-0} \text{ PSI/(LB/SEC)}^2$ $R = 5.43 \times 10^{-6} PSI/(LB/SEC)^2$ • UPPER BASKET CORE GEOMETRY IS NOMINAL BELOW BLOCKAGE 3

J. D. CARLTON

4. CORE BASKET GEOMETRY IS UNDISTORTED.

5. RELATIVE RESISTANCES OF THE CORE AND CORE BASKET REMAIN UNCHANGED DURING NATURAL CIRCULATION CONDITIONS COMPARED TO THEIR VALUES DURING 1/0 PUMP OPERATION.

This analysis has been Higginere. Mound Cite. N. UTA and of the huti

THE T	BABCOCK & WILCOX COMPANY REPARTION GROUP	
ō	G. A. MEYER, MANAGER, T-H ENGINEERING UNIT	THE-79-194
rom	J. A. WEIMER, T-H ENGINEERING UNIT, EXT. 3236	BDS 663.5
ust.	TMI-2	File No. or Ref.
ubj.	INCORE THERMOCOUPLE ERROR EVALUATION	Date APRIL 10, 1979
	This takes to sover one switches and one subject only.	┫ _╋ ┙╫╘┙╫╪╪╘╱╫╖╪╘╱╫ _╋ ┙╴╱╫╪╪╧╎╪╪╧╧╪╪╪╪╪╪╪╪╧╖╗╪╪╧╖╗╪╪╧╖╗╪╪╧╖╖╝╪╪

AN ANALYSIS WAS DONE TO DETERMINE THE MAGNITUDE OF INCORE THERMOCOUPLE ERRORS FOR TMI-2 PRIOR TO MARCH 28, 1979. THIS ANALYSIS WAS BASED ON A TEMPERATURE AND POWER DISTRIBUTION AT 98% AND 15% FULL POWER. THIS WORK ASSUMES THAT THE INLET AND OUTLET RTD (RESISTANCE TEMPERATURE DETECTOR) TEMPERATURES AND POWER DISTRIBUTIONS WERE CORRECT, AND INADDITION, ASSUMED A CONSERVATIVE + 3°F DIFFERENCE BETWEEN THE CORE OUTLET AND VESSEL OUTLET TEMPERATURE AT 98% POWER. THIS RESULTS IN A 0.5°F DIFFERENCE AT 16% POWER. MORE REALISTIC TEMPERATURE DIFFERENCES (IE. 2°F AT 98% FP AND .2°F AT 16% FP) WOULD INCREASE THE PREDICTED T-C ERRORS SLIGHTLY.

THE METHOD USED FOR THIS ANALYSIS WAS BASED ON A KNOWN BUNDLE DELTA ENTHALPY, AND FLOW RATES (FROM ONLINE COMPUTER (OLC)) FOR AN AVERAGE POWER BUNDLE (RELATIVE POWER = 1.0). THE EQUATION USED FOR THIS ANALYSIS IS:

 $H_{OUT_2} = \frac{Q_2}{Q_1} \times \frac{W_1}{W_2} \times (H_{OUT_1} - H_{IN_1}) + H_{IN_1}$

G. A. MEYER APRIL 10, 1979 PAGE 2

WHERE

 Q_2 = RELATIVE POWER OF BUNDLE FOR EACH CALCULATION (FROM OLC) Q_1 = RELATIVE POWER OF BUNDLE FOR AN RPD OF 1.0 Q_1 = 1.0 W_1 = BUNDLE FLOW FOR AN RPD OF 1.0 (FROM OLC) W_2 = BUNDLE FLOW OF BUNDLE FOR EACH CALCULATION (FROM OLC) H_{OUT_1} H_{IN_1} = DELTA ENTHALPY FOR AN RPD OF 1.0 RPD = RELATIVE POWER DIFFERENCE (NORMALIZED TO AVERAGE ASSEMBLY POWER) H_{OUT_2} = CALCULATED BUNDLE OUTLET ENTHALPY FOR EACH BUNDLE.

H_{OUT₂} IS THEN CONVERTED TO T_{OUT} AND COMPARED TO THE MEASURED T_{OUT} (T-C READING). THIS ANALYSIS (AT 98% AND 16% FP) WAS EXTRAPOLATED TO 1% FP.

ANY INHERENT ERRORS ON THE OLC FLOW AND RPD CALCULATIONS ARE ELIMINATED BY THIS RATIOING METHOD. THEREFORE, THE ONLY REAL UNCERTAINTY IS IN THE H_{OUT_1} AND H_{IN_1} MEASUREMENTS. THESE WERE ASSUMED CORRECT FOR THIS ANALYSIS.

THE RESULTS OF THIS ANALYSIS INDICATE AN AVERAGE + 7.94°F ERROR AT 98%, AND A + 5.59°F ERROR AT 16% POWER. THIS EXTRAPOLATES TO A + 5.16°F ERROR AT 1% POWER. G. A. MEYER APRIL 10, 1979 PAGE 3

JAW/SGH

CC:

ASSUMING NO DAMAGE OCCURRED TO THE T-C'S DURING THE TRANSIENT OF MARCH 28, 1979 AT TMI-2 THESE RESULTS WOULD APPLY TO THE PRESENT T-C READINGS, THUS IT IS POSSIBLE THAT THE INCORE THERMOCOUPLE READINGS PRESENTLY BEING OBTAINED ARE HIGH BY AN AVERAGE OF 5°F.

FINALLY, THE AVERAGE T-C ERRORS WERE CALCULATED AS A FUNCTION OF DIFFERENT POSITIONS IN THE CORE. THE RESULTS SHOW NO INHERENT CORE REGION DEPENDENCY.

GH QA: THE METHOD AND CALCULATIONS FE UNIT MANAGERS WERE REVIEWED AND FOUND TO BE J. S. TULENKO CORE HOT SPOT TASK FORCE CORRECT AND CONSISTENT WITH THE

2, Come DATE

STATED ASSUMPTIONS.

(15) 11 contal J. T. Willow PEManna CT Rombingh. T. L. Wulson PRELIMINARY TMI-2 4/9/71 Déscripance between Thermocouples and. Autlet RTD Transporture Measurements. Following the LOFW transvent, the average of the thermorrouples at the core outlet has been higher than the RTD'S. This menor provides some data on the Mermonique IRTD comparison prior to the LOFW transent. Bill Boyden and I reviewed the thermoroughe data pour PDO's prior to the transient to determine if a systematic bias existed. No isothermal, gero-pouver readings were found. However, use did locate several sets as a function of power. These ever average two ways. Note that the thermocouples give higher readings Them. the RTD's in all cases.

It is reasonable to succept this difference may to due to normal by saas flow. Accuming this is correct, we can state the following appropriate formal. $P_{\text{max}} = (m_{\overline{1}} - m_{BP}) K (\overline{1}_{1/c} - \overline{1}_{1U})$ $\frac{1}{P} = (M_T) K (T_{RTD} - T_{IV})$ P = Power min = Total for mBP = Bypans flow K = OrAverage over per & flow rate ______ den & degree ST______ Averai TRNS = Hothy RTD______ Tits = Inlet tenzverature

_Setting power equal $(m_T - m_{BP}) k (T_{OT/c} - T_{IN}) = m_T k (T_{PTD} - T_{IN})$ Sing Solve for Scorphigh Simplifying we get _ $= (I - f) (T_{1/c} - T_{1/v}) = T_{RTO} - B T_{I/v}$ where $f = \frac{m_B p}{n_T}$ -Tout - TRID= f Tric - 7 $T_{T/c} - T_{RTD} = f(T_{T/c} - T_{IN})$ _ Clearly_ if the system wer_ isothernal, then_ _T_T/c = TRID = . TIN ._ Moreover, since the asia DT is ___ proportional to power, the following instance should In true

 $T_{T/c} = T_{RTD} = \frac{f \odot P}{K(m_T - m_{BP})}$ The plot of DT = TTIC - TPTD in the attached estrapolating to figure illustrates that, OS, P=D, the DT is not gene. This suggests a possible bias, prior to the totansent, of + 5°F in the totanocouple readings. No explanation for the cause of the bias was found

Humaruph / RTD Comparison Table : DUTLET 7** T(2) 7(3) Date Feloen ΔT 09/19/25 593.9 593.2 585.97 587.32 16.70 6.26 599,14 600.44 591.96 592.55 41 7.64 9/30/28 2 61202 619.26 106.10 606-37 98% 10.78 30 3/13/29 617.2 630.1 206.34 606.66 98% 03/19/29 . 21 10.70 ____ " welconten areinge _____ -----** Analght allenge


PCWER GENERATION GROUP PREZIMINARY	+
G.A. MEYER - MANAGER, THERMAL HYDRAULIC ENGINEERING	
From	
R.M. HIATT - THERMAL HYDRAULIC ENGINEERING	THE-79-191 BDS 663.
Cust	File No. or Ref.
Subj.	Date
LYNX1 MODEL FOR TMI-2 BLOCKAGE STUDY	APRIL 10, 1979

THE OBJECTIVE OF THIS WORK WAS TO DEVELOP A METHOD FOR ANALYZING LOCAL COOLANT CONDITIONS FOR TMI-2 DURING SELECTED TIMES OF THE RECENT ACCIDENT. AN EQUALLY IMPORTANT CONSIDERATION WAS THE DETERMINATION OF LOCAL COOLING CAPABILITY FOR THE BLOCKED CORE UNDER NATURAL CIRCULATION.

FIGURE 1 ILLUSTRATES THE NODING SCHEME FOR THE SIMPLIFIED CORE MODEL. THE TWELVE CHANNELS WERE DESIGNED TO SEGMENT THE CORE INTO AREAS THAT IT WAS BELIEVED EXPERIENCED MAJOR DAMAGE, SOME DAMAGE AND POSSIELY NO DAMAGE.

LYNX1 PERFORMED WELL WITH THE MODEL FOR A CLEAN CORE. HOWEVER, WE WERE NOT ABLE TO ACHIEVE THE HIGH PRESSURE DROP (18 PSI) ACROSS THE CORE WITH THE FLOW RATE FOR ONE PUMP OPERATION AND A BLOCKED CORE CONDITION PREDICTED BY CONTROL ANALYSIS. THEY PREDICTED A FLOW OF 4500 LB/SEC FOR CORE PLUS CORE BARREL-CORE BAFFLE ANNULUS FOR A BLOCKED CORE CONFIGURATION. SINCE LYNX1 STRUGGLED FOR CONVERGENCE DUE TO A SENSITIVITY OF THE CODE TO THE BLOCKAGE MODEL, A NUMBER OF MODELING SCHEMES WERE TRIED WITH VARYING DEGREES OF SUCCESS. SEVERE BLOCKAGES AT EACH SPACER GRID (K=30-35), AN INCREASE IN WETTED PERIMETER FOR ALL CHANNELS, AND SLIGHT VARIATION IN RESISTANCE FROM CHANNEL TO CHAMMEL WERE ITERATING PARAMETERS. THE BEST ESTIMATE OF LOCAL FLOW BEHAVIOR OBTAINED TO DATE ACHIEVED AN UNRECOVERABLE PRESSURE DROP OF ABOUT 7 PSI FOR 4722 LB/SEC CORE FLOW THE BEST ESTIMATE FROM CONTROL ANALYSIS AT PRESENT IS 18 PSI FOR 4500 LB/SEC FLOW THROUGH THE CORE PLUS CORE BARREL-CORE BAFFLE ANNULUS.

A CHATA CASE WAS MODELED TO GIVE THE FLOW SPLIT BETWEEN THE CORE AND THE CORE BARREL-CORE BAFFLE ANNULUS. IT WAS ESTIMATED THAT 78% OF THE 4500 LB/SEC PREDICTED BY CONTROL ANALYSIS FLOWS THROUGH THE CORE WHICH AGREES WELL WITH CONTROL ANALYSIS ESTIMATES. THUS, BEST ESTIMATES TO DATE SHOW THAT 3510 LB/SEC IS FLOWING THROUGH THE CORE WITH 1 PUMP OPERATION. ONE IMPORTANT FACT THAT WAS EVIDENT FROM AN ENERGY BALANCE ON THIS FLOW RATE IS THAT THE INDICATED THERMOCOUPLE AT IS NOT POSSIBLE CONSIDERING A 4-5 MW_T DECAY HEAT RATE UNLESS THE THERMOCOUPLES ARE MEASURING LOCAL EFFECTS, SUCH AS AGGLOMERATIONS OF PELLETS NEAR THE THERMOCOUPLES. THIS APPEARS TO DISCREDIT THE THERMOCOUPLES, THEREFORE, SOME DISCRETION IS NECESSARY IN THE INTERPRE-TATION OF THIS DATA.

IN CONCLUSION, ALTHOUGH LYNX1 MODELING HAS NOT BEEN SUCCESSFUL IN MATCHING FLOW AND EXIT PRESSURE AT THIS TIME FOR A BLOCKED CORE WITH ONE PUMP OPERATION, IT IS BELIEVED THAT AN ACCEPTABLE MODE CAN BE DEVELOPED. THE ADVISABILITY OF ADDITIONAL WORK IN THIS AREA DEPENDS ON THE WORK SCOPE OF FUTURE WORK ON THE TMI-2 ACCIDENT. FROM PAST EXPERIENCE, THE MODEL DEVELOPMENT WILL NOT BE QUICK BUT COULD REQUIRE A MONTH'S EFFORT.

R MH/FFA

CC: F.E. UNIT MGRS.

Salt



Y THĖ POWE	BABCOCK & WILCOX COMPANY R GENERATION GROUP	NT YIW
To	G. A. MEYER, MANAGER, T-H ENGINEERING UNIT	THE-79-190
mc	P. J. HENNINGSON, T-H ENGINEERING UNIT, EXT. 351	12E12.13 BDS 663.5
Cust	TMI - 2	File No. 86-1100502-00 or Ref. 660-021A
Şubj.	DAMAGE MODEL - FLUIDIZED BED	Date APRIL 10, 1979
	This latter to cover one customer and one subject only.	

REFERENCES: 1) MEMO, CORE CONDITION TASK FORCE TO J. S. TULENKO, "CURRENT ASSESSMENT OF CORE CONDITION, APRIL 7, 1979 (1800)," APRIL 7, 1979 (7:48 PM)

> 2) <u>PERRY'S CHEMICAL ENGINEERS HANDBOOK</u>, FOURTH EDISON, PP. 549 - 551.

3) MEMO, P. J. HENNINGSON TO G. A. MEYER, "POSSIBLE MODE OF INCREASED T.C. READINGS," APRIL 7, 1979.

THE DAMAGED TMI-2 CORE WAS HYDRAULICALLY MODELED AS A PACKED BED. THE MECHANISM OF FUEL FAILURE WOULD RESULT IN APPROXIMATELY THIS GEOMETRY AND BE LOCATED IN THE UPPER REGION OF THE CORE. BRIEFLY THE CORE WOULD BE CONFIGURED AS UNDAMAGED FUEL UP TO A HEIGHT WITH DAMAGED FUEL (FUEL PARTICULATES AND CLADDING) ABOVE THIS RESEMBLING A POROUS MASS.

THE BASIC CONFIGURATION OF THE CORE WAS OBTAINED FROM REFERENCE 1. THE CORE WAS ASSUMED UNDAMAGED AT THE PERIPHERY WITH INCREASING FAILURE TOWARDS THE CENTER. PARTICLES OF FAILED FUEL WHICH COMPRISED THE FLUIDIZED BED WERE ASSUMED TO EVOLVE FROM THE FOLLOWING FAILURE MECHANISM: G. A. MEYER APRIL 10, 1979 PAGE 2

> THE FUEL CRACKED ALONG TWO PERPENDICULAR AXES LENGTHWISE AND PLANES ALONG THREE PERPENDICULAR TO ITS AXIS.

THE MASS OF FUEL WOULD THEN CONSTITUTE THE MAJORITY OF THE CONGLOMERATE WITH CLADDING FRAGMENTS ASSUMED TO HAVE A SIMILAR GEOMETRY.

A SUITABLE CORRELATION FOR PRESSURE DROP THROUGH A PACKED BED WAS OBTAINED FROM REFERENCE 2. THIS CORRELATION (ATTRIBUTED TO LEVA) WAS APPLICABLE IN THE HIGH REYNOLDS NUMBER RANGE EXISTING IN THE DAMAGED CORE (RE \sim 10,000). IT IS IMPORTANT THAT THE RANGE OF REYNOLD'S NUMBER APPLICABILITY BE ASCERTAINED FOR A GIVEN CORRELATION. THE SENSITIVITY OF THE FRICTION FACTOR $\stackrel{70}{\Longrightarrow}$ CHANGES IN FLOW FROM VISCOUS TO TURBULENT IN THE PACKED BED CANNOT BE NEGLECTED.

AN ATTEMPT TO MODEL THE CORE AS DEFINED IN REFERENCE 1 WAS MADE. THE LOW RESISTANCE IN THE PERIPHERAL BUNDLE CAUSED THIS METHOD TO FAIL. IT WAS THEN ASSUMED THAT FAILED FUEL (OR A CONGLOMERATE OF PARTICLES) EXISTED AT THE PERIPHERY. THE CORE TOOK ON THE FOLLOWING SHAPE:

CENTRAL BUNDLES (116)4 FEET OF FAILED FUEL BELOW THE UPPER END
FITTING (PACKED BED)REMAINING BUNDLES2 FEET OF FAILED FUEL BELOW THE UPPER END
FITTING

G. A. MEYER APRIL 10, 1979 PAGE 3

THE GENERAL SHAPE AND RECOMMENDATION OF A FOUR FOOT HEIGHT WAS OBTAINED FROM REFERENCE 1.

A TRIAL AND ERROR APPROACH WAS USED. THE VOID FRACTION OF THE PACKED BED WAS VARIED AND A CORE ΔP CALCULATED. THE FINAL RESULT WAS THAT FOR THE ABOVE CONFIGURATION A CORE $\Delta P = 14$ PSI WAS OBTAINED FOR A CORE FLOW OF 13.1 x 10⁶ LBM/HR. THE FLOW IN THE CENTRAL BUNDLES (61) WAS .058 x 10⁶ LBM/HR AND IN THE OUTER BUNDLES .082 x 10⁶LBM/HR. THIS WAS FOR A PACKED BED HEIGHT OF FOUR FEET ' AT THE CENTER 61 BUNDLES AND TWO FEET ON THE REMAINDER OF THE CORE. A VOID OF 60% WAS USED WHICH COMPARED WELL WITH THE 50% RECOMMENDED IN REFERENCE 1.

NO FURTHER ATTEMPTS WERE MADE TO MATCH PRESENTLY ASSUMED CORE CONDITIONS $\Delta P \sim 16.0$ PSI, CORE FLOW $\sim 14.10^6$ LBM/HR. VARIOUS ASSUMPTIONS CAN BE MADE CONCERNING THE GEOMETRY AND MAKEUP OF THE FAILED FUEL WHICH IS ASSUMED TO RESEMBLE A PACKED BED. WHAT IS IMPORTANT IS THAT:

1) CORE CONDITIONS COULD BE APPROXIMATED WITH THE PACKED BED ASSUMPTION,

2) FAILED FUEL (OR A HIGH RESISTANCE EXISTS ACROSS THE CORE). THE FUEL AT THE PERIPHERY COULD BE UNDAMAGED WITH A LAYER OF PARTICULATES BENEATH THE CORE SUPPORT PLATE ALTHOUGH IT SEEMS UNLIKELY THAT THE MATERIAL WOULD BE THAT NON-HOMOGENEOUS. G. Á. MEYER APRIL 10, 1979 PAGE 4

FURTHERMORE, IF THE FAILURE MODE OF THE CORE DESCRIBED IN REFERENCE 1 IS ASSUMED, THEN IT APPEARS THAT THE THERMOCOUPLES COULD BE SURROUNDED BY UO_2 . THIS WOULD EXPLAIN THEIR HIGH READINGS. THE EFFECT OF UO_2 SURROUNDING THE THERMOCOUPLE WELL WAS DESCRIBED IN REFERENCE 3.

'PJH/sgh

CC: J: H. JONES A. B. JACKSON J. C. MOXLEY D. V. DEMARS B. J. BUESCHER

H. W. WILSON

R. A. KING

D. C. SCHLUDERBERG.

G. S. CLEVINGER

QA: THE METHODS PRESENTED HAVE BEEN REVIEWED FOR APPLICABILITY AND THE CALCULATIONS SPOT-CHECKED FOR ACCURACY AND CONSISTENCY. THE METHOD IS DEEMED APPROPRIATE FOR THIS PARTICULAR APPLICATION.

by 11/143, DATE 4/10/79

To I		
10 1	J. B. ANDREWS	
From	CORE CONDITION TASK FORCE	BDS
Cust.		File No. or Ref.
Subj.	ESTIMATE OF LOOSE CORE DEBRIS VOLUME (4/9/79 - 2000)	Date TIME: APRIL 9. 1979
	This letter to cover one customer and one subject only.	•
		•
•	ATTACHED IS AN ESTIMATE OF THE AMOUNT OF DEBRIS AVAILABLE I	OR CORE BLOCKAGE
• •	AND ITS POTENTIAL DISTRIBUTION. THIS IS TO AID IN THE OVER	ALL ASSESSMENT
•	OF CODE BLOCKACE	•
	OF LORE BLOCKAGE.	
•		•
	MOST OF THE INFORMATION IN FORMING THIS ASSESSMENT IS STILL	PRELIMINARY
	AND IS BASED ON OUR BEST ESTIMATE OF CORE DAMAGE.	
		•
•		
		•
	CC: P. HENNINGSON	
••••	CC: P. HENNINGSON CORE CONDITION TASK FORCE	
• • • • • • • •	CC: P. HENNINGSON CORE CONDITION TASK FORCE J. S. TULENKO	
	CC: P. HENNINGSON CORE CONDITION TASK FORCE J. S. TULENKO	
-	CC: P. HENNINGSON CORE CONDITION TASK FORCE J. S. TULENKO ATTACHMENT	
	CC: P. HENNINGSON CORE CONDITION TASK FORCE J. S. TULENKO ATTACHMENT	
 	CC: P. HENNINGSON CORE CONDITION TASK FORCE J. S. TULENKO ATTACHMENT	
	CC: P. HENNINGSON CORE CONDITION TASK FORCE J. S. TULENKO ATTACHMENT	
-	CC: P. HENNINGSON CORE CONDITION TASK FORCE J: S. TULENKO ATTACHMENT	
	CC: P. HENNINGSON CORE CONDITION TASK FORCE J. S. TULENKO ATTACHMENT	•
	CC: P. HENNINGSON CORE CONDITION TASK FORCE J. S. TULENKO ATTACHMENT	
	CC: P. HENNINGSON CORE CONDITION TASK FORCE J. S. TULENKO ATTACHMENT	•
	CC: P. HENNINGSON CORE CONDITION TASK FORCE J: S. TULENKO ATTACHMENT	
	CC: P. HENNINGSON CORE CONDITION TASK FORCE J: S. TULENKO ATTACHMENT	· · · · · · · · · · · · · · · · · · ·
	CC: P. HENNINGSON CORE CONDITION TASK FORCE J. S. TULENKO ATTACHMENT	

CORE BLOCKAGE ESTIMATE

BELOW IS AN ESTIMATE OF THE LOOSE MATERIAL AVAILABLE TO CONTRIBUTE TO CORE BLOCKAGE.

1. ASSUME 30% OF TOTAL Zr CORE INVENTORY

IS OXIDIZED PRODUCING Zr0,

45,000 LB TOTAL FUEL CLAD INVENTORY

7,900 LB OTHER Zr INVENIORY

52,900 LB TOTAL

15870 LB OF Zr IS OXIDIZED WITH A 1.6 BULK VOLUME INCREASE, FORMING
63 FT³ OF Zr0₂.

THE TOP 30% (46 IN.) OF THE CLAD OXIDIZES EXPOSING 41" OF U02 TO THE COOLANT.

• TOTAL UO₂ EXPOSED IS 57,400 LBS OR 94 FT³.

• ASSUME AN ADDITIONAL 10 FT³ OF MATERIAL IS EXPOSED FROM FUEL ROD

(SPRINGS, END PLUGS, ETC.).

3. BASED ON THE ABOVE THE EXPOSED MATERIAL AVAILABLE FOR CORE BLOCKAGE IS:

Zr0 ₂	63 FT ³
uo ₂ .	94 FT ³
OTHER	10 FT^3
•	167 FT ³

4. OF THIS, SOME IS CAPABLE OF BEING MOVED BY FLOW

		VOLUME FT ³				
		AVAILABLE	MOBILE	INNOBILE		
•	ZrO ₂	63	45 (FLAKES & DUST)	18 LARGER FLAKES OR ON RODS		
	U0 ₂		14 (<1/16'' SIZE)	80 (>1/16'')		
	OTHER	<u>10</u>		10		
		167 '	59 •	108		

THE SMALLER PARTICLES MAY EXIT AND MOVE WITH THE FLOW AND MAY RE-DEPOSIT IN THE CORE OR SETTLE OUT ELSEWHERE IN THE SYSTEM.

EQUIVALENT FLOW BLOCKAGE

- ASSUME THE EQUIVALENT CORE FLOW AREA (10.6 FT DIA), IS 88 FT²
- TOTAL EQUIVALENT DEPTH OF BLOCKAGE IS

 $\frac{167}{88}$ = 1.90 FT ASSUMING SOLID MATERIAL

- ASSUME 1.5 VOLUME INCREASE FOR PACKING, THEN THE EQUIVALENT TOTAL DEPTH IS 1.90 × 1.5 = 2.85 FT
- . IT IS EXPECTED THAT THE DAMAGE WILL BE GREATER AT THE CENTER THAN AT THE CORE PERIPHERY (SEE NEXT SECTION).

CORE DAMAGE DISTRIBUTION

THE CORE DAMAGE WILL BE MORE SEVERE IN THE CENTER OF THE CORE THAN ON THE PERIPHERY. THIS RESULTS FROM THE CORE DECAY HEAT POWER DISTRIBUTION WHICH CLOSELY FOLLOWS THE CORE POWER DISTRIBUTION PRIOR TO SHUTDOWN (SEE FIG. 1). THIS WILL RESULT IN CORE DAMAGE DISTRIBUTION AS SHOWN IN FIGURE 2. THE FUEL RODS IN PERIPHERAL ASSEMBLIES MAY BE RELATIVELY INTACT WHILE THE CENTER ASSEMBLY IS PROBABLY SEVERELY DAMAGED, POSSIBLY TO THE CENTER OF THE CORE. THE CENTER ASSEMBLIES MAY HAVE VIRTUALLY NO RECOGNIZABLE ARRAY IN THE UPPERMOST GRID SPANS.

1/3	<u><u> </u></u>	<u></u>	i.3.A11 <u>10</u>	VS FORE? 1. 	12 12	<u> </u>	<u>.</u>	<u></u>	· · · · · · · · · · · · · · · · · · ·	•
	D	1.2.21	1.200	1.17:3-	1.11.70	1.161.5	Ø	.::		
Х	1.2727	D1.2314 4	1.2050	1.1465	1.105.	1.0753	j.(i [™] *)	.6196		· · · · · · · · · · · · · · · · · · ·
<u> </u>	1.20%	1.2050	.1517	1.1.72	k 4	<u> </u>	· · · · · · · · · · · · · · · · · · ·			
	1.11.1	<u>क</u> 1-1:35 र अ		<u>3</u> 1.0555			• • • · · · · · · · · · · · · · · · · ·			
14	1.0976	1.1052 *	9] .9534	1.0105	.21:33	.0112	6.33			· · · · · · · · · · · · · · · · · · ·
<u> </u>	<u> </u>	# 1_0970_* *		0232			· · ·	÷		
.	@1.2703	**************************************	1.1037			·	k 			
2	.t.75:(⁴)	.0196	<u> E</u> &196			<u>9</u>	rup	R.P.D	& Assy's	
•			······································	· .	• ••••••••••••••••••••••••••••••••••••		1	1.45	<u> </u>	

5

.57

20

•

Fiy. 2)cmarge . tion stribe ore :. • •. ٠ •• ••• • . • • • • : • . • . • • ٠ •. . . ۰. •. ... • ٠. . . . • • • . • • . . I • • • . . • • . • • • • • • . : : • . . ۰. . • Scionaly Denson . ••,_ . . Modero Dimesa V • • • •• · ...

THE BABCOCK & WILCOX COMPANY PRELIMINARI POWER GENERATION GROUP To DISTRIBUTION From P. S. BARTELLS, TECHNICAL STAFF BDS 611 File No. Cust. or Ref. TMI - 2 TONTO Date Subj. CORE PRESSURE DROP FOR NATURAL CIRCULATION APRIL 9, 1979 6:: CALCULATION This letter to cover one customer and one subject only. DISTRIBUTION E.A. Womack C.D. Morgan C.E. Parks B.E. Bingham G.F. Malan R.B. Davis B.M. Dunn J.J. Cudlin R.H. Stoudt J.S. Tulenko M.R. Gudorf J.D. Carlton **B.A.** Karrasch J.A. Castanes D.H. Roy R.M. Hiatt E.F. Dowling. J.M. Knoll P.A. Treventi REFERENCE: MEMO, SAME SUBJECT, APRIL 6, 1979. ADDITIONAL INFORMATION HAS BEEN OBTAINED FROM TMI WHICH FURTHER SUBSTANTIATES THE CONCLUSIONS PRESENTED IN THE REFERENCED MEMO. BASED ON THIS INFORMATION, AND THE FLOW SPLITS PREDICTED BY THE PUMP CODE, AN 18 PSIA DROP ACROSS VESSEL DOWNCOMER AND CORE (AT PRESENT CONDITIONS AND CORE FLOW OF 4500 lbm/sec) IS INDICATED. leso 27% Core Conver ATTACHMENT 1 IS THE TABULATION OF RC LOOP FLOW TRANSMITTER DIFFERENTIA PRESSURE SIGNALS OBTAINED AT 4:00 a.m., APRIL 9. ATTACHMENT 2 IS THE CONVERSION OF THE TRANSMITTER VOLTAGE MEASUREMENTS TO LOOP FLOWS. AS A FURTHER CHECK ON THE RESULTS, I HAVE ASKED MIKE KNOLL OF CONTROL ANALYSIS TO ANALYZE THE SAME CASE USING THE SPLIT CODE. IT IS HOPED THIS INFORMATION WILL BE AVAILABLE BY LATER TOMORROW AFTERNOON. AT THIS POINT I WOULD LIKE TO ACKNOWLEDGE THE EFFORTS OF MIKE KNOLL AND PHIL TREVENTI IN PERFORMING THIS ANALYSIS (WITHOUT WHICH I WOULD STILL BE SETTING UP THE INPUT). IF ANY ADDITIONAL INFORMATION ON PLANT STATUS (WHICH COULD PROVIDE A FURTHER CHECK ON THESE PREDICTIONS) IS KNOWN TO BE AVAILABLE, PLEASE CONTACT ME IMMEDIATELY. PSB/DH

attachment 2" Conversion of transmitter Nottage measurements :- to flous assumptions: 1. 10 volts = 80 × 106 l/mi/lus. 2. 10 volts = 895.8" AP Method 1 1-1.510 $W_a = W_d \left(\frac{V_d}{V_a}\right)^{1/2} \left(\frac{V_m}{10}\right)^{1/2}$ Wa - actual flow, ll- sac. Wd = flows at Noltage = 10 volta. Va = specifie volume at use conditions Va = apecific Molume at actual conditions Vm = measured transmitter Noltage, Notts. Mows: Va(460 pria, 280°F) = .01724. ft3/1/2 Va(2200 paia, 600'F) = .0232 ft3/11. Wd = 80 × 106 llon / lin = 22222 llon / lec -1-• • .

Alexence Wa = 25178 (Vin) lite / Leic Method 2: If: AP= 895.8" = 10 volte. $\Delta P_{a} = \left(\frac{\Delta P_{d}}{10}\right) V_{m}$ then : Wa = Wd (<u>Pa APa</u>).5. for : WJ = 22222 Um / sec Aa = 1/.01724 = 58.005 lbm/013 Ad = 1/.0232 = 43.103 lbn/ff3 and : $W_a = 25778 \left(\frac{\Delta P_a}{\Delta P_m}\right)^{\circ 5}$ Results: Following are the results of the Noltage measurements: -2-

Kot Lica A RPS (Volts) inches) (Alm / As a) CHANNEL A 1.9998 . 179.14 11528 C 2.0982. 187.96 11808 155.97 1.7411 D 10756 HOT LEG B RPS (Nolts) (inches) Ù CHANNEL (Iltra / sec -. 1061 63.25 -6850 -.7141 63.97 -6889 - ,6947 62.23 -6794 LOOP A avelage = 11364 lm/sec LOUP B Querage = - 6844 lim/sec This colculation has been reviewed and is correct

THE BABCOCK & WILCOX COMPANY POWER GENERATION GROUP To DISTRIBUTION From \$DS 663 PS BARTELLS, TECHNICAL STAFF File No. Cust. 121 or Ref. Part of TMI-2 Subj Date CORE PRESSURE DROP FOR NATURAL CIRCULATION APRIL 6, 1979 CALCULATIONS 10:10 PM This, lattar to subject <u>DISTRIBUTION</u> EA WOMACK DH ROY **CE PARKS** BE BINGHAM JD CARLTON RB DAVIS BM DUNN JS TULENKO MR GUDORF. **BA KARRASCH** CASTANES MORGAN CD GF MALAN JJ CUDLIN

An analysis (using the PUMP code) was performed earlier this week to estimate core flow blockage. Vessel (i.e. core and bypass) flow resistance was varied over a wide range and the change in loop flow rates, core flow rates and vessel delta P were calculated. The results are tabulated below: (* means unblocked core)

Rv	ΔP _V	W _V	WHLA	WHLB .		
1.712*	1.6*	10170*	12810*	-2643*		•
3.5	2.98	9450	12690	-3244	.	÷
7.0	5.05	8596	12500	-3900	•	
10.0	6.45	8095	12380	-4281	•	-
15.0	8.22	7443	12200	-4752		
30.0	11.89	6291	. 11870 [.]	-5580		
60.0	- 15.79	5136	11510	-6376	-	

Where:

Rv = downcomer + core + bypass flow resistance, (psia)/(lbm/sec)² X 10⁸ A^pv = pressure drop across core + bypass, psia

Wv = core + bypass flow rate, lbm/sec

WHLA = hot leg flow rate, active loop, lbm/sec

W_{HLB} = hot leg flow rate, idle loop, lbm/sec

1979 10:10 10

An be seen from the tabulated results, the active loop flow is not a ong function of the vessel resistance. This is due to the high reverse lows through the idle pumps. However, the reverse flow through the idle loop is a strong function of the vessel resistance. Prior to this afternoon, I had been under the impression that no method existed for calculation of reverse flow in the idle loop. Recent information from the I&C group shows this not the case. As early as last weekend they estimated the reverse flow to be -14.5% which translates to -6444 lb/sec. A further check today results in an estimate of -6797 lb/sec. Based on the tabulated data, the vessel pressure drop is <u>at least</u> 16 psia.

Additional evidence to back up this is the indicated flow in the active loop which is consistently indicating 49-50% of nominal which translates to approx. 11,000 lbm/sec.

Separate calculations by Jim Veenstra and Larry Losh (see attachments) on 4/4/79 place measured flow in the active loop at 88,350 GPM (based on Gentille delta P = 173"), which is a flow rate of 11,445 lbm/sec.

The attached figures indicate that the core and bypass pressure drop is between 16.7 and 17.7 psia. Allowing for conservatism, I would recommend the use of 18 psia for natural circulation calcuations. Additionally, I would estimate available core + bypass flow at present conditions to be 4600 to 4800 lbm/sec.

I have asked John Castanes to obtain up-to-date readings on Gentille delta **P's** as a further check on this analysis. He has been in contact with BMCo and they feel that the transmitter accuracy is very good.

ATTACHMENT .PSB:jws

		$\begin{bmatrix} 1 & 1 & 1 & 1 \\ 1 & 1 & 1 & 1 \\ 1 & 1 &$	
1000			
6000			
		ATES	VS CORE .
5000 WHLB		COEC	SS) RESISTANCE
(#/5)		WHLA	
			PSBaileur - 1200
			4/6179
	0 111 10 120		60 10 40
		TITTI RUXIOBIC PS	AD/(LEM/SCO)

•	• • • • • • • • • • • • • • • • • • • •	-	
	$ \begin{array}{c ccccccccccccccccccccccccccccccccccc$		
	AGURE	2	
	CORE - RY	PASENAP	
	NS. RESI	STANJE E	
Vel			
PEIN			
			15 Baralia
	-NORMAL WO OPERA	ττ ο ο ο ο ο ο ο ο ο ο ο ο ο ο ο ο ο ο	
	10 20 30		60 70 85
		$V \times 10^{\circ} H \times 10^{\circ} H$	NEH/SEE)
	1		•

,

ł

:

:

1 i

i

!					_		\sim) \sim \sim : :
•		[]		NORMAL	10 OPERAT		
•					Coxe 4	BUNCASS FLOUD	
:					KATE! (LEH/BEC) NS	
:	•	We+B'			COEFA		
	•	(#/sec)					
							S Cartelia
i		6000					
: : !							
:							
•		4000					
	8			20		50	75 11 50
:		·	· · · · · · · · · · · · · · · · · · ·	, , , , , , , , , , , , , , , , , , ,	J.I.I.I.I.I.I.I.I.I.I.I.I.I.I.I.I.I.I.I		

To .		1 20
	J. S. TULENKO - MANAGER, FUEL ENGINEERING	
	R.V. DE MARS - CCTF LEADER R.V. Q. Man CORE CONDITION TASK FORCE	BDS 663.5
Cust.		File No. or Ref.
Subj.	CURRENT ASSESSMENT OF CORE CONDITION 4/7/79 (1800)	Date 4-7-79 - 7:48 p.m.
	This latter to caver one customer and one subject only.	
	ATTACHED IS THE CURRENT ASSESSMENT OF THE CORE CONDITION	BASED ON INFORMATION
	AVAILABLE AS OF 1/7/79 MOST OF THE INFORMATION USED IN	FORMING THIS ASSESS-
	MENT, IS STILL PRELIMINARY AND REQUIRES VERIFICATION AND	DOCUMENTATION. THE
•	MOST SIGNIFICANT UNCERTAINTY IS THE TIME AND TEMPERATURE	CONDITIONS PRESENT
	DURING THE CORE UNCOVERY.	· · · · · · · · · · · · · · · · · · ·
•		•
	THE CORE CONDITION TASK FORCE CONSIDERS THIS A PRELIMINAR	Y BUT REALISTIC
;	ESTIMATE BASED ON VARIOUS SOURCES OF INFORMATION INCLUDIN	IG INPUT FROM THE
	EPRI TASK FURCE ON FUEL DAMAGE ASSESSMENT.	
	AS FURTHER INFORMATION BECOMES AVAILABLE THE ASSESSMENT W	ILL BE UPDATED
	ACCORDINGLY.	۰ <u>.</u>
		· · · · · · · · · · · · · · · · · · ·
	RKK:dww	
	ΑΤΤΔΓΗΜΕΝΤ	· •
	CC: D.H. ROY	
•	E.A. WOMACK C.D. Morgan	
	XC: CORE CONDITION TASK FORCE	
		•
		•

- · ·

INTRODUCTION

THE PHYSICAL CONDITION OF THE CORE IS BASED ON THE FOLLOWING POSTULATED SEQUENCE OF EVENTS. THE CORE WAS UNCOVERED ~11 FT DURING THE FIRST 15 MINUTES FOLLOWING THE SECOND PUMP TRIP. (SEE FIG. 1) THE CORE WAS THEN UNCOVERED ⁸ FT FOR 105 MINUTES. FOR THE REMAINDER OF THE TRANSIENT, THE CORE WAS ASSUMED TO BE QUASI-COVERED TO THE POINT THAT NO SIGNIFICANT OXIDATION OCCURRED. DURING THE INITIAL UNCOVERING, THE CLADDING WOULD FAIL NEAR THE TOP OF THE ROD DUE TO STRESS RUPTURE. DEPENDING ON THE HEATING RATES, THESE FAILURES WOULD HAVE OCCURRED BETWEEN ~1200-1650°F. THIS MAY PRECLUDE INITIAL FAILURE BY EUTECTIC FORMATION BETWEEN INCONEL GRID AND ZIRCALOY RODS. CLADDING STRAINS DUE TO HIGH-TEMPERATURE DEFORMATION PRIOR TO RUPTURE COULD APPROACH 35%. DURING THE HOLD TIME SUBSEQUENT TO THE RUPTURE, THE CLADDING OXIDIZED SEVERELY, FORMING ZIRCONIUM OXIDE AND RELEASING HYDROGEN GAS. THE DEGREE OF OXIDATION WILL VARY WITH THE POWER, HAVING BOTH AXIAL AND RADIAL DISTRIBUTION. THE DEGREE OF OXI-DATION ALONG THE LENGTH OF A ROP COULD VARY FROM NEGLIGIBLE AT THE BOTTOM TO 100% AT THE HOTTEST REGION NEAR THE TOP OF THE ROD.

BASED ON EVALUATION AND INTREPRETATION OF AVAILABLE INFORMATION AS OF (4/7/79) IT IS POSTULATED THAT THE CURRENT CORE CONDITION IS:

1. FUEL ROD PRESSURE BOUNDARY

APPROXIMATELY 90% OF THE FUEL RODS MAY HAVE PERFORATED CLADDING, ALLOWING RELEASE OF HELIUM AND VOLATILE FISSION PRODUCTS.

2. FUEL ROD STRUCTURAL INTEGRITY

MANY OF THE INTERIOR FUEL ASSEMBLIES MAY VIRTUALLY HAVE NO RECOGNIZABLE FUEL ROD ARRAY BETWEEN THE UPPER END FITTING AND FIRST (TOP) INTERMEDIATE SPACER GRIDS. IN SOME ASSEMBLIES THIS CONDITION MAY EXIST TO A LESSER EXTENT AS FAR DOWN AS THE SECOND OR THIRD INTERMEDIATE GRIDS. MOST OF THE PERIPHERAL RODS AND THE LOWER PORTION OF MOST RODS WILL BE OXIDIZED BUT NOT TO AN EXTENT TO SIGNIFICANTLY AFFECT STRUCTURAL INTEGRITY.

- 1 -

FUEL ASSEMBLY STRUCTURE

THE INTERMEDIATE INCONEL SPACER GRIDS SHOULD BE CLOSE TO THEIR ORIGINAL AXIAL POSITION. THE UPPER END GRID AND END FITTING IN MANY OF THE INTERIOR ASSEMBLIES MAY HAVE LITTLE STRUCTURAL SUPPORT. THE FIRST AND SECOND INTERMEDIATE SPACER GRIDS IN THESE INTERIOR ASSEMBLIES ARE LIKELY TO BE SUPPORTED AXIALLY FROM BELOW BY BADLY OXIDIZED GUIDE TUBES AND POSSIBLY FUEL RODS. THE REMAINING LOWER GRIDS ARE EXPECTED TO HAVE STRUCTURAL SUPPORT FROM THE DEGRADED BUT REMAINING GUIDE TUBES AND FUEL RODS.

4. ZIRCALOY COMPONENT MATERIAL CONDITION

THE ZIRCONIUM OXIDE (Zro2) PRODUCED BY THE OXIDATION OF THE ZIRCALOY COMPONENTS HAS RELATIVELY LOW DENSITY AND CAN RANGE IN FORM FROM SMALL PARTICLES OF A FEW MILS IN SIZE, TO IRREGULAR SHAPED FLAKES OF A FEW MILS IN THICKNESS AND UP TO A QUARTER INCH ON A SIDE, TO VIRTUALLY INTACT TUB-ULAR BUT FRAGILE SEGMENTS OF CLADDING. THE PARTICLES AND FLAKES ARE LIKELY TO BE MOBILE IN MOVING WATER. THESE PARTICLES CAN BE EXPECTED TO LODGE IN THE UPSTREAM SIDE OF ANY FLOW RESTRICTION SUCH AS SPACER GRIDS. GRAVITY MAY BE SUFFICIENT TO CAUSE THE LARGER ZIRCALOY AND Zro, FRAGMENTS TO SETTLE OUT ON THE DOWNSTREAM OR UPPER SIDE OF SPACER GRIDS. THE QUANTITY OF Zro, AND FRAGMENTED ZIRCALOY PRODUCED DURING THE PARTIAL CORE UNCOVERY IS LARGE. EXCEPT FOR SOME RODS IN PERIPHERAL ASSEMBLIES AND THE LOWER PORTION OF MOST RODS IN ALL ASSEMBLIES, THE TEMPERATURES PROJECTED FOR THE ZIRCALOY FUEL RODS WAS SUFFICIENT TO CAUSE SIGNIFICANT OXIDATION. THUS, THE MOBILITY, QUANTITY AND ORIGIN OF Zr02 IS SUCH THAT LOCAL FLOW BLOCKAGE COULD BE EXPECTED TO OCCUR IN ALMOST ANY LOCATION IN THE CORE. HOWEVER, THE MOST EXTENSIVE FLOW BLOCKAGE COULD BE EXPECTED IN THE UPPER CENTRAL PART OF THE CORE, WHERE THE Zro2 PARTICLES COULD FURTHER RESTRICT THE GENERAL FLOW RESTRICTION CAUSED BY THE HEAVIER FUEL PARTICLES AND FUEL ROD FRAGMENTS.

5. FUEL (UO_2) CONDITION

THE FUEL RELEASED FROM THE DETERIORATED CLADDING IS VERY DENSE. THE ORIGINAL SIZE OF PELLETS IS APPROXIMATELY 3/8 INCH IN DIAMETER BY 5/8 INCH LONG. UNDER IRRADIATION, THERMAL STRESSES CAUSE THE PELLETS TO BREAK UP INTO FRAGMENTS GENERALLY RANGING IN SIZE FROM 1/16 INCH TO 1/4 INCH ON A SIDE. DURING A TRANSIENT AND THE PERIOD FOLLOWING, THE FLOWING WATER AND STEAM CAN BE EXPECTED TO CAUSE SOME FUEL EROSION, WHICH WILL PRODUCE VERY

- 2 -

SHALL PARTICLES WHICH CAN BE SUSPENDED IN MOVING WATER.

IN THE CENTER ASSEMBLIES, IT IS LIKELY THAT MOST OF THE FUEL HAS BEEN RELEASED_FROM-THE RODS BETWEEN THE END FITTING AND THE SECOND OR THIRD INTERMEDIATE GRIDS. BASED ON THE UNDERSTANDING THAT THE FLOW IN THE CORE IS SEVERELY BLOCKED. THE FUEL FRAGMENTS HAVE SETTLED ON TO THE INTERMEDIATE GRIDS. LOCAL FLOW PERTURBATIONS CAN HOVE PELLET FRAGMENTS THROUGHOUT THE SYSTEM. FUEL FROM THE UPPER LEVEL MAY HAVE SETTLED DOWN THROUGH THE TOP' INTERMEDIATE SPACER GRID TO THE SECOND LEVEL AND LOWER LEVELS TO A LESSER EXTENT. THERE IS SOME REMOTE POSSIBILITY THAT THE STRUCTURE SUPPORTING THE FIRST TWO INTERMEDIATE GRIDS IN THE CENTER FEW ASSEMBLIES MAY COLLAPSE, CAUSING THE TOP 5 FT OF FUEL TO SETTLE ON THE THIRD INTERMEDIATE GRID. THE FUEL FRAGMENTS WOULD LIKELY BE MIXED IN WITH SOME REMAINING ZIRCALOY ROD FRAGMENTS. THE SPACE BETWEEN FRAGMENTS COULD BE FILLED WITH WATER, STEAM, Zro, OR SOME COMBINATION THEREOF. THE LARGE QUANTITY OF SMALL Zro, PARTICLES COULD CAUSE SOME LOCALIZED FLOW BLOCKAGE TO PREVENT FULL COVERAGE WITH WATER. THE PRESENCE OF SOME TUBULAR SEGMENTS COULD ALLOW LOCAL FLOW CHANNELING AND ATTENDANT "JETTING".

6. PROJECTED STABILITY OF CORE CONDITION

THE POSSIBILITY OF CONTINUED STRUCTURAL DEGRADATION REQUIRES FURTHER EVALUATION. FLOW BLOCKAGE IS LIKELY WHICH CAN CAUSE LOCALIZED BOILING. WHEN LOCALIZED BOILING EXISTS, A FURTHER REDUCTION IN SYSTEM PRESSURE WILL INCREASE THE AREA OF BOILING AND RAISE THE TEMPERATURE OF CLADDING IN THE AFFECTED AREA. IF THE TEMPERATURE OF ANY ZIRCALOY COMPONENT EXCEEDS 1000°F, ACCELERATED OXIDATION WILL ADD TO THE GENERATION OF HYDROGEN AND CAUSE FURTHER DEGRADATION OF THE CORE STRUCTURE.

7. DISTRIBUTION OF FUEL AND Zro, IN SYSTEM

IT IS VERY LIKELY THAT PARTICLES OF ZrO2 AND UO2 ARE CIRCULATING THROUGHOUT THE PRIMARY SYSTEM AND MAY SETTLE OUT IN STAGNANT AREAS.



ATTACHMENT

CORE MELT SCENARIOS

GENERAL

UNDER THE CONDITIONS OF NATURAL CIRCULATION, THE CORE WILL BE SURROUNDED BY COLD WATER NEAR 100[°]F. THE POSSIBILITY OF CORE MELT IS CONSIDERED TO BE REMOTE UNDER THESE CONDITIONS. WITH THE CURRENT LOW DECAY HEAT RATE AND WITH APPROPRIATE MONITORING OF INCORE THERMOCOUPLES, THERE WILL BE SUFFICIENT EARLY WARNING SIGNALS TO PREVENT A CORE MELT SITUATION.

CORE MATERIAL MELTING POINT

THE MELTING TEMPERATURES FOR THE CRITICAL FUEL ASSEMBLY MATERIALS ARE SUMMARIZED ON THE ATTACHED TABLE. THE MATERIALS INCLUDE THE FUEL ASSEMBLY STRUCTURAL MATERIALS (END FITTINGS, GRIDS, HOLDDOWN SPRING, AND GUIDE TUBES) AND PRIMARY FUEL ROD MATERIALS (PELLETS, CLADDING, AND END CAPS). IN ADDITION, THE MELTING TEMPERATURE OF THE CHROMEL ALUMEL THERMOCOUPLES IS ALSO INCLUDED.

至5.3

ASSESSMENT OF ORIGINAL FUEL DAMAGE CONDITIONS

DURING THE INITIAL ACCIDENT, WHEN THE CORE WAS PARTIALLY UNCOVERED, THE THERMAL CONDITIONS WERE VERY SEVERE. HOWEVER, THERE ARE INDICATIONS THAT THE CORE DID NOT UNDERGO MELTING.

THE DECAY HEAT RATE WAS IN EXCESS OF 25 MM_T. ANY WATER NEAR THE CORE WAS NEAR SATURATION TEMPERATURE OR ~500-650°F. UNDER THESE CONDITIONS THE FUEL ROD CLADDING REACHED 2000F OR HIGHER AND OXIDIZED SEVERELY TO PRODUCE HYDROGEN. HOWEVER, CONTINUED OPERATION OF THE INCORE CHROMEL ALUMEL THERMOCOUPLES, WHICH HAVE A MELTING POINT NEAR 2500F, INDICATE THAT THE STEAM TEMPERATURE INSIDE OF THE INSTRUMENT TUBE WAS LESS THAN 2500F. THIS IS APPROXIMATELY 2500F FROM THE MELTING POINT OF UO₂. THE CENTER-LINE TEMPERATURE OF UO₂ PELLET FRAGMENTS IS ESTIMATED TO BE NO MORE THAN 100F HIGHER THAN THE STEAM; THUS, SHOWING A LARGE HARGIN TO UO₂ MELTING. LOCAL HOTSPOTS FUEL MAY HAVE BEEN HIGHER FOR SHORT PERIODS BUT THE ESTIMATED 2500F MARGIN TO MELTING WAS SUFFICIENT TO PRECLUDE MELTING.

THE RADIOCHEMISTRY ANALYSIS OF B_A 140 AND OTHER ISOTOPES IN COOLANT SAMPLE TAKEN A DAY AFTER THE ACCIDENT DID NOT INDICATE THAT UO₂ MELTING HAD OCCURRED.

EARLY WARNING SIGNALS

DURING THE TRANSITION TO NATURAL CIRCULATION, THE INCORE THERMO-COUPLES WILL BE MONITORED. THE TEMPERATURES ON THESE THERMOCOUPLES HAVE A NORMAL READOUT RANGE OF UP TO 900F. SINCE SOME LOCALIZED BOILING IS EXPECTED, A FEW OF THE THERMOCOUPLES CAN BE EXPECTED TO READ HIGHER THAN SATURATION TEMPERATURE. HOWEVER, BECAUSE OF THE SLOW HEAT UP OF THE OVERALL SYSTEM, THE MAJORITY OF THERMO-COUPLES, AS A GROUP, CAN BE USED TO MONITOR THE BULK COOLANT TEMPERATURE AT THE TOP OF THE CORE. A TEMPERATURES APPROACHING SATURATION TEMPERATURE WOULD BE AN EARLY INDICATOR THAT LOCALIZED BOILING WAS SPREADING AND THAT CORRECTIVE ACTION SHOULD BE TAKEN. LARGE AREAS OF BOILING ARE UNDESIRABLE SINCE THEY LEAD TO HIGH STEAM TEMPERATURES. WHEN THE STEAM EXCEEDS 1000F, THE ZIRCALOY COMPONENT WILL BEGIN TO OXIDE AND PRODUCE HYDROGEN. AT HIGHER TEMPERATURES THE RATE OF HYDROGEN PRODUCTION WILL INCREASE. HOWEVER, AS INDICATED IN **25.3**, EVEN WITH THE HIGH STEAM TEMPER-ATURES PRODUCED DURING THE INITIAL CORE UNCOVERY, THE UO₂ DID NOT MELT. THUS, THE INCORE THERMOCOUPLES CAN PROVIDE EARLY WARNING SIGNALS SUCH THAT CORRECTIVE ACTION CAN BE TAKEN TO PREVENT A CORE MELT SITUATION.

TABLE T

Melting Points of Core Materials

<u>Naterial</u>	Melting Poin
υο ₂	5081 (1)
Zr-4	3353 (2)
Inconel X-750	2570 (3)
Inconel 718	2323 (4)
CF3MSS (and fitting)	. 2550 (5)
Zr 02	5010 (6)
Chromel Alumel	2500 (7)

Oxidation of Zircaloy is assumed to initiate at 1000 F

 Hausner, H., "Determination of the Melting Point of Uranium Dioxide", Journal of Nuclear Materials, Vol. 15, 1965.

2. Hammer, R. R., In-1093, Sept., 1967.

3. Huntington Alloys Technical Bulletin, Inconel Alloy X-750, (1970).

4. Huntington Alloys Technical Bulletin, Inconel Alloy 718, (1968).

5. Materials Engineering, Materials Selector 77.

6. Lynch, J. F., et al, Engineering Properties of Selected Ceramic Materials, (1966).

7. Neast, R. C., CRC Handbook of Chemistry and Physics, 48th Ed, (1968).