#### **CONTAINMENT SYSTEMS**

### CONTAINMENT VENTILATION SYSTEM

## LIMITING CONDITION FOR OPERATION

3.6.1.7 Each containment purge supply and exhaust isolation valve shall be OPERABLE and:

- a. Each 48-inch containment purge supply and exhaust isolation valve shall be sealed closed.
- b. The 8-inch containment purge supply and exhaust isolation valves may be open for purging and/or venting as required for safety related purposes such as:
  - 1. Maintaining containment pressure within the limits of Specification 3.6.1.4.
  - 2. Reducing containment atmosphere airborne radioactivity and/or improving air quality to an acceptable level for containment access.

#### APPLICABILITY: MODES 1, 2, 3 and 4.

### ACTION:

- a. With a 48-inch containment purge supply and/or exhaust isolation valve(s) open or not sealed closed, close and/or seal close the open valve(s) or isolate the penetration(s) within 4 hours, otherwise be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.
- b. With an 8-inch containment purge supply and/or exhaust isolation valve(s) open for reasons other than those stated in Specification 3.6.1.7.b, close the open 8-inch valve(s) or isolate the penetration(s) within 4 hours, otherwise be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.
- c. With a containment purge supply and/or exhaust isolation valve(s) having a measured leakage rate exceeding the limits of Surveillance Requirements 4.6.1.7.3 and/or 4.6.1.7.4, within 24 hours either restore the inoperable valve(s) to OPERABLE status or isolate the affected penetration flow path by use of at least one closed and de-activated automatic valve with resilient seals or blind flange, verify the affected penetration flowpath is isolated, and perform Surveillance Requirement 4.6.1.7.3 or 4.6.1.7.4 for resilient seated valves closed to isolate the penetration flowpath, otherwise be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.
  - 1. Closed and de-activated automatic valve(s) with resilient seals used to isolate the penetration flowpath(s) shall be tested in accordance with either Surveillance Requirement 4.6.1.7.3 for 48-inch valves at least once per 6 months or Surveillance Requirement 4.6.1.7.4 for 8-inch valves at least once per 92 days.
  - 2. Verify\* the affected penetration flowpath is isolated once per 31 days for isolation devices outside containment and prior to entering MODE 4 from MODE 5 for isolation devices inside containment if not performed within the previous 92 days.
- \* Verification of isolation devices by administrative means is acceptable when they are located in high radiation areas or they are locked, sealed, or otherwise secured by administrative means.

## **CONTAINMENT SYSTEMS**

## CONTAINMENT VENTILATION SYSTEM

# LIMITING CONDITION FOR OPERATION (continued)

### SURVEILLANCE REQUIREMENTS

**4.6.1.7.1** Each 48-inch containment purge supply and exhaust isolation valve shall be verified to be sealed-closed at least once per 31 days.

**4.6.1.7.2** Documentation shall be reviewed every 18 months to confirm that purging and venting were performed in accordance with Specification 3.6.1.7.b.

4.6.1.7.3 At least once per 6 months on a STAGGERED TEST BASIS each sealed closed 48-inch containment purge supply and exhaust isolation valve with resilient material seals shall be demonstrated OPERABLE by verifying that the measured leakage rate is less than or equal to 0.05  $L_a$  when pressurized to  $P_a$ .

4.6.1.7.4 At least once per 92 days, each 8-inch containment purge supply and exhaust isolation valve with resilient material seals shall be demonstrated OPERABLE by verifying that the measured leakage rate is less than or equal to  $0.05 L_a$  when pressurized to  $P_a$ .