

March 23, 2006

Mrs. Mary G. Korsnick
Vice President R.E. Ginna Nuclear Power Plant
R.E. Ginna Nuclear Power Plant, LLC
1503 Lake Road
Ontario, NY 14519

SUBJECT: R.E. GINNA NUCLEAR POWER PLANT - REQUEST FOR ADDITIONAL
INFORMATION REGARDING MOVEMENT OF FUEL WITH EQUIPMENT
HATCH OPEN (TAC NO. MC8910)

Dear Mrs. Korsnick:

By a letter dated November 7, 2005, R.E. Ginna Nuclear Power Plant, LLC (Ginna LLC) requested an amendment to the Technical Specifications (TSs) for the R. E. Ginna Nuclear Power Plant. Specifically, Ginna LLC proposed to revise TS 3.9.3, "Containment Penetrations," to allow an emergency egress door, access door, or roll-up door, as associated with the equipment hatch, to be open, but capable of being closed, during core alterations or movement of irradiated fuel within containment.

The Nuclear Regulatory Commission staff has reviewed the information provided in the application and has determined that additional information is needed. The specific information is described in the enclosed request for additional information (RAI). During a telephone discussion with the Ginna LLC staff on March 22, 2006, it was agreed that a response would be provided within 45 days from the date of this letter.

If you have any questions, please contact me at 301-415-1457.

Sincerely,

/RA/

Patrick D. Milano, Senior Project Manager
Plant Licensing Branch I-1
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-244

Enclosure:
RAI

cc w/encl: See next page

March 23, 2006

Mrs. Mary G. Korsnick
Vice President R.E. Ginna Nuclear Power Plant
R.E. Ginna Nuclear Power Plant, LLC
1503 Lake Road
Ontario, NY 14519

SUBJECT: R.E. GINNA NUCLEAR POWER PLANT - REQUEST FOR ADDITIONAL
INFORMATION REGARDING MOVEMENT OF FUEL WITH EQUIPMENT
HATCH OPEN (TAC NO. MC8910)

Dear Mrs. Korsnick:

By a letter dated November 7, 2005, R.E. Ginna Nuclear Power Plant, LLC (Ginna LLC) requested an amendment to the Technical Specifications (TSs) for the R. E. Ginna Nuclear Power Plant. Specifically, Ginna LLC proposed to revise TS 3.9.3, "Containment Penetrations," to allow an emergency egress door, access door, or roll-up door, as associated with the equipment hatch, to be open, but capable of being closed, during core alterations or movement of irradiated fuel within containment.

The Nuclear Regulatory Commission staff has reviewed the information provided in the application and has determined that additional information is needed. The specific information is described in the enclosed request for additional information (RAI). During a telephone discussion with the Ginna LLC staff on March 22, 2006, it was agreed that a response would be provided within 45 days from the date of this letter.

If you have any questions, please contact me at 301-415-1457.

Sincerely,

/RA/

Patrick D. Milano, Senior Project Manager
Plant Licensing Branch I-1
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-244

Enclosure:
RAI

cc w/encl: See next page

Accession Number: ML060810211

| | | | | | |
|--------|-----------|-----------|-----------|-----------|--|
| OFFICE | LPLI-1\PM | LPLI-1\LA | AADB\BC | LPLI-1\BC | |
| NAME | PMilano | SLittle | MKotzalas | RLaufer | |
| DATE | 03/22/06 | 03/22/06 | 02/24/06 | 03/23/06 | |

Official Record Copy

REQUEST FOR ADDITIONAL INFORMATION RE: AMENDMENT TO RENEWED FACILITY
OPERATING LICENSE NO. DPR-18 FOR FUEL MOVEMENT WITH EQUIPMENT HATCH
OPEN AT R.E. GINNA NUCLEAR POWER PLANT

DISTRIBUTION:

PUBLIC

LPLI-1 Reading File

R. Laufer

RidsNrrDorlLpla

S. Little

RidsNrrLASLittle

P. Milano

RidsNrrPMPMilano

M. Kotzalas

RidsNrrDraAadb

L. Brown

OGC

RidsOgcMailCenter

ACRS

RidsAcrsAcnwMailCenter

B. McDermott, R-I

RidsRgn1MailCenter

B. Singal

RidsNrrDorlLdpr

cc: Plant Service list

R.E. Ginna Nuclear Power Plant

cc:

Mr. Michael J. Wallace
President
R.E. Ginna Nuclear Power Plant, LLC
c/o Constellation Energy
750 East Pratt Street
Baltimore, MD 21202

Mr. John M. Heffley
Senior Vice President and
Chief Nuclear Officer
Constellation Generation Group
1997 Annapolis Exchange Parkway
Suite 500
Annapolis, MD 21401

Kenneth Kolaczyk, Sr. Resident Inspector
R.E. Ginna Nuclear Power Plant
U.S. Nuclear Regulatory Commission
1503 Lake Road
Ontario, NY 14519

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Mr. Peter R. Smith, President
New York State Energy, Research,
and Development Authority
17 Columbia Circle
Albany, NY 12203-6399

Mr. Carey W. Fleming, Esquire
Senior Counsel - Nuclear Generation
Constellation Generation Group, LLC
750 East Pratt Street, 17th Floor
Baltimore, MD 21202

Mr. Charles Donaldson, Esquire
Assistant Attorney General
New York Department of Law
120 Broadway
New York, NY 10271

Ms. Thelma Wideman, Director
Wayne County Emergency Management
Office
Wayne County Emergency Operations
Center
7336 Route 31
Lyons, NY 14489

Ms. Mary Louise Meisenzahl
Administrator, Monroe County
Office of Emergency Preparedness
1190 Scottsville Road, Suite 200
Rochester, NY 14624

Mr. Paul Eddy
New York State Department of
Public Service
3 Empire State Plaza, 10th Floor
Albany, NY 12223

REQUEST FOR ADDITIONAL INFORMATION
REGARDING FUEL MOVEMENT WITH EQUIPMENT HATCH OPEN
R.E. GINNA NUCLEAR POWER PLANT, LLC
R.E. GINNA NUCLEAR POWER PLANT
DOCKET NO. 50-244

By a letter dated November 7, 2005 (Agencywide Documents Access and Management System Accession No. ML053190213), R.E. Ginna Nuclear Power Plant, LLC (the licensee) proposed a revision to Technical Specification 3.9.3, "Containment Penetrations," to allow an emergency egress door, access door, or roll-up door, as associated with the equipment hatch, to be open, but capable of being closed, during core alterations or movement of irradiated fuel within containment. In order to complete its review of the information in the application, the Nuclear Regulatory Commission (NRC) staff requests the following information:

1. In Enclosure 1 to the November 7, 2005, application, the licensee states that the proposed amendment would permit either both equipment hatch doors, the closure plate access door, or the roll-up door associated with the enclosure building to be open during refueling. The control room atmospheric dispersion factor (X/Q value) used in the dose assessment to support this amendment request assumes that the equipment hatch is the limiting case because it is the largest penetration and has the shortest distance to the control room air intake. However, the equipment hatch to control room X/Q values were generated assuming a diffuse (area) release, which could result in lower X/Q values than for a point source release slightly further from the control room intake.

Confirm that the control room X/Q values associated with a postulated release from the equipment hatch are more limiting than the postulated releases from the closure plate access door or the roll-up door associated with the enclosure building.