

From: Emmett Murphy
To: Drew Holland
Date: 3/9/06 9:49AM
Subject: Re: Plugging report.

Then it's OK to close it out.

>>> Drew Holland 03/09/06 9:48 AM >>>

Emmett: This TS is: "Following each inservice inspection of steam generator tubes the number of tubes plugged in each steam generator shall be reported to the commission within 15 days."

>>> Emmett Murphy 03/09/06 9:16 AM >>>

Drew, what does TS 6.6.7.a say? I just want to be clear on what requirement there April 11 report is responsive to.

DOCKET 50-368

PERTAINS TO SUCCESSFUL NRC REVIEW OF
AND-2 2005 STEAM GENERATOR
TUBE INSPECTION DURING OUTAGE.
NRR REVIEWED THE LICENSEE'S
INSPECTION REPORT AND FOUND IT
TO BE ADEQUATE.

Mail Envelope Properties (44104075.288 : 22 : 35304)

Subject: Re: Plugging report.
Creation Date: 3/9/06 9:49AM
From: Emmett Murphy

Created By: ELM@nrc.gov

Recipients

nrc.gov
owf4_po.OWFN_DO
DGH1 (Drew Holland)

Post Office
owf4_po.OWFN_DO

Route
nrc.gov

Files	Size	Date & Time
MESSAGE	966	03/09/06 09:49AM

Options

Expiration Date: None
Priority: Standard
Reply Requested: No
Return Notification: None

Concealed Subject: No
Security: Standard