Calvert Cliffs Nuclear Power Plant Constellation Generation Group, LLC 1650 Calvert Cliffs Parkway Lusby, Maryland 20657



March 24, 2006

U. S. Nuclear Regulatory Commission Washington, DC 20555

ATTENTION: Document Control Desk

SUBJECT:Calvert Cliffs Nuclear Power Plant
Unit Nos. 1 & 2; Docket Nos. 50-317 & 50-318
Independent Spent Fuel Storage Installation; Docket No. 72-8
Report of Changes, Tests, and Experiments – 10 CFR 50.59 and 10 CFR 72.48

In accordance with 10 CFR 50.59(d)(2) and 10 CFR 72.48(d)(2), Calvert Cliffs Nuclear Power Plant, Inc. hereby submits a report containing brief descriptions of changes, tests, and experiments approved under the provisions of 10 CFR 50.59 and 10 CFR 72.48.

Attachment (1) of this report includes 10 CFR 50.59 and 10 CFR 72.48 evaluations recorded and approved between January 1, 2005 and December 31, 2005.

Should you have questions regarding this matter, please contact Mr. L. S. Larragoite at (410) 495-4922.

Very truly yours, Ken F. Robinson

General Supervisor-Design Engineering

KFR/PSF/bjd

Attachment: (1) Calvert Cliffs Nuclear Power Plant Report of Changes, Tests, and Experiments [10 CFR 50.59(d)(2) and 10 CFR 72.48(d)(2)]

cc: P. D. Milano, NRC S. J. Collins, NRC Resident Inspector, NRC R. I. McLean, DNR

MMSSOI



CALVERT CLIFFS NUCLEAR POWER PLANT REPORT OF CHANGES, TESTS, AND EXPERIMENTS [10 CFR 50.59(d)(2) and 10 CFR 72.48(d)(2)]

Calvert Cliffs Nuclear Power Plant, Inc. March 24, 2006

Document Id	Doc Type	Rev Status	Revision	Date Issued
SE00495	50.59	64	0003	3/11/2005
Subject	ES200300217-000, Revision 3 (UN	IT 2 CYCLE 16 CORE RELOAD (2	005 RFO))	
Summary	The proposed activity is the core rel	oad and operation of Unit 2 Cycle 16	5 (2005-2007) in all plant modes.	
	Scope:			
	 Implement Zirc diboride In 	tergral Fuel Burnable Absorber (repl	laces Erbium)	
·	• Implement Annular Fuel P	ellets		
1	 Implement Low Enriched A 	Axial Blankets (2.6 w/o fuel)		
· · ·	 Implement Radial Enrichm 	ent Zoning		
	 Increase fresh fuel batch er 	nrichment to up to 4.60 w/o		
	Increase fuel cycle length ((~4.2% longer than any previous cycl	le)	
	 Implement more aggressive 	e fuel assembly management called t	he "T" pattern.	
	• Implement ABB-TV Heat	Transfer DNB Correlation (already in	n use on Unit 1)	
	 Implement the Westinghout 	ise physics APA code set (ANC/PAF	RAGON)	
· · · ·	Implement Xenon Swing A	Analytical Methodology		
	 Incorporate Thermal Powe 	r uprate of up to 1.4% to 2737 MWt	(Appendix K)	
	• Increase COLR peaking lin	mits to $F_{xy}^{T} = 1.70$ and $F_{r}^{T} = 1.65$ (before	ore and after Appendix K uprate)	
	Core Loading Pattern/Cycl	le Length/Cycle Specific Parameters		
	CECOR Library Replacem	nent Mid-Cycle (as required)		
	• Potential for Grid to Rod F	Fretting		
1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1	Core Operating Limits Rep	port (COLR) Changes		
	Refueling Boron Concentr	ation/Credited CEAs/Incore Shuffle	· · · · · · · · · · · · · · · · · · ·	
	UFSAR & Technical Requ	irements Manual TNC 15.3.3 Chang	e for Incore Instruments	
	UFSAR Changes for Batch	h 2V, cycle specific parameter update	es, ICIs, Chapter 14 events	
	• Replace all remaining old	CEAs (64)		
	• Insert both Framatome and	d Westinghouse test LFAs for a 2 nd c	ycle of irradiation.	
	ES200300217-000 Revision 3 authority	orized the alternate core loading patte	ern for operation in all plant Modes.	
	Since the NRC has already issued a	a change to Tech Spec 5.6.5 to add a	reference to the Zirc Diboride Topi	cal Report and references to the Westinghouse
	physics APA code set, no license an	mendment request is required to impl	lement this alternate core loading part	ttern for U2C16 in all plant Modes.
		hustod appingt the 9 oritoria -f 100F	DED 50 (a)(2) with the approximate	hat the proposed activity door not require union
	NRC approval.	anualed against the 8 criteria of 10CF	$K_{20,29}$ (C)(2), with the conclusion t	

Document Id	Doc Type	Rev Status	Revision	Date Issued
SE00495		64	0002	3/8/2005
Subject	ES200300217-000 Revision 2 (ALTERNATE CORE LOADING PAT	FRN (MODES 5 AND 6 ONLY)	
Subject	The proposed activity is the corr	reload and operation of Unit 2 Cycle 1	6 (2005-2007) in all plant modes	
Summary	Scope:			
•	Implement Zirc diborio	e Intergral Fuel Burnable Absorber (ren	laces Erbium)	
•	Implement Annular Fu	el Pellets		
	Implement Low Enrich	ed Axial Blankets (2.6 w/o fuel)		
• . • .	Implement Radial Enri	chment Zoning		
	 Increase fresh fuel bate 	h enrichment to up to 4.60 w/o		
: · · · ·	• Increase fuel cycle len	th (~4.2% longer than any previous cyc	le)	
	• Implement more aggre	ssive fuel assembly management called	the "T" pattern.	
	 Implement ABB-TV H 	cat Transfer DNB Correlation (already i	n use on Unit 1)	
	• Implement the Westing	house physics APA code set (ANC/PA)	RAGON)	
· · · ·	 Implement Xenon Swi 	ng Analytical Methodology		
	Incorporate Thermal P	ower uprate of up to 1.4% to 2737 MWt	(Appendix K)	
	 Increase COLR peakin 	g limits to $F_{xy}^{T}=1.70$ and $F_{r}^{T}=1.65$ (before	ore and after Appendix K uprate)	
	Core Loading Pattern/	Cycle Length/Cycle Specific Parameters		
	CECOR Library Repla	cement Mid-Cycle (as required)		
	Potential for Grid to R	od Fretting		
	Core Operating Limits	Report (COLR) Changes		
	 Refueling Boron Conc 	entration/Credited CEAs/Incore Shuffle		· · ·
	 UFSAR & Technical F 	equirements Manual TNC 15.3.3 Chang	ge for Incore Instruments	
	UFSAR Changes for E	atch 2V, cycle specific parameter updat	es, ICIs, Chapter 14 events	
	Replace all remaining	old CEAs (64)		
	Insert both Framatome	and Westinghouse test LFAs for a 2^{nd} c	ycle of irradiation	
	ES200300217-000, Revision 2	authorized the alternate core loading pat	tern for operation in plant Modes 5 a	and 6. Additional engineering and a revision to
	this 50.59 will be required before	re the alternate core loading pattern may	be used in plant Modes 1 through 4.	
	Since the NRC has already issu	ed a change to Tech Spec 5.6.5 to add a	reference to the Zirc Diboride Topi	cal Report and references to the Westinghouse
	physics ANC code set, no licen	se amendment request is required to imp	lement this alternate core loading pa	ttern for U2C16 in plant Modes 5 and 6.
	This proposed activity has been NRC approval.	evaluated against the 8 criteria of 10CF	R50.59 (c)(2), with the conclusion t	hat the proposed activity does not require prior
·		· · ·		

Document Id	Doc Type	Rev Status	Revision	Date Issued
SE00495	50.59	64	0001	3/4/2005
				····
Subject	ES200300217-000, Revision 1 (ALT)	ERNATE CORE LOADING PAT	TERN FOR U2C16 (2005-2007))	
Summary	The proposed activity is the core relo	ad and operation of Unit 2 Cycle 10	(2005-2007) in all plant modes.	
	Scope:			
	Implement Zirc diboride Inter	ergral Fuel Burnable Absorber (rep	laces Erbium)	
	• Implement Annular Fuel Pel			
1	• Implement Low Enriched A	xial Blankets (2.6 w/o fuel)		
	• Implement Radial Enrichme	nt Zoning		
1 A	• Increase fresh fuel batch enr	ichment to up to 4.60 w/o	•	
	• Increase fuel cycle length (~	4.2% longer than any previous cyc	le)	
	Implement more aggressive	fuel assembly management called	the "I" pattern.	
	• Implement ABB-TV Heat T	ransfer DNB Correlation (already i	n use on Unit 1)	
	• Implement the Westinghous	e physics APA code set (ANC/PAI	RAGON)	
	• Implement Xenon Swing Ar	alytical Methodology		
	Incorporate Thermal Power	uprate of up to 1.4% to 2737 MWt	(Appendix K)	
	 Increase COLR peaking lim 	its to F_{xy} = 1.70 and F_r = 1.65 (before	ore and after Appendix K uprate)	
	Core Loading Pattern/Cycle	Length/Cycle Specific Parameters		
	CECOR Library Replaceme	nt Mid-Cycle (as required)	an a	
	• Potential for Grid to Rod Fr	etting		والمحفظة فالأرجار والمراد وتترك المغتر والمناجر وأرد والمعا
•	Core Operating Limits Repo	ort (COLR) Changes		
	Refueling Boron Concentrat	ion/Credited CEAs/Incore Shuffle		
· · ·	UFSAR & Technical Require	rements Manual TNC 15.3.3 Chang	e for Incore Instruments	
	UFSAR Changes for Batch	2V, cycle specific parameter update	es, ICIs, Chapter 14 events	
1 ·	Replace all remaining old C	EAs (64)		المعالم المراجع المراجع المحمد المراجع المحمد المحمد المراجع المحمد المحمد المحمد المحمد المحمد المحمد المحمد وما يراجع المراجع المحمد ال
	• Insert both Framatome and	Westinghouse test LFAs for a 2 nd c	ycle of irradiation	
	ES200300217-000, Revision 1 autho	rizes an alternate core loading patt	ern for Unit 2 Cycle 16 (U2C16). Fi	uel "sipping" during the 2005 refueling pattern
1	identified that fuel assembly 2S118 (which was planned on being reinse	erted into the U2C16 core) contains a	at least one failed fuel rod. This fuel assembly
	may be reused provided that the leal	king pin(s) are replaced with stain	less steel rod(s) per previously appro	oved limits. The alternate core loading patter
	does not use 2S118. Either core load	ling patter may be used. However,	, at this time, the alternate core loadi	ng pattern is only authorized for Mode 6 plant
	operation. Additional engineering a	nd a revision to this 50.59 will be	required before the alternate core I	oading pattern may be used in plant modes 1
· .	through 5. Since the NRC has alrea	dy issued a change to Tech Spec	5.6.5 to add a reference to the Zirc	Diboride Topical Report and references to the
	westinghouse physics ANC code set	, no license amendment request is r	equired to implement this alternate c	ore loading pattern for U2C16.
	·			

This proposed activity has been evaluated against the 8 criteria of 10CFR50.59 (c)(2), with the conclusion that the proposed activity does not require prior NRC approval.

3 ·

Document Id	Doc Type	Rev Sta	tus Revision	Date Issued
SE00495	50.59	64	0000	2/24/2005
		·		
Subject	ES200300217-000, Revision	0 (UNIT 2 CYCLE 16 COR	E RELOAD (2005 RFO))	
Summary	The proposed activity is the	core reload and operation of	Unit 2 Cycle 16 (2005-2007) in all plan	t modes.
	Scope:			
	• Implement Zirc dib	oride Intergral Fuel Burnable	e Absorber (replaces Erbium)	
	Implement Annular	Fuel Pellets	/ A N	
	Implement Low En	riched Axial Blankets (2.6 w	/o fuel)	
	• Implement Radial B	Inrichment Zoning		
	• Increase fresh fuel	batch enrichment to up to 4.6	0 w/o	
	• Increase fuel cycle	length (~4.2% longer than an	ly previous cycle)	
	Implement more ag	gressive fuel assembly mana	gement called the "1" pattern.	
	• Implement ABB-1	V Heat Transfer DNB Correl	ation (already in use on Unit 1)	
	• Implement the Wes	tinghouse physics APA code	set (ANC/PARAGON)	
	• Implement Xenon :	Swing Analytical Methodolog		
	Incorporate Therma	I Power uprate of up to 1.4%	to 2737 MWt (Appendix K)	
	• Increase COLR pea	king limits to $F_{xy} = 1.70$ and I	$F_r = 1.65$ (before and after Appendix K.	uprate)
	Core Loading Patte	rn/Cycle Length/Cycle Speci	inc Parameters	
	CECOR Library Re	eplacement Mid-Cycle (as rec	quired)	
	• Potential for Grid t	o Rod Fretting		
	Core Operating Lin	nits Report (COLR) Changes		
	Refueling Boron C	oncentration/Credited CEAs/	Incore Shuffle	
	UFSAR & Technic	al Requirements Manual TN	C 15.3.3 Change for Incore Instruments	
	UFSAR Changes for	or Batch 2V, cycle specific pa	arameter updates, ICIs, Chapter 14 even	its
	Replace all remain	ng old CEAs (64)		
	Insert both Framato	ome and Westinghouse test L	FAs for a $2^{n\alpha}$ cycle of irradiation	
	ES200300217-000 Revision	n 0 evaluated the operation o	f Unit 2 Cycle 16 (2005-2007) in all nl	ant modes. New design features implemented for the first
	time at Calvert Cliffs include	le Zirc Diboride, axial blank	ets, annular fuel pellets, and radial enri	chment zoning. Some fuel pellets will not be enriched to
	4.60 w/o. The ABB-TV DI	NB correlation (previously in	nplemented on Unit 1) will not be appl	icable to Unit 2 since the majority of fuel assemblies now
	contain mixing vanes. Fou	Lead Fuel Assemblies (LF	As) from Westinghouse and four LFAs	from Framatome/AREVA previously inserted during the
	2003 RFO will be reinserted	during the 2005 RFO for the	eir 2nd cycle of irradiation.	
		.		
	Tech Specs 5.6.5 must be	revised to add the following	5 new references for Zirc Diboride a	nd the Westinghouse physics codes. AIT ES200300217
	Milestone 099 has been ope	ned to verify that the NRC is	sues this change prior to any Batch 2V f	fuel being put into the reactor core.
	-WCAP-11596-P-A, "Quali	lication of the PHOENIX-P,	ANC Nuclear Design System for Pressu	irized water keactor Lores .
	-WCAP-10965-P-A, "ANC:	A westinghouse Advanced	Nodal Computer Code"	"homosurente to ANIC Ded Derror Deserver"
	-WCAP-10965-P-A Addend	ium I, "ANC: A Westinghou	ise Auvanced Nodal Computer Code; E	nnancements to ANC Kod Power Recovery"
L	-wCAP-160/2-P-A, "Imple	mentation of Zirconium Dibe	oride Burnable Absorber Coatings in CE	nuclear Power Fuel Assembly Designs
			4	

	Safety Evaluations approved by NSRB, 1/1/2005 through 12/31/2005
	-WCAP-16045-P-A, "Qualification of the Two-Dimensional Transport Code PARAGON"
	This proposed activity has been evaluated against the 8 criteria of 10CFR50.59 (c)(2), with the conclusion that the proposed activity does not require prior NRC approval.
Document Id SE00496	Doc TypeRev StatusRevisionDate Issued50.5964000011/23/2004
Subject	TEMPORARY ALTERATION (T/A) 1-04-0060 (SILICA REMOVAL SKID INSTALLATION/OPERATION SUPPORTING 2005 UNIT 2 RFO)
Summary	A temporary filtration skid using reverse osmosis filtration technology will be installed on the 69' elevation of the Auxiliary Building south of the SFP. The skid will be used to filter silica from the SPF by recycling SFP water through flexible supply and return hoses. The skid will require electrical, demineralized water, and compressed air services. This evaluation addresses adverse affects on UFSAR described design functions identified in the 10 CFR 50.59 Screen associated with TA 1-03-042. This activity is for a one time performance of cleaning up silica from the Spent Fuel Pool (SFP). The maximum change in silica concentration that is allowed to be processed from Unit 1 and 2 Spent Fuel Pools shall not exceed 15 mm
	The purpose of this activity is to reduce silica levels in the Spent Fuel Pool (SFP). The source of silica has been determined to be a chemical byproduct of the gradual deterioration of the boraflex poison used in the Unit 2 SFP racks. At high concentrations, silica is a chemical contaminant in the reactor coolant system (RCS). Under operating conditions high concentrations of silica combine with other chemical impurities in the RCS and result in plate-out of insulating compounds on the fuel clad causing reduced heat transfer.
	This activity is supported by CA06346, Rev. 0. The criticality code, KENO (previously approved by the NRC), was used to calculate the delta k effective between the current design basis Unit 2 fuel rack criticality case and a Unit 2 fuel rack boraflex reduction case. The resulting k-effective was determined to be significantly less than the two-signma uncertainty associated with the KENO code. As a result, the criteria for determining "not more than a minimal increase" of NEI 96-07, Rev. 1, was met.
	This proposed activity has been evaluated against the 8 criteria of 10CFR50.59 (c)(2), with the conclusion that the proposed activity does not require prior NRC approval.