

ACTIONS (continued)

SURVEILLANCE	FREQUENCY
<p>SR 3.3.2.10 -----NOTE-----                      Not required to be performed for the turbine driven AFW pump until 24 hours after SG pressure is <math>\geq</math> 532 psig.                      -----                      Verify ESF RESPONSE TIMES are within limits.</p>	<p>18 months on a STAGGERED TEST BASIS</p>
<p>SR 3.3.2.11 -----NOTE-----                      Verification of setpoint not required.                      -----                      Perform TADOT.</p>	<p>18 months</p>

Table 3.3.2-1 (page 6 of 6)  
Engineered Safety Feature Actuation System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	CONDITIONS	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE(a)
7. Automatic Switchover to Containment Sump					
a. Automatic Actuation Logic and Actuation Relays	1, 2, 3, 4	2 trains	C	SR 3.3.2.2 SR 3.3.2.4 SR 3.3.2.6	NA
b. Refueling Water Storage Tank (RWST) Level - Low Low	1, 2, 3, 4	4	K	SR 3.3.2.1 SR 3.3.2.5 SR 3.3.2.9 SR 3.3.2.10	≥ 43.9% instrument span
Coincident with Safety Injection	Refer to Function 1 (Safety Injection) for all initiation functions and requirements.				
8. ESFAS Interlocks					
a. Reactor Trip, P-4	1, 2, 3	1 per train, 2 trains	F	SR 3.3.2.11	NA
b. Pressurizer Pressure, P-11	1, 2, 3	3	L	SR 3.3.2.5 SR 3.3.2.9	≤ 1975.2 psig (Unit 1) ≤ 1976.4 psig (Unit 2)

(a) The Allowable Value defines the limiting safety system setting. See the Bases for the Trip Setpoints.