



GE Energy

**Proprietary Notice**

*This letter forwards proprietary information in accordance with 10CFR2.390. Upon the removal of Enclosure 1 and the Enclosure 2 compact disk, the balance of this letter may be considered non-proprietary.*

David H. Hinds  
Manager, ESBWR

PO Box 780 M/C L60  
Wilmington, NC 28402-0780  
USA

T 910 675 6363  
F 910 362 6363  
david.hinds@ge.com

MFN 06-094

Docket No. 52-010

March 28, 2006

U.S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, D.C. 20555-0001

**Subject: Revised Response - GE Response to Results of NRC Acceptance Review for ESBWR Design Certification Application – Item 2**

Reference 1 submitted additional information in certain areas of the ESBWR design certification application, required for the NRC to begin its review in those areas. Subsequent to the submittal of this design information, revisions were made to the feedwater line model to improve the analytical representation of the feedwater line break area and to incorporate minor reviewer comments.

The enclosures update the information provided to the staff in Reference 1. The contents of this letter supersede the information provided by Reference 1 in their entirety.

Enclosure 1 contains:

- Response to NRC question regarding TRACG applicability for the feedwater line break.
- Design information (feedwater line model), which documents that the largest possible feedwater line break location and area was considered.
- Summary of ESBWR TRACG nodalization changes (from preapplication design to DCD design).
- Response to informal NRC questions regarding SCRAM water volume injected by HCUs, spillover hole locations/drywell annulus and suppression pool water level increase.

D068

Also, GE was requested during a conference phone call, to provide the ESBWR TRACG input decks for the 4,500 Mw LOCA/Containment cases. The requested input decks are provided in Enclosure 2.

Enclosures 1 and 2 contain GE proprietary information as defined by 10 CFR 2.390. GE customarily maintains this information in confidence and withholds it from public disclosure. A non-proprietary version of Enclosure 1 is contained in Enclosure 3. The information in Enclosure 2 is completely proprietary and a non-proprietary version is not available.

The Enclosure 4 affidavit identifies that the information contained in Enclosures 1 and 2 has been handled and classified as proprietary to GE. GE hereby requests that the information of Enclosures 1 and 2 be withheld from public disclosure in accordance with the provisions of 10 CFR 2.390 and 9.17.

If you have any questions about the information provided here, please let me know.

Sincerely,



David H. Hinds  
Manager, ESBWR

Reference:

1. MFN 05-109, Letter from David Hinds to U. S. Nuclear Regulatory Commission, *GE Response to Results of NRC Acceptance Review for ESBWR Design Certification Application – Item 2 (TAC # MC8168)*, October 20, 2005
2. MFN 05-103, Letter from U. S. Nuclear Regulatory Commission, to Steven A. Hucik, *Results of Acceptance Review for ESBWR Design Certification Application (TAC #. MC8168)*, September 23, 2005

Enclosures:

1. Revised Response - GE Response to Results of NRC Acceptance Review for ESBWR Design Certification Application – Item 2 – GE Proprietary Information
2. Compact Disk - ESBWR TRACG Input for the 4,500 Mw LOCA/Containment Analysis Cases - GE Proprietary Information

MFN 06-094

Page 3 of 3

3. Revised Response - GE Response to Results of NRC Acceptance Review for ESBWR Design Certification Application – Item 2 – Non-Proprietary Version
4. Affidavit, George B. Stramback, March 28, 2006

cc: WD Beckner, USNRC (w/o encl)  
GB Stramback, GE/San Jose (w/ encl)  
AE Cubbage, USNRC (w/ encl)  
LA Dudes USNRC (w/o enclosures)  
eDRF 0000-0037-3348

## **ENCLOSURE 3**

**MFN 06-094**

### **Revised Response - GE Response to Results of NRC Acceptance Review for ESBWR Design Certification Application – Item 2**

**Non-Proprietary Version**

#### **IMPORTANT NOTICE**

This is a non-proprietary version of Enclosure 1, which has the proprietary information removed. Portions of the enclosure that have been removed are indicated by an open and closed bracket as shown here [[            ]]

### **NRC Request**

Justify the applicability of the TRACG code and the associated PIRT and test programs to the FWLB. (The staff's approval of the TRACG thermal-hydraulic computer code for applicability to ESBWR LOCA analyses was based on the gravity driven cooling system line break, the bottom drain line break, and the main steam line break as the limiting break locations. The FW LB was not considered.) Provide justification of TRACG code applicability and associated PIRT and test programs.

## **GE Response - TRACG Applicability for Feedwater Line Break**

Reference 1 provides a summary of the changes between the ESBWR design evaluated by the NRC staff during the pre-application review and the current design in the DCD, as well as the rationale for the applicability of TRACG and the SER to the new design. The purpose of this document is to amplify on the item related to the feedwater line break becoming the limiting break in the LOCA analysis.

A break in the feedwater line represents a liquid line break from the downcomer region at an elevation above the top of the core. This is similar to the GDCS line break. The differences are that a feedwater line break would be at a higher elevation and has a larger maximum break area. It will be shown that the nature of the transient is similar for both breaks; the important phenomena are the same; and there is test coverage of these phenomena. Thus, TRACG should be applicable to the analysis of the feedwater line break, as well as the other breaks previously analyzed.

Tables 6.3-7 and 6.3-9 in the DCD show the operational sequences of ECCS for the feedwater and GDCS line breaks. The sequences are similar, with the feedwater break transient showing a faster progression. The transient scenarios are similar for the two transients. There is a large initial drop in the downcomer level as the static heads equalize inside and outside the shroud following scram and loss of feedwater flow. The break flow from the feedwater break is approximately three times as much as that from the GDCS line break (DCD Figures 6.3-11 and 6.3-35). This results in a faster downcomer level decrease (DCD Figures 6.3-9 and 6.3-33) and a more rapid depressurization (DCD Figures 6.3-10 and 6.3-34). The falling downcomer level triggers reactor isolation, IC initiation and ADS/GDCS timers for both transients. When DPV actuation begins, the SLCS system is signaled to start. The minimum chimney level is reached prior to GDCS injection. When the vessel pressure drops below the maximum injection pressure of the GDCS, GDCS flow into the vessel begins. The water level in the shroud is restored shortly thereafter.

The long term RPV transient scenarios for both break locations are discussed in Reference 1. For the feedwater line break, the long term level settles out close to the feedwater line elevation, substantially higher than the minimum short term level position.

The containment response to the feedwater line break is closer to that for the main steam line break, primarily because of the large break flow to the upper portion of the drywell. The break flow from the RPV is supplemented by the flow from the upstream portion of the feedwater piping. The analysis assumes that the inventory in the feedwater line to the direct contact feedwater heater is available to discharge into the drywell. The large initial break flow from both sides of the break results in a more pronounced drywell pressure peak due to vent clearing at about 6 seconds (DCD Table 6.2-7). Following vent clearing, the drywell pressure continues to increase due to an initial purge of the noncondensibles to the wetwell gas space, and a short term peak pressure is reached. This early peak pressure has a large margin to the design pressure of 4.137 bar, but is

slightly higher than the long term pressure at 72 hours for the feedwater line break. For the steam line break, the break flow from the upstream side is terminated by the rapid closure of the isolation valves. The vent clearing transient pressure rise is milder and the peak pressure is reached in the long term following the eventual transfer of the noncondensibles from the drywell to the wetwell. Apart from differences in the magnitudes of the early and late pressure peaks, the transient responses for the two break locations are similar.

#### Important Phenomena for the Feedwater Line Break

The ESBWR TRACG LTR (Reference 2) shows PIRTs for the LOCA scenario for the RPV and containment. Tables 1 and 2 were extracted from Reference 2.

Table 1 shows the PIRT for the GDCS line break for the RPV from Reference 2, to which columns have been added for the feedwater line break. The important phenomena are virtually identical for the two break locations. For the blowdown phase the important parameters are the break flow (from the break and the DPVs), flashing, level swell and redistribution of inventory in various regions of the RPV. For the GDCS injection phase, additional phenomena related to decay heat, mixing of the colder GDCS water and condensation of voids become important. The PIRT for the long term phase for the feedwater line break was provided in Reference 1. The important phenomena that govern the long term response are decay heat, PCC capacity (medium), and GDCS pool and RPV volumes vs. elevation.

Table 2 shows the PIRT from the containment perspective. This PIRT is taken from Reference 2 and covers the blowdown, GDCS injection and long term phases of the LOCA transient. For each of the three phases, a separate column provides the ranking of the phenomena. The PIRT was developed without consideration of a specific break location and is valid for feedwater line breaks as well as steam line, GDCS line and bottom drain line breaks.

The short-term drywell pressure response is governed by energy deposition by break flow and DPV discharge flow and energy removal from the drywell through main vent and PCCS flow, and condensation on walls and internal structures. The pressure difference required for clearing of the main vents controls the initial pressure increase in the drywell. Thermal stratification of the suppression pool is a key factor in determining how this energy is distributed within the pool; it sets the pool surface temperature and, therefore, the temperature and steam partial pressure in the wetwell gas space. Another key parameter controlling the short-term wetwell pressure is the extent to which the noncondensibles (nitrogen) initially in the drywell are purged to the wetwell in the initial blowdown.

In the GDCS injection phase, PCC performance and condensation by reactor inventory spilling from the break are important phenomena. Vacuum breaker openings are expected in this phase, returning noncondensibles from the wetwell to the drywell. The

long-term containment response is controlled primarily by the heat removal by the PCCS relative to the decay heat. The energy deposition in the wetwell is due to the PCC vent flow and any steam leakage from the drywell that bypasses the PCCS.

These phenomena are relevant for all break locations that discharge into the drywell.

In summary, no new phenomena are introduced by consideration of the feedwater line break.

#### TRACG Model Applicability for analysis of the Feedwater Line Break

Tables 2.3-1 and 3.3-1 of Reference 2 show TRACG model capability matrices for the RPV and containment respectively. These tables show that TRACG models have the capability to model the high ranked phenomena that determine the ESBWR LOCA response. As concluded above, the analysis of the feedwater line break introduces no new phenomena. Hence, these tables are also applicable to the feedwater line break and show that TRACG has the necessary models for the analysis.

#### Test Data Coverage for Feedwater Line Break

Tables 2.3-2, 2.3-3 and 2.3-4 in Reference 2 show that the highly ranked phenomena for LOCA for the RPV are covered by a combination of separate effect, component and integral tests. As the highly ranked phenomena for the feedwater line break are the same as for the GDCS line break, test coverage for the feedwater line break is also demonstrated by Tables 2.3-2 through 2.3-4. For example, break flow is covered by the PSTF and Marviken tests, level swell in the PSTF tests, and flashing and inventory redistribution in the GIRAFFE/SIT and GIST tests. Effects of GDCS injection were covered by the GIRAFFE/SIT and GIST tests and PCC performance by the prototypical PANTHERS tests. Thus, even though specific tests simulating a feedwater line break have not been performed in the GIST or GIRAFFE/SIT test facilities, the highly ranked phenomena have been covered by these tests.

Containment test coverage is indicated in Tables 3.3-2, 3.3-3 and 3.3-4 for separate effect, component and integral tests. For example, critical flow is covered by the PSTF and Marviken tests, the early blowdown period, pool stratification and vent clearing phenomena are covered by the PSTF tests; transport of noncondensibles to the wetwell is part of the GIRAFFE/SIT and PANDA tests. PCCS performance was tested in the prototypical PANTHERS tests and the long term phase is simulated in the PANDA tests.

#### Summary

Based on the above, it can be concluded that:

- The highly ranked phenomena for the feedwater line break are the same as for the GDCS line break for the RPV

- The highly ranked phenomena for the feedwater line break are covered by the PIRT in Reference 2 (Table 3.2-1) for the containment
- TRACG models are applicable to analyze these highly ranked phenomena
- There is adequate test coverage and TRACG qualification for these phenomena.

Therefore, TRACG is applicable for feedwater line break analysis.

References:

1. MFN 05-105, Letter from David H. Hinds to U.S. Nuclear Regulatory Commission, *TRACG LOCA SER Confirmatory Items (TAC # MC 1868)*, Enclosure 2, *Reactor Pressure Vessel (RPV) Level Response for the Long Term PCCS Period, Phenomena Identification and Ranking Table, and Major Design Changes from Pre-Application Review Design to DCD Design*, October 6, 2005.
2. 'TRACG Application for ESBWR', NEDC-33083P-A, March 2005.



|


**Table 2: LOCA/RPV PIRT (from Table 3.2-1 of NEDC-33083P-A)**

[[



This is a revision to the material submitted in MFN-109 which includes:

- 1) Design change to the FW line break area, RPV side.
- 2) Consideration of the FW flow venturies to set the FW line break area, BOP side.
- 3) Other miscellaneous changes in TRACG inputs for LOCA analysis.

#### **NRC Request**

Provide design information to document that the largest possible feedwater line break location and area was considered. State the break area on both sides of the break. 10 CFR 50.46 requires that a spectrum of break sizes and locations be analyzed to demonstrate that the limiting break has been identified.

## GE Response - Feedwater Line Model

Figure 3-1 shows the schematic of the entire feedwater line model. The model encompasses the feedwater lines from the FW heaters to the RPV. Figure 3-2 depicts a single flow path that represents parallel trains of FW heaters and FW pumps in the Turbine Building. Elevations are conservatively assumed so that the inventory can be flashed into the containment through the postulated break location.

Feedwater lines in the Steam Tunnel and in the containment are modeled with two loops: Intact Loop and Broken Loop, one for each 550 mm (22") main feedwater line in the steam tunnel and associated piping. Figure 3-3 shows a TEE component that represents the FW header in the Turbine Building and main feedwater lines in the Steam Tunnel. Two branches of TEE components end at the Isolation Valves near the containment boundary.

Figure 3-4 shows the Intact Loop inside the containment. Figure 3-5 shows the Broken Loop inside the containment. Inside the containment, each 550 mm main feedwater line is physically connected to an arc-shaped header that also has three 300 mm (12") risers connected to the feedwater nozzles inside the RPV. The flow area of the ring header is doubled to represent the branched flow and the three risers are combined in the TRACG model.

A guillotine break is postulated at the connection of main feedwater line to the arc-shaped header in the broken loop. The break flow area is  $0.1977 \text{ m}^2$  at each end of the guillotine break. The break flow from the reactor is flashed through one of these areas and the break flow from FW heater, pumps and the Intact Loop is flashed through the other area.

The break flow from the reactor is limited by the smallest flow area located in the sparger pipe, the thermal sleeve or the riser pipe. For the current feedwater sparger design, the smallest flow area is identified to be  $115 \text{ in}^2$  ( $0.07420 \text{ m}^2$ ) and this value is used in the safety analyses presented in the ESBWR Design Control Document, Tier 2, Chapter 6 (26A6642AT, Rev.1, January 2006).

The break flow from the FW heaters is limited by a venturi in the horizontal section of the feedwater lines. Figure 3-3 shows the locations of these venturies, one venturi in each feedwater line. The venturi flow area is  $0.049965 \text{ m}^2$  at the throat location.

In addition to the modeling of the break flow areas discussed above; there are several comments and corrections identified during the GE internal review and verification processes. These items have been incorporated into the TRACG input decks for the safety analyses presented in the ESBWR Design Control Document, Tier 2, Chapter 6 (26A6642AT, Rev.1, January 2006). These updated items are listed and discussed in the following.

- a. The transient input decks for the GDL (GDCS Line Break) and the FWL (Feedwater Line Break) cases was not built from the steady-state case with the corrected partial air pressure in the IC steam pipe. These input decks were corrected accordingly.
- b.  $KRVC = 1$ , for CHAN0212 (the heat transfer from CHAN to bypass), the corrected value should be 2. This correction applies to all cases.
- c. Transient GDL input decks were corrected to include the input block "IOPHTC.INP" which specifies the condensation heat transfer in the PCC tubes.
- d. VSSL cell two-phase level indicator (ILEV) used a value of -1 at Levels 14 and 15 in the downcomer. The recommended value is  $ILEV = 0$  (turn on the level tracking model) for two-phase level tracking in the downcomer. This correction applies to all cases.
- e. For 1 DPV failure, the input block "1-DPV\_FAILURE.BDK" specified the corrected total DPV flow area (reduced from 4 DPVs to 3 DPVs). However, the valve area opening time table used 4 steps to open 3 DPVs. Assuming the first DPV fails, the correct sequence should be no opening for the first step, and one DPV opens on each of the next 3 steps. The input block "1-DPV\_FAILURE\_VLTB.BDK" contains this correction. This correction applies to all cases.
- f. For 1 SRV failure, the input block "1-SRV\_FAILURE.BDK" specified the corrected total SRV flow area (reduced from 7 SRVs to 6 SRVs). However, the valve area opening time table used 2 banks to open 6 SRVs, the first bank opens 3/7 of the total area and the second bank opens the 4/7 of the total area. Assuming one SRV fail for the first bank, the correct sequence should be 2/6 of the total area for the first step and the 4/6 of the total area for the second step. The input block "1-SRV\_FAILURE\_VLTB.BDK" contains this correction. This correction applies to all cases.
- g. For FW flow measurement, two venturies are used in the horizontal sections of the FW lines. For ESBWR, each venturi has a flow area of  $0.049965 \text{ m}^2$  at the throat location.
- h. For FWL break cases, the input block specifies the total number of junction as 152. The corrected number of junction should be 154.
- i. The total FW line break flow area (from the RPV side) was identified as 115 sq.in ( $0.07420 \text{ m}^2$ ).
- j. Critical flow parameter  $PIRT84 = 1.19$ , corresponding to  $+2 \sigma$  uncertainty, is used in the FWL break case for the bounding containment pressure calculation.
- k. Radiological Gas Release – correction to FILL velocities to be consistent with the assumed FILL component pressure. This correction applies to all cases.

Item (j) is related to the uncertainty of the critical flow model in TRACG, or parameter  $PIRT84$ , in the TRACG input. The uncertainty range for critical flow is  $1\sigma = 9.5\%$  (NEDC-33083P-A, "TRACG Application for ESBWR", Mar. 2005, Table 3.4-1). The

corresponding range for  $\pm 2\sigma$  is (1.19 and 0.81). In the previous study (NEDC-33083P-A), the main steam line break was modeled and the peak containment pressure occurred at the tail end of the run (72 hours). Results of this study showed that critical flow multiplier (PIRT84) has a negative impact on the peak containment pressure. For MSL break, slower release (lower critical flow) of the RPV inventory to the DW would result in longer time period for the DW air to transfer to the WW through the PCCS. This results in less energy removed by the PCCS (due to higher air content in the mixture through the PCC) and more energy deposited in the suppression pool, or high containment pressure. A ( $-2\sigma$ ) value (or 0.81) was used for PIRT84 for the 4000 Mw ESBWR MSL break in NEDC-33083P-A.

For the 4500 Mw ESBWR, results of parametric study show that the FWL break results in containment pressure that is higher than the other breaks. For FWL break, the peak containment pressure occurs at about 100 seconds following the break. Due the large amount of high energy FW break flows (from the RPV and from the FW line connected to the FW heaters), all air in the upper region of the DW was pushed to the WW during the early stage of the transient. During this early stage, any additional break flow or DPV flow to the DW would result in higher DW pressure. For the bounding case, a ( $+2\sigma$ ) value (or 1.19 for PIRT84) and a single failure of 1 SRV are used for the bounding containment pressure calculation. Both of these conditions would result in higher break flow and higher total DPV flow to the DW and therefore higher DW pressure.




Figure 3-1. Feedwater Line Model for FWL Break Analysis




Figure 3-2. TRACG Model for Feedwater Lines in Turbine Building




Figure 3-3. TRACG Model for Feedwater Header in Turbine Building  
Main Feedwater Lines in Steam Tunnel




Figure 3-4 TRACG Feedwater Line Model for Intact Loop inside the Containment




Figure 3-5 TRACG Feedwater Line Model for Broken Loop inside the Containment




Non-Proprietary Information  
Summary of ESBWR TRACG Nodalization Changes  
From Pre-application Design to DCD Design  
DCD Acceptance Review, Item 2, Part C



[[

•

]]



REACTOR BUILDING  
FLOOR EL 9060



SECTION "A-A"  
ROTATED INTO VIEW  
(90°-270°)

**ENCLOSURE 4**

**MFN 06-094**

**Affidavit**

# General Electric Company

## AFFIDAVIT

I, George B. Stramback, state as follows:

- (1) I am Manager, Regulatory Services, General Electric Company ("GE") and have been delegated the function of reviewing the information described in paragraph (2) which is sought to be withheld, and have been authorized to apply for its withholding.
- (2) The information sought to be withheld is contained in Enclosures 1 & 2 (CD) of GE letter MFN 06-094, David H. Hinds to NRC, *Revised Response – GE Response to Results of NRC Acceptance Review for ESBWR Design Certification Application – Item 2*, dated March 28, 2006. The proprietary information in Enclosure 1, *Revised Response - GE Response to Results of NRC Acceptance Review for ESBWR Design Certification Application – Item 2*, is delineated by a double underline inside double square brackets. Figures and large equation objects are identified with double square brackets before and after the object. The proprietary information in Enclosure 2, *ESBWR TRACG Input decks for the 4,500 Mw LOCA/Containment Analysis*, is all the files on the CD. The CD label contains the designation "GE Proprietary Information <sup>{3}</sup>." In each case, the superscript notation<sup>{3}</sup> refers to Paragraph (3) of this affidavit, which provides the basis for the proprietary determination.
- (3) In making this application for withholding of proprietary information of which it is the owner, GE relies upon the exemption from disclosure set forth in the Freedom of Information Act ("FOIA"), 5 USC Sec. 552(b)(4), and the Trade Secrets Act, 18 USC Sec. 1905, and NRC regulations 10 CFR 9.17(a)(4), and 2.790(a)(4) for "trade secrets" (Exemption 4). The material for which exemption from disclosure is here sought also qualify under the narrower definition of "trade secret", within the meanings assigned to those terms for purposes of FOIA Exemption 4 in, respectively, Critical Mass Energy Project v. Nuclear Regulatory Commission, 975F2d871 (DC Cir. 1992), and Public Citizen Health Research Group v. FDA, 704F2d1280 (DC Cir. 1983).
- (4) Some examples of categories of information which fit into the definition of proprietary information are:
  - a. Information that discloses a process, method, or apparatus, including supporting data and analyses, where prevention of its use by General Electric's competitors without license from General Electric constitutes a competitive economic advantage over other companies;

- b. Information which, if used by a competitor, would reduce his expenditure of resources or improve his competitive position in the design, manufacture, shipment, installation, assurance of quality, or licensing of a similar product;
- c. Information which reveals aspects of past, present, or future General Electric customer-funded development plans and programs, resulting in potential products to General Electric;
- d. Information which discloses patentable subject matter for which it may be desirable to obtain patent protection.

The information sought to be withheld is considered to be proprietary for the reasons set forth in paragraphs (4)a., and (4)b, above.

- (5) To address 10 CFR 2.390 (b) (4), the information sought to be withheld is being submitted to NRC in confidence. The information is of a sort customarily held in confidence by GE, and is in fact so held. The information sought to be withheld has, to the best of my knowledge and belief, consistently been held in confidence by GE, no public disclosure has been made, and it is not available in public sources. All disclosures to third parties including any required transmittals to NRC, have been made, or must be made, pursuant to regulatory provisions or proprietary agreements which provide for maintenance of the information in confidence. Its initial designation as proprietary information, and the subsequent steps taken to prevent its unauthorized disclosure, are as set forth in paragraphs (6) and (7) following.
- (6) Initial approval of proprietary treatment of a document is made by the manager of the originating component, the person most likely to be acquainted with the value and sensitivity of the information in relation to industry knowledge. Access to such documents within GE is limited on a "need to know" basis.
- (7) The procedure for approval of external release of such a document typically requires review by the staff manager, project manager, principal scientist or other equivalent authority, by the manager of the cognizant marketing function (or his delegate), and by the Legal Operation, for technical content, competitive effect, and determination of the accuracy of the proprietary designation. Disclosures outside GE are limited to regulatory bodies, customers, and potential customers, and their agents, suppliers, and licensees, and others with a legitimate need for the information, and then only in accordance with appropriate regulatory provisions or proprietary agreements.
- (8) The information identified in paragraph (2), above, is classified as proprietary because it contains details of the ESBWR design for licensing application of TRACG to the ESBWR passive safety system design. GE has developed this TRACG code for over fifteen years, at a total cost in excess of three million dollars. The reporting, evaluation and interpretations of the results, as they relate to the ESBWR, was achieved at a significant cost, to GE.

The development of the evaluation process along with the interpretation and application of the analytical results is derived from the extensive experience database that constitutes a major GE asset.

- (9) Public disclosure of the information sought to be withheld is likely to cause substantial harm to GE's competitive position and foreclose or reduce the availability of profit-making opportunities. The information is part of GE's comprehensive BWR safety and technology base, and its commercial value extends beyond the original development cost. The value of the technology base goes beyond the extensive physical database and analytical methodology and includes development of the expertise to determine and apply the appropriate evaluation process. In addition, the technology base includes the value derived from providing analyses done with NRC-approved methods.

The research, development, engineering, analytical and NRC review costs comprise a substantial investment of time and money by GE.


The precise value of the expertise to devise an evaluation process and apply the correct analytical methodology is difficult to quantify, but it clearly is substantial.

GE's competitive advantage will be lost if its competitors are able to use the results of the GE experience to normalize or verify their own process or if they are able to claim an equivalent understanding by demonstrating that they can arrive at the same or similar conclusions.

The value of this information to GE would be lost if the information were disclosed to the public. Making such information available to competitors without their having been required to undertake a similar expenditure of resources would unfairly provide competitors with a windfall, and deprive GE of the opportunity to exercise its competitive advantage to seek an adequate return on its large investment in developing these very valuable analytical tools.

I declare under penalty of perjury that the foregoing affidavit and the matters stated therein are true and correct to the best of my knowledge, information, and belief.

Executed on this 28<sup>th</sup> day of March 2006

  
\_\_\_\_\_  
George B. Stramback  
General Electric Company

# ENCLOSURE 1

MFN 06-094

## Revised Response - GE Response to Results of NRC Acceptance Review for ESBWR Design Certification Application – Item 2

### IMPORTANT NOTICE

#### GE Proprietary Information

#### PROPRIETARY INFORMATION NOTICE

This enclosure contains proprietary information of the General Electric Company (GE) and is furnished in confidence solely for the purpose(s) stated in the transmittal letter. No other use, direct or indirect, of the document or the information it contains is authorized. Furnishing this enclosure does not convey any license, express or implied, to use any patented invention or, except as specified above, any proprietary information of GE disclosed herein or any right to publish or make copies of the enclosure without prior written permission of GE. The header of each page in this enclosure carries the notation "GE Proprietary Information."

GE proprietary information is identified by a double underline inside double square brackets. In each case, the superscript notation<sup>(3)</sup> refers to Paragraph (3) of the affidavit provided in Enclosure 4, which documents the basis for the proprietary determination. [[This sentence is an example.<sup>(3)</sup>]] Specific information that is not so marked is not GE proprietary.

## **ENCLOSURE 2**

**MFN 06-094**

### **Compact Disk**

## **ESBWR TRACG Input for the 4,500 Mw LOCA-Containment Cases**

### **IMPORTANT NOTICE**

### **GE Proprietary Information**

#### **PROPRIETARY INFORMATION NOTICE**

This enclosure contains proprietary information of the General Electric Company (GE) and is furnished in confidence solely for the purpose(s) stated in the transmittal letter. No other use, direct or indirect, of the document or the information it contains is authorized. Furnishing this enclosure does not convey any license, express or implied, to use any patented invention or, except as specified above, any proprietary information of GE disclosed herein or any right to publish or make copies of the enclosure without prior written permission of GE.

The entirety of the enclosed compact disk is proprietary. Therefore, the disk in this enclosure carries the notation "GE Proprietary Information. <sup>(3)</sup>." The superscript notation<sup>(3)</sup> refers to Paragraph (3) of the affidavit provided in Enclosure 4, which documents the basis for the proprietary determination.