

April 13, 2006

Mr. James J. Sheppard
President and Chief Executive Officer
STP Nuclear Operating Company
South Texas Project Electric
Generating Station
P. O. Box 289
Wadsworth, TX 77483

SUBJECT: SOUTH TEXAS PROJECT, UNIT 2 - RE: COMPLIANCE OF CONTROL ROOM
HABITABILITY TO APPLICABLE REGULATORY REQUIREMENTS
(TAC NO. MB9859)

Dear Mr. Sheppard:

In Generic Letter 2003-01 "Control Room Habitability" (GL-2003-01), the NRC staff states that, during the design of nuclear power plants, licensees performed analyses to demonstrate that the control room habitability systems (CRHSs), as designed, provide a habitable environment during postulated design basis events. These design analyses model the transport of potential contaminants into the control room envelope (CRE) and their removal. The amount of inleakage of assumed contaminants is important to these analyses, because unaccounted-for contaminants entering the CRE may impact the ability of the operators to perform plant control functions. If contaminants impair the response of the operators to an accident, there could be inadequate response to mitigate the impact of the accident consequences to the public health and safety.

Because of the importance of ensuring habitable control rooms under all normal and off-normal plant conditions, the addressees of GL-2003-01 were asked to provide confirmation that their facility's control room meets the applicable habitability regulatory requirements and that the CRHSs are designed, constructed, configured, operated, and maintained in accordance with the facility's design and licensing bases. The NRC staff specifically requested the addressees to confirm that the most limiting unfiltered inleakage (and the filtered inleakage if applicable) into their facility's CRE was no more than the value assumed in their design basis radiological analyses for control room habitability and incorporated into their hazardous chemical assessment, and that reactor control could be maintained from either the control room or the alternate shutdown panel in the event of evolution of smoke. Licensees were also requested to describe how and when they performed the analyses, tests, and measurements for this confirmation.

In a letter dated August 5, 2004, South Texas Project Nuclear Operating Company (STPNOC) provided the results of an integrated tracer gas test conducted at South Texas Project (STP), Unit 1, during the week of March 8, 2004. To date, Unit 2 has not been tested. It is STPNOC's position that it is sufficient to test only the Unit 1 CRE, since inleakage of the Unit 2 CRE can be inferred from the results of the Unit 1 test because the two unit's CREs are identical in terms of design, materials, and construction. Therefore, because STPNOC asserts that the two reactors and their associated balance of plant designs are identical, STPNOC believes the two CRE's performances of inleakage would be identical.

It is the NRC staff's experience, that structures (i.e. CREs) that are designed and constructed of the same materials by the same company with similar components rarely demonstrate identical inleakage performance. This is especially true with respect to inleakages measured during tests. For example, potential sources of CRE inleakage include the walls, floors, ceilings, ductwork that passes through the envelope, intake and exhaust dampers and ductwork of the CRE ventilation system, fans, filter housing, instrument air lines, and electrical penetrations. CRE inleakage is a function of the differential pressure gradient across the boundary of the envelope, where inleakage results from respective penetrations in the envelope. In order for two CREs to have identical inleakage characteristics, each of the two CREs should demonstrate identical differential pressure gradients at similar locations across the penetrations in the two CREs. With different heat generation and removal rates within the CRE and areas adjacent to the CRE, it is unlikely that this can be demonstrated. In order to assure identical performance, the redundant equipment must also perform in an identical manner. Experience has shown that, typically, there is a significant variation in the inleakage performance of redundant trains of ventilation equipment. This was evident in the STPNOC testing performed on STP, Unit 1, as discussed next.

STPNOC's letter dated August 5, 2004, provided test results from tracer gas testing performed at STP, Unit 1, during the week of March 8, 2004. The design of the control room emergency ventilation systems for Units 1 and 2 is based on three 50 percent trains serving the same control room. The possible inleakage test result configurations for Unit 1 as reported are:

Trains A & B 9.4±50 cfm

Trains A & C -27±50 cfm

Trains B & C 1.9±25 cfm

Note that the three trains of the same system serving the same CRE do not have identical inleakage results. The NRC staff expects that, if three trains in a different CRE were tested, it is unlikely that the results would be similar to the results obtained for Unit 1 and, in fact, it would be more likely that the results would be different and could be greater than the results for Unit 1. There are numerous reasons why differences exist. Some differences are based upon the buildings of interest having different locations or different orientations. Some other differences are attributed to reactors' balance-of-plant designs exhibiting different performance characteristics.

A review of plants' technical specifications shows that it is not acceptable to rely upon the test results from one train when the design consists of redundant trains. The staff finds that both trains need to be tested. Consequently, it is reasonable that all CREs should be tested even if they are considered to be identical in construction.

Therefore, contrary to STPNOC's position, the NRC staff concludes that Unit 2 should be tracer gas tested to determine CRE inleakage. As discussed above, the staff's conclusion is based upon the results of the Unit 1 tests and the Unit 1 and Unit 2 differential pressure measurements, testing results from other CREs, and current technical specification requirements for redundant trains.

J. Sheppard

- 3 -

If you have any questions please contact the NRC Project Manager, Mohan Thadani at (301) 415-1476.

Sincerely,

/RA/ Cornelius Holden for

Catherine Haney, Director
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-499

cc: See next page

J. Sheppard

- 3 -

If you have any questions please contact the NRC Project Manager, Mohan Thadani at (301) 415-1476.

Sincerely,

/RA/ Cornelius Holden for

Catherine Haney, Director
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-499

cc: See next page

DISTRIBUTION

PUBLIC

LPLIV Reading

RidsNrrDorl

RidsNrrDorlLplg

RidsNrrPMMThadani

RidsNrrLADJohnson

RidsNrrDorlDpr

RidsOgcRp

RidsAcrcAcnwMailCenter

RidsRgn4MailCenter

RDennig

HWalker

JHayes

ACCESSION NO: **ML060940664**

OFFICE	NRR/LPL4/PM	NRR/LPL4/LA	NRR/LPL4/BC	NRR/DORL/D
NAME	MThadani;sem2	DJohnson	DTerao	CHaney (CHolden for)
DATE	4/12/06	4/12/06	4/12/06	4/13/06

OFFICIAL RECORD COPY

South Texas Project, Units 1 & 2

cc:

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P. O. Box 910
Bay City, TX 77414

C. Kirksey/C. M. Canady
City of Austin
Electric Utility Department
721 Barton Springs Road
Austin, TX 78704

Mr. J. J. Nesrsta
Mr. R. K. Temple
City Public Service Board
P. O. Box 1771
San Antonio, TX 78296

INPO
Records Center
700 Galleria Parkway
Atlanta, GA 30339-3064

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011

Steve Winn
Texas Genco, LP
12301 Kurland Drive
Houston, TX 77034

Judge, Matagorda County
Matagorda County Courthouse
1700 Seventh Street
Bay City, TX 77414

A. H. Gutterman, Esq.
Morgan, Lewis & Bockius
1111 Pennsylvania Avenue, NW
Washington, DC 20004

E. D. Halpin
Vice President Oversight
STP Nuclear Operating Company
P. O. Box 289
Wadsworth, TX 77483

S. M. Head, Manager, Licensing
STP Nuclear Operating Company
P. O. Box 289, Mail Code: N5014
Wadsworth, TX 77483

Environmental and Natural Resources
Policy Director
P. O. Box 12428
Austin, TX 78711-3189

Jon C. Wood
Cox, Smith, & Matthews
112 East Pecan, Suite 1800
San Antonio, TX 78205

Director
Division of Compliance & Inspection
Bureau of Radiation Control
Texas Department of State Health Services
1100 West 49th Street
Austin, TX 78756

Brian Almon
Public Utility Commission
William B. Travis Building
P. O. Box 13326
1701 North Congress Avenue
Austin, TX 78701-3326

Susan M. Jablonski
Office of Permitting, Remediation
and Registration
Texas Commission on
Environmental Quality
MC-122
P.O. Box 13087
Austin, TX 78711-3087

Mr. Terry Parks, Chief Inspector
Texas Department of Licensing
and Regulation
Boiler Division
P. O. Box 12157
Austin, TX 78711

Mr. Ted Enos
4200 South Hulen
Suite 630
Ft. Worth, Texas 76109