

**AUDIT WORKSHEET**  
**GALL REPORT AMP**

PLANT: \_\_\_\_\_

LRA AMP: \_\_\_\_\_

REVIEWER: \_\_\_\_\_

GALL AMP: **XI.M7, BWR Stress Corrosion Cracking**

DATE: \_\_\_\_\_

Program Element	Auditable GALL Criteria	Documentation of Audit Finding
Program Description	A. The program to manage intergranular stress corrosion cracking (IGSCC) in boiling water reactor (BWR) coolant pressure boundary piping made of stainless steel (SS) and nickel based alloy components is delineated in NUREG-0313, Rev. 2, and Nuclear Regulatory Commission (NRC) Generic Letter (GL) 88-01 and its Supplement 1. The material includes base metal and welds. The program includes (a) preventive measures to mitigate IGSCC, and (b) inspection and flaw evaluation to monitor IGSCC and its effects. The staff-approved boiling water reactor vessel and internals project (BWRVIP-75) report allows for modifications to the inspection scope in the GL 88-01 program.	Consistent with GALL AMP: <input type="checkbox"/> Yes <input type="checkbox"/> No Document(s) used to confirm Criteria:  Comment:
1. Scope of Program	A. The program focuses on (a) managing and implementing countermeasures to mitigate IGSCC and (b) performing inservice inspection (ISI) to monitor IGSCC and its effects on the intended function of BWR components. The program is applicable to all BWR piping and piping welds made of austenitic SS and nickel alloy that is 4 in. or larger in nominal diameter and contains reactor coolant at a temperature above 93°C (200°F) during power operation, regardless of code classification. The program also applies to pump casings, valve bodies and reactor vessel attachments and appurtenances, such as head spray and vent components. NUREG-0313 and NRC GL 88-01, respectively, describe the technical basis and	Consistent with GALL AMP: <input type="checkbox"/> Yes <input type="checkbox"/> No Document(s) used to confirm Criteria:  Comment:

Program Element	Auditable GALL Criteria	Documentation of Audit Finding
	<p>staff guidance regarding mitigation of IGSCC in BWRs. Attachment A of NRC GL 88-01 delineates the staff-approved positions regarding materials, processes, water chemistry, weld overlay reinforcement, partial replacement, stress improvement of cracked welds, clamping devices, crack characterization and repair criteria, inspection methods and personnel, inspection schedules, sample expansion, leakage detection, and reporting requirements.</p>	
2. Preventive Actions	<p>A. The comprehensive program outlined in NUREG-0313 and NRC GL 88-01 addresses improvements in all three elements that, in combination, cause IGSCC. These elements consist of a susceptible (sensitized) material, a significant tensile stress, and an aggressive environment. Sensitization of nonstabilized austenitic SSs containing greater than 0.03 wt.% carbon involves precipitation of chromium carbides at the grain boundaries during certain fabrication or welding processes. The formation of carbides creates an envelope of chromium depleted region that, in certain environments, is susceptible to stress corrosion cracking (SCC). Residual tensile stresses are introduced from fabrication processes, such as welding, surface grinding, or forming. High levels of dissolved oxygen or aggressive contaminants, such as sulfates or chlorides, accelerate the SCC processes. The program delineated in NUREG-0313, NRC GL 88-01, and in the staff-approved BWRVIP-75 report includes recommendations regarding selection of materials that are resistant to sensitization, use of special processes that reduce residual tensile stresses, and monitoring and maintenance of coolant chemistry. The resistant materials are used for new and replacement components and include low-carbon grades of austenitic SS and weld metal, with a maximum carbon of 0.035 wt.% and a minimum ferrite of 7.5% in weld metal and cast austenitic stainless steel (CASS). Inconel 82 is the only commonly used nickel-base weld metal considered to be resistant to SCC; other nickel-alloys, such as</p>	<p>Consistent with GALL AMP: <input type="checkbox"/> Yes <input type="checkbox"/> No  Document(s) used to confirm Criteria:</p> <p>Comment:</p>

Program Element	Auditable GALL Criteria	Documentation of Audit Finding
	Alloy 600 are evaluated on an individual basis.	
“	B. Special processes are used for existing, new, and replacement components. These processes include solution heat treatment, heat sink welding, induction heating, and mechanical stress improvement. The program delineated in NUREG-0313 and NRC GL 88-01 does not provide specific guidelines for controlling reactor water chemistry to mitigate IGSCC. Maintaining high water purity reduces susceptibility to SCC or IGSCC. The program description, and evaluation and technical basis of monitoring and maintaining reactor water chemistry are addressed through implementation of Section XI.M2, “Water Chemistry.”	<p>Consistent with GALL AMP: <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Document(s) used to confirm Criteria:</p> <p>Comment:</p>
3. Parameters Monitored/ Inspected	A. The program detects and sizes cracks and detects leakage by using the examination and inspection guidelines delineated in NUREG-0313, Rev. 2, and NRC GL 88-01 or the referenced BWRVIP-75 guideline as approved by the NRC staff.	<p>Consistent with GALL AMP: <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Document(s) used to confirm Criteria:</p> <p>Comment:</p>
4. Detection of Aging Effects	A. The extent, method, and schedule of the inspection and test techniques delineated in NRC GL 88-01 or BWRVIP-75 are designed to maintain structural integrity and ensure that aging effects will be discovered and repaired before the loss of intended function of the component. The inspection guidance in approved BWRVIP-75 replaces the extent and schedule of inspection in NRC GL 88-01. The program uses volumetric examinations to detect IGSCC. NRC GL 88-01 recommends that the detailed inspection procedure, components, and examination personnel be qualified by a formal program approved by the NRC. These inspection guidelines, updated in the approved BWRVIP-75 document, provide the technical basis for revisions to NRC GL 88-01 inspection schedules. Inspection can reveal cracking and leakage of coolant. The extent and frequency of inspection recommended by the program are based on the condition of each weld (e.g., whether	<p>Consistent with GALL AMP: <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Document(s) used to confirm Criteria:</p> <p>Comment:</p>

Program Element	Auditable GALL Criteria	Documentation of Audit Finding
	the weldments were made from IGSCC-resistant material, whether a stress improvement process was applied to a weldment to reduce residual stresses, and how the weld was repaired if it had been cracked).	
5. Monitoring and Trending	A. The extent and schedule for inspection, in accordance with the recommendations of NRC GL 88-01 or approved BWRVIP-75 guidelines, provide timely detection of cracks and leakage of coolant. Based on inspection results, NRC GL 88-01 or approved BWRVIP-75 guidelines provide guidelines for additional samples of welds to be inspected when one or more cracked welds are found in a weld category.	Consistent with GALL AMP: <input type="checkbox"/> Yes <input type="checkbox"/> No Document(s) used to confirm Criteria:  Comment:
6. Acceptance Criteria	A. As recommended in NRC GL 88-01, any indication detected is evaluated in accordance with ASME Section XI, IWB-3600 of Section XI of the 1986 Edition of the ASME Boiler and Pressure Vessel Code and the guidelines of NUREG-0313. Applicable and approved BWRVIP-14, BWRVIP-59, BWRVIP-60, and BWRVIP-62 documents provide guidelines for evaluation of crack growth in SSs, nickel alloys, and low-alloy steels. An applicant may use BWRVIP-61 guidelines for BWR vessel and internals induction heating stress improvement effectiveness on crack growth in operating plants.	Consistent with GALL AMP: <input type="checkbox"/> Yes <input type="checkbox"/> No Document(s) used to confirm Criteria:  Comment:
7. Corrective Actions	A. The guidance for weld overlay repair and stress improvement or replacement is provided in NRC GL 88-01; ASME Section XI, Subsections IWB-4000 and IWB-7000, IWC-4000 and IWC-7000, or IWD-4000 and IWD-7000, respectively for Class 1, 2, or 3 components; and ASME Code Case N-504-1. As discussed in the appendix to this report, the staff finds the requirements of 10 CFR Part 50, Appendix B, acceptable to address the corrective actions.	Consistent with GALL AMP: <input type="checkbox"/> Yes <input type="checkbox"/> No Document(s) used to confirm Criteria:  Comment:
8. Confirmation Process	A. Site quality assurance (QA) procedures, review and approval processes, and administrative controls are implemented in accordance with the requirements of 10 CFR Part 50, Appendix B. As discussed in the appendix to this report, the staff finds the requirements of 10 CFR Part 50, Appendix B, acceptable to	Consistent with GALL AMP: <input type="checkbox"/> Yes <input type="checkbox"/> No Document(s) used to confirm Criteria:

Program Element	Auditable GALL Criteria	Documentation of Audit Finding
	address the confirmation process and administrative controls.	Comment:
9. Administrative Controls	A. See Item 8, above.	Consistent with GALL AMP: <input type="checkbox"/> Yes <input type="checkbox"/> No Document(s) used to confirm Criteria:  Comment:
10. Operating Experience	A. Intergranular stress corrosion cracking has occurred in small- and large-diameter BWR piping made of austenitic stainless steel and nickel-base alloys. Cracking has occurred in recirculation, core spray, residual heat removal (RHR), control rod drive (CRD) return line penetrations, and reactor water cleanup (RWCU) system piping welds (NRC GL 88-01, NRC Information Notices [INs] 82-39, 84-41, and 04-08). The comprehensive program outlined in NRC GL 88-01, NUREG-0313, and in the staff-approved BWRVIP-75 report addresses mitigating measures for SCC or IGSCC (e.g., susceptible material, significant tensile stress, and an aggressive environment). The GL 88-01 program has been effective in managing IGSCC in BWR reactor coolant pressure-retaining components and the revision to the GL 88-01 program, according to the staff-approved BWRVIP-75 report, will adequately manage IGSCC degradation.	Consistent with GALL AMP: <input type="checkbox"/> Yes <input type="checkbox"/> No Document(s) used to confirm Criteria:  Comment:

EXCEPTIONS

Item Number	Program Elements	LRA Exception Description	Basis for Accepting Exception	Documents Reviewed (Identifier, Para.# and/or Page #)
1.				
2.				
...				

ENHANCEMENTS

Item Number	Program Elements	LRA Enhancement Description	Basis for Accepting Enhancement	Documents Reviewed (Identifier, Para.# and/or Page #)
1.				
2.				
...				

DOCUMENT REVIEWED DURING AUDIT

Document Number	Identifier (number)	Title	Revision and/or Date
1.			
2.			
3.			
4.			
....			