



FPL

MAR 2 2 2006

L-2006-077
10 CFR 50.90

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

RE: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
License Nos. DPR-31 and DPR-41
Proposed License Amendment Submitted January 20, 2005
Withdrawal of Technical Specification Changes Associated with TSTF-95
(TAC Nos. MC6029 and MC6030)

By letter dated January 20, 2005 (L-2005-008), Florida Power & Light Company (FPL) requested to amend Facility Operating Licenses DPR-31 and DPR-41 for Turkey Point Units 3 and 4 respectively. The proposed amendments would revise the Turkey Point Units 3 and 4 Technical Specifications to incorporate generic changes that have been made to the Improved Standard Technical Specifications (ISTS), NUREG-1431, "Standard Technical Specifications Westinghouse Plants." These generic changes, known as Travelers, were developed by the Technical Specifications Task Force (TSTF) and had been previously reviewed and approved by the NRC.

In recent conversations with the NRC staff, and considering additional information supporting the proposed change, the proposed TSTF-95 changes to "Revise Completion Time for Reducing Power Range High Trip Setpoint from 8 to 72 Hours" were judged to be not applicable to the Turkey Point Plant by the NRC. Accordingly, FPL requests that the proposed changes to Technical Specifications 3.1.3.1, 3.2.1, 3.2.2, 3.2.3, 3.2.4, and 3.3.1, under TSTF-95 be withdrawn.

Additionally, please note that the proposed change to Technical Specification 6.9.1.5 submitted by the same Proposed License Amendment is no longer required, since deletion of that particular technical specification section was approved by the NRC in a letter dated January 13, 2006 from Mr. Brendan T. Moroney, NRC to Mr. J. A. Stall, Florida Power & Light.

A001

Please contact Mr. Walter J. Parker, Licensing Manager, Turkey Point Units 3 and 4 at 305-246-6632 if there are any questions about this request.

Very truly yours,

A handwritten signature in black ink that reads "Terry Jones". The signature is written in a cursive, flowing style.

Terry O. Jones
Vice President
Turkey Point Nuclear Plant

cc: Regional Administrator, Region II, USNRC
Senior Resident Inspector, USNRC, Turkey Point
USNRC Project Manager, Turkey Point
W. A. Passetti, Florida Department of Health