

2

Tennessee Valley Authority, Post Office Box 2000, Spring City, Tennessee 37381-2000

MAR 3 1 2006

WBN-TS-05-07

10 CFR 50.90

U. S. Nuclear Regulatory Commission Mail Stop: OFWN P1-35 ATTN: Document Control Desk Washington, D.C. 20555-0001

Gentlemen:

In the Matter of Tennessee Valley Authority Docket No. 50-390

AOLI

WATTS BAR NUCLEAR PLANT (WBN) UNIT 1 - PROPOSED LICENSE AMENDMENT REQUEST NO. WBN-TS-05-07, ONE-TIME FREQUENCY EXTENSION FOR TYPE A TEST (CONTAINMENT INTEGRATED LEAK RATE 'TEST [CILRT]) - REQUEST FOR ADDITIONAL INFORMATION (TAC NO. MC9239)

)

)

The purpose of this letter is to provide TVA's response to NRC's request for additional information dated January 24, 2006, concerning the subject proposed technical specification request. The proposed amendment that was submitted on December 14, 2005 revises Technical Specification 5.7.2.19, "Containment Leakage Rate Testing Program," to allow a one time 5-year extension to the current 10-year test interval for the performance-based leakage rate test program.

The Enclosure provides TVA's response to NRC's concerns. TVA has determined this additional information and the revision to the calculation, do not significantly change the conclusions in the December 14, 2005 submittal for the No Significant Hazards Considerations associated with the proposed change, consequently, the No Significant Hazards Consideration is not being revised. U.S. Nuclear Regulatory Commission Page 2

MAR 3 1 2005

There are no regulatory commitments associated with this submittal. If you have any questions concerning this matter, please call me at (423) 365-1824.

I declare under penalty of perjury that the foregoing is true and correct. Executed on this 31^{st} day of March 2006.

Sincerely,

P. L. Pace Manager, Site Licensing and Industry Affairs

Enclosure

cc (Enclosure): NRC Resident Inspector Watts Bar Nuclear Plant 1260 Nuclear Plant Road Spring City, Tennessee 37381

> Mr. D. V. Pickett, Project Manager U.S. Nuclear Regulatory Commission MS 08G9a One White Flint North 11555 Rockville Pike Rockville, Maryland 20852-2738

> U.S. Nuclear Regulatory Commission Region II Sam Nunn Atlanta Federal Center 61 Forsyth St., SW, Suite 23T85 Atlanta, Georgia 30303

1

WATTS BAR NUCLEAR PLANT (WBN) UNIT 1 TECHNICAL SPECIFICATION REQUEST WBN-TS-05-07 ONE-TIME FREQUENCY EXTENSION FOR TYPE A TEST REQUEST FOR ADDITIONAL INFORMATION

NRC QUESTION 1

÷

ê

The risk assessment methodology used to support the integrated leakage rate test (ILRT) interval extension for Watts Bar is based on a methodology developed by the Electric Power Research Institute (EPRI) in 1994. A revision to this methodology, developed for the Nuclear Energy Institute (NEI) by EPRI in 2001, corrected/improved the original methodology in several areas. Based on a Nuclear Regulatory Commission (NRC) staff assessment, the revised methodology (referred to as the NEI interim guidance) would indicate larger risk impacts (e.g., Δ large early release frequency (LERF)) for the ILRT interval extension than the In view of the nonconservative nature of the original original. EPRI methodology, please provide a reassessment of the risk impacts of the requested change for Watts Bar based on the NEI interim guidance. In reporting risk results (for Δ person-rem, Δ LERF, and Δ conditional containment failure probability), include results corresponding to a change in test frequency from three tests in 10 years to one test in 15 years

TVA RESPONSE

TVA's attached calculation, CN-NUC-WBN-MEB-MDN00199920050099, was revised such that it is now based on the 2001 NEI interim guidance. The calculation includes results corresponding to a change in test frequency from both three tests in 10 years to one test in 15 years and one test in 10 years to one test in 15 years. Based on this revision to the calculation, a revised Risk Assessment from pages E1-6 and E1-7 of TVA's December 14, 2005, request is also attached as Attachment 1 for your convenience.

NRC QUESTION 2

In Enclosure 4, the population dose for each release class is obtained based on information in Table 6, together with an assumption that the 50-mile population dose for an intact containment (1 La) is equal to the average conditional population dose (2.76E+5 person-rem per core damage event). The resulting population dose for each release class is substantially higher than estimated in the Tennessee Valley Authority's evaluation of severe accident mitigation alternatives (SAMDAs) performed in 1994 (Reference 10 in Enclosure 4). For example, the population dose assigned to the intact containment release class is 2.76E+5 person-rem per event in the ILRT amendment request, versus approximately 200 person-rem per event in the SAMDA evaluation;

WATTS BAR NUCLEAR PLANT (WBN) UNIT 1 TECHNICAL SPECIFICATION REQUEST WBN-TS-05-07 ONE-TIME FREQUENCY EXTENSION FOR TYPE A TEST REQUEST FOR ADDITIONAL INFORMATION

the population dose assigned to the largest release class is 2.76E+7 person-rem per event in the ILRT amendment request versus approximately 4E+5 person-rem per event in the SAMDA evaluation. Furthermore, use of a very large population dose for the intact containment release class in the ILRT evaluation (both in absolute terms and relative to the largest release class) leads to an over-estimate of the impact of the ILRT extension on population dose. Please reconcile the population dose values with those in the SAMDA analysis, and provide a reassessment of the impact of the ILRT interval extension on population dose based on appropriate population dose values.

TVA RESPONSE

r,

2

TVA's attached calculation was revised as requested, to use the population dose values documented in the SAMDA analysis. NRC approval of those values is documented in Reference 16 of the calculation.

NRC QUESTION 3

Inspections of some reinforced and steel containments (e.g., North Anna, Brunswick, D. C. Cook, and Oyster Creek) have indicated degradation from the uninspectable (embedded) side of the steel shell and liner of primary containments. Please describe the uninspectable areas of the Watts Bar containment, and the programs used to monitor their condition. Provide a quantitative assessment of the impact on LERF due to age-related degradation in these areas, in support of the requested ILRT interval extension to 15 years. This could be based on methods such as those utilized in the Browns Ferry ILRT extension request.

TVA FESPONSE

3a. Watts Bar Steel Containment Vessel (SCV) inaccessible Areas

The inaccessible surface areas for the WBN Unit 1 SCV are identified as areas of the exterior SCV surface with insulation and the shielding area around the fuel transfer penetration. The area below the floor of the embedded metal liner and concrete base slab is also inaccessible for the inspection.

The inaccessible surface areas due to insulation are identified in TVA's WBN Engineering Specification entitled "Installation,

WATTS BAR NUCLEAR PLANT (WBN) UNIT 1 TECHNICAL SPECIFICATION REQUEST WBN-TS-05-07 ONE-TIME FREQUENCY EXTENSION FOR TYPE A TEST REQUEST FOR ADDITIONAL INFORMATION

Modification and Maintenance of Heat and Anti-Sweat Insulation." These areas are from 54 degrees to 126 degrees between Elevation 716.0 feet and 747.0 feet.

A walkdown of the SCV also identified additional insulation locations from 50 degrees to 126 degrees between Elevation 713.0 feet and 716.0 feet and from 50 degrees to 54 degrees between Elevation 716.0 feet and 733.0 feet.

The total inaccessible area for inspection, including the shielding area around the fuel transfer penetration, is estimated as 2800 square feet. The area below the floor of the embedded metal liner and concrete base slab is not included in the 2800 square feet.

3b. Inspection Programs

2

General visual examination of accessible exterior surfaces of WBN Unit 1 SCV was performed during Unit 1 Cycle 6 Refueling Outage for any evidence of structural deterioration that may affect either the containment structural integrity or leak-tightness. It is noted that the conditions identified during Unit 1 Cycle 3 Refueling Outage general visual examination do not appear to have changed significantly.

Currently, there are no monitoring programs established for the WBN Unit 1 inaccessible areas of the exterior SCV surface with insulation and the area around the fuel transfer penetration. The inaccessible surface areas due to insulation are provided with a moisture barrier prior to installing the insulation. However, general visual inspection of the SCV during the Unit 1 Cycle 6 Refueling Outage did not identify any moisture present at the edges of the moisture barrier.

During Unit 1 Cycle 6 Refueling Outage, general visual inspection of SCV per Surveillance Instruction entitled, General Visual Inspection of Steel Containment Vessel, identified several areas on the annulus side exhibiting light rust at the floor-to-SCV interface (Elevation 702 Annulus Floor Elevation), tee joint for ice condenser seal with heavy rust (Elevation 743 Azimuth 300) and medium rust on SCV (Elevation 757, Azimuth 292-301) in the containment side. The condition of the containment structure is covered under 10 CFR 50.65, Maintenance Rule and the results of the Unit 1 Cycle 6 Refueling Outage examination were reviewed to include the structure condition for maintenance rule reporting. The conditions of WBN Unit 1 SCV were evaluated by WBN

WATTS BAR NUCLEAR PLANT (WBN) UNIT 1 TECHNICAL SPECIFICATION REQUEST WBN-TS-05-07 ONE-TIME FREQUENCY EXTENSION FOR TYPE A TEST REQUEST FOR ADDITIONAL INFORMATION

Engineering with support from Non-destruction examination (NDE) Specialists. The rust was considered to be superficial and there was no flaking, pitting, or visible loss of base metal. It was determined that there was no impact on the leak tightness and structural integrity of the SCV.

3c. Quantitative Assessment of impact on LERF due to age-related degradation

TVA's attached calculation was revised to include a quantitative assessment of the impact on LERF due to a degradation mechanism as found at North Anna, Brunswick, D. C. Cook, and Oyster Creek.

NRC QUESTION 4

5

In Enclosure 4, it is assumed that the LERF associated with both internal and external events can be estimated by doubling the LERF associated with only internal events. This simplified approach has been accepted by the NRC if sufficient justification is provided that the core damage frequency (CDF) from external events, including seismic and fire events, is approximately equal to or less than that for internal events. Although fire risk is discussed briefly in Section 9.0, the contribution from seismic events was dismissed on the basis that the seismic margin assessment did not calculate seismic CDF or LERF. Provide additional justification that the contribution from seismic events is small. This could be based on simplified methods such as those utilized in the Browns Ferry ILRT extension request.

TVA RESPONSE

TVA's attached calculation was revised to include a quantitative assessment of the impact of seismic events based upon a simplified method used in the BFN ILRT extension request.

ENCLOSURE ATTACHMENT 1

, ;

> WATTS BAR NUCLEAR PLANT (WBN) UNIT 1 TECHNICAL SPECIFICATION REQUEST WBN-TS-05-07 ONE-TIME FREQUENCY EXTENSION FOR TYPE A TEST REQUEST FOR ADDITIONAL INFORMATION

> > REVISED TVA RISK ASSESSMENT

ENCLOSURE ATTACHMENT 1

WATTS BAR NUCLEAR PLANT (WBN) UNIT 1 TECHNICAL SPECIFICATION REQUEST WBN-TS-05-07 ONE-TIME FREQUENCY EXTENSION FOR TYPE A TEST

REVISED TVA RISK ASSESSMENT

The risk assessment below is a revision to the Risk Assessment in TVA's letter to NRC dated December 12, 2005 on Page E1-6 and E1-7). This revised assessment is being provided for your convenience.

'TVA Risk Assessment

A risk assessment for this one-time frequency extension on WBN Unit 1 was performed to determine the risk significance of a decrease in containment integrity leak rate testing (CILRT) frequency. The effect of a decrease in the frequency of performing a CILRT is that the exposure time of a pre-existing leak in the containment shell increases. The resulting increase in the calculated frequency of both large and small fission product releases to the environment correlates to an increase in calculated population dose. 'This calculation [Reference 5 in December 14, 2005 request] quantifies the increase in large early release frequency (LERF), population dose, and conditional containment failure probability as a result of a decrease in the frequency of performing a CILRT (see Enclosure 4 in December 14, 2005 request).

The existence of a leak in a containment penetration is identified by either a LLRT or a CILRT. The existence of a leak in the containment shell is identified by a CILRT. The decrease in the frequency of conducting CILRTs increases the calculated probability of a preexisting leak in containment, but does not affect the probability of other containment failure mechanisms.

The risk assessment showed the increase in LERF to be 1.58E-07/reactor years (ry) when the frequency of a Type A test was decreased from one in 10 years to one in 15 years. The risk assessment showed the increase in LERF to be 3.72E-07/ry when the frequency of a Type A test was decreased from three in 10 years to one in 15 years. The total LERF was calculated to be 2.78E-06. NRC Regulatory Guide 1.174, "An Approach for Using Probabilistic Risk Assessment In Risk-Informed Decisions On Plant-Specific Changes to the Licensing Basis", [Reference 6 in December 14, 2005 request] defines small changes in LERF as increases in LERF less than 1.0E-6/ry but greater than 1.0E-07/ry. A small change in LERF is acceptable provided the total LERF is less than 1.0E-05/ry. Therefore, the proposed change in Type A test frequency is acceptable.

ē

The risk assessment also showed the increase in population dose to be 5.93E-03 person-rem/ry when the frequency of a Type A test was decreased from one in 10 years to one in 15 years. The risk assessment showed the increase in population dose to be 1.40E-02 person-rem/ry when the frequency of a Type A test was decreased from three in 10 years to one in 15 years.

The risk assessment showed the increase in conditional containment failure probability to be 0.52 percent when the frequency of a Type A test was decreased from one in 10 years to one in 15 years. The risk assessment showed the increase in conditional containment failure probability to be 1.23 percent when the frequency of a Type A test was decreased from three in 10 years to one in 15 years.

ENCLOSURE ATTACHMENT 2

٠

÷

WATTS BAR NUCLEAR PLANT (WBN) UNIT 1 TECHNICAL SPECIFICATION REQUEST WBN-TS-05-07 ONE-TIME FREQUENCY EXTENSION FOR TYPE A TEST RISK ASSESSMENT

CALCULATION CN-NUC-WBN-MEB-MDN00199920050099

TVAN CALCULATION COVERSHEET/CCRIS UPDATE

Page 1

<u>REV 0 EDM</u> T7105110	(<u>S/R</u>))18(<u>MS NO.</u>)]				·····	EDN calculat	MS TYPE: tions(nuclear)	EDMS ACC	<u>CESSIC</u> 71			<u>sv. 0)</u> 3 2	3 817
Calc Title: E	EVAL	UATION	OF THE	RISK	SIGNIFI	CANCE OF	DECREA	SED CONTA	INMENT INTE	GRAT	ED LEAK	RATE	TEST	FREQUENCY
CALC ID		<u>TYPE</u>	ORG	P	LANT	BRANCH		NUMB	ER	<u>c</u>	UR REV	NEW	<u>rev</u>	
CURRENT		CN	NUC		NBN	MEB	MDN00	019992005009	9		1	2	2	REVISION APPLICABILITY
NEW														Entire calc. 🛛 Selected pages 🗖
ACTION	NE RE	W VISION		DELEI RENAI	re C Me C] SUPEI DUPL	RSEDE		S UPDATE ON ier Approval Sig	LY 🔲 matures	s Not Requ	ired)	No (Fo revi cha	CCRIS Changes or calc revision, CCRIS been iewed and no CCRIS nges r:quired)
UNITS		SYST	<u>ems</u>					UNIDS						
DCN,EDC,N	<u>/A</u>	999		APPLIC	CABLEI	DESIGN DC	CUMENT	<u>N/A</u> (S)						CLASSIFICATION
N/A D QUALITY SAFETY RELATED? UNVERIFIED SPECIAL REQUIREMENTS AND/OR DESIGN OUTPUT SAR/TS and/or ISI RELATED? (If yes, QR = yes) ASSUMPTION LIMITING CONDITIONS? ATTACHMENT? SAR/CoC AFFEC' Yes No Yes No Yes No Yes No Yes No							SAR/TS and/or ISFSI SAR/CoC AFFECTED							
PREPARER ID PREPARER PHONE NO PREPARING ORG (BRANCH) VERIFICATION METHOD NEW METHOD OF ANALYSIS XBPYZJO24 (423) 751-4124 MEB N/A Yes No														
PREPARER Calvin A. Mc	SIG1 Cull	IATURE	li a	M.L	low	2/0	DATE 3 /2006	CHECKE	signiture	A				DATE 3-14-06
VERIFIER S N/A	IGN.	ATURE					DATE	APPROV.	IL STENATUR	1 -				DATE 3/23/06
STATEMEN This calcu Probability integrated The effect containme environme	<u>STATEMENT OF PROBLEM/ABSTRACT</u> This calculation determines the effect on Large Early Release Frequency (LERF), Conditional Containment Failure Probability (CCFP), and population dose as a result of a proposed decrease in the frequency of performing containment integrated leak rate testing (ILRT). The effect of a decrease in the frequency of performing an ILRT is that the exposure time to a pre-existing leak in the containment shell increases. This results in an increase in the calculated frequency of fission product releases to the provision product releases to the													
calculation The nume	n. rica	l result	s of this	calc	ulation	are prov	vided in S	Section 7	or ILRT free	quen	cies of t	petwee	en 3/1	10 years and 1/20
years. The increathe CCFP	ase and	in LERI I the po	F is "sm opulation	all" p n dos	er RG e are r	1.174, a not risk si	nd is acc ignifican	ceptable si t.	nce the tota	al LEf	RF is les	ss thar	1 1E-	-05. Increases in
MICRO LOAD LOAD LOAD	DFIC INT INT INT	HE/EFICH D EDMS A D EDMS A D EDMS A	IE Ye AND DES AND RET AND RET	IROY URN C URN C		FICH ATION TO ATION TO:	E NUMBEI CALCULA	R(S) TION LIBRA	RY. ADDRI	ESS: E	QB 1A-WI	BN	-	-

TVA 40532 [12-2000]

. **.**

NEDP-2-1 [07-08-2005]

TVAN CALCULATION COVERSHEET/CCRIS UPDATE Page 2 of 2

÷

CALC ID TYPE PLANT BRANCH NUMBER REV MEB 2 CN SQN MDN00199920050099 <u>FIRM</u> TVA BLDG N/A ROOM N/A ELEV N/A COORD/AZIM Print Report Yes 🗋 N/A CATEGORIES N/A KEY NOUNS (A-add, D-delete) <u>ACTION</u> KEY NOUN <u>A/D</u> KEY NOUN <u>(A/D)</u> CROSS-REFERENCES (A-add, C-change, D-delete)

CCRIS ONLY UPDATES: Following are required only when making keyword/cross reference CCRIS updates and page 1 of form NEDP-2-1 is not included: N/A N/A N/A N/A PREPARER SIGNATURE DATE CHECKER SIGNATURE DATE PREPARER SIGNATURE DATE CHECKER SIGNATURE DATE	ACTION (A/(:/D)	XREF CODE	XREF <u>TYPE</u>	XREF PLANT	XREF BRANCH	XREF NUMBER	XREF REV
CRIS ONLY UPDATES: Following are required only when making keyword/cross reference CCRIS updates and page 1 of form NEDP-2-1 is not included: N/A DATE CHECKER SIGNATURE DATE CHECKER SIGNATURE DATE CHECKER SIGNATURE DATE CHECKER SIGNATURE DATE	, .						
CRIS ONLY UPDATES: Following are required only when making keyword/cross reference CCRIS ONLY UPDATES: Following are required only when making keyword/cross reference CCRIS ONLY UPDATES: Following are required only when making keyword/cross reference CCRIS ONLY UPDATES: Following are required only when making keyword/cross reference CCRIS ONLY UPDATES: Following are required only when making keyword/cross reference CCRIS ONLY UPDATES: Following are required only when making keyword/cross reference CCRIS ONLY UPDATES: Following are required only when making keyword/cross reference CCRIS ONLY UPDATES: Following are required only when making keyword/cross reference CCRIS ONLY UPDATES: Following are required only when making keyword/cross reference CCRIS ONLY UPDATES: Following are required only when making keyword/cross reference CCRIS ONLY UPDATES: Following are required only when making keyword/cross reference CCRIS ONLY UPDATES: Following are required only when making keyword/cross reference CCRIS ONLY UPDATES: FOLLOWING ACCESSION NO. N/A DATE CHECKER SIGNATURE DATE CHECKER SIGNATURE DATE CHECKER ADATE					· ·		
CCRIS ONLY UPDATES:							·
CCRIS ONLY UPDATES:							
CCRIS ONLY UPDATES: Following are required only when making keyword/cross reference CCRIS updates and page 1 of form NEDP-2-1 is not included: N/A N/A PREPARER SIGNATURE DATE CHECKER SIGNATURE DATE PREPARER SIGNATURE DATE CHECKER SIGNATURE DATE CHECKER SIGNATURE DATE CHECKER SIGNATURE DATE CHECKER SIGNATURE DATE							
CCRIS ONLY UPDATES:							
CRIS ONLY UPDATES: Image: Constraint of the second secon				······			
CCRIS ONLY UPDATES: Following are required only when making keyword/cross reference CCRIS updates and page 1 of form NEDP-2-1 is not included: N/A N/A N/A N/A PREPARER SIGNATURE DATE CHECKER SIGNATURE DATE PREPARER SIGNATURE DATE						· · · · · · · · · · · · · · · · · · ·	
CCRIS ONLY UPDATES: Image: Control of the second							
CCRIS ONLY UPDATES:							
CCRIS ONLY UPDATES: Following are required only when making keyword/cross reference CCRIS updates and page 1 of form NEDP-2-1 is not included: N/A N/A N/A N/A PREPARER SIGNATURE DATE CHECKER SIGNATURE DATE PREPARER SIGNATURE DATE CHECKER SIGNATURE DATE			·				
CCRIS ONLY UPDATES:							
CCRIS ONLY UPDATES:						· · · · · · · · · · · · · · · · · · ·	
CCRIS ONLY UPDATES: CCRIS ONLY UPDATES: Following are required only when making keyword/cross reference CCRIS updates and page 1 of form NEDP-2-1 is not included: N/A N/A N/A N/A PREPARER SIGNATURE DATE CHECKER SIGNATURE DATE PREPARER PHONE NO. N/A	·					· · · · · · · · · · · · · · · · · · ·	
CCRIS ONLY UPDATES: Following are required only when making keyword/cross reference CCRIS updates and page 1 of form NEDP-2-1 is not included: N/A N/A PREPARER SIGNATURE DATE CHECKER SIGNATURE DATE PREPARER PHONE NO. N/A EDMS ACCESSION NO. N/A							- <u></u>
CCRIS OINLY UPDATES: Following are required only when making keyword/cross reference CCRIS updates and page 1 of form NEDP-2-1 is not included: N/A N/A N/A N/A PREPARER SIGNATURE DATE CHECKER SIGNATURE DATE PREPARER PHONE NO. N/A EDMS ACCESSION NO. N/A				· _			
CCRIS ONLY UPDATES: Following are required only when making keyword/cross reference CCRIS updates and page 1 of form NEDP-2-1 is not included: N/A N/A N/A N/A PREPARER SIGNATURE DATE CHECKER SIGNATURE DATE PREPARER PHONE NO. N/A EDMS ACCESSION NO. N/A							
N/A N/A N/A PREPARER SIGNATURE DATE CHECKER SIGNATURE DATE CHECKER SIGNATURE DATE DATE	CCRIS ONLY UP	PDATES:					
N/A N/A N/A PREPARER SIGNATURE DATE CHECKER SIGNATURE DATE PREPARER PHONE NO. N/A EDMS ACCESSION NO. N/A	Following are req		making keywon	a/cross reference		s and page 1 of form NEDP-2-1 is not includ	
PREPARER PHONE NO. N/A EDMS ACCESSION NO. N/A							
PREPARER PHONE NO. N/A EDMS ACCESSION NO. N/A	Pi	REPARER SIG	INATURE			CHECKER SIGNATURE	DATE
VA 40532 12-2000 "Page 2 of 2 NEDP-2.1 [12-04-2000]	PREPARER PHO		N/A	<u> EDN</u>	IS ACCESSION Page 2 of 2	I NONANE	DP-2.1 [12-04-2000]

Page 2

		rayes						
	TVAN CALCULATION RECORD OF REVISION							
CALCULA	TION IDENTIFIER: MDN001-999-2005-0099							
Title	EVALUATION OF THE RISK SIGNIFICANCE OF DECREASED CONTAINMENT INT FREQUENCY	EGRATED LEAK RATE TEST						
Revision	DESCRIPTION OF REVISION							
Np.								
0	Initial Issue							
	calculation does not affect the SAR.	and this revision of the						
	This calculation supports a proposed change to Technical Specification parage 5.7.2.19, "Containment Leakage Rate Testing Program."							
	Total Pages = 31							
1	Revised to incorporate WBN Site Comments.							
	The Living SAR has been reviewed by Calvin A. McCullough a calculation does not affect the SAR.	and this revision of the						
	This calculation supports a proposed change to Technical Spe 5.7.2.19, "Containment Leakage Rate Testing Program."	ecification paragraph						
	Pages revised: 1, 2, 3, 6, 7, 25. Total Pages = 31							
2	Revised to address NRC RAI questions (reference 17)							
-	The Living SAR has been reviewed by Calvin A. McCullough and this revision of the calculation does not affect the SAR.							
	This calculation supports a proposed change to Technical Spe 5.7.2.19, "Containment Leakage Rate Testing Program."	cification paragraph						
	Pages revised: all Total Pages = 43							

TVA 40709 [12-2000]

NEDP-2-2 [12-04-2000]

			Page	4
	TVAN COMPU STORAGE INFO	TER INPUT RMATION S	FILE HEET	
Document	MDN001-999-2005-0099	Rev. 2	Plant: WBN	
Subject:				
EVALUATION	OF THE RISK SIGNIFICANCE OF DECREASED (ONTAINMENT	INTEGRATED LEAK RA	TE TEST FRECUENCY
Electron	nic storage of the input files for this calc	ulation is not	required. Commen	ts:
Input file provide use.)	es for this calculation have been stored d below for each input file. (Any retrieve	electronically ed file require	v and sufficient iden es re-verification of	tifying information is its contents before
The spread stored by Fi	sheet (Microsoft Excel), this docume ilekeeper.	ent (Microso	ft Word), and Risł	kman files are
File Name:	mdn-001-999-2005-099-r2.zip	. •		
Reference I	D: 308158			
		~_~		
Microfic	ne/Fiche			
			· ·	

TVA 40535 [12-2000]

NEDP-2-6 [12-04-2000]

	TVAN CALCULATION TABLE OF CONTENTS	
Calculation	Identifier: MDN001-999-2005-0099 Revision: 2	
	TABLE OF CONTENTS	
SECTION	TITLE	PAGE
	COVERSHEET	1
	REVISION LOG	3
	COMPUTER INPUT FILE STORAGE INFORMATION SHEET	4
	TABLE OF CONTENTS	5
1.0	Purpose	7
2.0	References	7
30	Design Input	9
4.0	Assumptions	9
5.U 6.0	Requirements/Limiting Conditions	9
0.0 6 1	Computations	9
611		9
612	Fire Events	12
613	Seismic Events	13
6.1.4	Total CDF	16
6.2	Population Dose	18
6.3	Containment Failure Probability	24
6.3.1	Pre-existing	24
6.3.2	Corrosion	24
6.4	Accident Class Information as a Function of ILRT Frequency	29
6.5	Population Dose as a Function of ILRT Frequency	33
6.6	LERF as a Function of ILRT Frequency	34
6.7	CCFP as a Function of ILRT Frequency	36
7.0	Summary of Results	37
8.0	Supporting Graphics	39
9.0	Conclusions	39
	APPENDIXES	
А	SCV Inspection Area	40
В	Industry Primary Containment Failures due to Corrosion	41
	_ · · · · · · · · · · · · · · · · · · ·	
÷		

	Page6	
	TVAN CALCULATION TABLE OF CONTENTS	
Calculation Id	entifier: MDN001-999-2005-0099 Revision: 2	
	TABLE OF CONTENTS	
SECTION	TITLE	PAGE
	FIGURES Figure 1: Probability of exceedance of 0.30g pga	15
	TABLES	
	Table 1 Plant Damage State Frequencies for Internal Events	10
	Table 1a Key Plant Damage State Frequencies for Internal Events	11
	Table 1b Hydrogen Control Designators	11
	Table 1c PDS ENI, LNI Mapping to KPDS	12
	Table 2 Annual Probability of Exceedance	14
	Table 3 Key Release Categories for Internal and External Events	17
	Table 4 KRCs mapped to APBs	19
	Table 4a NUREG-1150 Accident Progression Bins	21
	Table 4b KRCs mapped to EPRI Classes	22
	Table 4c EPRI Accident Classes	23
	Table 4d Baseline Dose mapped to EPRI Class	23
	Table 5 Corrosion Model Parameters	2€
-	Table 5a Containment Failure Frequency due to Corrosion Base Rate for Small Through-Wall Holes	27
	Table 5b Containment Failure Frequency due to Corrosion Base Rate for Large Through-Wall Holes	27
•	Table 5c Containment Failure Frequency due to Corrosion Containment Failure Frequency as a Function of Time	28
	Table 5d Containment Failure Probability as a Function of ILRT Frequency	29
•	Table 6 Accident Class Information for ILRT Frequency of 3/10 years	30
•	Table 6a Accident Class Information for ILRT Frequency of 1/10 years	31
-	Table 6b Accident Class Information for ILRT Frequency of 1/15 years	32
· •	Table 6c Accident Class Information for ILRT Frequency of 1/20 years	33
1	Table 7 Class 3a + 3b Population Dose as a function of ILRT Frequency	33
1	Table 8 LERF as a function of ILRT Frequency	34
٦	Fable 8a Total LERF	35
1	able 9 CCFP as a function of ILRT Frequency	36
	able 10 Summary of Results	37
	able 10a Summary of Results w/ 10% safety factor	38

TVA 40710 [12-2000]

ł

NEDP-2-3 [12-04-2000]

Calculation No. MDN001-999-2005-0099	Rev: 2	Plant: WBN	Page: 7	
Subject: EVALUATION OF THE RISK SIGNIFICANCE OF DECREASED	Prep	ared:	Date:	
	Chee	cked:	Date:	

1.0 <u>Purpose</u>

TAV/A

The purpose of this calculation is to determine the risk significance of a decrease in ILRT frequency. The effect of a decrease in the frequency of performing an ILRT is that the exposure time of a pre-existing leak in the containment shell increases. This results in an increase in the calculated frequency of fission product releases to the environment which correlates to an increase in calculated population dose. This calculation quantifies the increase in large early release frequency, conditional containment failure probability, and population dose as a result of a decrease in the frequency of performing an ILRT.

2.0 <u>References</u>

- 1. Sequoyah Nuclear Plant Probabilistic Safety Assessment, Revision 3.
- 2. NUREG-1493, <u>Performance-Based Containment Leak-Test Program</u>, September, 1995.
- 3. SQNP Probabilistic Risk Assessment, Revision 3, Level II Model SQNR3L2.
- 4. NUREG/CR-4551, Volume 5, Revision 1, Part 1, <u>Evaluation of Severe Accident Risks:</u> Sequoyah, Unit 1, December, 1990.
- 5. Regulatory Guide 1.174, <u>An Approach for Using Probabilistic Risk Assessment In Risk-Informed Decisions On Plant-Specific Changes to the Licensing Basis</u>.
- Watts Nuclear Plant Generic Letter 88-20 Supplements 4 and 5, <u>Individual Plant</u> <u>Examinations of External Events (IPEEE) for Severe Accident Vulnerabilities</u> (T04 980217 539).
- 7. Reserved.
- 8. Staff Evaluation Report of the Individual Plant Examinations of External Events (IPEEE) Submittal on Watts Bar Nuclear Plant, Unit 1 (L44 000530 002).
- 9. TVA Calculation CN-NUC-SQN-NTB-SQS20211, R1, <u>Evaluation of the Risk</u> Significance of Decreased Containment Integrated Leak Rate Test Frequency.
- 10. ERIN letter and report, <u>Value Impact Analysis of Potential Plant Enhancements for</u> <u>Watts Bar Nuclear Plant</u>, (SAMDA) (T25 940630 838).
- 11. Watts Bar Nuclear Plant Probabilistic Safety Assessment, Revision 3.

12. Reserved.

Calculation No.	MDN001-999-2005-0099		: 2	2 Plant: WBN Prepared:		Page: 8
Subject: EVALUATION OF THE RISK SIGNIFICANCE OF DECREASED			Prep			Date:
		ſ	Cheo	cked:	Date:	

13. Reserved.

117/1

- 14. Reserved.
- 15. "Interim Guidance for Performing Risk Impact Assessments In Support of One-Time Extensions for Containment Integrated Leakage Rate Test Surveillance Intervals." Developed for NEI by EPRI, November, 2001.
- 16. NUREG-0498, Supplement 1. <u>Final Environmental Statement related to the operation</u> of Watts Bar Nuclear Plant, Units 1 and 2. April 1995.
- 17. Letter from NRC to TVA, WATTS BAR NUCLEAR PLANT, UNIT 1 REQUEST FOR ADDITIONAL INFORMATION REGARDING EXTENSION OF THE INTEGRATED LEAKAGE RATE TEST INTERVAL (TAC NO. MC9239), 1/24/2006. (L44 060130 066).
- 18. "One-time extensions of containment integrated leak rate test interval additional information." NEI letter from Anthony R. Pietrangelo to NEI Administrative Points of Contact. 11/30/2001.
- Kennedy, Robert P. "Overview of Methods for Seismic PRA and Margin Analysis Including Recent Innovations." <u>Proceedings of the OECD/NEA Workshop on Seismic</u> <u>Risk</u>. Committee on the Safety of Nuclear Installations PWG3 and PWG5. Hosted by the Japan Atomic Energy Research Institute under the Sponsership of the Science and Technology Agency. 10-12 August, 1999, Tokyo, Japan. (B44060310001)
- 20. TVA Calculation CN-NUC-BFN-NTB-NDN0-064-2004-0005, R0. <u>Risk Assessment for</u> Integrated Leak Rate Test (ILRT) Extension.
- 21. EPRI NP-6395 D, <u>Probabilistic Seismic Hazard Evaluations at Nuclear Plant Sites in</u> the Central and Eastern United States: Resolution of the Charleston Earthquake <u>Issue</u>. April, 1989.
- 22. Marks' Standard Handbook for Mechanical Engineers. Eighth Edition.
- 23. Letter from Calvert Cliffs Nuclear Power Plant to NRC. Response to Request for Additional Information Concerning the License Amendment Request for a one-time Integrated Leakage Rate Test Extension. March 27, 2002. (B44060310001)
- 24. Letter from NRC to Duke Energy Corporation. McGuire Nuclear Station, Units 1 and 2 re: issuance of amendments [including SER]. March 12, 2003. (B44060310001)
- 25. Letter from Duke Energy Corporation to the NRC. Catawba Nuclear Station and McGuire Nuclear Station Proposed TS Amendments ... One-Time Extension of Integrated Leak Rate testing (ILRT) Interval. January 8, 2003. (B44060310001)

Calculation No. MDN001-999-2005-0099	Rev: 2	Plant: WBN	Page: 9	
Subject: EVALUATION OF THE RISK SIGNIFICANCE OF DECREASED	Prep	ared:	Date:	
	Che	cked:	Date:	

26. Letter from Indiana Michigan Power Company to the NRC. Donald C. Cook Nuclear Plant Response to NRC Request for Additional Information Regarding License Amendment Request for One-Time Extension of Containment Integrated Leakage Rate Test Interval. November 11, 2002.

- 27. NUREG 1350, Volume 16. Information Digest, 2004-2005 Edition.
- 28. Information Notice 86-39: Degradation of Steel Containments [Oyster Creek event]. 12/8/1986.
- 29. Information Notice 86-99 Supplement 1: Degradation of Steel Containments. 2/14/1991.
- 30. Information Notice 2004-09: Corrosion of Steel Containment and Containment Liner. 4/27/2004.

3.0 Design Input Data

Appendix A contains the only design input data specific to this calculation.

4.0 Assumptions

Assumptions and associated justification are documented in the relevant text paragraphs and tables.

5.0 Requirements/Limiting Conditions

None.

6.0 Computations and Analyses

6.1 Core Damage Frequency

6.1.1 Internal Events

Core damage due to internal events, including internal flooding, was calculated using revision 3 of the WBN PSA (reference 11). The PSA exists as a Riskman model. The level I model of record, denoted WR3ES, was executed using master frequency file

Calculation No. MDN001-999-2005-0099	Rev	r: 2	Plant: WBN		Page: 10
Subject: EVALUATION OF THE RISK SIGNIFICANCE OF DECREASED CONTAINMENT INTEGRATED LEAK RATE TEST FREQUENCY Dat		te:			
		Chec	ked:	Dat	:e:

(MFF) WBNREV3 with a universal truncation frequency of 1E-11. The output from this model included unconditional frequencies of the plant damage states (PDSs), provided in Table 1. Physical characteristics of the PDSs are described in section 4.3 of reference 1.

PDS	Frequency	PDS	Frequency		PDS	Frequency
					<u>.</u>	
FCI	8.11E-06	HCS	3.54E-09		GGB	2.31E-10
ENI	1.57E-06	LCS	3.17E-09		FRL	2.10E-10
HCI	8.59E-07	AGI	2.39E-09		DCS	2.01E-10
LCI	7.58E-07	GGI	2.20E-09		НІ	1.70E-10
GNI	6.59E-07	KNI	1.94E-09]	CNS	1.42E-10
ECB	4.29E-07	LEI	1.77E-09		FTL	1.34E-10
BCI	3.78E-07	BCS	1.72E-09] ·	FEB	1.31E-10
FGI	2.19E-07	LNI	1.45E-09]	KNS	1.16E-10
FNI	1.68E-07	FII	1.22E-09		BNI	1.07E-10
ENS	1.25E-07	LGI	9.23E-10		HNS	1.02E-10
ENB	7.36E-08	FGS	9.22E-10] [CNI	7.83E-11
FCB	7.16E-08	GTL	9.00E-10		DNI	7.22E-11
EGI	6.78E-08	BEI	8.63E-10	[ERL	7.13E-11
ATV	5.36E-08	GNB	8.46E-10		HEB	6.61E-11
GNS	4.90E-08	HPL	8.09E-10		DPL	4.15E-11
DCI	4.58E-08	LPL	7.75E-10		FIB	3.72E-11
FCS	3.82E-08	BGI	7.66E-10		HGS	2.41E-11
HCB	3.75E-08	FNS	7.58E-10		HIB	2.08E-11
HNI	2.22E-08	LII	5.96E-10		HNB	1.85E-11
EIB	1.32E-08	HEI	4.97E-10	[CTL	1.76E-11
FPL	1.03E-08	BPL	4.64E-10		ANS	1.44E-11
ETL	1.03E-08	FNB	4.11E-10	[HTL	1.38E-11
HGI	9.94E-09	GCB	3.00E-10			_
EEB	8.34E-09	BII	2.93E-10	[Total PDS	1.38E-05
KGI	5.62E-09	EGS	2.79E-10		· · · · · · · · · · · · · · · · · · ·	
EGB	4.70E-09	DGI	2.56E-10			
FEI	3.64E-09	FGB	2.44E-10			

Table 1 Plant Damage State Frequencies for Internal Events

The PDSs were condensed into key plant damage states (KPDSs) in accordance with section 4.6 of reference 1. The frequency of each KPDS is calculated using an Excel spreadsheet. Results of that summation are provided in Table 1a.

TVA						
Calculation No. MDN001-999-2005-0099	Rev	<i>r</i> : 2	Plant: WBN		Page: 11	
Subject: EVALUATION OF THE RISK SIGNIFICANCE OF DECREASED		Prep	bared:	Da	ate:	
	i	Checked:			Date:	

Note that KPDSs ENIYA, ENIYB, ENIYN, LNIYA, and LNIYC are actually a subset of PDSs ENI and LNI, respectively. These two KPDSs were subdivided according to Table 1b. Sensitivity runs were used to determine the split fractions. In addition, the "Y" designator indicates that the ice beds are available. Details of the sensitivity runs are provided in Table 1c.

KPDS	Frequency	Description
FCI	8.11E-06	
EIB	1.44E-07	Sum of PDSs EIB, FCS, FCB, ETL, GTL, HTL, and FPL
ENIYA	5.22E-07	
ENIYB	5,21E-07	Refer to Tables 1b and 1c
ENIYN	5.22E-07	
FNI	1.68E-07	
BCI	3.78E-07	
ENB	2.49E-07	Sum of PDSs ENB, GNS, ENS, and FNS
FGI	2.19E-07	
LCI	8.04E-07	Sum of PDSs LCI and DCI
GNI	6.59E-07	
HCI	8.59E-07	
ATV	5.36E-08	
HNI	2.22E-08	
EGI	6.78E-08	
LNIYA	7.24E-10	Refer to Tables 1b and 1c
LNIYC	7.24E-10	
· ·		
Total KPDS	1.33E-05	

Table 1aKey Plant Damage State Frequencies for Internal Events

Table 1b

Hydrogen Co	ntrol Designat	ors					
Air Return Ignitors							
Fans	Yes No						
Available -	A	В					
Not avail.	С	Ν					

Calculation No. MDN001-999-2005-0099	Rev	: 2	Plant: WBN		Page: 12
Subject: EVALUATION OF THE RISK SIGNIFICANCE OF DECREASED CONTAINMENT INTEGRATED LEAK RATE TEST FREQUENCY		Prep	ared:	Da	te:
	ſ	Chec	ked:	Da	te:

Table 1c PDS ENI, LNI Mapping to KPDS

PDS	Frequency	Relative Frequency	KPDS
			Description
ENI	1.5330E-06	33.34%	Model WR3ES with IC=S, AR=S and HH=S ENIYA
ENI	1.5314E-06	33.31%	Model WR3ES with IC=S, AR=S and HH=F ENIYB
ENI	1.5330E-06	33.34%	Model WR3ES with IC=S, AR=F and HH=F ENIYN
	4.5974E-06		
LNI	1.1186E-09	50.00%	Model WR3ES with IC=S, AR=S and HH=S LNIYA
LNİ	1.1186E-09	50.00%	Model WR3ES with IC=S, AR=F and HH=S LNIYC
	2.2372E-09		

Note 1: The frequency for KPDS ENIYA, for example, is calculated as the product of the frequency of PDS ENI (from the Level 1 model) by the appropriate relative frequency (from this table).

The Sequoyah Level II model (reference 3) was used to transform KPDSs to key release categories (KRCs). The Sequoyah Level II model was recently updated and represents the state-of-the-art analysis. This treatment is acceptable for this WBN calculation due to the physical similarity of WBN to SQN.

The level II portion of the PSA reports the frequency of KRCs which have a frequency greater than 1E-11. Columns 2 and 3 of Table 3 (refer to section 6.1.4), labeled "internal events," present the results of this Riskman quantification. Physical characteristics of the KRCs are described in section 4.9 of reference 1.

6.1.2 Fire Events

The WBN PRA does not include a model for fire events. The Individual Plant Examination of External Events (IPEEE, reference 6) documents a screening analysis referred to as a Fire-Induced Vulnerability Evaluation (FIVE). The IPEEE does not calculate a CDF due to fire events. However, quoting from the NRC Staff Evaluation Fleport (SER, reference 8), "A quantification for fire events, that utilized the FIVE methodology, indicated that the contribution to plant CDF from fire was about 7E-6 per reactor-year (RY)." This value is consistent with a summation of fire-related CDF for areas screened at the second level, listed in Table 5.2 of reference 6.

Calculation No. MDN001-999-2005-0099	Rev: 2	Plant: WBN	Page:	13
Subject: EVALUATION OF THE RISK SIGNIFICANCE OF DECREASED CONTAINMENT INTEGRATED LEAK RATE TEST FREQUENCY	Prep	pared:	Date:	
	Che	cked:	Date:	

This value was inserted into Table 3 as the total CDF for fire events. It is assumed that the total fire event CDF can be allocated across release categories using the relative ranking of KRCs from internal events. For example, the frequency of KRC R21 due to fire events is calculated as

 $7E-06 \times 72.56\% = 5.08E-06.$

This allocation model is based on the analysis finding that fire does not pose a significant risk to containment integrity, as evaluated by the FIVE of the reactor building, documented in section 3.3 of reference 6.

6.1.3 Seismic Events

Reference 6, the WBN IPEEE, documents completion of a Seismic Margins Assessment (SMA). The SMA is a deterministic process which does not calculate risk values.

Reference 19 provides a simplified methodology (Simple Hybrid Method) for estimating the seismic risk based on a SMA analysis. This approach was used for the BFN ILRT frequency reduction calculation (reference 20), and was recommended by the NRC via reference 17.

The approach consists of 4 steps.

- 1. Determine the High Confidence Low Probability of Failure (HCLPF) seismic capacity from the SMA analysis.
- 2. Estimate the 10% conditional failure probability capacity. The following equations are from reference 19, section 6.2. β is the variability of the plant damage fragility. Reference 19, section 6.3, recommends a value of 0.3 for β .

$$C_{10\%} = F_{\beta} * C_{HCLPF}$$

$$F_{\beta} = \exp(1.044 * \beta)$$

- 3. Determine the hazard exceedance frequency (H_{10%}) that corresponds to C_{10%} from the hazard curves.
- 4. Determine the seismic risk (which is set equal to the seismic CDF).

$$CDF = 0.5^* H_{10\%}$$

From reference 6, C_{HCLPF} is greater than 0.30g peak ground acceleration (pga).

Calculation No. MDN001-999-2005-0099	Rev:	2	Plant: WBN		Page: 14
Subject: EVALUATION OF THE RISK SIGNIFICANCE OF DECREASED		rep	ared:	Da	te:
	C	hec	ked:	Dat	:e:

11///1

Table 2 provides the annual probability of exceedance for pga at WBN, from reference 21, Table 3-107. This same information is presented graphically in Figure 1 (reference 21 Figure 3-319).

The conversion factor for acceleration is 1g to 980.665 cm/sec² (reference 22, page 1-36).

 $F_B = \exp(1.044 * 0.3) = 1.37$

 $C_{10\%} = (1.37)^*(0.30 \text{ g})(980.665 \text{ cm/sec}^2\text{g}) = 403 \text{ cm/sec}^2$

From Figure 1, the annual probability of exceedance for $C_{10\%}$ is approximately 2E-5.

 $CDF = (0.5)^{*}(2E-5) = 1E-5$ per year.

This value was inserted into Table 3 as the total CDF for seismic events. It is assumed that the total seismic event CDF can be allocated across release categories using the relative ranking of KRCs from internal events. This treatment is justified because "there were no vulnerabilities noted in the containment walkdown and review that would lead to an early release due to the IPEEE RLE" (section 3.1.5 of reference 6).

Table 2

Annual Probability of Exceedance

Acceleration (cm/sec^2)	Probability of Exceedance
5	1.90E-02
50 100	<u> 1.80E-03 </u>
250	7.70E-05
500	9.90E-06
1000	7.50E-07

Note 1: Probabilities are mean values. Note 2: Reference 21, Table 3-107.

TVA		. •	
Calculation No. MDN001-999-2005-0099	Rev: 2	Plant: WBN	Page: 15
Subject: EVALUATION OF THE RISK SIGNIFICANCE OF DECREASED	Prep	bared:	Date:
	Che	cked:	Date:

Figure 1 Probability of exceedance of 0.30g pga



Calculation No. MDN001-999-2005-009	9	Rev:	2	Plant: WBN	Page: 16
Subject: EVALUATION OF THE RISK SIGNIFICANCE OF DECREASED CONTAINMENT INTEGRATED LEAK RATE TEST FREQUENCY			Prep	ared:	Date:
		Γ	Cheo	cked:	Date:

6.1.4 Total CDF

The total frequency for each KRC is just the sum of the frequencies due to internal events, fire events, and seismic events. The sum of all KRC frequencies is the total CDF. These results are presented in Table 3. Note that the total CDF is approximately 2.3 times the internal events CDF.

Calculation No. MDN001-999-2005-0099	Rev: 2	Plant: WBN	Page: 17
Subject: EVALUATION OF THE RISK SIGNIFICANCE OF DECREASED CONTAINMENT INTEGRATED LEAK RATE TEST FREQUENCY	Pre	pared:	Date:
	Che	cked:	Date:

								·····	
	Interna	al Events	F	ire	Sei	smic	Total		
	(No	ote 1)	(Note	es 2, 4)	(Note	es 3, 4)			
KRC	Frequency	Percentage	Frequency	Percentage	Frequency	Percentage	Frequency	Percentage	
R21	9.65E-06	72.56%	5.08E-06	72.56%	7.26E-06	72.56%	2.20E-05	72.56%	
R17L	8.54E-07	6.42%	4.50E-07	6.42%	6.42E-07	6.42%	1.95E-06	6.42%	
R11I	5.18E-07	3.90%	2.73E-07	3.90%	3.90E-07	3.90%	1.18E-06	3.90%	
R11IF	5.17E-07	3.89%	2.72E-07	3.89%	3.89E-07	3.89%	1.18E-06	3.89%	
R17LU	4.94E-07	3.71%	2.60E-07	3.71%	3.71E-07	3.71%	1.13E-06	3.71%	
R20	3.93E-07	2.96%	2.07E-07	2.96%	2.96E-07	2.96%	8.95E-07	2.96%	
R17U	3.23E-07	2.43%	1.70E-07	2.43%	2.43E-07	2.43%	7.36E-07	2.43%	
R01DI	2.19E-07	1.65%	1.15E-07	1.65%	1.65E-07	1.65%	4.99E-07	1.65%	
R22	9.64E-08	0.72%	5.07E-08	0.72%	7.25E-08	0.72%	2.20E-07	0.72%	
R04IF	8.84E-08	0.66%	4.65E-08	0.66%	6.65E-08	0.66%	2.01E-07	0.66%	
R19	5.33E-08	0.40%	2.82E-08	0.40%	4.03E-08	0.40%	1.22E-07	0.40%	
R01IF	3.51E-08	0.26%	1.85E-08	0.26%	2.64E-08	0.26%	8.00E-08	0.26%	
R02IF	2.13E-08	0.16%	1.15E-08	0.16%	1.64E-08	0.16%	4.97E-08	0.16%	
R03IF	1.35E-08	0.10%	7.09E-09	0.10%	1.01E-08	0.10%	3.07E-08	0.10%	
R04	6.87E-09	0.05%	3.62E-09	0.05%	5.17E-09	0.05%	1.57E-08	0.05%	
R18	5.63E-09	0.04%	2.96E-09	0.04%	4.23E-09	0.04%	1.28E-08	0.04%	
R031	4.20E-09	0.03%	2.21E-09	0.03%	3.16E-09	0.03%	9.57E-09	0.03%	
R04UIF	2.25E-09	0.02%	1.18E-09	0.02%	1.69E-09	0.02%	5.13E-09	0.02%	
R01UIF	9.63E-10	0.01%	5.07E-10	0.01%	7.24E-10	0.01%	2.19E-09	0.01%	
R05LIF	6.78E-10	0.01%	3.57E-10	0.01%	5.10E-10	0.01%	1.54E-09	0.01%	
R03UIF	5.88E-10	0.00%	3.10E-10	0.00%	4.42E-10	0.00%	1.34E-09	0.00%	
R06IF	4.33E-10	0.00%	2.28E-10	0.00%	3.26E-10	0.00%	9.87E-10	0.00%	
R05IF	7.99E-11	0.00%	4.21E-11	0.00%	6.01E-11	0.00%	1.82E-10	0.00%	
R03	1.97E-11	0.00%	1.04E-11	0.00%	1.48E-11	0.00%	4.50E-11	0.00%	
R011	1.06E-11	0.00%	5.56E-12	0.00%	7.94E-12	0.00%	2.41E-11	0.00%	
R06LIF	1.03E-11	0.00%	5.44E-12	0.00%	7.77E-12	0.00%	2.35E-11	0.00%	
Total	1.33E-05	100.00%	7.00E-06	100.00%	1.00E-05	100.00%	3.03E-05	100.00%	

 Table 3

 Key Release Categories for Internal and External Events

Note 1: KRC Frequencies for internal events from the PSA level II model.

3.03E-05 CDF

Note 2: Fire-related total KRC frequency from reference 8.

111//

Note 3: Seismic-induced total KRC frequency calculated in section 6.1.3.

Note 4: Individual KRC frequencies for fire and seismic are calculated as the product of the total and the internal event KRC percentages.

Calculation No. MDN001-999-2005-0099	Rev: 2	Plant: WBN	Page: 18
Subject: EVALUATION OF THE RISK SIGNIFICANCE OF DECREASED	Prep	bared:	Date:
	Che	cked:	Date:

6.2 Population Dose

KRCs are mapped to NUREG-1150 Accident Progression Bins (APBs) in Table C-1 of reference 10. In turn, each APB has an associated representative WBN population dose (person-rem), provided in Table C-4 of reference 10. The WBN population doses are based on equivalent doses for the Sequoyah Nuclear Plant (SQN), adjusted for meteorology and population distributional differences between SQN and WBN. Reference 16 states that "the staff concludes that the conversion of the WBN Plant release categories into the SQN Plant APBs appears to have been performed properly and is, therefore, acceptable."

Note that the doses documented in reference 10 are for the 1980 population surrounding WBN, and must be adjusted to the current population. Rather than evaluate the population based upon available census data, the scaling factor of 1.41 from reference 16, representing the projected WBN 50-mile population in 2035, will be used.

The mapping of KRCs to APBs is detailed in Table 4. Table 4a provides a description of each APB.

ĪA

Calculation No. MDN001-999-2005-0099	Rev	2 Plant: WBN			Page: 19
Subject: EVALUATION OF THE RISK SIGNIFICANCE OF DECREASED CONTAINMENT INTEGRATED LEAK RATE TEST FREQUENCY		Prepared: Date:		te:	
		Checked: Date:			te:

Table 4 KRCs mapped to APBs

					NUR	EG-1150 /	Accident P	rogressio	n Bins (No	te 1)		
KRC	Frequency	Percentage	1	2	3	4	5	6	7	8	9	10
R21	2.20E-05	72.56%		·						2.20E-05		
R17L	1.95E-06	6.42%					1.95E-06					
R11I	_1.18E-06	3.90%					1.18E-06					
R11IF	1.18E-06	3.89%					1.18E-06					
R17LU	1.13E-06	3.71%					1.13E-06					
R20	8.95E-07	2.96%							8.95E-07			
R17U	7.36E-07	2.43%						7.36E-07				
R01DI	4.99E-07	1.65%			4.99E-07							
R22	2.20E-07	0.72%										2.20E-07
_R04IF	2.01E-07	0.66%				2.01E-07						
R19	1.22E-07	0.40%							1.22E-07			
R01IF	8.00E-08	0.26%			8.00E-08							
R02IF	4.97E-08	0.16%			4.97E-08							
R031F	3.07E-08	0.10%		3.07E-08								
R04	1.57E-08	0.05%		1.57E-08								·
R18	1.28E-08	0.04%							1.28E-08			·
R03I	9.57E-09	0.03%		9.57E-09		,						
R04UIF	5.13E-09	0.02%				5.13E-09						
R01UIF	2.19E-09	0.01%			2.19E-09							
R05LIF	1.54E-09	0.01%			1.54E-09							
R03UIF	1.34E-09	0.00%				1.34E-09						
R06IF	9.87E-10	0.00%			9.87E-10							
R05IF	1.82E-10	0.00%	i		1.82E-10						•	

.

ΤΑ

Calculation No. MDN001-999-2005-0099	Rev	<i>v</i> : 2	Plant: WBN Pag		ge: 20
Subject: EVALUATION OF THE RISK SIGNIFICANCE OF DECREASED CONTAINMENT INTEGRATED LEAK RATE TEST FREQUENCY		Prepared: Date:			
		Chec	:ked:	Date:	

Table 4 KRCs mapped to APBs

				NUREG-1150 Accident Progression Bins (Note 1)								
KRC	Frequency	Percentage	1	2	3	4	5	6	7	8	9	10
R03	4.50E-11	0.00%				4.50E-11						
R011	2.41E-11	0.00%			2.41E-11							
R06LIF	2.35E-11	0.00%			2.35E-11							
Total	3.03E-05	1.00E+00	0.00E+00	5.59E-08	6.34E-07	2.08E-07	5.43E-06	7.36E-07	1.03E-06	2.20E-05	0.00E+00	2.20E-07

Representative WBN Population Dose		•								
person-rem (Note 2)	3.90E+05	1.85E+05	3.18E+05	3.41E+05	6.86E+04	2.14E+04	4.07E+05	1.98E+02	2.41E+05	1.43E+02

Representative WBN Population Dose		ł								
_person-rem (Note 3)	5.50E+05	2.61E+05	4,48E+05	4.81E+05	9.67E+04	3.02E+04	5.74E+05	2.79E+02	3.40E+05	2.02E+02

Note 1: from Table C-1, Reference 10, except KRCs R05IF, R05LIF, R06IF, R06LIF

KRCs R05IF, R05LIF, R06IF, R06LIF from Section 4.9, Reference 1

Note 2: from Table C-4, Reference 10.

Note 3: Corrected for estimated year 2035 population (factor of 1.41) from reference 16.

Calculation No. MDN001-999-2005-0099	Rev: 2	Plant: WBN	Page: 2	
Subject: EVALUATION OF THE RISK SIGNIFICANCE OF DECREASED	Prep	pared:	Date:	
	Che	cked:	Date:	

Table 4a	
NUREG-1150 Accident Progression Bins (N	lote 1)

Number	Description
1	VB, early CF (during CD)
2	VB, alpha, early CF (at VB)
3	VB > 200 psi, early CF (at VB)
4	VB < 200 psi, early CF (at VB)
5	VB, late CF
6	VB, BMT, very late CF
7	Bypass
8	VB, no CF
	No VB, early CF (during
9	CD)
10	no VB

Note 1: from Table C-1, Reference 10.

Note 2: Vessel Breach (VB), Containment Failure (CF) Core Damage (CD), Basemat Melt-Through (BMT)

To follow the guidance of reference 15, WBN population doses must be allocated to each EPRI accident class (classes are defined in Table 4c), except classes 3a and 3b. Doses associated with each KRC is taken from Table 4. Each KRC is allocated to an EPRI accident class using the definition of each KRC contained in section 4.9 of reference 1. If multiple KRCs are allocated to a single EPRI accident class, the resultant dose is a frequency-weighted average across the applicable KRCs. Doses for classes 3a and 3b are as defined in reference 15. Results of this allocation are detailed in Table 4b. EPRI accident classes are described in Table 4c.

Note that the reference 15 method maps class 1 (containment intact) accident sequences into class 3a and 3b. The method conservatively ignores the fact that some accident sequences will lead to a large early release regardless of the existence of a pre-existing leak.

Table 4d provides a summary of the dose calculations.

Calculation No. MDN001-999-2005-0099	Rev	/: 2	Plant: WBN	Page: 22
Subject: EVALUATION OF THE RISK SIGNIFICANCE OF DECREASED CONTAINMENT INTEGRATED LEAK RATE TEST FREQUENCY		Prep	ared:	Date:
		Cheo	cked:	Date:

					FI	PRI Acci	dent Cla	iss (Not	e 1)		
KRC	Frequency	Percentage	1	2	3a	35	4	5	6	7	8
R21	2.20E-05	72.56%	2.20E-05	1							
R17L	1.95E-06	6.42%								1.95E-06	1
R11I	1.18E-06	3.90%								1.18E-06	
R11IF	1.18E-06	3.89%								1.18E-06	
R17LU	1.13E-06	3.71%								1.13E-06	
R20	8 95E-07	2.96%									8.95E-07
R17U	7 36E-07	2.43%								7.36E-07	
R01DI	4 99E-07	1.65%		<u> </u>						4.99E-07	
R22	2.20E-07	0.72%	2.20E-07								
R04IF	2.01E-07	0.66%								2.01E-07	
R19	1.22E-07	0.40%									1.22E-07
R01IF	8.00E-08	0.26%								8.00E-08	
R02IF	4.97E-08	0.16%		<u> </u>						4.97E-08	L
R03IF	3.07E-08	0.10%		l						3.07E-08	
R04	1.57E-08	0.05%		L						1.57E-08	
R18	1.28E-08	0.04%									1.28E-08
R031	9.57E-09	0.03%								9.57E-09	
R04UIF	5.13E-09	0.02%	<u> </u>							5.13E-09	
R01UIF	2.19E-09	0.01%								2.19E-09	
R05LIF	1.:54E-09	0.01%								1.54E-09	
R03UIF	1.34E-09	0.00%								1.34E-09	
R06IF	9.87E-10	0.00%								9.87E-10	
R051F	1.82E-10	0.00%	1							1.82E-10	
R03	4.50E-11	0.00%								4.50E-11	
R011	2.41E-11	0.00%								2.41E-11	·
R06LIF	2.35E-11	0.00%								2.35E-11	
Total	3 03E-05	100 00%	2 22E-05	0.00E+00						7.065-06	1.03E-06

Table 4b KRCs mapped to EPRI Class

Note 1: Class designation from Table 1, Reference 15

ТА					
Calculation No. MDN001-999-2005-0099	Re	ev: 2	Plant: WBN		Page: 23
Subject: EVALUATION OF THE RISK SIGNIFICANCE OF DECREASED		Prepared:		Date:	
		Checked:		Date:	

Table 4c	
EPRI Accident Classes (Note	1)

Number	Description
1	Containment intact, accident sequences do not lead to failure, not affected by changes to ILRT leak testing frequencies
2	Failure of isolation system to operate from common cause or power failure; not affected by changes to ILRT leak testing frequencies.
3a	Small pre-existing leak in containment structure or liner, identifiable by ILRT; affected by ILRT testing frequency
3b	Large pre-existing leak in containment structure or liner, identifiable by ILRT; affected by ILRT testing frequency
4	Type B tested components fail to seal, not affected by ILRT leak testing frequencies
5	Type C tested components fail to seal, not affected by ILRT leak testing frequencies
6	Failure to isolate due to valves failing to stroke closed, not affected by ILRT testing frequency, low probability
7	Failure induced by severe accident phenomena, not affected by ILRT testing frequency.
8	Containment Bypass, not affected by ILRT testing frequency.

Note 1: from Table 1, Reference 15.

Table 4d Baseline Dose mapped to EPRI Class

class	Description	Baseline Dose (person-rem/event)	Basis
1	Containment Intact	2.78E+02	weighted average of APBs 8 and 10 (Note 1)
2	Isolation Failures, common cause		no populated release categories mapped to this EPRI Accident Class
3a	Small pre-existing Leak	2.78E+03	10 La per reference 15
3b	Large pre-existing Leak	9.74E+03	35 La per reference 15
4	Type B tested components		N/A per reference 15
5	Type C tested components		N/A per reference 15
6	Isolation Failures, redundant valves		N/A per reference 15
7	Severe Accident Phenomena	1.34E+05	weighted average of APBs 1-6, 9
8	Bypass	5.74E+05	APB 7

Note 1: This baseline dose is set equal to 1 La.

Calculation No.	MDN001-999-2005-0099	Rev	: 2	Plant: WB	N Page: 24	
Subject: EVALUATION OF THE RISK SIGNIFICANCE OF DECREASED CONTAINMENT INTEGRATED LEAK RATE TEST FREQUENCY		1	Prepared:		Date:	
		Ţ	Cheo	cked:	Date:	

6.3 Containment Failure Probability

6.3.1 <u>Pre-existing</u>

The probability of containment failure such that the failure would be detectable by an ILRT but not LLRTs is developed in reference 15 for EPRI accident classes 3a and 3b, and will not be repeated here. Those values are entered into Table 5d as source data.

6.3.2 <u>Corrosion</u>

NRC review of previous ILRT test extension requests has set the precedent that failures described above as "pre-existing" exclude containment failures due to corrosion.

NEI guidance, provided in reference 15, does not address a separate corrosion failure mechanism.

A corrosion model acceptable to the NRC was developed in reference 23. This model, as applied to WBN, has the following features:

- 1. Corrosion failures are represented as a failure rate that increases with time. The rate doubling time was assumed to be 5 years. The base failure rate was assumed to be the average failure rate for years 6 through 10, inclusive.
- 2. Industry events can be classified as either "small" (class 3a) or "large" (class 3b) and are recorded by existing reporting mechanisms, such as LERs and Inspection Notices.
- 3. Success data begins in September 1996 when 10 CFR 50.55a started requiring visual inspections.
- 4. Recorded industry events are not screened for applicability to WBN. This is a very conservative treatment since most events have been associated with construction errors at a concrete-liner interface, and the WBN SCV is freestanding.
- 5. Recorded industry events are not screened for applicability to this corrosion model. This is a conservative treatment because most events have been associated with construction errors at a concrete-liner interface and are therefore more representative of an infant mortality mechanism than a wear-out mechanism.
- 6. For "large" failures in which no industry events have been recorded, 0.5 failures are assumed for the purpose of generating a failure rate.
- 7. The probability that a visual inspection fails to identify a flaw for inspectable areas is 5%.
- 8. The probability that a visual inspection fails to identify a flaw for un-inspectable areas is 100%.

Calculation No. MDN001-999-2005-0099	Rev	/: 2	Plant: WBN		Page: 25
Subject: EVALUATION OF THE RISK SIGNIFICANCE OF DECREASED Prepared: Date		te:			
		Cheo	cked:	Dat	te:

- The exposure time for corrosion failures is assumed to be T/2, where T is the ILRT interval. This is a conservative treatment for accelerating failure mechanisms.
- 10. Flaws in the SCV underneath the basemat are assumed not to be detectable via ILRT (reference 25).

Table 5 summarizes the input data for the corrosion model. Appendix B contains a list of industry events involving primary containment corrosion. Those assessed as a failure are so indicated.

Table 5a and 5b document the calculation of the base failure rates for class 3a and 3b events.

Table 5c documents the time-dependent failure rates for small and large events. Note that the average failure rate for years 6 to 10 is set to the base rate. The rate for the previous period is just $\frac{1}{2}$ of the base rate. Rates for succeeding periods are accelerated at 2x per five years.

Table 5d summarizes the pre-existing, corrosion, and total failure probabilities as a function of the ILRT frequency. The total failure probability is used in subsequent calculations.

			•		
Calculation No. MDN001-999-2005-0099	Rev	: 2	Plant: WBN		Page: 26
Subject: EVALUATION OF THE RISK SIGNIFICANCE OF DECREASED		Prepared:		Da	Date:
		Che	cked:	Da	te:

Value	Units	Parameter	Basis
5		Number of small corrosion events in industry	Appendix B (those events classified as failures)
0		Number of large corrosion events in industry	Reference 25
104		Number of operating nuclear units	Reference 27, page 38
31-Jan-2002		Date of Calvert Cliffs ILRT Extension Request	Reference 23
4	years	Calendar years from Calvert Cliffs ILRT Extension Request to present	
5.5	years	Data reporting period for corrosion events	Reference 23
20857	square feet	WBN Containment surface area dome	Appendix A
40443	square feet	WBN Containment surface area cylinder	Appendix A
61300	square feet	WBN Containment surface area total except basemat	sum of dome + cylinder, 1 side only
2800	square feet	WBN Containment surface area that is not inspectable (not including basemat)	Appendix A
no		Basemat liner failures detectable by ILRT?	Reference 25
5	years .	Containment failure probability due to corrosion doubling time	Reference 23
6 - 10	year interval	Containment failure base rate anchor point	Reference 23
5	percent	Failure probability for visually detecting containment corrosion damage to inspectable area	Reference 23
100	percent	Failure probability for visually detecting containment corrosion damage to un- inspectable area	Reference 23

Table 5 Corrosion Model Parameters

Calculation No. MDN001-999-2005-0099	Rev	/: 2	Plant: WBN		Page: 27	
Subject: EVALUATION OF THE RISK SIGNIFICANCE OF DECREASED		Prepared:		Da	Date:	
	Checked: Date		ite:			

Table 5a Containment Failure Frequency due to Corrosion Base Rate for Small Through-Wall Holes

5	Number of events at all US nuclear units
988	Exposure time for all US nuclear units (years)
5.06E-03	Frequency of small holes (events/year)
4.57E-02	Conditional Probability that hole occurs in un-inspectable location
9.54E-01	Conditional Probability that hole occurs in inspectable location
0.05	Conditional Probability that hole in inspectable location is not detected visually
9.34E-02	Conditional Probability that hole is not visually detected
4.73E-04	Frequency of small holes that are not visually detected (events/year)

Note 1: conditional probability for hole location based upon the ratio of surface areas Note 2: conditional probability that hole is not visually detected is based on 100%

of un-inspectable area plus 5% of inspectable area

Table 5b Containment Failure Frequency due to Corrosion Base Rate for Large Through-Wall Holes

0	Number of events at all US nuclear units
988	Exposure time for all US nuclear units (years)
5.06E-04	Frequency of large holes (events/year)
4.57E-02	Conditional Probability that hole occurs in un-inspectable location
9.54E-01	Conditional Probability that hole occurs in inspectable location
0.05	Conditional Probability that hole in inspectable location is not detected visually
9.34E-02	Conditional Probability that hole is not visually detected
4.73E-05	Frequency of large holes that are not visually detected (events/year)

Note 1: Frequency of large events based upon 0.5 failures.

Calculation No. MDN001-999-2005-0099	Rev	: 2	Plant: WBN		Page: 28
Subject: EVALUATION OF THE RISK SIGNIFICANCE OF DECREASED Prepared: Date:		e:			
	ļ	Cheo	cked:	Dat	te:

Table 5c Containment Failure Frequency due to Corrosion Containment Failure Frequency as a Function of Time

Year	Small	Large
1	1.57E-04	1.57E-05
2	1.85E-04	1.85E-05
3	2.17E-04	2.17E-05
4	2.55E-04	2.55E-05
5	2.99E-04	2.99E-05
6	3.51E-04	3.51E-05
7	4.04E-04	4.04E-05
8	4.64E-04	4.64E-05
9	5.33E-04	5.33E-05
10	6.12E-04	6.12E-05
11	7.03E-04	7.03E-05
12 *	8.07E-04	8.07E-05
13	9.27E-04	9.27E-05
·14	1.07E-03	1.07E-04
15	1.22E-03	1.22E-04
16	1.41E-03	1.41E-04
17	1.61E-03	1.61E-04
18	1.85E-03	1.85E-04
19	2.13E-03	2.13E-04
20	2.45E-03	2.45E-04

r = yearly rate of return to double in 5 years

 $(1 + r)^{5} = 2.0$

r = (2.0)^0.20 - 1

1.49E-01

average frequency of small failures for years 6 - 10

4.73E-04

average frequency = (year 6 + year 7 + year 8 + year 9 + year 10)/5x = year 6 frequency of small failures

average = $((x) + x^{*}(1+r) + x^{*}(1+r)^{2} + x^{*}(1+r)^{3} + x^{*}(1+r)^{4})/5$

 $x = 5^{(average)/(1 + (1+r) + (1+r)^2 + (1+r)^3 + (1+r)^4)$ 3.51E-04

average frequency of large failures for years 6 - 10

4.73E-05

3.51E-05

average frequency = (year 6 + year 7 + year 8 + year 9 + year 10)/5

x = year 6 frequency of large failures

average = $((x) + x^{*}(1+r) + x^{*}(1+r)^{2} + x^{*}(1+r)^{3} + x^{*}(1+r)^{4})/5$

 $x = 5^{(average)/(1 + (1+r) + (1+r)^2 + (1+r)^3 + (1+r)^4)$

Calculation No. MDN001-999-2005-0099	Rev: 2	Plant: WBN	Page: 29	
Subject: EVALUATION OF THE RISK SIGNIFICANCE OF DECREASED	Prep	pared:	Date:	
	Checked:		Date:	

Та	ble 5d
Containment Failure Probability	y as a Function of ILRT Frequency

		Corr	osion	Pre-e:	xisting	To	otal
ILRT Frequency	T/2 (months)	Small	Large	Small	Large	Small	Large
3/10 years	18.00	5.21E-04	5.21E-05	0.0270	0.0027	0.0275	0.0028
1/10 years	60.00	1.74E-03	1.74E-04	0.0900	0.0090	0.0917	0.0092
1/15 years	90.00	4.10E-03	4.10E-04	0.1350	0.0135	0.1391	0.0139
1/20 years	120.00	8.83E-03	8.83E-04	0.1800	0.0180	0.1888	0.0189

Note 1: corrosion probabilities are calculated as (average frequency)*(1/12)*(T/2)

Note 2: Small pre-existing failure probability calculated as (0.027)*(1/18)*(T/2)

11///

Note 3: Large pre-existing failure probability calculated as (0.0027)*(1/18)*(T/2)

Note 4: T/2 is used as the exposure time for corrosion failures. This is a conservative treatment.

Note 5: the probabilities for small and large pre-existing failures for the 3/10 year ILRT frequency are from reference 15.

6.4 Accident Class Information as a Function of ILRT Frequency

EPRI accident class population doses (person-rem/reactor year) are calculated in Tables 6 through 6c for ILRT frequencies of 3/10 years, 1/10 years, 1/15 years, and 1/20 years, respectively. The dose per event is from Table 4d. The frequencies for classes 2, 7, and 8 are from Table 4b. The frequency for class 1 is per the guidance of reference 15. The frequencies for classes 3a and 3b are from Table 5d.

Calculation No. MDN001-999-2005-0099		Rev: 2	Plant: WBN	Page: 30
Subject: EVALUATION OF THE RISK SIGNIFICANCE OF DECREASED		Prep	ared:	Date:
		Che	cked:	Date:

				Population
			Frequency	Dose (person-
		Dose (person-	(events per	rem/reactor
class	Description	rem/event)	reactor year)	year)
1	Containment Intact	2.78E+02	2.13E-05	5.93E-03
2	Isolation Failures, common cause		0.00E+00	0.00E+00
3a	Small pre-existing Leak	_2.78E+03	8.34E-07	2.32E-03
3b	Large pre-existing Leak	9.74E+03	8.34E-08	8.13E-04
4	Type B tested components			
5	Type C tested components			
6	Isolation Failures, redundant valves			
7	Severe Accident Phenomena	1.34E+05	7.06E-06	9.46E-01
8	Bypass	5.74E+05	1.03E-06	5.91E-01
	Total		3.03E-05	1.55E+00

 Table 6

 Accident Class Information for ILRT Frequency of 3/10 years

Note 1: Frequency for Class 1 set equal to Frequency of Class 1 from Table 4b less Frequency of Classes 3a and 3b. This maintains the correct CDF.

Note 2: Frequency for Class 3a and 3b from Table 5d.

Note 3: This case is refered to as the baseline case in Reference 15.

Calculation No. MDN001-999-2005-0099	Rev:	2	Plant: WBN		Page: 31
Subject: EVALUATION OF THE RISK SIGNIFICANCE OF DECREASED		rep	ared:	Dat	l
	Ċ	hec	ked:	Dat	e:

			Population
		Frequency	Dose (person-
	Dose (person-	(events per	rem/reactor
Description	rem/event)	reactor year)	year)
Containment Intact	2.78E+02	1.91E-05	5.33E-03
Isolation Failures, common cause		0.00E+00	0.00E+00
Small pre-existing Leak	2.78E+03	2.78E-06	7.74E-03
Large pre-existing Leak	9.74E+03	2.78E-07	2.71E-03
Type B tested components			
Type C tested components			
Isolation Failures, redundant valves			
Severe Accident Phenomena	1.34E+05	7.06E-06	9.46E-01
Bypass	5.74E+05	1.03E-06	5.91E-01
Total		3.03E-05	1.55E+00
	Description Containment Intact Isolation Failures, common cause Small pre-existing Leak Large pre-existing Leak Type B tested components Type C tested components Isolation Failures, redundant valves Severe Accident Phenomena Bypass Total	DescriptionDose (person-rem/event)Containment Intact2.78E+02Isolation Failures, common causeSmall pre-existing Leak2.78E+03Large pre-existing Leak9.74E+03Type B tested componentsType C tested componentsIsolation Failures, redundant valvesSevere Accident Phenomena1.34E+05Bypass5.74E+05Total	DescriptionFrequency (events per rem/event)Containment Intact2.78E+021.91E-05Isolation Failures, common cause0.00E+00Small pre-existing Leak2.78E+032.78E-06Large pre-existing Leak9.74E+032.78E-07Type B tested components11Type C tested components1Isolation Failures, redundant valves5.74E+05Severe Accident Phenomena1.34E+057.06E-06Bypass5.74E+051.03E-06

 Table 6a

 Accident Class Information for ILRT Frequency of 1/10 years

Note 1: Frequency for Class 1 set equal to Frequency of Class 1 from Table 4b less Frequency of Classes 3a and 3b. This maintains the correct CDF. Note 2: Frequency for Class 3a and 3b from Table 5d.

Calculation No. MDN001-999-2005-0099	Re	v: 2	Plant: WBN	1	Page: 32
Subject: EVALUATION OF THE RISK SIGNIFICANCE OF DECREASED CONTAINMENT INTEGRATED LEAK RATE TEST FREQUENCY	,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,	Prep	ared:	Da	ite:
		Che	cked:	Da	te:

Table 6b	2
Accident Class Information for ILRT Frequency of 1/15	5 years

		Dose (person-	Frequency (events per	Population Dose (person- rem/reactor
class	Description	rem/event)	reactor year)	year)
1	Containment Intact	2.78E+02	1.76E-05	4.89E-03
2	Isolation Failures, common cause		0.00E+00	0.00E+0C
3a	Small pre-existing Leak	2.78E+03	4.21E-06	1.17E-02
3b	Large pre-existing Leak	9.74E+03	4.21E-07	4.11E-03
4	Type B tested components			
5	Type C tested components			
6	Isolation Failures, redundant valves			
7	Severe Accident Phenomena	1.34E+05	7.06E-06	9.46E-01
8	Bypass	5.74E+05	1.03E-06	5.91E-01
	Total		3.03E-05	1.56E+00

Note 1: Frequency for Class 1 set equal to Frequency of Class 1 from Table 4b less Frequency of Classes 3a and 3b. This maintains the correct CDF. Note 2: Frequency for Class 3a and 3b from Table 5d.

Calculation No. MDN001-999-2005-0099	Rev:	2	Plant: WBN		Page: 33
Subject: EVALUATION OF THE RISK SIGNIFICANCE OF DECREASED		rep	ared:	Dati	9:
	C	Chec	ked:	Dati););

Table 6c
Accident Class Information for ILRT Frequency of 1/20 years

				Population
			Frequency	Dose (person-
		Dose (person-	(events per	rem/reactor
class	Description	rem/event)	reactor year)	year)
1	Containment Intact	2.78E+02	1.59E-05	4.43E-03
2	Isolation Failures, common cause		0.00E+00	0.00E+00
3a	Small pre-existing Leak	2.78E+03	5.72E-06	1.59E-02
3b	Large pre-existing Leak	9.74E+03	5.72E-07	5.57E-03
4	Type B tested components			
5	Type C tested components			
6	Isolation Failures, redundant valves		_	
7	Severe Accident Phenomena	1.34E+05	7.06E-06	9.46E-01
8	Bypass	5.74E+05	1.03E-06	5.91E-01
	Total		3.03E-05	1.56E+00

Note 1: Frequency for Class 1 set equal to Frequency of Class 1 from Table 4b less Frequency of Classes 3a and 3b. This maintains the correct CDF. Note 2: Frequency for Class 3a and 3b from Table 5d.

6.5 <u>Population Dose as a Function of ILRT Frequency</u>

Changes in population dose as a function of ILRT frequency, expressed both in absolute terms (person-rem/reactor year) and as a percentage, are documented in Table 7.

ILRT Frequency	Dose for Class 3a and 3b (person-rem/reactor year)	Dose for Class 3a and 3b (percent of total)	Delta Class 3a and 3b dose from baseline case (person- rem/reactor year)	De ta Class 3a and 3b dose from baseline case (percent of total)
3/10 years	3.13E-03	0.20%	0.00E+00	0.00%
1/10 years	1.04E-02	0.67%	7.31E-03	0.47%
1/15 years	1.58E-02	1.02%	1.27E-02	0.81%
1/20 years	2.15E-02	- 1.38%	1.84E-02	1.17%

Table 7

Class 3a + 3b Population Dose as a function of ILRT Frequency

Calculation No. MDN001-999-2005-0099	Rev: 2	Plant: WBN	Page: 34
Subject: EVALUATION OF THE RISK SIGNIFICANCE OF DECREASED CONTAINMENT INTEGRATED LEAK RATE TEST FREQUENCY	Pre	pared:	Date:
	Che	cked:	Date:

6.6 LERF as a Function of ILRT Frequency

H I V. 1

Changes in LERF as a function of ILRT frequency, expressed in absolute terms (events/reactor year), are documented in Table 8. For the purposes of this calculation, LERF is set equal to the frequency of EPRI class 3b. Note that LERF so calculated represents only large early release accident sequences that are affected by the ILRT frequency.

Because the delta LERF values are greater than 1E-7, a calculation of total LERF is provided in Table 8a. This value of LERF represents all accident sequences.

ILRT Frequency	Frequency of Class 3b (events per reactor year)	LERF (events per reactor year)	Delta LERF from baseline case (events per reactor year)
3/10 years	8.34E-08	8.34E-08	0.00E+00
1/10 years	2.78E-07	2.78E-07	1.95E-07
1/15 years	4.21E-07	4.21E-07	3.38E-07
1/20 years	5.72E-07	5.72E-07	4.89E-07

Table 8LERF as a function of ILRT Frequency

Calculation No. MDN001-999-2005-0099	Rev	: 2	Plant: WBN		Page: 35
Subject: EVALUATION OF THE RISK SIGNIFICANCE OF DECREASED CONTAINMENT INTEGRATED LEAK RATE TEST FREQUENCY		Prep	pared: Da		ate:
		Che	cked:	Da	te:

Table 8a Total LERF

KDC		1000
KRC	Total KRC Flequency	
R21	2.20E-05	
R17L	1.95E-06	
R11I	1.18E-06	
R11IF	<u>1.18E-06</u>	1.18E-06
R17LU	1.13E-06	l
R20	8.95E-07	
R <u>17U</u>	7.36E-07	
R01DI	4.99E-07	4.99E-07
R22	2.20E-07	
R04IF	2.01E-07	2.01E-07
R19	1.22E-07	1.22E-07
R01IF	8.00E-08	8.00E-08
R02IF	4.97E-08	4.97E-08
R03IF	3.07E-08	3.07E-08
R04	1.57E-08	1.57E-08
R18	1.28E-08	1.28E-08
R03I	9.57E-09	9.57E-09
R04UIF	5.13E-09	5.13E-09
R01UIF	2.19E-09	2.19E-09
R05LIF	1.54E-09	
R03UIF	1.34E-09	1.34E-09
R06IF	9.87E-10	
R05IF	1.82E-10	
R03	4.50E-11	4.50E-11
R011	2.41E-11	2.41E-11
R06LIF	2.35E-11	
	· · · · · · · · · · · · · · · · · · ·	
Total all KRCs	3.03E-05	2.21E-06
[Total LERF	2.78E-06

Note 1: Total KRC Frequency from Table 3.

Note 2: Allocation of KRCs to LERF per section 4.9 of reference 1.

Note 3: Total LERF is the sum of LERF for the total all KRCs plus LERF from Table 8 for ILRT frequency of 1/20 years.

Calculation No.	MDN001-999-2005-0099	Rev	: 2	Plant: WBN	Page: 36
Subject: EVALUATION OF THE RISK SIGNIFICANCE OF DECREASED CONTAINMENT INTEGRATED LEAK RATE TEST FREQUENCY			Prep	bared:	Date:
		ſ	Che	cked:	Date:

6.7 <u>CCFP as a Function of ILRT Frequency</u>

CCFP and percentage changes in the CCFP as a function of ILRT frequency are documented in Table 9.

	Frequency of Class 1 (events	Frequency of Class 3a (events per		Delta CCFP
ILRT Frequency	per reactor year)	reactor year)	CCFP (percent)	(percent)
3/10 years	2.13E-05	8.34E-07	26.99%	0.00%
1/10 years	1.91E-05	2.78E-06	27.63%	0.64%
1/15 years	1.76E-05	4.21E-06	28.10%	1.12%
1/20 years	1.59E-05	5.72E-06	28.60%	1.61%

Table 9CCFP as a function of ILRT Frequency

CDF 3.03E-05

Note 1: CCFP (percent) = 1- (frequency of class 1 + frequency of class 3a)/CDF

Calculation No. MDN001-999-2005-0099	Rev: 2	Plant: WBN	Page: 37
Subject: EVALUATION OF THE RISK SIGNIFICANCE OF DECREASED CONTAINMENT INTEGRATED LEAK RATE TEST FREQUENCY	Prepared: Date:		Date:
	Ch	ecked:	Date:

7.0 Summary of Results

ЦĄ

Table 10 provides a summary of the results. Table 10a provides the same figures of merit as Table 10, but includes 10% margin. Table 10a should be referenced for the proposed ILRT frequency Technical Specification change.

Table 10 Summary of Results							
		Delta LERF per reactor year	Delta CCFP percent	Delta Population Dose person-rem	Delta Population Dose percent		
ILRT Change from 3/10 years to 1/10 years		1.95E-07	0.64%	7.31E-03	0.47%		
ILRT Change from 3/10 years to 1/15 years		3.38E-07	1.12%	1.27E-02	0.81%		
ILRT Change from 3/10 years to 1/20 years		4.89E-07	1.61%	1.84E-02	1.17%		
ILRT Change from 1/10 years to 1/15 years		1.44E-07	0.47%	5.39E-03	0.34%		

I VA						
Calculation No.	MDN001-999-2005-0099	Rev	1: 2	Plant: WBN	Page: 38	
Subject: EVALUATION OF THE RISK SIGNIFICANCE OF DECREASED		Prepared:		ared:	Date:	
			Che	cked:	Date:	

Table 10aSummary of Results w/ 10% safety factor

r	 Delta LERF per reactor year	Delta CCFP percent	Delta Population Dose person-rem	Delta Population Dose percent
ILRT Change from 3/10 years to 1/10 years	2.14E-07	0.71%	8.04E-03	0.52%
ILRT Change from 3/10 years to 1/15 years	3.72E-07	1.23%	1.40E-02	0.90%
ILRT Change from 3/10 years to 1/20 years	5.38E-07	1.77%	2.02E-02	1.29%
ILRT Change from 1/10 years to 1/15 years	1.58E-07	0.52%	5.93E-03	0.38%

Calculation No. MDN001-999-2005-0099	9-2005-0099 Rev: 2 Plant: M		Page: 39
Subject: EVALUATION OF THE RISK SIGNIFICANCE OF DECREASED CONTAINMENT INTEGRATED LEAK RATE TEST FREQUENCY	Prepared:		Date:
	Che	cked:	Date:

8.0 Supporting Graphics

Figure 1 is provided in section 6.1.3.

9.0 Conclusions

TIVAN

The following conservative treatments are used within this calculation. The numerical results are therefore deemed conservative.

- The EPRI interim methodology assumes that all events classified as 3a or 3b are mapped from class 1 (containment intact). This ignores events in which a pre-existing containment leak is masked by other containment failure modes.
- The frequency of fire-induced CDF is based on the FIVE screening analysis performed for the IPEEE.
- The 50 mile surrounding population is assumed to be equal to the projected value at year 2035.
- The corrosion model does not screen industry events for applicability to the containment design or to a degradation mechanism. All industry events are assumed to be applicable to WBN.
- The numerical results include a 10% margin.

The increase in LERF when the frequency of an ILRT is decreased from 1/10 years to 1/15 years is 1.58E-07. This value is a "small" increase in LERF (less than 1E-6 and greater than 1E-7) per Regulatory Guide 1.174 (reference 5). A small increase in LERF is acceptable if the total LERF is shown to be below 1E-5 per reactor year. Table 8a documents the total LERF. The proposed ILRT extension is acceptable with respect to Δ LERF.

The change in the calculated CCFP is small, indicative of a proposed change that does not significantly challenge the principle of defense in depth.

The change in the calculated population dose is very small, and indicative of a proposed change that does not significantly increase risk to the public.

Based on these risk measures, the proposed ILRT frequency change is acceptable.

Calculation No. MDN001-999-2005-0099	Rev: 2	Plant: WBN	Page: 40	
ubject: EVALUATION OF THE RISK SIGNIFICANCE OF DECREASED	Prepared: FDM		Date: 3/9/06	
	Che	cked: ERW	Date: 3/9/06	

Appendix A

SCV Inspection Area

Watts Bar Steel Containment Vessel (SCV) Inspection Area

The Watts Bar Nuclear Plant (WBN) Unit 1 SCV surface area is estimated using Chicago Bridge & Iron Company (CBI) (Contract No. 75320) drawings (See References). The exterior surface areas of the dome (20857 sq.ft.) and cylinder (40443 sq.ft.) are added to determine the estimated exterior surface area for the Unit 1 SCV. The total Unit 1 SCV surface area is estimated as 61300 sq.ft.

Inaccessible Area for Inspection

1 1// 1

The WBN Unit 1 SCV exterior insulation types and locations are identified in WBN Engineering Specification "N3M-936" Revision 4, "For Installation, Modification and Maintenance of Heat and Anti-Sweat Insulation", Section 4.10.2.3. These areas are from 54° to 126° between elevation 716'-0" and 747'-0".

Walkdown of the SCV also identified additional insulation locations from 50° to 126° between elevation 713'-0" and 716'-0" and from 50° to 54° between elevation 716'-0" and 733'-0".

The inaccessible surface areas for the WBN Unit 1 SCV are identified as areas of the exterior SCV surface with insulation and the shielding area around the fuel transfer penetration. The area below the floor of the embedded metal liner and concrete base slab is also inaccessible for the inspection.

The total inaccessible area for inspection including the shielding area around the fuel transfer penetration is estimated as 2800 sq.ft. The area below the floor of the embedded metal liner and concrete base slab is not included in the 2800 sq.ft.

Reference Drawings:

- 1. 1, 2-48N401 Rev. 1, "Structural Steel Containment Vessel Anchor Bolt Plan and Base Dets SH 1"
- 2. Chicago Bridge & Iron Company (CBI) (Contract No. 75320) Drawing No. 400 Rev 6 "Roof Plan View"
- Chicago Bridge & Iron Company (CBI) (Contract No. 75320) Drawing No. 34 Rev 8 "Shell Ring No. 1, Assy. 34-A"
- 4. ISI-0503-C-03 Rev 1, "Watts Bar Nuclear Plant Unit 1 Metal Containment Penetrations & Elevations"
- 5. ISI-0503-C-04 Rev 1, "Watts Bar Nuclear Plant Unit 1 Metal Containment Penetrations & Elevations"
- 6. ISI-0503-C-05 Rev 1, "Watts Bar Nuclear Plant Unit 1 Metal Containment Penetrations & Elevations"

This page Prepared: Francis D. Menachery This page Reviewed: Everett R. Winters

Calculation No. MDN001-999-2005-0099		Rev	: 2	Plant: WBN		Page: 41
Subject: EVALUATION OF THE RISK SIGNIFICANCE OF DECREASED		Prepared:		Dat	Date:	
			Chee	cked:	Dat	te:

Appendix B

Industry Primary Containment Failures due to Corrosion

Plant:	Davis Besse
Date:	July, 2002
Extent:	corrosion of free-standing shell where it meets floor. As-found containment thickness above minimum.
Cause:	no moisture barrier.
ID Method:	visual inspection
Reference:	Reference 30.
Failure:	no
Plant:	Sequoyah 2
Date:	May, 2002
Extent:	degraded coating and surface rust
Cause:	clogged floor drain
ID Method:	visual inspection
Reference:	Reference 30.
Failure:	no
Plant:	Dresden 2
Date:	November, 2001
Extent:	missing coating, corrosion area 2-4 inches wide, encircling drywell near floor. Degraded area within corrosion allowance.
Cause:	not reported
ID Method:	visual inspection
Reference:	Reference 30.
Failure:	no
Plant:	D. C. Cook 2
Date:	March, 2001
Extent:	Through-wall hole.
	Corrosion outside liner, near hole.
Cause:	Hole caused by construction error.

Calculation No.	MDN001-999-2005-0099	Rev	: 2	Plant: WBI	N	Page: 42	
Subject: EVALUATION OF THE RISK SIGNIFICANCE OF DECREASED CONTAINMENT INTEGRATED LEAK RATE TEST FREQUENCY			Prepared:		Date:		
		F	Checked:		Date:		
	Corrosion near hole caused by wood em	- bedde	d in d	concrete.			
D Method:	visual during weld repair inspection				•		
Reference:	Reference 30.						
Failure:	yes				÷		
Size:	small						
Plant:	D. C. Cook 1						
Date:	February, 1988						
Extent:	Corrosion, not through-wall. More than 6 than minimum.	60 pits	in wh	ich as-found	wali	thickness le	
Cause:	Moisture barrier failure.						
D Method:	not reported.						
Reference:	Reference 30.						
ailure:	yes			·			
Size:	small (size based upon reference 26)						
Plant:	Surry 2						
)ate:	Fall, 2003						
ixtent:	degraded coating and rust at the junction floor. Not through-wall.	n of the	meta	al liner and ir	nterior	concrete	
ause:	failed moisture barrier.						
D Method:	visual inspection						
leference:	Reference 30						
ailure:	no						
lant:	Palisades			•			
ate:	October, 1999		•				
xtent:	minor corrosion at floor-to-liner crevice.						

Cause: moisture barrier not installed.

ID Method: not reported. Reference: Reference 30

no

Failure:

Plant:	North Anna 2	
Date:	9/22/1999	
Extent:	1 through-wall hole.	LLRT passed.

Calculation N	lo. MDN001-999-2005-0099	Rev:	2	Plant: WE	BN	Page: 43
Subject: EVALUATION OF THE RISK SIGNIFICANCE OF DECREASED		- P	Prepared:		Date:	
CONT	AINWENT INTEGRATED LEAK RATE TEST FREQUENCT	Checked:		ked:	Date:	
Cause:	Lumber embedded in concrete.		•		· · ·	
ID Method:	visual inspection					
Reference:	Reference 23.					
Failure:	yes	·				
Size:	small					
Plant:	Brunswick 2					
Date:	May, 1999					•
Extent:	3 through-wall holes					
Cause:	Glove and wood embedded in concrete.					
ID Method:	not reported.					
Reference:	References 23, 30					
Failure:	yes					· · ·
Size:	smali					
Plant:	Robinson 2					
Date:	December, 1996					
Extent:	degraded caulk, insulation, coating. Son greater than minimum.	ne corro	sion	of liner. A	s-found	l thickness
Cause:	degraded caulk					
D Method:	visual inspection					
Reference:	Reference 30					
-ailure:	no .					•
Plant:	Oyster Creek					
Date:	12/8/1986					
	wall thinning no through holes reported					
Extent:	wai uliming, no uliougn-noies reported			d during r	afualing	. .
Extent: Cause:	Contact with wet sand. Moisture from fai	led seals	s use	eu uuning re	sidening	.
Extent: Cause: D Method:	Contact with wet sand. Moisture from fai visual detection of water from drains	led seals	s use	eu uunng re	erdennig	
Extent: Cause: D Method: Reference:	Contact with wet sand. Moisture from fai visual detection of water from drains References 17, 28, 29.	led seals	s use		sidening]. .
Extent: Cause: D Method: Reference: 'ailure:	Contact with wet sand. Moisture from fai visual detection of water from drains References 17, 28, 29. yes, based upon reference 17.	led seals	s use	ed danng fe	erdenny	. .