

April 24, 2006

Mr. Michael R. Kansler
President
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

SUBJECT: PILGRIM NUCLEAR POWER STATION - REQUEST FOR ADDITIONAL
INFORMATION REGARDING UNRESOLVED INSPECTION ITEM
05000293/2005003-01 FROM THE NRC INTEGRATED INSPECTION REPORT
05000293/2005003 (TAC NO. MD0178)

Dear Mr. Kansler:

On June 30, 2005, the Nuclear Regulatory Commission (NRC) completed an inspection at the Pilgrim Nuclear Power Station (Pilgrim). The inspectors determined that the overlap testing conducted under an approved change to Procedure No. 8.M.3-1, by Entergy Nuclear Operations, Inc. (the licensee), does not actually verify the load sequencing as prescribed by Pilgrim Technical Specifications (TSs) 4.9.A.1.b and 4.9.A.1.c. The licensee justified the change based, in part, on the Pilgrim TSs basis wording and existing load sequence overlap testing.

The NRC staff has been reviewing the unresolved inspection item and has determined that additional information is needed to complete its review. The specific questions are found in the enclosed request for additional information (RAI). A response to this RAI is requested to be provided within 45 days.

Sincerely,

/RA/

James J. Shea, Project Manager
Plant Licensing Branch I-1
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-293

Enclosure: As stated

cc w/encl: See next page

April 24, 2006

Mr. Michael R. Kansler
President
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

SUBJECT: PILGRIM NUCLEAR POWER STATION - REQUEST FOR ADDITIONAL
INFORMATION REGARDING UNRESOLVED INSPECTION ITEM
05000293/2005003-01 FROM THE NRC INTEGRATED INSPECTION REPORT
05000293/2005003 (TAC NO. MD0178)

Dear Mr. Kansler:

On June 30, 2005, the Nuclear Regulatory Commission (NRC) completed an inspection at the Pilgrim Nuclear Power Station (Pilgrim). The inspectors determined that the overlap testing conducted under an approved change to Procedure No. 8.M.3-1, by Entergy Nuclear Operations, Inc. (the licensee), does not actually verify the load sequencing as prescribed by Pilgrim Technical Specifications (TSs) 4.9.A.1.b and 4.9.A.1.c. The licensee justified the change based, in part, on the Pilgrim TSs basis wording and existing load sequence overlap testing.

The NRC staff has been reviewing the unresolved inspection item and has determined that additional information is needed to complete its review. The specific questions are found in the enclosed request for additional information (RAI). A response to this RAI is requested to be provided within 45 days.

Sincerely,

/RA/

James J. Shea, Project Manager
Plant Licensing Branch I-1
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-293
Enclosure: As stated
cc w/encl: See next page

DISTRIBUTION:

PUBLIC RidsNrrDORLLp1-1 RidsOgcRP APal
LPLI-1 R/F RidsNrrLASLittle RidsAacrsAcnwMailCenter
RidsNrrPMJShea RidsNrrDORLDpr RidsRgn1MailCenter

Accession Number: ML060970397 see memo dated March 14, 2006

OFFICE	LPL1-1/PM	LPL1-1/LA	EEEB/BC	LPL1-1/BC
NAME	JShea	SLittle	EBrown*	RLaufer
DATE	4/18/06	4/20/06	03/14/06	4/24/06

Official Record Copy

REQUEST FOR ADDITIONAL INFORMATION (RAI)

UNRESOLVED INSPECTION ITEM 05000293/2005003-01

FROM THE NRC INTEGRATED INSPECTION REPORT 05000293/2005003

ENTERGY NUCLEAR OPERATIONS, INC.

PILGRIM NUCLEAR POWER STATION

DOCKET NO. 50-293

On June 30, 2005, the Nuclear Regulatory Commission (NRC) completed an inspection at the Pilgrim Nuclear Power Station (Pilgrim). The inspectors determined that the overlap testing conducted under an approved change to Procedure No. 8.M.3-1, by Entergy Nuclear Operations, Inc. (the licensee), does not actually verify the load sequencing as prescribed by Pilgrim Technical Specifications (TSs) 4.9.A.1.b and 4.9.A.1.c. The licensee justified the change based, in part, on the Pilgrim TSs basis wording and existing load sequence overlap testing.

The NRC staff has been reviewing the unresolved inspection item and has determined that additional information is needed to complete its review.

- 1) The Pilgrim Final Safety Analysis Report Section 8.5.5 states that "Readiness can best be demonstrated by periodic testing, which insofar as practical, simulates actual emergency conditions." What was your basis for determining that it was not practical to sequence load one Reactor Building Closed Cooling Water (RBCCW) Pump and one Salt Service Water (SSW) Pump on the Emergency Diesel Generator (EDG) during surveillance testing (TS Surveillance Requirements 4.9.A.1.b and 4.9.A.1.c)? Also, explain why equivalent loads in lieu of RBCCW and SSW pumps were not added in order to have required DG loading.
- 2) Explain why starting the last sequenced load(s) RBCCW and SSW will not adversely affect the performance of the EDG. Specifically address Kilowatt (KW) and Kilovar (KVAR) requirements and available DG margin in KW and KVAR.
- 3) What does Entergy consider a "small" EDG load? Would this include the RBCCW and SSW pumps? Explain why these loads would not impact EDG performance when taken in total during the sequence load of the emergency diesel.
- 4) Please provide a copy for review of Entergy Procedure No. 8.M.3-1.

Enclosure

Pilgrim Nuclear Power Station

cc:

Regional Administrator, Region I
U. S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406-1415

Senior Resident Inspector
U. S. Nuclear Regulatory Commission
Pilgrim Nuclear Power Station
Post Office Box 867
Plymouth, MA 02360

Chairman, Board of Selectmen
11 Lincoln Street
Plymouth, MA 02360

Chairman
Nuclear Matters Committee
Town Hall
11 Lincoln Street
Plymouth, MA 02360

Chairman, Duxbury Board of Selectmen
Town Hall
878 Tremont Street
Duxbury, MA 02332

Office of the Commissioner
Massachusetts Department of
Environmental Protection
One Winter Street
Boston, MA 02108

Office of the Attorney General
One Ashburton Place
20th Floor
Boston, MA 02108

Director, Radiation Control Program
Commonwealth of Massachusetts
Executive Offices of Health and
Human Services
174 Portland Street
Boston, MA 02114

Secretary of Public Safety
Executive Office of Public Safety
One Ashburton Place
Boston, MA 02108

Director, Massachusetts Emergency
Management Agency
Attn: James Muckerheide
400 Worcester Road
Framingham, MA 01702-5399

Mr. William D. Meinert
Nuclear Engineer
Massachusetts Municipal Wholesale
Electric Company
P.O. Box 426
Ludlow, MA 01056-0426

Mr. Michael A. Balduzzi
Site Vice President
Entergy Nuclear Operations, Inc.
Pilgrim Nuclear Power Station
600 Rocky Hill Road
Plymouth, MA 02360-5508

Mr. Stephen J. Bethay
Director, Nuclear Safety Assurance
Entergy Nuclear Operations, Inc.
Pilgrim Nuclear Power Station
600 Rocky Hill Road
Plymouth, MA 02360-5508

Mr. Bryan S. Ford
Manager, Licensing
Entergy Nuclear Operations, Inc.
Pilgrim Nuclear Power Station
600 Rocky Hill Road
Plymouth, MA 02360-5508

Ms. Charlene D. Faison
Manager, Licensing
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Pilgrim Nuclear Power Station

cc:

Mr. Gary J. Taylor
Chief Executive Officer
Entergy Operations
1340 Echelon Parkway
Jackson, MS 39213

Mr. John T. Herron
Sr. VP and Chief Operating Officer
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Mr. Oscar Limpias
Vice President, Engineering
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Mr. Christopher Schwarz
Vice President, Operations Support
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Mr. John F. McCann
Director, Nuclear Safety Assurance
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Mr. Michael J. Colomb
Director of Oversight
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Mr. Travis C. McCullough
Assistant General Counsel
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Ms. Stacey Lousteau
Treasury Department
Entergy Services, Inc.
639 Loyola Avenue
New Orleans, LA 70113

Mr. James Sniezek
5486 Nithsdale Drive
Salisbury, MD 21801-2490

Mr. Michael D. Lyster
5931 Barclay Lane
Naples, FL 34110-7306