

From: <allan.haeger@exeloncorp.com>
To: <jeh@nrc.gov>, <nxs@nrc.gov>, <sko@nrc.gov>, <ras@nrc.gov>
Date: 12/17/05 3:03PM
Subject: Tritium sample results

Gentlemen,

Attached are results as of Thursday.

Al Haeger

> > <<Tritium Sample Results.xls>> > > <<Map of Well Locations.pdf>>
>
>

This e-mail and any of its attachments may contain Exelon Corporation
proprietary information, which is privileged, confidential, or subject
to copyright belonging to the Exelon Corporation family of Companies.
This e-mail is intended solely for the use of the individual or entity
to which it is addressed. If you are not the intended recipient of this
e-mail, you are hereby notified that any dissemination, distribution,
copying, or action taken in relation to the contents of and attachments
to this e-mail is strictly prohibited and may be unlawful. If you have
received this e-mail in error, please notify the sender immediately and
permanently delete the original and any copy of this e-mail and any
printout. Thank You.

CC: <kenneth.ainger@exeloncorp.com>

E-27

Braidwood Station Tritium Sample Results

Sample ID	Report #	Collection Date	Lab Code	pCi/L
BL-01	1860	11-17-15	BDWW-6559	70±96;96
BL-02	1860	11-17-15	BDWW-6560	156±99;101
BL-03	1860	11-17-15	BDWW-6562	4,058±201;587
BL-04	1860	11-17-15	BDWW-6563	1,178±128;205
BL-05	1860	11-17-15	BDWW-6564	70±96;96
BL-06	1860	11-17-15	BDWW-6565	76±96;97
BL-07	1860	11-17-15	BDWW-6566	126±87;89
BL-08	1861	11-17-05	BDWW-6573	61±96;97
BL-09	1861	11-17-05	BDWW-6574	295±118;124
BL-10	1861	11-18-05	BDWW-6575	90±111;112
BL-10D				
BL-11	1861	11-18-05	BDWW-6576	39±109;110
BL-11D				
BL-12	1861	11-18-05	BDWW-6577	114±112;113
BL-12D				
BL-13	1861	11-18-05	BDWW-6579	102±98;99
BL-13D				
BL-14	1861	11-18-05	BDWW-6580	40±95;96
BL-14D				
BL-15	1861	11-18-05	BDWW-6581	0±94;94
BL-15D				
BL-16D				

Braidwood Station Tritium Sample Results

Sample ID	Report #	Collection Date	Lab Code	pCi/L
MW-110	1858	11-15-05	BDWW-6518	93±90;91
MW-111	1857	11-15-05	BDWW-6504	224±112;116
MW-112	1857	11-15-05	BDWW-6505	167±110;112
MW-113	1857	11-15-05	BDWW-6503	4,830±219;692
MW-113	1869	12-05-05	BDWW-6843	4,009±207;155
MW-113	1870	12-05-05	BDWW-6930	3,598±188;524
MW-113D				
P-1	1865	12-01-05	BDWW-6707	2,484±174;380
P-2	1867	12-02-05	BDWW-6777	4,344±288;657
P-2D	1873	12-12-05	BDWW-7038	2,599±177;395
P-3	1867	12-02-05	BDWW-6778	3,258±258;513
P-4	1865	12-01-05	BDWW-6700	33,041±509;4,522
P-4	1870	12-06-05	BDWW-6916	25,311±435;3,470
P-5	1865	12-01-05	BDWW-6699	6,621±248;934
P-6	1865	12-01-05	BDWW-6704	450±123;138
P-7	1865	12-01-05	BDWW-6705	1,210±133;212
P-8	1865	12-01-05	BDWW-6706	2,998±185;448
P-8	1870	12-06-05	BDWW-6917	2,212±160;341
P-9	1869	12-05-05	BDWW-6835	1,346±148;235
P-9	1870	12-06-05	BDWW-6918	-90±96;97
P-9	1874	12-13-05	BDWW-7053	111±112;113
P-10	1869	12-05-05	BDWW-6836	1,934±162;309

Braidwood Station Tritium Sample Results

Sample ID	Report #	Collection Date	Lab Code	pCi/L
RW-2@10.6'	1872	12-06-05	BDWW-6968	58,621±644;7,998
RW-2@20'	1874	12-13-05	BDWW-7055	171,166±1,115;23,305
RW-2@20.6'	1872	12-06-05	BDWW-6969	170,024±1,089;23,149
RW-2@25'	1874	12-13-05	BDWW-7056	246,442±1,337;33,543
RW-2@25.0'	1872	12-06-05	BDWW-6970	223,888±1,299;30,476
RW-3	1867	12-02-05	BDWW-6783	197±107;111
RW-4	1867	12-02-05	BDWW-6784	380±113;125
S-1	1869	12-05-05	BDWW-6829	-21±107;107
S-1	1870	12-06-05	BDWW-6910	83±111;111
S-2	1869	12-05-05	BDWW-6830	95±111;112
S-2	1870	12-06-05	BDWW-6911	88±103;104
S-2D	1873	12-12-05	BDWW-7037	225±101;105
S-3	1869	12-05-05	BDWW-6831	145±113;115
S-3	1870	12-06-05	BDWW-6912	57±102;102
S-4	1869	12-05-05	BDWW-6832	1,280±147;228
S-4	1870	12-06-05	BDWW-6913	1,086±133;199
S-5	1869	12-05-05	BDWW-6833	2,023±165;321
S-5	1870	12-06-05	BDWW-6914	1,874±152;297
S-6	1869	12-05-05	BDWW-6834	679±130;160
S-6	1870	12-06-05	BDWW-6915	411±113;126
VB1-1	1858	11-15-05	BDWW-6512	1,194±140;215
VB1-1D				

Braidwood Station Tritium Sample Results

Sample ID	Report #	Collection Date	Lab Code	pCi/L
VB3-2	1859	11-15-05	BDWW-6501	26,686±453;3,658
VB3-3	1860	11-16-05	BDWW-6557	43,894±580;5,998
VB3-4	1860	11-16-05	BDWW-6558	58,489±702;7,985
VB3-4	1869	12-05-05	BDWW-6842	43,708±592;5,974
VB3-4	1870	12-05-05	BDWW-6926	40,654±545;5,544
VB3-4D				
VB3-5	1862	11-22-05	BDWW-6629	95±98;99
VB3-6	1862	11-22-05	BDWW-6630	53,572±637;7,314
VB3-7	1867	12-02-05	BDWW-6779	169±106;109
VB3-7D				
VB3-8	1867	12-02-05	BDWW-6782	171±106;109
VB3-9D	1874	12-13-05	BDWW-7052	21,715±408;2,981
VB3-10				
VB3-10D				
VB4-1				
VB4-1D				
VB5-1				
VB5-1D				
VB6-1				
VB6-1D				
VB7-1				
VB7-1D				