



The University of Michigan
MICHIGAN MEMORIAL PHOENIX PROJECT

PHOENIX MEMORIAL LABORATORY
FORD NUCLEAR REACTOR
ANN ARBOR, MI 48109-2100

06 April 2006

Attn: Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001

Docket 50-2, License R-28

Subject: Ford Nuclear Reactor – Technical Specification Amendment Request, Revision 02

Dear Sir:


The University of Michigan's, Ford Nuclear Reactor is requesting a revision to the Reactor Building Confinement section of the Technical Specification Amendment: *Elimination and Relaxation of Specifications Following Permanent Cessation of Operations* date 8 September 2005. Only this section of the amendment request is being revised. This revision is to make the wording of the Technical Specification 3.3 FNR Confinement match the analysis which allowed for the gamma radiation detector which utilizes a Geiger Mueller tube to measure the radiation level in the building air exhaust plenum may be out of service *for one week*. The paragraph after 3.3.1.b.v should be revised to read:

The gamma radiation detector which utilizes a Geiger Mueller tube to measure the radiation level in the building air exhaust plenum may be out of service for one week, BUT during that period, no activities which could lead to the release of radioactivity from the facility may be conducted within the reactor building. This restriction does not apply to activities required for restoring the monitoring system to service.

Additionally, it is requested that the proposed limiting conditions for operation 3.4 should be labeled **Pool Water Conditions** and the proposed surveillance 4.4 should be labeled **Pool Water Conditions**.

If there are any questions regarding this information, please feel free to contact Christopher W. Becker at (734) 764-6224.

I declare under penalty of perjury that the foregoing is, to the best of my knowledge, true and correct.

Signature: 
Christopher W. Becker
Nuclear Reactor Laboratory Manager

Executed on: 06 April 2006

Cc: Patrick Isaac

File: Correspondence 06-007
License Amendment – Elimination of Specifications following shutdown

Phone: (734) 764-6224

Fax: (734) 936-1571

A020