

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE	FREQUENCY
<p>SR 3.6.1.3.8 -----NOTE-----            1. Leakage through penetrations 1MC-101 and 1MC-102 is excluded.             2. Only required to be met in MODES 1, 2, and 3.            -----             Verify the combined leakage rate for all secondary containment bypass leakage paths is <math>\leq 0.08 L_a</math> when pressurized to <math>\geq P_a</math>.</p>	<p>In accordance with the Primary Containment Leakage Rate Testing Program</p>
<p>SR 3.6.1.3.9 -----NOTE-----            Only required to be met in MODES 1, 2, and 3.            -----             Verify the leakage rate through each MSIV leakage path is <math>\leq 100</math> scfh when tested at <math>\geq P_a</math> and the combined leakage rate for all MSIV leakage paths is <math>\leq 200</math> scfh when tested at <math>\geq P_a</math>.</p>	<p>In accordance with the Primary Containment Leakage Rate Testing Program</p>
<p>SR 3.6.1.3.10 -----NOTE-----            Only required to be met in MODES 1, 2, and 3.            -----             Verify combined leakage rate through hydrostatically tested lines that penetrated the primary containment is within limits.</p>	<p>In accordance with the Primary Containment Leakage Rate Testing Program</p>

(continued)