

Palisades Nuclear Plant Operated by Nuclear Management Company, LLC

April 14, 2006

10 CFR 50.73(a)(2)(ii)(B)

U. S. Nuclear Regulatory Commission ATTN: Document Control Desk Washington, DC 20555-0001

Palisades Nuclear Plant Docket 50-255 License No. DPR-20

Licensee Event Report 06-001, Potential Loss Of Primary Coolant Makeup Function For Postulated Fire Scenario

Licensee Event Report (LER) 06-001 is enclosed. The LER describes the discovery of a postulated fire scenario in which spurious component operation could result in the potential inability to maintain a primary coolant makeup path in accordance with 10 CFR 50, Appendix R. This event is reportable in accordance with 10 CFR 50.73(a)(2)(ii)(B).

Summary of Commitments

This letter contains no new commitments and no revisions to existing commitments.

Paul A. Harden Site Vice President, Palisades Nuclear Plant Nuclear Management Company, LLC

Enclosure (1)

CC Administrator, Region III, USNRC Project Manager, Palisades, USNRC Resident Inspector, Palisades, USNRC

> 27780 Blue Star Memorial Highway • Covert, Michigan 49043-9530 Telephone: 269.764.2000

ENCLOSURE 1

^

1

,

.

LER 06-001, Potential Loss Of Primary Coolant Makeup Function For Postulated Fire Scenario

NRC FORM 366 U.S. NUCLEAR REGULATORY COMMISSION					APPROVED BY OMB NO. 3150-0104 EXPIRES 6-30						IES 6-30-2007					
(See reverse for required number of digits/characters for each block)						Estimated burden per response to comply with this mandatory collection request: 50 hours. Reported lessons learned are incorporated into the licensing process and fed back to industry. Send comments regarding burden estimate to the Records and FOIA/Privacy Service Branch (T-5 F52), U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, or by internet e-mail to infocollects@nrc.gov, and to the Desk Officer, Office of Information and Regulatory Affairs, NEOB-10202, (3150-0066), Office of Management and Budget, Washington, DC 20503. If a means used to impose an information collection does not display a currently valid OMB control number, the NRC may not conduct or sponsor, and a person is not required to respond to, the information collection.										
FACILITY NA	ME (1)	in Consideration of			Sector 1		DOCKET NUMBER (2)				PAGE (3)					
Palisades	s Nuclear	Plant					05000-255				1 of 3					
TITLE (4) Potentia	al Loss (of Prim	nary C	oolant Ma	akeu	ıp Fı	inct	ion for	Po	ostulated	Fire S	Scen	ario			
ËV	ENT DATE (5)		<u> </u>	ER NUMBER (6)		RE	PORT	DATE (7)		OTHER FACILITIES INVOLVED (8))			
мо	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REV NO	мо	DAY	YEAR	F	FACILITY NAME			DOCKET NUMBER			
02	14	2006	2006	001	00	04	14	2006	F/	FACILITY NAME			DOCKET NUMBER			
OPER	ATING		THIS REPORT IS SUBMITTE			MITTED	PURS	UANT TO T	THE REQUIREMENTS OF 10 CFR : (Check all that apply) (11)					ply) (11)		
MOD	E (9)		20.2201(b)		20.22	20.2203(a)(3)(ii)		X	X 50.73(a)(2)(ii)(B)		50.73(a)(2)(ix)(A)					
POV	VER	100	20.2201(d)		20.22	2203(a)(4)			50.73(a)(2)(iii)		50.73(a)(2)(x)					
LEVE	L (10)		20.2203(a)(1)		50.36	0.36(c)(1)(i)(A)			50.73(a)(2)(iv)(A)		73.71(a)(4)					
			20.2203(a)(2)(i) 20.2203(a)(2)(ii)		50.36(c)(1)(ii)(A)			50.73(a)(2)(v)(A)		73.71(a)(5)						
1919 - 201					50.36	50.36(c)(2)			50.73(a)(2)(v)(B)							
			20.2203(a)(2)(iii) 20.2203(a)(2)(iv) 20.2203(a)(2)(v) 20.2203(a)(2)(v)		50.46	50.46(a)(3)(ii) 50.73(a)(2)(i)(A) 50.73(a)(2)(i)(B) 50.73(a)(2)(i)(C)			50.73(a)(2)(v)(C) 50.73(a)(2)(v)(D) 50.73(a)(2)(vii) 50.73(a)(2)(vii)		Specify in Abstract below or in NRC Form 366A					
					50.73			-								
					50.7			+								
			20.2203(a)(2)(V)		50.7	50.73(a)(2)(i)(0)		-	50.73(a)(2)(viii)(A)							
V&			1 120.2		I	CONT		FOR THIS	LEE	(12)	((((())))))))	1		h. 19		
NAME				LIUL					<u>т</u>	ELEPHONE NU	MBER (Inc	lude Are	a Code))		
Daniel G. Malone					(269) 764-2463											
		COMPL	ETE ON	E LINE FOR EA	ACH C	омро	NENT	FAILURE	DES	SCRIBED IN 1	THIS REP	ORT (1	3)			
CAUSE	CAUSE SYSTEM COMPONENT FACTURER		MANU- FACTURER	REPO	ORTABLE EPIX	LE CAUSE			SYSTEM COMP		NENT	MA FA CT	NU- URER	REPORTABLE TO EPIX		
			I													
	S	UPPLEME	NTAL RE	PORT EXPEC	TED (1	4)			-	EXPEC	TED	MON	тн I	DAY	YEAR	
YES (If yes, complete EXPECTED SUBMISSION DATE).				.,	x	NO		SUBMIS	SION (15)							
ABSTRACT			545			-		n	-			-				
On Fé	ebruary 1	4.200	6 duri	ina review	of a	10 (CFR	50. Ar	ne	ndix R ar	alvsis.	a co	nditi	on w	as	

On February 14, 2006, during review of a 10 CFR 50, Appendix R analysis, a condition was identified that could challenge the ability to maintain the primary (reactor) coolant makeup function, as required by Appendix R, paragraph III.G, "Fire Protection of Safe Shutdown Capability."

In the analysis, the specific fire scenario is assumed to render all charging pumps unavailable for maintaining the primary coolant makeup function. To compensate for the loss of all charging pumps, the analysis credited high pressure safety injection pump (HPSI) P-66B for supplying makeup. However, the review determined that the fire scenario could also result in damage to the control circuit for the HPSI pump's credited suction valve, CV-3031, resulting in a spurious closure of the valve. The spurious closure of the HPSI pump's suction valve with the HPSI pump in operation would likely render the HPSI pump inoperable, causing a loss of the ability to maintain the primary coolant makeup function.

This event is reportable in accordance with 10 CFR 50.73(a)(2)(ii)(B) as an unanalyzed condition.

NRC FORM 366A
(1-2001)

ļ

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

	1					
FACILITY NAME (1)	DOCKET NUMBER (2)				PAGE (3)	
		YEAR	NUMBER	NUMBER	2 of 3	
Palisades	05000-255	2006	001	00		
FACILITY NAME (1) Palisades TEXT (If more space is required, use additional copies of NRC Form 366A) (17) EVENT DESCRIPTION On February 14, 2006, during review of a 10 0 identified that could challenge the ability to ma as required by Appendix R, paragraph III.G, "I In the analysis, the specific fire scenario is as unavailable for maintaining the primary coolar all charging pumps, the analysis credited high for supplying makeup. The analysis further redamage to the control circuit for the HPSI pump the HPSI pump was deemed acceptable in th desired operating state of the pump for provid However, the review determined that the fire s circuit for the HPSI pump's credited suction valof the valve. The spurious closure of the HPSI pump the primary coolant makeup function. This event is reportable in accordance with 10 CAUSE OF THE EVENT At the time this Appendix R analysis was deve only one worst case spurious actuation or sign requires the consideration of equipment failur	DOCKET NUMBER (2) 05000-255 CFR 50, Append aintain the prima Fire Protection o sumed to render nt makeup function pressure safety acognized that the np, resulting in a e analysis since ling primary cool scenario could a alve, CV-3031 [N SI pump's suction inoperable, caus D CFR 50.73(a)(2 eloped, the copir nal. Current guine e combinations a	VEAR 2006 lix R ar iry (read of Safe r all cha on. To r injection is fire s spurion this wo ant ma lso resu /;BP], r n valve sing a k 2)(ii)(B) ng stratt dance f and mu	LER NUMBER (6 SEQUENTIAL NUMBER 001 nalysis, a cor ctor) coolant Shutdown C arging pumps compensate on (HPSI) pu scenario coul scenario	ndition wa makeup apability. s [P;CB] e for the ump P-66 Id result i spurious istent wit e to the c spurious SI pump pility to ma alyzed co analysis a c R analysis	PAGE (3) 2 of 3 2 of 3 function, " loss of B [P;BQ] n start of h the control closure in aintain ondition.	
SAFETY SIGNIFICANCE						
The safety significance of the event is consider sufficient primary coolant inventory would be core damage for greater than 24 hours without sufficient time to complete proceduralized em the primary coolant makeup function.	ered to be minim maintained to ke at makeup capab ergency repairs	al. Ana ep the bility. A to a ch	alysis has de core covered 24-hour per arging pump	emonstra d and pre riod is con and to re	ted that vent nsidered estore	

NRC	FORM	366
11-20	01)	

U.S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT (LER)

TEXT CONTINUATION

FACILITY NAME (1)	DOCKET NUMBER (2)	LER NUMBER (6)			PAGE (3)	
		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	3 of 3	
Palisades	05000-255	2006	001	00		
TEXT (If more space is required, use additional copies of NRC Form 366A) (17)						

CORRECTIVE ACTIONS

Compensatory actions were established for this fire scenario to preserve the HPSI pump for primary coolant makeup capability. In the event of a spurious start of the HPSI pump, guidance directs operators to stop the HPSI pump. Guidance also directs isolation of control circuit power to CV-3031 to disable it in the open position, precluding HPSI pump damage caused by pump operation without a suction flow path. Once the suction valve is assured open, the HPSI pump may be operated as necessary to maintain the primary coolant makeup function.

An extent of condition evaluation of other Appendix R credited pumps with similar potential for pump damage resulting from spurious pump and valve operation is being conducted.

Final resolution of this condition is expected to be addressed with the planned transition to National Fire Protection Association (NFPA) 805, "Performance–Based Standard for Fire Protection for Light Water Reactor Electric Generating Plants, 2001 Edition."

PREVIOUS SIMILAR EVENTS

Licensee Event Report 95-015, "Appendix R Scenario Results in Spurious Operation and Damage to Alternate Shutdown Motor Operated Valves"

Licensee Event Report 97-008, "Spurious Valve Operation Could Result in Loss of Shutdown Capabilities Per 10 CFR 50, Appendix R, Section III.L"

Licensee Event Report 97-010, "Inadequacy in Appendix R Analysis Results in a Condition Outside the Design Basis of the Plant"