

April 18, 2006

Mr. Randall K. Edington  
Vice President-Nuclear and CNO  
Nebraska Public Power District  
P. O. Box 98  
Brownville, NE 68321

SUBJECT: COOPER NUCLEAR STATION - CORRECTION TO AMENDMENT  
NO. 218 (TAC NO. MC6760)

Dear Mr. Edington:

By letter dated March 30, 2006, the Commission issued Amendment No. 218 to Facility Operating License No. DPR-46 for the Cooper Nuclear Station (CNS). The amendment, in response to your application dated April 13, 2005, as supplemented by letter dated September 29, 2005, revised various sections in the CNS Technical Specifications (TSs). The TS changes: (1) revised the frequency for performing control rod scram time surveillance following outages; (2) allowed insertion of a control rod withdrawal block and verification that all rods are fully inserted in lieu of suspending fuel movement when a refueling equipment interlock is inoperable; (3) clarified which Emergency Core Cooling System (ECCS) instrumentation must be operable when in shutdown; and (4) eliminated the need to require automatic start of the emergency diesel generators when the ECCS does not need to be operable.

Nebraska Public Power District submitted the license amendment request with markup and final typed TS pages. The logical connectors in Condition A Required Action of TS Section 3.9.1 were correctly aligned on the markup of TS page 3.9-1, but were incorrectly aligned on the final typed page. Enclosed is the corrected page. The page to be replaced is page 3.9-1 of the TS issued in the letter dated March 30, 2006.

Sincerely,

**/RA/**

Brian J. Benney, Project Manager  
Plant Licensing Branch IV  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket No. 50-298

Enclosure: Page 3.9-1 of the TSs

cc w/encl: See next page

April 18, 2006

Mr. Randall K. Edington  
Vice President-Nuclear and CNO  
Nebraska Public Power District  
P. O. Box 98  
Brownville, NE 68321

SUBJECT: COOPER NUCLEAR STATION - CORRECTION TO AMENDMENT  
NO. 218 (TAC NO. MC6760)

Dear Mr. Edington:

By letter dated March 30, 2006, the Commission issued Amendment No. 218 to Facility Operating License No. DPR-46 for the Cooper Nuclear Station (CNS). The amendment, in response to your application dated April 13, 2005, as supplemented by letter dated September 29, 2005, revised various sections in the CNS Technical Specifications (TSs). The TS changes: (1) revised the frequency for performing control rod scram time surveillance following outages; (2) allowed insertion of a control rod withdrawal block and verification that all rods are fully inserted in lieu of suspending fuel movement when a refueling equipment interlock is inoperable; (3) clarified which Emergency Core Cooling System (ECCS) instrumentation must be operable when in shutdown; and (4) eliminated the need to require automatic start of the emergency diesel generators when the ECCS does not need to be operable.

Nebraska Public Power District submitted the license amendment request with markup and final typed TS pages. The logical connectors in Condition A Required Action of TS Section 3.9.1 were correctly aligned on the markup of TS page 3.9-1, but were incorrectly aligned on the final typed page. Enclosed is the corrected page. The page to be replaced is page 3.9-1 of the TS issued in the letter dated March 30, 2006.

Sincerely,

**/RA/**

Brian J. Benney, Project Manager  
Plant Licensing Branch IV  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket No. 50-298

Enclosure: Page 3.9-1 of the TSs

cc w/encl: See next page

DISTRIBUTION:

PUBLIC RidsNrrDirsltsb  
LPLIV R/F APal  
RidsNrrDorlLpl4 (DTerao) TTjader  
RidsNrrPMBBenney  
RidsNrrLALFeizollahi  
RidsAcrsAcnwMailCenter  
RidsOgcRp  
RidsRgn4MailCenter (KKennedy)  
GHill, OIS (2)

PKG Accession No. **ML061100048**

TS Accession No. **ML061100162**

**ADAMS Accession No.: ML061070308**

**NRR-106**

OFFICE	NRR/LPL4/PM	NRR/LPL4/LA	NRR/LPL4/BC
NAME	BBenney;mxr4	LFeizollahi	DTerao
DATE	4/18/06	4/18/06	4/18/06

**OFFICIAL RECORD COPY**

Cooper Nuclear Station

cc:

Mr. William J. Fehrman  
President and Chief Executive Officer  
Nebraska Public Power District  
1414 15<sup>th</sup> Street  
Columbus, NE 68601

Mr. Gene Mace  
Nuclear Asset Manager  
Nebraska Public Power District  
P.O. Box 98  
Brownville, NE 68321

Mr. John C. McClure  
Vice President and General Counsel  
Nebraska Public Power District  
P. O. Box 499  
Columbus, NE 68602-0499

Mr. Paul V. Fleming  
Licensing Manager  
Nebraska Public Power District  
P.O. Box 98  
Brownville, NE 68321

Mr. Michael J. Linder, Director  
Nebraska Department of Environmental  
Quality  
P. O. Box 98922  
Lincoln, NE 68509-8922

Chairman  
Nemaha County Board of Commissioners  
Nemaha County Courthouse  
1824 N Street  
Auburn, NE 68305

Ms. Julia Schmitt, Manager  
Radiation Control Program  
Nebraska Health & Human Services R & L  
Public Health Assurance  
301 Centennial Mall, South  
P.O. Box 95007  
Lincoln, NE 68509-5007

Mr. H. Floyd Gilzow  
Deputy Director for Policy  
Missouri Department of Natural Resources  
P. O. Box 176  
Jefferson City, MO 65102-0176

Senior Resident Inspector  
U.S. Nuclear Regulatory Commission  
P. O. Box 218  
Brownville, NE 68321

Regional Administrator, Region IV  
U.S. Nuclear Regulatory Commission  
611 Ryan Plaza Drive, Suite 400  
Arlington, TX 76011

Director, Missouri State Emergency  
Management Agency  
P. O. Box 116  
Jefferson City, MO 65102-0116

Chief, Radiation and Asbestos  
Control Section  
Kansas Department of Health  
and Environment  
Bureau of Air and Radiation  
1000 SW Jackson  
Suite 310  
Topeka, KS 66612-1366

Mr. Daniel K. McGhee  
Bureau of Radiological Health  
Iowa Department of Public Health  
Lucas State Office Building, 5th Floor  
321 East 12th Street  
Des Moines, IA 50319

Mr. Keith G. Henke, Planner  
Division of Community and Public Health  
Office of Emergency Coordination  
930 Wildwood P.O. Box 570  
Jefferson City, MO 65102

Jerry C. Roberts, Director of Nuclear  
Safety Assurance  
Nebraska Public Power District  
P.O. Box 98  
Brownville, NE 68321

Mr. John F. McCann, Director  
Licensing, Entergy Nuclear Northeast  
Entergy Nuclear Operations, Inc.  
440 Hamilton Avenue  
White Plains, NY 10601-1813

February 2006