



# UNIVERSITY OF FLORIDA

**Nuclear Facilities**  
Department of Nuclear and Radiological Engineering

202 Nuclear Sciences Center  
P.O. Box 118300  
Gainesville, Florida 32611-8300  
Tel: (352) 392-1408  
Fax: (352) 392-3380  
Email: vernet@ufl.edu

April 11, 2006

Attn: Document Control Desk  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

**Potential Tech Spec Violation –  
Operation Outside Allowed Interval  
for Operability Tests of Certain  
Limiting Safety System Settings**

University of Florida Training Reactor  
Facility License R-56, Docket No. 50-83

As per my telephone conversation on April 11, 2006 with NRC Project Manager Marvin Mendonca concerning UFTR operation outside the allowed quarterly interval for the operability tests of certain Limiting Safety System Settings (LSSS's), we have concluded that this operation with the LSSS's not checked for operability within the requisite quarterly interval as specified in Tech Spec Table 3.2 is a potentially promptly reportable occurrence per UFTR Technical Specifications Section 6.6.2 delineating requirements for special reports. The applicable section of the Tech Specs is Table 3.2 in Section 3.2.2 which lists the LSSS's required to be tested for operability on a quarterly basis.

Sincerely,

William G. Vernetson  
Director of Nuclear Facilities

WGV/dms

cc: A. Adams, NRC Project Manager  
C. Bassett, NRC Inspector  
Reactor Safety Review Subcommittee

Sworn and subscribed this 11<sup>th</sup> day of April 2006.

Notary Public



**Terri L. Sparks**  
Commission # DD346498  
Expires August 12, 2008  
Bonded Troy Fain - Insurance, Inc. 800-385-7019

A020