

Jack,

I have one follow-up question from Don Naujock, as follows:

The Appendix VIII, Supplement 11 qualification of the procedures and personnel did not cover examinations of cast stainless steel (CSST) piping/components. The dissimilar weld configuration has a CSST safe-end/pipe component. For the UT technique that will be used on the CSST piping, discuss the qualification process that will be used to satisfy Supplement 11 performance demonstration for detection of flaws, i.e. blind performance demonstration, representative flaws, representative mock-ups, and pass/fail screening criteria.

Please let me know if you need to have a "clarification call" with Don.

Thanks

Kaly

Mail Envelope Properties (4416EE9D.A3C : 14 : 744)

**Subject:** SONGS Pressurizer Welds  
**Creation Date:** 3/14/06 11:26AM  
**From:** N. Kaly Kalyanam

**Created By:** NXK@nrc.gov

**Recipients**

songs.sce.com  
rainsbjl (Jack Rainsberry)

**Post Office**  
songs.sce.com

**Route**  
internet

<b>Files</b>	<b>Size</b>	<b>Date &amp; Time</b>
MESSAGE	1476	03/14/06 11:26AM

**Options**

**Expiration Date:** None  
**Priority:** Standard  
**Reply Requested:** No  
**Return Notification:** None

**Concealed Subject:** No  
**Security:** Standard