



State of New Jersey
DEPARTMENT OF ENVIRONMENTAL PROTECTION

JON S. CORZINE
Governor

LISA P. JACKSON
Commissioner

Division of Environmental Safety and Health
Radiation Protection and Release Prevention Element
Bureau of Nuclear Engineering
PO Box 415
Trenton, New Jersey 08625-0415
Phone: (609) 984-7700
Fax: (609) 984-7513

April 3, 2006

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555-0001

Ladies and Gentlemen:

Subject: Hope Creek Generating Station
Docket No. 50-354
License Change Request H05-07

PSEG Nuclear LLC (PSEG) submitted the subject change request to the Nuclear Regulatory Commission (NRC) on October 11, 2005. The proposed change would revise the Technical Specifications to remove the requirement for the Standby Liquid Control System to be operable during Operational Condition 5* (*Refueling, with any control rod withdrawn) and would also remove corresponding isolation instrumentation requirements.

The New Jersey Department of Environmental Protection's Bureau of Nuclear Engineering reviewed the request in accordance with the requirements of 10 CFR 50.91(b). We have no comments.

If you have any questions, please contact Jerry Humphreys at (609) 984-7469.

Sincerely,

Kent Tosch
Manager

Distribution:

D. Zannoni
N.J. DEP

R. Bores, Ph. D.
NRC Region I State Liaison Officer

S. Bailey
NRC Project Manager

D. Benyak
PSEG
