

May 11, 2006

Mr. Ronnie L. Gardner, Manager
PWR Owners Group
AREVA NP
3315 Old Forest Road
Lynchburg, VA 24501

SUBJECT: DRAFT SAFETY EVALUATION FOR BAW-2441, REVISION 2, "RISK
INFORMED JUSTIFICATION FOR LCO END-STATE CHANGES"
(TAC NO. MC6241)

Dear Mr. Gardner:

By letter dated January 19, 2004, the Babcock and Wilcox Owners Group (B&WOG), now known as Pressurized Water Reactor (PWR) Owners Group, submitted Topical Report (TR) BAW-2441, Revision 2, "Risk Informed Justification for LCO End-State Changes," to the U.S. Nuclear Regulatory Commission (NRC) staff for review and approval. By e-mail dated June 29, 2004, the NRC provided a request for additional information (RAI) to the B&WOG. By letter dated August 3, 2004, the B&WOG explained that, due to other priorities, the RAI would not be responded to until March 31, 2005. Because of this delay, by letter dated August 18, 2004, the NRC notified the B&WOG that its review efforts on this TR were suspended until the RAI responses were submitted. Subsequently, the B&WOG submitted its RAI response on February 17, 2005, and the NRC staff resumed its review of BAW-2441, Revision 2.

The NRC staff has completed its review of BAW-2441, Revision 2, and enclosed for PWR Owners Group's review and comment is a copy of the NRC staff's draft Safety Evaluation (SE). Twenty working days are provided to you to comment on any factual errors or clarity concerns contained in the SE. The final SE will be issued after making any necessary changes and will be made publicly available. The NRC staff's disposition of your comments on the draft SE will be discussed in the final SE.

R. Gardner

- 2 -

To facilitate the NRC staff's review of your comments, please provide a marked-up copy of the draft SE showing proposed changes and provide a summary table of the proposed changes.

If you have any questions, please contact Girija Shukla at (301) 415-8439.

Sincerely,

/RA/

Juan D. Peralta, Acting Chief
Special Projects Branch
Division of Policy and Rulemaking
Office of Nuclear Reactor Regulation

Project No. 693

Enclosure: Draft SE

cc w/encl: See next page

R. Gardner

- 2 -

To facilitate the NRC staff's review of your comments, please provide a marked-up copy of the draft SE showing proposed changes and provide a summary table of the proposed changes.

If you have any questions, please contact Girija Shukla at (301) 415-8439.

Sincerely,

/RA/

Juan D. Peralta, Acting Chief
Special Projects Branch
Division of Policy and Rulemaking
Office of Nuclear Reactor Regulation

Project No. 693

Enclosure: Draft SE

cc w/encl: See next page

DISTRIBUTION:

PUBLIC

PSPB Reading

RidsNrrAdra

RidsNrrDpr

RidsNrrDprPspb

RidsNrrPMGShukla

RidsNrrLADBaxley

RidsOgcMailCenter

RidsAcrcAcnwMailCenter

RidsOpaMail

YHsii

NSaltos

ADAMS Accession No.: **ML061160291**

*SE input

NRR-106

| | | | | | | |
|--------|---------|---------|----------|--------------|------------|---------|
| OFFICE | PSPB/PM | PSPB/LA | SPWB/BC* | APLB/BC * | PSPB/BC(A) | ITSB/BC |
| NAME | GShukla | DBaxley | JNakoski | LMrowca | JPeralta | TKobetz |
| DATE | 5/8/06 | 5/8/06 | 7/26/05 | 3/23/06 | 5/15/06 | 5/11/06 |

OFFICIAL RECORD COPY

B&W Owners Group

Project No. 693

cc:

Mr. Howard C. Crawford
AmerGen Energy Company
Route 441 South
P.O. Box 480
Middletown, PA 17057-0480

Mr. David J. Firth
Manager, B&W Owners Group Services
Framatome ANP
3315 Old Forest Road
Lynchburg, VA 24501

Mr. W. R. McCollum, Chairman
B&WOG Executive Committee
Duke Energy Corporation
Oconee Nuclear Station
MC ONO 1VP
7800 Rochester Highway
Seneca, SC 29672

12/21/05

DRAFT SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

BAW-2441, REVISION 2, "RISK INFORMED JUSTIFICATION FOR LCO

END-STATE CHANGES"

PWR OWNERS GROUP (FORMERLY B&W OWNERS GROUP)

PROJECT NO. 693

1 1.0 INTRODUCTION AND BACKGROUND

2
3 By letter dated January 19, 2004, B&W Owners Group (B&WOG), now known as the
4 Pressurized Water Reactor (PWR) Owners Group, submitted topical report BAW-2441,
5 Revision 2, "Risk Informed Justification For LCO End-State Changes," (Ref. 1) for review by the
6 NRC staff. The B&WOG supplemented the topical report by letter dated February 17, 2005
7 (Ref. 2), in response to the NRC staff request for additional information.
8

9 The purpose of BAW-2441 is to make changes to the end states of selected limiting conditions
10 for operation (LCOs) from Mode 5, cold shutdown, to Mode 4, hot shutdown, to (1) reduce risk
11 associated with unnecessary shutdown cooling (SDC) operations, and (2) reduce plant
12 unavailability associated with reduced plant downtime caused by unnecessary cooldown to
13 Mode 5 and subsequent reheat to Mode 3 or 4. With a condition not meeting an LCO, and the
14 associated required action not met within the specified completion time (CT) from a Mode 1
15 condition, the B&WOG Standard Technical Specifications (STs) generally require actions that
16 result in Mode 3 entry in 6 hours and in a Mode 5 entry within 36 hours. BAW-2441 generally
17 retains the B&WOG STS time philosophy in establishing the required mode entry times except
18 that the end state of Mode 5 within 36 hours is replaced with Mode 4 within 12 hours.
19

20 BAW-2441 is similar to the report that the NRC staff approved for Combustion Engineering
21 Owners Group (CEOG) PWRs (CE-NPSD-1186, Revision 00, "Technical Justification for the
22 Risk-Informed Modification to Selected Required Action End States for CEOG Member PWRs,"
23 July 17, 2001) and the report that the NRC staff approved for boiling water reactors (BWRs)
24 (NEDC-32988, Revision 2, "Technical Justification to Support Risk-Informed Modification to
25 Selected Required Action End States for BWR Plants," January 5, 2001).
26

27 To justify the proposed end-state change, the topical report provides a qualitative assessment
28 and a quantitative analysis to confirm that Mode 4 is the preferred end state from a risk and
29 operational perspective. The qualitative assessment describes the risk associated with
30 operation in Mode 4 compared to operation in Mode 5, and is intended to justify that the end
31 state of Mode 4, versus Mode 5, for the proposed LCO conditions invoked is acceptable. The
32 qualitative assessment also concludes that the increment of risk associated with unnecessary
33 SDC can be removed from the overall plant risk as a result of making the proposed LCO
34 end-state changes.
35

1 BAW-2441 compared the core damage frequencies during the two modes of operation using
2 the probabilistic safety assessment (PSA) for a typical B&W-designed plant, assuming the
3 inoperable conditions specified in STSs. Important insights were also obtained from the
4 assessment of the applicability of the representative B&W plant results to other B&WOG plants,
5 through sensitivity studies accounting for design and operational differences and/or direct
6 comparison of features using risk insights for the representative B&W plant. In addition to
7 quantitative analysis, BAW-2441 evaluated the two modes of operation based on
8 defense-in-depth considerations and then proposed a list of end-state changes.
9

10 BAW-2441 request would allow a Mode 4 end-state, rather than a Mode 5 end-state, for the
11 selected LCOs listed in Table 1.
12

13 Table 1 LCOs Proposed for End-State Change
14

| LCO | CURRENT END-STATE | PROPOSED END-STATE |
|---|----------------------|-----------------------|
| 3.3.5 Engineered Safety Features Actuation System (ESFAS) Instruments | 5 | 4 |
| 3.3.6 ESFAS Manual Initiation | 5 | 4 |
| 3.4.6 Reactor Coolant System (RCS) Loops Mode 4 | 5 | 4 |
| 3.4.15 RCS Leak Detection Instrumentation | 5 | 4 |
| 3.5.4 Borated Water Storage Tank Boron Concentration | 5 | 4 |
| 3.6.1 Containment | 5 | 4 |
| 3.6.2 Containment Air Locks | 5 | 4 |
| 3.6.3 Containment Isolation Valves | 5 | 4 |
| 3.6.4 Containment Pressure | 5 | 4 |
| 3.6.5 Containment Air Temperature | 5 | 4 |
| 3.6.6 Containment Spray and Cooling | 5 | 4 |
| 3.7.7 Component Cooling Water (CCW) System | 5 | 4 |
| 3.7.8 Service Water System (SWS) | 5 | 4 |
| 3.7.9 Ultimate Heat Sink | 5 | 4 |
| 3.7.10 Control Room Emergency Ventilation System | 5 | 4 |
| 3.7.11 Control Room Emergency Air Temperature System | 5 | 4 |
| 3.8.1 Alternating Current (AC) Sources - Operating | 5 | 4 |

| | | | |
|-------|---|---|---|
| 3.8.4 | Direct Current (DC) Sources - Operating | 5 | 4 |
| 3.8.7 | Inverters - Operating | 5 | 4 |
| 3.8.9 | Distribution System - Operating | 5 | 4 |

2.0 REGULATORY EVALUATION

LCOs are the lowest functional capability or performance levels of equipment required for safe operation of a facility. The regulation at 50.36(c)(2), "Limiting conditions for operation," of Title 10 of the *Code of Federal Regulations* (10 CFR) specifies that "When a limiting condition for operation of a nuclear reactor is not met, the licensee shall shut down the reactor or follow any remedial action permitted by the technical specifications until the condition can be met." The regulation does not specify the shutdown conditions a plant must enter. For each LCO that is not met, the plant Technical Specification (TS) Required Action provides a CT for remedial actions to meet the LCO. If the LCO or remedial action cannot be met, then the reactor is required to be shutdown within a specified time. When the individual plant TSs were written, the shutdown conditions or end states specified were usually Mode 5, cold shutdown. This was based on the perception that putting a plant in Mode 5, cold shutdown, would result in the safest condition. However, preliminary risk and operational considerations have indicated that end-state modifications could be beneficial. For example, establishing Mode 4, hot shutdown, instead of Mode 5 as the end-state for several TS action statements could reduce operational costs without compromising safety and may enhance safety.

The proposed amendment to change the end state from Mode 5 to Mode 4 for failure to meet selected LCOs is based on risk-informed analysis with consideration of risk associated with the transition from Mode 4 to Mode 5. The risk analysis results demonstrated that Mode 4 end state is a preferred end state over Mode 5. Designation of Mode 4, hot shutdown, end state continues to comply with 10 CFR 50.36(c)(2)

3.0 EVALUATION OF ENGINEERING ASSESSMENTS

Section 4.4 of BAW-2441 provides the bases for each of the proposed LCO end-state changes. The bases are in general based on the argument discussed below.

Section 4.0 of BAW-2441 provides a qualitative engineering assessment to justify the proposed end state of Mode 4, hot shutdown, compared to current Mode 5, cold shutdown. The Mode 5 end state was generally based on the idea that the lower the RCS pressure, the lower the risk associated with operating with a given LCO in effect. However, various events occurring during shutdown operations have resulted in the NRC and industry assessing the risk associated with various modes of operation.

Section 4.2 of BAW-2441 provides a qualitative assessment of a general risk comparison between Modes 3, 4, and 5, and concludes there are some risk advantages associated with operations in Modes 3 and 4 compared to Mode 5 (and a portion of Mode 4 with SDC) operations. The characteristics that differentiate the plant operations between Mode 4 and Mode 5 is the core cooling mechanism. In Mode 4 heat removal continues through the steam generator (SG) until transition into the SDC systems at lower RCS temperature and pressure,

1 whereas in Mode 5, SDC systems are used. The transition process required to go from Mode 4
2 to Mode 5 presents increased risk due to SDC system vulnerabilities and fewer mitigating
3 systems being immediately available. In Mode 5, there is less equipment available because
4 plant realignments lead to general unavailability of the emergency feedwater (EFW) and high
5 pressure injection (HPI) systems. The transition from Mode 4 to Mode 5 also exposes the plant
6 to several potential failure modes, including inadvertent closure of SDC system valves,
7 inadvertent diversion of reactor coolant through the SDC system, and loss of reactor coolant
8 through the SDC relief valves or other leak paths. With the SDC system being aligned to the
9 RCS to cool the core, core cooling can be terminated with the inadvertent closure of a single
10 valve in the SDC system suction line. There is also a possibility of inadvertent RCS draining
11 caused by inappropriate valve alignments and/or maintenance activities while on SDC.
12 Therefore, remaining in Mode 4 has the advantage of increased redundancy and diversity of
13 mitigating systems, as well as the avoidance of human error during SDC initiation and
14 operation, loss of SDC system, and inadvertent RCS draining.
15

16 3.1 ESFAS Instrumentation 17

18 The ESFAS provides an automatic actuation of the engineered features that are required for
19 mitigation of design-basis accidents (DBAs), especially the loss-of-coolant accident (LOCA) and
20 steam line break events. The ESFAS actuates the following systems: HPI, low-pressure
21 injection (LPI), reactor building (RB) cooling, RB spray, RB isolation, and onsite standby power
22 source start. The ESFAS also provides a signal to EFW initiation and control (EFIC) system
23 and initiates EFW, when HPI is initiated.
24

25 The ESFAS consists of two trains. Each train consists of three protection channels. Each
26 channel provides input to logic circuits that initiate equipment with a two-out-of-three logic on
27 each component. Four parameters are used by the ESFAS for actuation: Low RCS pressure,
28 Low Low RCS pressure, High RB pressure, and High High RB pressure.
29

30 TS LCO 3.3.5 specifies that three channels of ESFAS instrumentation for each parameter in TS
31 Table 3.3.5-1 (i.e., Low RCS pressure, Low Low RCS pressure, High RB pressure, and High
32 High RB pressure setpoints) shall be OPERABLE in each ESFAS train. For Condition B with
33 two or more channels of one or more actuation parameters inoperable, or one channel
34 inoperable and required action and associated CT time not met, Required Action B requires an
35 initial cooldown to Mode 3 within 6 hours. If the inoperable channels are that of the High RB
36 Pressure setpoint or High High RB Pressure setpoints, Required Action B.2.3 further requires
37 the plant to be in the end state of Mode 5 within 36 hours. The proposed change would change
38 the Required Action B.2.3 end state to be in Mode 4 within 12 hours.
39

40 BAW-2441 provides a qualitative assessment for changing the end state from Mode 5 to
41 Mode 4. When operating in Mode 4, the reactor is in a shutdown and subcritical condition, and
42 there is no power generation except for decay heat. The RCS thermal-hydraulic conditions are
43 very different from those associated with a DBA occurring at power. In Mode 4 the RCS
44 temperature is less than 350 °F, the RCS pressure is reduced, and the likelihood of an initiating
45 event occurring is greatly reduced. Also, loss of core cooling and loss of inventory events are
46 characterized by lower initial fuel temperatures and a lower decay heat generation rate because
47 of the time elapsed since power operation. Therefore, the transient will proceed more slowly
48 and with reduced challenges to the reactor and containment systems than those associated

1 with at-power conditions. These characteristics enhance both a reduced likelihood of events
2 and the ability to respond to events should they occur.
3

4 When operating in Mode 4 there are more mitigation systems (e.g., HPI and EFW) available to
5 respond to initiating events that could challenge RCS inventory or decay heat removal than
6 when operating in Mode 5. In addition, all redundant functions initiated by the ESFAS can be
7 manually initiated to mitigate transients that will proceed more slowly and with reduced
8 challenges to the reactor and containment systems than those associated with at-power
9 conditions.

10
11 Figure 2 of BAW-2441 also shows that the risk is lower operating in Mode 4 with the SG in
12 operation than Mode 5 with SDC operation. Therefore, the NRC staff concludes that the
13 proposed end state of Mode 4 for Required Action B.2.3 is acceptable.
14

15 3.2 ESFAS Manual Initiation 16

17 TS LCO 3.3.6 specifies that two manual initiation channels of each one of the ESFAS functions
18 (HPI, LPI, RB cooling, RB spray, RB isolation, and control room isolation) shall be OPERABLE
19 during MODES 1, 2, and 3, and 4 when associated engineered safeguard equipment is
20 required to be OPERABLE. If one or more ESFAS functions with one channel inoperable and
21 the required action (i.e., restoration to OPERABLE status) and associated CT are not met
22 (Condition B), Required Action B requires the plant to be place in Mode 3 within 6 hours and in
23 Mode 5 within 36 hours. The proposed change would change the end state from Mode 5 in
24 36 hours to Mode 4 within 12 hours.
25

26 The ESFAS manual initiation capability allows for the operator to actuate ESFAS functions from
27 the main control room (MCR) in the absence of any other initiation condition. This manual
28 initiation capability is provided as a backup to automatic trip function, in the event that the
29 operator determines that an ESFAS function is needed and has not been automatically
30 actuated. Furthermore, this capability allows operators to rapidly initiate ESFAS functions if the
31 trend of unit parameters indicates that ESFAS actuation will be needed.
32

33 The ESFAS manual initiation function relies on the operability of the automatic actuation logic
34 for each component to perform the actuation of the systems. The ESFAS manual initiation
35 channel is defined as the instrumentation between the console switch and the automatic
36 actuation logic that actuates the end device. Other means of manual initiation, such as controls
37 for individual ESFAS devices, may be available in the control room and other unit locations.
38 These alternative means are not required by, nor credited to fulfill the requirements of this LCO.
39

40 In Mode 4, the RCS temperature is less than 350 °F at low RCS pressure, the loss of cooling
41 and loss of inventory events are characterized by lower initial fuel temperatures and a lower
42 decay heat generation rate because of the time elapsed since power operation. There are also
43 more mitigation systems (e.g., HPI and EFW) available to respond to initiating events that could
44 challenge RCS inventory or decay heat removal than when operating in Mode 5. In addition, all
45 redundant functions initiated by the ESFAS can be manually initiated via individual component
46 controls. Therefore, should an initiating event occur, the transient will proceed slowly, which
47 provides the plant operator with adequate time to respond to the challenges to the reactor and

1 containment systems. Also, when operating in Mode 4 with the SG in operation and the SDC
2 system not in operation, the risk associated with SDC is avoided.

3
4 In addition, as a backup to the automatic actuation of the ESFAS, the manual initiation channels
5 of an ESFAS function are used only in the event of the failure of the ESFAS instrumentation. In
6 any event, there are also the manual initiation of individual ESFAS devices to provide backup to
7 the manual initiation channels. Based on this multiple redundancy in the ESFAS initiation, the
8 adequate response time should an initiation event occur in Mode 4, and the avoidance of risk
9 associated with SDC operation, the NRC staff concludes that the proposed change of end state
10 to Mode 4 is acceptable.

11 3.3 RCS Loops - MODE 4

12 LCO 3.4.6 specifies that two loops consisting of any combination of RCS loops and decay heat
13 removal (DHR) loops shall be operable and one loop shall be in operation during Mode 4.

14 With one required loop inoperable (Condition A), Required Action A.1 requires restoration of a
15 second loop to an operable status immediately. If the remaining operable loop is a DHR loop,
16 Required Action A.2 requires the plant to be in Mode 5 within 24 hours. The proposed change
17 would delete Required Action A.2 so as to allow continued operations in Mode 4.

18 In Mode 4, the primary function of the reactor coolant is the removal of decay heat and the
19 transfer of this heat to the SGs or DHR heat exchangers. The secondary function of the reactor
20 coolant is to act as a carrier for soluble neutron poison, boric acid.

21
22 The purpose of this LCO is to require that two loops, either RCS or DHR, be operable in
23 Mode 4 and one of these loops be in operation. Any one loop in operation provides enough
24 flow to remove decay heat from the core with forced circulation. The second loop that is
25 required to be operable provides a redundant path for heat removal. With one required
26 operable loop inoperable, redundancy for heat removal is lost. Required Action A.1 specifies
27 that action be initiated immediately to restore the inoperable loop to an operable status.

28
29 In the case when the inoperable loop is the RCS, the DHR loop is operable and operating, with
30 sufficient capability for core decay heat removal. Should the operating DHR loop fail and the
31 inoperability of the RCS loop is due to inoperable reactor coolant pump (RCP), the SGs are still
32 available as a heat sink to provide for core heat removal through natural circulation, which, in
33 Mode 4 can be effective for heat removal with steaming. The availability of SGs for heat
34 removal is ensured by LCOs 3.7.4, 3.7.5, and 3.7.6, that, respectively, require that the
35 atmospheric vent valves, EFW system, and the condensate storage tank, be operable while in
36 Modes 1, 2, and 3, and in Mode 4 when SGs are relied upon for heat removal.

37
38 The failure of the only operable and operating DHR loop in Condition A would result in
39 Condition B with inoperability of two required operable loops or no required loop in operation.
40 Required Action B allows the plant to remain in MODE 4 and relies on natural circulation for
41 decay heat removal, while only requiring (B.1) suspension of operations that would cause
42 introduction of water into the RCS coolant with boron concentration less than that required to
43 meet the shutdown margin (SDM) requirement of LCO 3.1.1, and (B.2) initiation of action to
44 restore one loop to operable status and be operating, immediately. Therefore, the proposed
45
46
47
48

1 change to allow the plant to remain in Mode 4 with one DHR loop operable and operating is
2 justified by the required action for Condition B. If the plant is placed in Mode 5 (with 24 hours
3 as required by Action A.2), and the operating DHR loop fail, use of natural circulation would not
4 be effective. The RCS must be heated up to the temperature region of Mode 4 where steaming
5 can be effective for heat removal. Also, in Mode 5, the RCP would not be operating even if
6 restored to operable status because of net positive suction head (NPSH) considerations.
7 Figure 2 of BAW-2441 also shows that the risk is lower operating in Mode 4 with the SG in
8 operation than Mode 5 with SDC operation. Therefore, the NRC staff agrees with the proposed
9 amendment to delete Required Action A.2 so that the plant would be allowed to remain in
10 Mode 4.

11 3.4 Borated Water Storage Tank (BWST)

12 LCO 3.5.4 specifies that the BWST shall be operable, including maintaining boron
13 concentration, water temperature, and water volume within limits, during Modes 1, 2, 3, and 4
14 operation. With the BWST boron concentration, water temperature, and water volume not
15 within limits, and failure to restore the BWST to comply with the limits within the specified CTs,
16 the required action requires that the plant be in Mode 3 within 6 hours and in Mode 5 within
17 36 hours. The proposed change would rearrange the existing Actions Statements by
18 separating the conditions and required actions for exceeding the boron concentration and the
19 temperature limits, and change the end state for failure to restore the boron concentration to
20 within the limit within 8 hours from being in Mode 5 in 36 hours to being in Mode 4 within
21 12 hours. No change is made regarding the end state for failure to comply with the water
22 temperature and volume limits.
23

24 The BWST provides a source of borated water to HPI, LPI, and RB spray pumps during
25 accident conditions. The LCO specifies the limits on the BWST boron concentration, water
26 volume, and water temperature to ensure that the BWST contains sufficient borated water to
27 support the emergency core cooling system (ECCS) for core cooling and to maintain SDM.
28 There are two limits for boron concentration in the BWST. The minimum and maximum BWST
29 boron concentration limits, respectively, are established to (1) ensure the reactor will be
30 maintained in a cold shutdown condition following a postulated large break LOCA (LBLOCA)
31 while in Mode 1 that assumes that all rods remain withdrawn from the core following initiation of
32 the event; and (2) avoid the potential boron precipitation in the core resulting from reactor
33 coolant boil off during the long-term cooling period following a LOCA that could result in flow
34 channel blockage.
35

36 Upon entering into Mode 3, the core is subcritical with all rods inserted and the reactor is
37 maintained shutdown by operating procedures and other administrative controls. Hence, in the
38 highly unlikely event of a LBLOCA occurring while in Mode 4, all control rods will be inserted.
39 This provides for the reactor SDM to be very conservative (the applicant indicated excess of
40 approximately -9.0 percent $\Delta k/k$). If the boron concentration in the BWST is below the
41 minimum boron concentration limit, the excessive SDM provided by the control rods being
42 inserted provides margin to compensate for injected ECCS water should a LOCA occur in
43 Mode 4. Also, deviations in boron concentration are likely to be relatively slow and small, and
44 the boric acid addition systems would normally be available.
45
46
47

1 If the BWST boron concentration exceeds the maximum concentration limit, the concern would
2 be boron precipitation during long-term cooling following a LOCA. However, due to low power
3 levels associated with Mode 4, there will be ample time to establish boron dilution flow paths
4 should the need arise. Post LOCA emergency procedures direct the operator to establish
5 dilution flow paths in the LPI system to prevent this condition by establishing a forced flow path
6 through the core regardless of break location. By utilizing these procedures following a LOCA,
7 potential boric acid precipitation from the core could be avoided.

8
9 Since the need for a large volume of water from the BWST in Mode 4 is due to low likelihood of
10 LOCA events, the anticipated deviations in the BWST boric acid concentrations are expected to
11 be small, and the ability to correct this deficiency is expected to be readily available, the
12 requested change to have Mode 4 end state would have an insignificant impact on safety, and
13 is therefore acceptable to the NRC staff.

14 15 4.0 EVALUATION OF RISK ASSESSMENTS

16
17 BAW-2441 documents a risk-informed analysis of the proposed TS change. Probabilistic risk
18 assessment (PRA) results and insights are used, in combination with the results of deterministic
19 assessments, to identify and propose changes in “end-states” for all B&W plants. This is in
20 accordance with guidance provided in Regulatory Guides (RGs) 1.174 and 1.177. The three-
21 tiered approach, documented in RG 1.177, “An Approach for Plant-Specific, Risk-Informed
22 Decisionmaking: Technical Specifications,” was followed. The first tier of the three-tiered
23 approach includes the assessment of the risk-impact of the proposed change for comparison to
24 acceptance guidelines consistent with the Commission’s Safety Goal Policy Statement, as
25 documented in RG 1.174, entitled “An Approach for Using Probabilistic Risk Assessment in
26 Risk-Informed Decisions on Plant-Specific Changes to the Licensing Basis.” In addition, the
27 first tier aims at ensuring that there are no unacceptable temporary risk increases during the
28 implementation of the proposed TS change, such as when equipment is taken out of service.
29 The second tier addresses the need to preclude potentially high risk configurations which could
30 result if equipment is taken out of service concurrently with the implementation of the proposed
31 TS change. The third tier addresses the application of 10 CFR 50.65(a)(4) of the Maintenance
32 Rule for identifying risk-significant configurations, resulting from maintenance or other
33 operational activities, and taking appropriate compensatory measures to avoid such
34 configurations. The scope of the topical report and the NRC staff evaluation was limited to
35 identifying changes in end-state conditions that excluded continued power operation as an
36 acceptable end-state, regardless of the risk.

37
38 The risk assessment approach followed by BAW-2441 includes the following tasks:

- 39 ● Performance of a generic qualitative risk assessment,
- 40 ● Performance of a quantitative risk assessment for a pilot plant that includes the following:
 - 41 - Comparison of baseline risks between Modes 4 and 5 (i.e., risks when no
 - 42 - Comparison of configuration-specific risks between Modes 4 and 5 (i.e., risks
 - 43 -
 - 44 - Comparison of baseline risks between Modes 4 and 5 (i.e., risks when no
 - 45 - equipment outages are assumed),
 - 46 -
 - 47 - Comparison of configuration-specific risks between Modes 4 and 5 (i.e., risks
 - 48 - when certain equipment is assumed to be unavailable),

- 1 - Performance of sensitivity studies to investigate the robustness of the results to
- 2 uncertainties in data and modeling assumptions, and
- 3
- 4 - Performance of sensitivity studies to ensure that the conclusions of the
- 5 quantitative assessment for the pilot plant apply also to other B&W plants.
- 6
- 7 ● Use of risk insights, derived from the qualitative and quantitative generic risk assessments,
- 8 in the individual TS assessments supporting each of the proposed end-state changes.
- 9

10 The objective of the generic qualitative risk assessment is to show that the proposed TS
11 end-state changes result in an increase in defense-in-depth for expected initiating events. This
12 is achieved by performing qualitative risk comparisons between cold shutdown (Mode 5) and
13 hot shutdown (Mode 4). Such comparisons include risk parameters, such as initiating events
14 and mitigating systems, associated with each critical safety function (e.g., reactivity control and
15 core decay heat removal) at the various B&W plants. The objectives of the quantitative risk
16 assessment are: (1) to substantiate the conclusion of the qualitative risk assessment by
17 providing numerical results for a representative plant, (2) to investigate the robustness of the
18 results regarding uncertainties in data and modeling assumptions through sensitivity analyses,
19 and (3) to assess the applicability of the results to other B&W plants through sensitivity
20 analyses accounting for design and operational differences. In addition, specific risk
21 assessments were also performed for several of the proposed TS end-state changes to ensure
22 that the specific condition causing the LCO does not increase the risk when the proposed new
23 end-state is implemented. Finally, an integrated discussion of the risk-significance and
24 defense-in-depth considerations is provided (using risk insights from both the qualitative and
25 quantitative risk assessments) for each proposed TS end-state change. This discussion
26 provides useful information that can be used by individual licensees applying for such TS
27 changes to develop guidance in appropriate plant procedures and/or administrative controls to
28 ensure that risk-significant plant configurations are avoided. The NRC staff's review finds that
29 the BAW-2441 risk assessment approach is comprehensive and follows staff guidance as
30 documented in RGs 1.174 and 1.177.

31 32 4.1 Evaluation of the Quality of the Risk Assessment

33
34 The risk impact of the proposed end-state changes was assessed subject to the following major
35 general assumptions:

- 36
- 37 ● The request is to allow Mode 4 (hot shutdown) as the end-state for all of the selected TS
- 38 action statements, instead of Mode 5 (cold shutdown). However, licensees will still have
- 39 the option to take the plant to Mode 5 (cold shutdown) to complete maintenance.
- 40
- 41 ● An important difference between Mode 4 and Mode 5 as end-states is the transition in the
- 42 mode of core cooling. In Mode 4, heat removal continues through the SGs, while Mode 5
- 43 requires the initiation of the SDC system, a transition that exposes the plant to several
- 44 potential failure modes.
- 45
- 46 ● Entry into the shutdown mode under consideration is for a short interval, with the primary
- 47 intent being to repair a nonfunctional component and return the plant to power as soon as
- 48 practical.

- 1
2 ● The RCS remains at its nominal inventory and the RCS boundary strength is not
3 compromised (e.g., via installation of nozzle dams).
4

5 The NRC staff finds that these assumptions adequately represent the proposed changes and
6 can be used in PRA models to compare risks between Mode 4 and Mode 5 associated with the
7 “short” duration repairs (i.e., repairs needed to correct the initiating condition and return to
8 power as soon as is practical). This comparison can be made by considering only steady state
9 risks because transition risks, as discussed later in this SE, are about equal for the two
10 end-states, or favor Mode 4 as the end-state.

11
12 The quality of the risk assessment is a very important part of any risk-informed license
13 amendment review. In this case, both the qualitative and quantitative risk assessments must
14 be of adequate quality and completeness to support their intended purposes. Regarding the
15 qualitative risk assessment, the comparisons between current and proposed end-states for the
16 various B&WOG plants must be of adequate quality and completeness to ensure confidence in
17 the robustness of the conclusion that the proposed TS end-state changes result in an increase
18 in defense-in-depth for expected initiating events, and that all expected initiating events were
19 addressed in the analysis. Regarding the quantitative risk assessment, the various models
20 (including assumptions and data) and sensitivity studies must be of adequate quality and
21 completeness (e.g., with respect to initiating events and failure modes of the various safety
22 systems) to provide confidence in the robustness of the conclusion that the risk will not increase
23 if the proposed new TS end-states are approved and implemented. The NRC staff’s evaluation
24 of the qualitative and quantitative risk assessments are documented in Sections 4.2 and 4.3,
25 respectively, of this SE.
26

27 4.2 Qualitative Risk Assessment

28
29 The qualitative risk assessment is a comparison between operation in Modes 4 and 5 at the
30 various B&WOG plants. This comparison, which assesses qualitatively the means that exist at
31 each B&WOG plant to maintain critical safety functions for expected initiating events, contains
32 the following three parts:
33

- 34 ● Assessment of critical safety functions at shutdown,
35
36 ● Generic comparison of risks at shutdown, and
37
38 ● Comparison of safety and operational features at shutdown among B&WOG plants.
39

40 Several critical safety functions at shutdown (reactivity control, RCS inventory control, core
41 decay heat removal, containment integrity control, and power availability) were identified based
42 on insights from previous risk studies. The means utilized at the B&WOG plants to perform
43 each of the critical functions during Mode 4 (hot shutdown) and Mode 5 (cold shutdown) are
44 discussed and used in the generic (i.e., without reference to a specific plant) comparison of
45 risks.
46

47 In the generic comparison of risks at shutdown, Mode 4 and Mode 5 risks are qualitatively
48 compared to each other by discussing the likelihood of the various initiating events and the

1 availability of mitigating systems at each plant operating condition. This generic comparison of
2 risks is complemented by a comparison of safety and operational features among B&WOG
3 plants. Such a comparison is needed in order to ensure that the conclusions of the generic
4 qualitative risk assessment are valid for each specific B&WOG plant.
5

6 The NRC staff finds that the qualitative risk assessment is of adequate quality and
7 completeness to support a conclusion that the proposed TS end-state changes do not decrease
8 defense-in-depth based on examination of the following:
9

- 10 ● Challenges and mitigating capabilities of B&WOG plants and comparison between current
11 and proposed end-states;
- 12
- 13 ● Documentation of the various design and operational features used to mitigate shutdown
14 accidents at B&WOG plants; and
- 15
- 16 ● Proper use of results and insights from previous deterministic and probabilistic studies.
17

18 4.3 Quantitative Risk Assessment 19

20 A quantitative risk assessment of current and proposed end-states (corresponding to shutdown
21 Modes 5 and 4, respectively) was performed for a B&WOG plant (Davis-Besse). The scope
22 was to provide a comparison of the risks associated with either staying in Mode 4, or going to
23 Mode 5 to carry out equipment repair. Variability in safety and operational features among
24 B&WOG plants was addressed by a series of direct comparisons of features as well as by
25 sensitivity studies to ensure that the conclusions of the quantitative assessment for
26 Davis-Besse apply to all B&WOG plants.
27

28 The NRC staff reviewed the quality of the quantitative risk assessment to ensure that:
29

- 30 ● Initiating events, accidents sequences, and failures found to be significant contributors to
31 shutdown risk in previous studies have been addressed;
- 32
- 33 ● Important assumptions made and data used are reasonable;
- 34
- 35 ● Important uncertainties in data and modeling assumptions were identified, and appropriate
36 sensitivity studies were performed in order to provide confidence in the conclusions
37 regarding the proposed TS end-states; and
- 38
- 39 ● Design and operational differences among the various B&WOG plants were identified and
40 appropriate sensitivity studies were performed, which show that the conclusions of the
41 quantitative risk assessment apply to all B&WOG plants.
42

43 The quantitative risk analysis was performed using PRA models of Mode 4 (on both SG and
44 SDC) and Mode 5 for internal initiating events of the representative plant (Davis-Besse). The
45 Davis-Besse non-power PRA models evolved from generic shutdown and transition templates,
46 which were developed in a cooperative effort by the B&WOG (BAW-2393, "Generic Template
47 for Shutdown Risk Assessment," Framatome ANP, November 2001 and BAW-2415, "Generic
48 Method to Assess Transition Risk," Framatome ANP, December 2001) to provide "top logic"

1 that is consistent across all B&WOG plants. These generic templates were subsequently
2 adapted by each B&WOG plant for plant-specific operational and design differences, and are
3 used for outage risk management. The Davis-Besse models are representative for the
4 B&WOG plants because of their generic origin. Furthermore, the use of the Davis-Besse risk
5 estimates to compare Mode 4 to Mode 5 risks is conservative.

6 This conservatism stems primarily from the following plant-specific differences between Davis-
7 Besse and other B&WOG plants:

- 8
- 9 ● Davis-Besse has two safety-related turbine-driven emergency feedwater (TDEFW) pumps,
10 and no safety-related motor-driven emergency feedwater (MDEFW) pumps. All other
11 B&WOG plants have at least one MDEFW pump. The availability of an MDEFW pump
12 results in a better reliability of the EFW system at very low pressures, as may be the case
13 during plant operation in Mode 4 with SG cooling.
- 14
- 15 ● At Davis-Besse, the DHR suction line valves must be opened during plant operation in
16 Mode 4, even when cooling is provided by the SGs. The reason for this alignment is to
17 provide sufficient relief capacity for low-temperature overpressure protection (LTOP)
18 considerations, which rely on a DHR system relief valve located on the DHR suction line.
19 Therefore, the Davis-Besse PRA includes a higher frequency of SDC-related loss of
20 inventory events associated with Mode 4 on SG cooling than do other B&WOG plants.
- 21

22 In developing the Davis-Besse models for the various shutdown modes, several initiating events
23 applicable to the shutdown modes of interest were considered and appropriate accident
24 sequence models were developed. Such initiating events were selected from a broad list of
25 postulated initiating events by screening out those events that either do not apply at shutdown,
26 or are not risk-significant based on previous PRA insights. The success criteria for the various
27 safety functions were derived from the full power PRA, after accounting for the reduced decay
28 heat levels in the shutdown modes. The PRA models were quantified for Modes 3, 4, and 5
29 base cases (i.e., assuming no equipment outages), as well as for several other cases reflecting
30 the LCO conditions for which an end-state change is requested. The Mode 4 (on SG cooling)
31 and Mode 5 core damage frequency (CDF) results were used to identify important risk
32 contributors and to investigate the sensitivity of the risk assessment results to important
33 uncertainties in data and modeling assumptions.

34

35 The quantitative risk assessment does not include risks from external events (dominated by
36 internal fires, internal floods and seismic events), risks associated with transitions from one
37 mode of operation to another, or risks in terms of large early release frequency (LERF). The
38 following qualitative arguments are made to justify not assessing such risks:

- 39 ● Risks associated with external events are smaller when Mode 4 instead of Mode 5 is
40 selected as the end-state for the following reasons:
41
- 42 - Seismic events, which are equally likely in either mode, have a larger impact on
43 the plant's accident mitigation capability during Mode 5 than during Mode 4.
44 Although during both modes of operation there are an adequate number of
45 seismically-designed safety systems available to mitigate accidents (e.g., EFW,
46 DHR, ECCS, cooling water systems, and onsite standby power sources), there
47 are more systems available during Mode 4 on SG cooling than during Mode 5.
48

1 In addition, since a seismic event is very likely to result in an unrecoverable
2 loss of offsite power event, the plant's ability to prevent core damage is higher
3 in Mode 4 (on SG cooling) due to the availability of the TDEFW pumps.
4

5 - Internal fire and flood events are equally likely to occur during Mode 4 or Mode
6 5, during either mode the same fire or flood event would impact the same
7 equipment, most likely equipment located in the affected fire or flood zone.
8 Because there are more systems available for accident mitigation in Mode 4
9 than in Mode 5, the plant's ability to prevent core damage is at least as good in
10 Mode 4 as is in Mode 5.
11

- 12 ● The only transition risk that needs to be considered in the comparison of risks between the
13 proposed and the current end-states is the risk associated with the transition from SG
14 cooling to SDC, using the DHR system, which occurs in Mode 4. This risk is primarily due
15 to the likelihood of a drain-down event while the DHR valves are being aligned for SDC.
16 This transition risk is most likely avoided when Mode 4 on SG cooling, instead of Mode 4
17 on SDC or Mode 5, is selected as the end-state for short duration repairs. Therefore, there
18 is no need to assess such a risk because it supports the position that it is safer to stay in
19 Mode 4 rather than go to Mode 5. It should be noted that for Davis-Besse there is no
20 realignment risk associated with the transition from SG cooling to SDC because the DHR
21 suction line valves must be opened during plant operation in Mode 4 even when cooling is
22 provided by the SGs.
23
- 24 ● During power operation, LERF are the result of: (1) energetic containment failure due to a
25 high pressure core melt, (2) a containment bypass event, and (3) a core damage event
26 occurring in combination with a non-isolated containment. Compared to power operation,
27 Mode 4 or Mode 5 operation is associated with lower initial energy level, reduced fission
28 product inventory level, and reduced decay heat load. Due to the combined effect of these
29 factors, the likelihood of LERFs in Modes 4 and 5 is very low. These factors serve to
30 provide time for the operator to respond to serious plant upsets and, consequently, they
31 contribute to delaying the core melt progression and reducing radiation releases.
32 Therefore, any potential increase due to changing the end-state is negligible.
33

34 BAW-2441 identified several areas of uncertainty, in both data and modeling assumptions,
35 associated with the shutdown models that could have an impact on results and conclusions,
36 including the following:
37

- 38 ● Accident initiating event frequencies used in the risk analysis;
- 39 ● Recovery probabilities used in the risk analysis; and
- 40 ● Common cause failure probabilities used in the risk analysis.
41
42

43 The identified areas of uncertainty were evaluated to determine how they impact the results and
44 conclusions of the quantitative risk assessment. Major risk insights from this evaluation, which
45 included, whenever necessary, the performance of sensitivity studies, are documented in
46 Sections 4.0 and 5.0 of this SE.
47
48

1 BAW-2441 identified several important design and operational differences between the various
2 B&WOG plants and the analyzed plant (Davis-Besse) used in the quantitative risk assessment.
3 The risk impact of such differences was investigated by a sensitivity study using a generic “non-
4 Davis-Besse” PRA model, which was developed by modifying the Davis-Besse PRA model to
5 account for the identified design and operational differences between Davis-Besse and other
6 B&WOG plants. The purpose of the investigation was to extend the results and conclusions of
7 the quantitative risk assessment performed for Davis-Besse to other B&WOG product lines
8 beyond the analyzed plant. Some major design and operational differences that were
9 investigated are:

- 10 ● Davis-Besse has separate makeup and HPI pumps, while the other B&WOG plants have
11 combined makeup and HPI pumps. These separate pumps at Davis-Besse provide an
12 extra measure of redundancy for “feed-and-bleed” not available at the other B&WOG
13 plants.
14
- 15 ● The SDC system is not aligned when the plant operates in Mode 4 on SG cooling, except
16 for Davis-Besse. At Davis-Besse the SDC system is aligned even when the plant operates
17 in Mode 4 on SG cooling. At Davis-Besse, this alignment is needed to implement LTOP
18 control because the LTOP control valve is located on the DHR suction line.
19
- 20 ● At all B&WOG plants, except for Davis-Basse, the LTOP control is an integral part of the
21 RCS because it is implemented through the use of the power-operated relief valves
22 (PORVs). During plant cooldown, procedures require that the PORV is reset from its
23 normal operational value to implement LTOP control. Therefore, there are design and
24 operational differences among plants in the means used to depressurize the RCS to initiate
25 SDC in the case of a total loss of feedwater event.
26
- 27 ● All EFW pumps at Davis-Besse are TDEFW pumps, while other B&WOG plants have a
28 combination of MDEFW pumps and TDEFW pumps.
29
- 30 ● While at Davis-Besse there are non-safety MDEFW pumps, startup feed pumps and
31 auxiliary boilers available, this is not the case at all other B&WOG plants.
32
- 33 ● At Davis Besse, the SG loops are raised in comparison to other B&WOG plants.
34
- 35 ● There is variability among B&WOG plants regarding support systems. Important
36 differences are in the number and type of emergency onsite power sources, electrical
37 divisions, and service water loops.
38

39
40 The identified design and operational differences were evaluated to determine how they impact
41 the results and conclusions of the quantitative risk assessment performed for Davis-Besse.
42 Major risk insights from qualitative and quantitative risk evaluations are documented in
43 Sections 4.4 and 4.5 of this SE.
44

45 The NRC staff concludes that the quality of the quantitative risk assessment, including the
46 sensitivity studies performed to address uncertainties and differences among plants, are
47 adequate to show that there are no significant risk increases associated with the proposed TS
48 end-state changes for B&WOG plants.

1 4.4 Risk Insights from the Qualitative Risk Assessment

2
3 BAW-2441 documents a generic qualitative comparison of shutdown risks in Modes 4 and 5
4 that aims to show that the proposed TS end-state changes do not decrease defense-in-depth.
5 Mode 4 and Mode 5 risks are qualitatively compared by discussing the means used to address
6 critical functions and the availability of systems needed to mitigate likely accident initiating
7 events. This generic risk comparison is complemented by a comparison of safety and
8 operational features among B&WOG plants, a comparison needed to ensure that the
9 conclusions of the generic qualitative risk assessment are valid for each B&WOG plant. It
10 should be noted that the qualitative comparison of risks is based on a plant configuration that
11 does not include any additional outages for maintenance beyond what is associated with the
12 subject LCO. Comparison of risks between Modes 4 and 5 when specific maintenance outages
13 are taking place are part of the quantitative risk assessment discussed in Section 4.5 of this SE.
14

15 Important insights regarding the various means used to accomplish critical functions and
16 mitigate accidents occurring in Modes 4 and 5 are listed below:

- 17
18 ● The means used to achieve reactivity control, containment integrity control, and power
19 availability are approximately equally reliable in Modes 4 and 5. Furthermore, their
20 reliability is not altered by invoking any of the LCO proposed for change.
21
22 ● More means are available to achieve inventory control when the plant is operating in Mode
23 4 than when the plant is operating in Mode 5. In Mode 4, two trains of HPI and two trains
24 of LPI are either immediately available, via automatic means, or can be placed in
25 operation, via operator action from the control room. In Mode 5, HPI may not be available
26 and one LPI train is unavailable because it is aligned for SDC. Even though breaks and
27 SG tube rupture events are unlikely in Mode 5, the availability of inventory control systems
28 is important to mitigate inadvertent RCS draining events, which are more likely during plant
29 alignment for SDC and in Mode 5 operation than in other modes of operation.
30
31 ● More means are available to perform the core decay heat removal critical function while the
32 plant is operating in Mode 4 on SG cooling than when it is aligned to the SDC system
33 (either in Mode 4 or in Mode 5) for decay heat removal. In Mode 4 (on SG cooling), in
34 addition to the main feedwater system, the condensate system and the EFW system can
35 be used to remove heat from the reactor core. In the unlikely event of a total loss of
36 feedwater, there are reliable means (e.g., use of PORVs and pressurizer vents) to
37 depressurize the RCS and initiate SDC (at Davis-Besse this is not necessary because the
38 plant is aligned to the SDC system for LTOP pressure control). In Mode 4 (on SDC) or in
39 Mode 5 operation, heat is removed by either one of the two trains of the DHR system,
40 which provides the SDC function. However, closure of a single valve in the SDC suction
41 line will terminate core cooling. Also, when the SDC system is being aligned to the RCS,
42 there is a possibility of inadvertent RCS draining caused by inappropriate valve alignments,
43 as there is a possibility of draining while on SDC due to human errors during maintenance
44 activities. Although it is possible to return to SG cooling (in either the forced or natural
45 circulation mode), this backup means of core cooling to SDC is not as reliable as is SDC
46 when operating on SG cooling. Some of the reasons are: (1) the long time that may be
47 required to restart the RCPs for forced circulation, (2) the potential unavailability of the SGs

1 when the plant is in Mode 5, and (3) the significant core heatup necessary to develop
2 appropriate hydraulic heads for natural circulation.
3

4 Potentially significant accident initiating events at shutdown and available mitigating systems
5 were evaluated to establish the acceptability of Mode 4 (on SG cooling) end-state as the default
6 action for the identified TSs. Important insights are:
7

8 ● All potentially risk significant initiating events that can occur while the plant is operating at
9 shutdown Mode 4 (on either SG cooling or SDC) and Mode 5, are those associated with
10 insufficient removal of decay heat and insufficient inventory.
11

12 ● In Mode 4 (on SG cooling), initiating events causing insufficient decay heat removal via the
13 SGs or insufficient inventory are represented (or subsumed) by the following:
14

- 15 - Loss of feedwater;
- 16 - Loss of offsite power (LOOP);
- 17 - Loss of one or more power buses;
- 18 - Loss of cooling water;
- 19 - Loss of instrument air;
- 20 - Floods in pump rooms
- 21 - Loss of inventory outside the RB;

22 and

- 23 - Loss of inventory inside the RB.

24 ● In Mode 5 and 4 (on SDC), initiating events causing insufficient decay heat removal via the
25 DHR system or insufficient inventory are represented (or subsumed) by the following:
26

- 27 - Loss of running DHR train;
- 28 - LOOP;
- 29 - Loss of one or more power buses;
- 30 - Loss of ooling water (either

31 component water or SWS);

- 32 - Floods in rooms where the DHR
33 pumps, the CCW, or the SWS
34 pumps are located;
- 35 - Loss of inventory outside the RB;

36 and

- 37 - Loss of inventory inside the RB.

38 ● The risk impact of LOCAs, as pressure driven initiating events, are not as significant in
39 Modes 4 and 5 as they are in Mode 1. The major contributor to this initiator is loss of
40 inventory caused by incorrect valve lineups. Since incorrect valve lineups are more likely
41 during Mode 5 operation, the risk associated with LOCAs will be smaller if Mode 4 (on SG
42 cooling) is adopted as the end-state.
43

44 ● LOOP is an important initiating event in both Modes 4 and 5 with approximately the same
45 frequency. Therefore, their risk impact is lower when there is more redundancy and
46
47

1 diversity of the mitigating systems, as is the case when the plant is operating in Mode 4 (on
2 SG cooling).
3

- 4 ● Loss of feedwater in Mode 4 (on SG cooling) and loss of the operating DHR train in the
5 SDC mode in Modes 4 and 5 are important initiating events of the same order of
6 magnitude frequency. Since there is much more redundancy and diversity of the mitigating
7 systems when the plant is operating in Mode 4 on SG cooling, the risk impact associated
8 with the loss of feedwater initiating event (occurring in Mode 4 on SG cooling) is lower than
9 the risk impact associated with the loss of the operating DHR train initiating event
10 (occurring in Mode 4 on SDC and in Mode 5).
11
- 12 ● Loss of cooling water is an equally important initiating event in both Modes 4 and 5 with
13 approximately the same frequency and risk impacts.
14

15 A comparison of risk important safety and operational features among B&WOG plants was
16 made to show that the conclusions of the generic qualitative risk assessment are valid for each
17 of the B&WOG plants. The differences in risk-important safety and operational features among
18 B&WOG plants, discussed in Section 4.0 of this SE, do not change the conclusions of the
19 qualitative risk assessment in favor of establishing Mode 4 (on SG cooling) as the preferred
20 end-state for the following reasons:
21

- 22 ● Although there are some differences among B&WOG plants regarding the means used for
23 inventory makeup and heat removal at high pressures, all B&WOG plants have such
24 features. Therefore, the conclusion that more means are available to perform the core
25 decay heat removal critical function when the plant operates in Mode 4 on SG cooling than
26 when the plant is aligned to the SDC system (in either Mode 4 or Mode 5), is valid for any
27 plant.
28
- 29 ● Although there are some differences in the means available to depressurize the RCS
30 among the various B&WOG plants, the conclusion that for accidents initiated in Mode 4 (on
31 SG cooling) the reactor can be depressurized reliably so that SDC can be used, is valid for
32 any plant.
33
- 34 ● Although there are some differences among B&WOG plants regarding the means used for
35 inventory makeup and heat removal at low pressures, these differences do not change any
36 conclusions because they impact Mode 4 and Mode 5 risks at a specific plant equally; this
37 also true for differences among B&WOG plants regarding support systems.
38

39 The above listed insights lead to the conclusion that, in general, plant operation in Mode 4 on
40 SG cooling (hot shutdown) offers at least the same robustness to plant upsets as operation in
41 Mode 5 (cold shutdown). The insights gained from the quantitative risk study (listed below)
42 substantiate this conclusion.
43

44 4.5 Risk Insights from the Quantitative Risk Assessment 45

46 The scope of the quantitative risk assessment was to compare the core damage risks
47 associated with either staying in Mode 4 (on SG cooling), or going to Mode 5 to carry out
48 equipment repairs. This comparison was made for each of the LCO cases for which an

1 end-state change is proposed, and for which the equipment of interest is modeled in the PRA
2 as well as for the non-LCO case (base case). The results are summarized in Table 2 of this
3 SE. "LCO-specific" quantitative risk assessments were not performed for some of the proposed
4 LCO cases for which an end-state change is proposed, because they have a negligible or
5 intangible contribution to CDF (e.g., LCOs involving boron concentration and containment). For
6 each of the cases for which "LCO-specific" quantitative risk assessments were performed, CDF
7 values were assessed for both the current end-state (i.e., Mode 5) and the proposed end-state
8 (i.e., Mode 4 on SG cooling). It should be noted that the assessed CDF values are yearly
9 values (i.e., they are an estimate of the risk associated with plant operation at the current and
10 proposed end-states for an entire year). In addition to these two CDF values, the percent
11 change (always a reduction) in CDF due to changing the end-state from Mode 5 to Mode 4 is
12 also listed in Table 2 for each of the analyzed cases.

13
14 Important results and insights from the quantitative risk assessment, which substantiate the
15 conclusions of the qualitative risk assessment by providing numerical results, are listed below:

- 16
17 ● The CDF estimates, reported in Table 2 of this SE, support the requested end-state
18 change. These estimates show that staying in Mode 4 (on SG cooling), rather than going
19 to Mode 5 to carry out equipment repairs, does not have any adverse effect on plant risk
20 and may actually lead to significant risk reduction. This conclusion is supported by the
21 following:
 - 22
23 - When no equipment is taken out (base case), the Mode 5 CDF is about 1.2E-
24 5/year, while the Mode 4 (on SG cooling) CDF is 3.4E-6/year (an approximately
25 71 percent reduction).
 - 26
27 - When equipment associated with the proposed changes is taken out of service,
28 the Mode 4 (on SG cooling) CDF is lower than the Mode 5 CDF, ranging from a
29 reduction of about 6 percent for LCO 3.4.6 (one RCS loop inoperable) to a
30 reduction of about 92 percent for LCO 3.8.9 (ac distribution subsystem
31 inoperable). This indicates that, for outages involving the LCOs proposed for
32 end-state change, the end-state change may lead to significant risk reductions.
 - 33
34 ● The accident sequences that dominate the risk in Mode 4 (on SG cooling) are initiated by a
35 LOOP event, with subsequent failure of onsite standby power sources causing loss of all
36 primary and backup core cooling options (i.e., SG cooling, DHR system cooling, and
37 "feed-and-bleed" cooling). Other accident sequences that are significant contributors to
38 risk in Mode 4 (on SG cooling) are initiated by a loss of RCS inventory outside of the RB,
39 with subsequent failure of the operator to take action to stop the drain before DHR suction
40 (the backup cooling method) is lost, and failure to initiate "feed-and-bleed" cooling.
 - 41
42 ● The major contributing accident sequences to the risk in Mode 5 and 4 (on SDC) are
43 initiated by loss of the operating DHR train and LOOP events. In addition, there is
44 significant contribution from accident sequences initiated by a loss of CCW event, which
45 affects the function of the DHR and other systems, and, to a lesser extent, by accident
46 sequences initiated by a loss of RCS inventory outside of the RB event.
- 47

Table 2 Comparison of CDF Between Mode 4 and Mode 5 End-States (Davis-Besse Model) for Proposed Changes.

| Technical Specification | Condition | Mode 5 CDF/yr | Mode 4 CDF/yr | Decrease in CDF/yr (percent) |
|----------------------------|--|---------------|---------------|------------------------------|
| Base Case | No LCO | 1.2E-5 | 3.4E-6 | 71 |
| 3.7.7 (CCW) | A. One CCW train inoperable | 4.8E-4 | 7.6E-5 | 83 |
| 3.7.8 (SWS) | A. One SWS train inoperable | 4.8E-5 | 5.6E-6 | 88 |
| 3.8.1 (AC Sources) | A. One offsite circuit inoperable | 1.1E-5 | 1.4E-6 | 87 |
| | B. One emergency diesel generator (EDG) inoperable | 1.0E-4 | 9.1E-5 | 9 |
| | C. Two offsite circuits inoperable | 8.7E-4 | 1.1E-4 | 87 |
| | D. One offsite circuit and one EDG inoperable | 1.1E-4 | 9.2E-5 | 16 |
| | E. Two EDGs inoperable | 1.2E-3 | 1.1E-3 | 8 |
| 3.8.4 (DC Sources) | A. One train battery chargers inoperable | 1.5 E-5 | 3.6E-6 | 76 |
| | B. Batteries on one train inoperable | 1.6E-4 | 4.8E-5 | 70 |
| | C. One DC subsystem inoperable -other | 1.4E-4 | 4.6E-5 | 67 |
| 3.8.9 (AC/DC Distribution) | A. AC distribution subsystem inoperable | 1.1E-3 | 8.6E-5 | 92 |
| | B. AC vital bus inoperable | 5.6E-5 | 4.4E-5 | 21 |
| | C. DC distribution subsystem inoperable | 1.4E-4 | 4.6E-5 | 67 |
| 3.8.7 (Inverters) | A. One Inverter inoperable | 5.6E-5 | 4.4E-5 | 21 |
| 3.4.6 (RCS loops Mode 4) | A. One RCS loop inoperable | 4.8E-3 | 4.5E-3 | 6 |

- The dominant contributors to risk when the plant is in the proposed end-state (Mode 4 on SG cooling), are associated with failures of redundant or diverse means of performing a safety function, such as failures that affect normal cooling (feedwater) and also backup and emergency cooling methods. The most common reasons for these failures are LOOP and failure of the EDGs, which affects SG cooling as well as backup DHR and “feed-and-bleed” cooling. When the reason for being in the LCO is inoperability of one train of a safety system (such as EDG, batteries, CCW, or SWS), then common cause failure of the remaining train(s) is usually an important contributor to risk. In general, failures that dominate the risk are associated with equipment that has already been

1 recognized as an important contributor by the TS, and for which operational requirements
2 and guidance (e.g., compensatory measures) are in place. In addition, implementation
3 guidance for the proposed end-state changes should be developed to ensure that insights
4 and assumptions made in the risk assessment are properly reflected in the plant-specific
5 configuration risk management program (CRMP) at the participating B&WOG plants.
6

- 7 ● The conclusion that staying in Mode 4 (on SG cooling), rather than going to Mode 5 to carry
8 out equipment repairs, does not have any adverse effect on plant risk and may actually lead
9 to significant risk reduction, can be extended to the proposed LCO cases for which an end-
10 state change is proposed without performing “LCO-specific” quantitative risk assessments.
11 Although no “LCO-specific” quantitative risk assessments were performed for LCO cases
12 having a negligible or intangible contribution to CDF (such as LCOs involving boron
13 concentration or containment), the results of the non-LCO cases (base cases) and the
14 insights from the qualitative risk assessments support this conclusion.
15

16 Based on the results of the quantitative risk assessment for Davis-Besse, one can conclude that,
17 in the analyzed cases, it is safer to stay in Mode 4 (on SG cooling) than to go to Mode 5 (cold
18 shutdown) to carry out equipment repair. This conclusion has been extended to all other
19 B&WOG plants through a PRA sensitivity study, which accounts for the pertinent differences
20 between Davis-Besse and the other plants. For this sensitivity study, a “non-Davis-Besse” PRA
21 model was developed and used to re-quantify the risk associated with Mode 4 and 5 end-states.
22 The “non-Davis-Besse” PRA model was developed by identifying the important differences in
23 design and operational features among B&WOG plants, and by changing the Davis-Besse
24 model to reflect these differences. Conservative or bounding assumptions were made, as
25 necessary, so that the “non-Davis-Besse” PRA model could be used to extend the conclusion
26 reached for Davis-Besse to all other B&WOG plants. In addition, the robustness of such a
27 conclusion has been investigated by performing sensitivity studies to assess the impact of
28 uncertainties in data and modeling assumptions.
29

30 The “non-Davis-Besse” PRA model was developed from the Davis-Besse PRA model by making
31 the following changes, which reflect important differences in design and operational features
32 between Davis-Besse and other B&WOG plants, that can have a significant impact on the
33 results and conclusions of the risk assessment:
34

- 35 ● Deleted separate makeup pumps and added combined makeup and HPI pumps.
- 36 ● Reduced the Mode 4 (on SG cooling) initiating event frequency for loss of RCS inventory
37 outside of the RB because all B&WOG plants with the exception of Davis-Besse do not
38 align to the SDC for LTOP in Mode 4 while the SG are used for core cooling.
- 39 ● Replaced one of TDEFW pumps with a MDEFW pump.
- 40 ● Deleted credit for the auxiliary boiler.
- 41 ● Added a model for the means to depressurize the RCS in order to initiate SDC for the case
42 of total loss of feedwater (conservatively assumed that only the PORVs can be used to
43 depressurize the RCS).
44
45
46
47
48

- Deleted the non-safety-related MDEFW pumps, startup feedwater pumps, and auxiliary boiler available at Davis-Besse but not at all other B&WOG plants.
- Accounted for the difference between the raised loop and the lowered-loop SG on the human recovery model.

The “non-Davis-Besse” PRA model was used to quantify and compare the core damage risks associated with either staying in Mode 4 (on SG cooling), or going to Mode 5 to carry out equipment repairs. This comparison was made for each of the LCO cases for which an end-state change is proposed, and for which the equipment of interest are modeled in the PRA as well as for the non-LCO case (base case). The results are summarized in Table 3 of this SE. Important insights from the assessment of the applicability of the Davis-Besse results to other B&WOG plants are listed below:

- Any changes in CDF that result from such design and operational differences would not impact the conclusion reached for Davis-Besse regarding the proposed TS end-state change. Therefore, the conclusion that staying in Mode 4 (on SG cooling), rather than going to Mode 5 to carry out equipment repairs, does not have any adverse effect on plant risk and may actually lead to significant risk reduction, is valid for all B&WOG plants. This finding is supported by the following:

- When no equipment is taken out (base case), the Mode 5 CDF is about 5.2E-5/year while the Mode 4 (on SG cooling) CDF is 1.4E-5/year (an approximately 73 percent reduction).

- When equipment associated with the proposed changes is taken out of service, the Mode 4 (on SG cooling) CDF is lower than the Mode 5 CDF, ranging from a reduction of about 3 percent for LCO 3.4.6 (one RCS loop inoperable) to a reduction of about 95 percent for LCO 3.7.7 (one CCW train inoperable). This indicates that, for outages involving the LCOs proposed for end-state change, the change would not increase risk but may lead to significant risk reductions.

- The accident sequences that dominate the risk in Mode 4 (on SG cooling) are similar to the Davis-Besse case. LOOP initiated accident sequences, with subsequent failure of onsite standby power sources causing loss of all primary and backup core cooling options (i.e., SG cooling, DHR system cooling, and “feed-and-bleed” cooling), continue to be major contributors to risk. Accident sequences involving loss of RCS inventory outside RB are

larger contributors to risk than they are at Davis-Besse, due to the lower probability of successful recovery because of the smaller SG inventory available to drain back into the RCS in a lowered-loop plant. Also, loss of feedwater accident sequences are more important than they are at Davis-Besse because there is no credit for the backup non-safety feedwater pump and the auxiliary boiler in the “non-Davis-Besse” model.

Table 3 Comparison of Core Damage Frequency Between Mode 4 and Mode 5 End States (Non-Davis-Besse Model) for Proposed Changes.

| Technical Specification | Condition | Mode 5 CDF/yr | Mode 4 CDF/yr | Decrease in CDF/yr (percent) |
|----------------------------|---|---------------|---------------|------------------------------|
| Base Case | No LCO | 5.2E-5 | 1.4E-5 | 73 |
| 3.7.7 (CCW) | A. One CCW train inoperable | 3.7E-3 | 1.7E-4 | 95 |
| 3.7.8 (SWS) | A. One SWS train inoperable | 8.8E-5 | 3.0E-5 | 66 |
| 3.8.1 (AC Sources) | A. One offsite circuit inoperable | 6.4E-5 | 1.2E-5 | 81 |
| | B. One EDG inoperable | 1.4E-4 | 1.0E-4 | 28 |
| | C. Two offsite circuits inoperable | 6.0E-4 | 4.0E-5 | 93 |
| | D. One offsite circuit and one EDG inoperable | 1.5E-4 | 1.0E-4 | 33 |
| | E. Two EDGs inoperable | 1.2E-3 | 1.1E-3 | 8 |
| 3.8.4 (DC Sources) | A. One train battery charger inoperable | 6.3 E-5 | 1.4E-5 | 78 |
| | B. Batteries on one train inoperable | 2.1E-4 | 1.3E-4 | 38 |
| | C. One DC subsystem inoperable-other | 1.9E-4 | 1.1E-4 | 42 |
| 3.8.9 (AC/DC Distribution) | A. AC distribution subsystem inoperable | 2.7E-3 | 2.4E-3 | 11 |
| | B. AC vital bus inoperable | 9.4E-5 | 7.1E-5 | 24 |
| | C. DC distribution subsystem inoperable | 1.9E-4 | 1.1E-4 | 42 |
| 3.8.7 (Inverters) | A. One inverter inoperable | 9.4E-5 | 7.1E-5 | 24 |
| 3.4.6 (RCS loops - Mode 4) | A. One RCS loop inoperable | 3.3E-3 | 3.2E-3 | 3 |

- The accident sequences that dominate the risk in Mode 5 and 4 (on SDC cooling) are similar to the Davis-Besse case. The major contributing accident sequences to the risk are

1 initiated by loss of the operating DHR train, which includes LOOP and loss of CCW initiating
2 accident sequences, that affect the function of the DHR among other systems, and by
3 accident sequences initiated by a loss of RCS inventory outside of the RB. The latter
4 category of accident sequences are larger contributors to risk than they are at Davis-Besse
5 due to the higher initiating event frequency of the loss of RCS inventory events in the “non-
6 Davis-Besse” model associated with the alignment of SDC.

- 7
8 ● As in the case for Davis-Besse, the dominant contributors to risk when the plant is in the
9 proposed end-state (Mode 4 on SG cooling) are associated with failures of redundant or
10 diverse means of performing a safety function, such as failures that affect normal cooling
11 (feedwater) and also backup and emergency cooling methods. Therefore, the insight that
12 failures that dominate the risk are associated with equipment which have already been
13 recognized as important contributors by the TS and for which operational requirements and
14 guidance (e.g., compensatory measures) are in place, is valid for all B&WOG plants.

15
16 These insights indicate that the results of the quantitative risk assessment are robust, and that
17 the conclusions of both the qualitative and quantitative risk assessments do not change when
18 the impact of design and operational differences among B&WOG plants is considered.

19
20 Important insights from the investigation of the robustness of the results to uncertainties in data
21 and modeling assumptions, through sensitivity studies, are listed below.

- 22
23 ● Accident initiating event (IE) frequencies were calculated based on a combination of
24 operating experience and data from previous PRA studies. Because some of these
25 frequencies are important contributors to risk, the sensitivity of the risk assessment results
26 to values assumed for these frequencies was investigated. The following sensitivity studies,
27 associated with IE frequencies, were performed:

28
29 -

The IE frequency for the loss of inventory event (both inside and outside the RB at Davis-Besse while the plant is operating in Mode 4 (on SG cooling) was increased by a factor of 5. Since Davis-Besse aligns the RCS to SDC in Mode 4, the Mode 4 pressure is not very different than the Mode 5 pressure. For this reason, the same IE frequencies for the loss of inventory event are used for both Modes 4 and 5 in the baseline risk assessment (8.4E-3/year for loss of inventory inside the RB and about 1.3E-2/year for loss of inventory outside the RB. This sensitivity study was performed to investigate the robustness of the risk assessment results and conclusions to the slightly higher RCS pressure

1 associated with the Mode 4
2 end-state. It was shown that the
3 results and conclusions are valid,
4 even if the frequencies for the loss of
5 inventory event (both inside and
6 outside the RB are conservatively
7 assumed to be significantly worse in
8 Mode 4 than in Mode 5.
9

10 -
11 The Mode 4 (on SG cooling) IE
12 frequency for loss of inventory inside
13 the RB at B&WOG plants with
14 lowered-loop SG design (as
15 compared to Davis-Besse) was
16 increased by a factor of 5. This
17 sensitivity study was performed to
18 investigate the robustness of the risk
19 assessment results and conclusions
20 to the assumed loss of inventory IE
21 frequency in conjunction with the
22 lowered-loop SG design. In the
23 lowered-loop plants, less SG
24 inventory is available to drain back
25 into the RCS. This results in shorter
26 boil-off times to core uncover and
27 affects recovery probabilities. Since
28 these plants do not pre-align the RCS
29 to the SDC system in Mode 4 (on SG
30 cooling) and use the PORVs for
31 LTOP, the factor of 5 was applied
32 only to the loss inventory frequency
33 inside the RB. It was shown that the
34 results and conclusions are valid,
35 even if the frequency of the loss of
36 inventory event inside the RB is
37 conservatively assumed to be
38 significantly worse in Mode 4 than it
39 is in Mode 5.

40 -
41 The IE frequency for transients
42 occurring in Mode 4 and Mode 5
43 were increased by a factor of 5. This
44 sensitivity study was performed to
45 investigate the robustness of the risk
46 assessment results and conclusions
47 to transient initiating events, which
48 are major contributors to risk since
they involve loss of the operating

1 decay heat removal method, such as
2 loss of feedwater, LOOP, loss of
3 CCW, and loss of SWS events. The
4 investigation focused on initiating
5 events that have the potential to
6 affect Mode 4 (on SG cooling) risk
7 more than Mode 5 risk. It was shown
8 that the results and conclusions of
9 the quantitative risk assessment
10 regarding the comparison between
11 Mode 4 and Mode 5 end-state risks
12 are valid, even when uncertainties in
13 the transient IE frequencies are
14 considered.
15

- 16 ● All failure to recover probabilities (in both the Davis-Besse and the “non-Davis-Besse” PRA
17 models), were increased by a factor of 10 (were changed to 1.0 if greater than 0.1). The
18 results of this sensitivity have shown that the Mode 4 versus Mode 5 end-state comparisons
19 are robust, even when considering an order of magnitude increase of the recovery
20 probability values to account for uncertainties.
21
- 22 ● The failure to trip the RCPs following a transient IE, to prevent RCP seal LOCA, was
23 changed to 1.0 (screening probability). The results of this sensitivity study have shown no
24 sensitivity to this human error probability.
25
- 26 ● All CDF probabilities, in both the Davis-Besse and the “non-Davis-Besse” PRA models, and
27 both the Mode 4 and Mode 5 end-states, were increased by a factor of 3. The results of this
28 sensitivity study have shown that the Mode 4 versus Mode 5 end-state comparisons are
29 robust and demonstrate that uncertainty in CDF data does not affect the conclusion of the
30 quantitative risk assessment.
31

32 These insights indicate that the results of the quantitative risk assessment are robust and that
33 the conclusions of both the qualitative and quantitative risk assessments do not change when
34 uncertainties in data and modeling assumptions are considered.
35

36 The NRC staff believes that the above listed insights substantiate the generic conclusion that
37 plant operation in Mode 4 (hot shutdown) offers at least the same robustness to plant upsets as
38 operation in Mode 5 (cold shutdown).
39

40 4.6 Conclusions

41 The NRC staff’s review finds that the BAW-2441 risk assessment approach is comprehensive
42 and follows staff guidance as documented in RGs 1.174 and 1.177. In addition, the analyses
43 show that the criteria of the three-tiered approach for allowing TS changes (documented in
44 RG 1.177) are met as explained below:
45

- 46 ● Risk Impact of the Proposed Change (Tier 1). The risk changes associated with the
47 proposed TS changes, in terms of mean yearly increases in CDF and LERF, are risk-neutral
48

1 or risk-beneficial. In addition, there are no significant temporary risk increases, as defined
2 by RG 1.177 criteria, associated with the implementation of the proposed TS end-state
3 changes.
4

- 5 ● Avoidance of Risk-Significant Configurations (Tier 2). The performed risk analyses, which
6 are based on single LCOs, have shown that there are no high risk configurations associated
7 with the proposed TS end-state changes. The reliability of redundant trains is normally
8 covered by a single LCO. When multiple LCOs occur, which affect trains in several
9 systems, the plant's risk-informed CRMP, implemented in response to the Maintenance
10 Rule 10 CFR 50.65(a)(4), will ensure that high risk configurations are avoided. As part of
11 the implementation of the 10 CFR 50.65(a)(4) program, licensees are expected to include
12 guidance in appropriate plant procedures and/or administrative controls to preclude high risk
13 plant configurations when the plant is at the proposed end-state. The NRC staff finds that
14 such guidance is adequate for preventing risk-significant plant configurations.
15
- 16 ● Configuration Risk Management (Tier 3). Licensees have programs in place to comply with
17 10 CFR 50.65(a)(4) to assess and manage the risk from proposed maintenance activities.
18 These programs can support licensee decision making regarding the appropriate actions to
19 control risk whenever a risk-informed TS is entered.
20

21 The generic risk impact of the proposed end-state mode change was evaluated subject to the
22 following assumptions:
23

- 24 ● The entry into the proposed end-state is initiated by the inoperability of a single train of
25 equipment, or a restriction on a plant operational parameter, unless otherwise stated in the
26 applicable technical specification;
27
- 28 ● The primary purpose of entering the end-state is to correct the initiating condition and return
29 to power as soon as is practical.
30
- 31 ● Implementation guidance for the proposed end-state changes should be developed to
32 ensure that insights and assumptions made in the risk assessment are properly reflected in
33 the plant-specific CRMP at the participating B&WOG plants.
34

35 These assumptions are consistent with typical entries into Mode 4 for short duration repairs,
36 which is the intended use of the TS end-state changes.
37

38 The NRC staff concludes that, in general, going to Mode 4 (hot shutdown) instead of going to
39 Mode 5 (cold shutdown) to carry out equipment repairs does not have any adverse effect on
40 plant risk and may actually reduce risk. Therefore, the NRC staff finds that the risk information
41 provided by BAW-2441 supports the requested change.
42

43 5.0 CONCLUSION 44

45 BAW-2441, Revision 2, proposed to change the end state of the selected LCOs from Mode 5 to
46 Mode 4. The NRC staff has reviewed the technical and risk assessments that provide
47 justification to the proposed changes to the end-states for selected LCOs. Based on the above
48 evaluations, the NRC staff concludes the proposed changes to these LCOs are acceptable.

1 6.0 REFERENCES:
2

- 3 1. Letter from James F. Malley, B&W Owners Group, to US Nuclear Regulatory Commission,
4 "Request for Review of BAW-2441, Revision 2, 'Risk Informed Justification for LCO End-
5 State Changes,'" January 19, 2004, NRC:04:001. ADAMS Accession No. ML040260016
6
7 2. Letter from Howard Crawford, B&W Owners Group, to US Nuclear Regulatory Commission,
8 "Response to Request for Additional Information for BAW-2441, Revision 2, 'Risk Informed
9 Justification for LCO End State Changes,'" February 17, 2005, NRC:05:010. ADAMS
10 Accession No. ML050560034
11

12 Principal Contributors:

Y. Hsii
N. Saltos

13
14
15 Date: May 15, 2006
16