

Part 50 License Amendment Request (LAR) for Dry Storage Loadings at Oconee

Presentation to the
United States Nuclear Regulatory Commission (NRC)
Rockville, MD
March 22, 2006



Purpose

- **Provide Information to the NRC Concerning:**
 - Duke's recent LAR for dry cask loading at Oconee in response to Regulatory Issue Summary (RIS) 2005-05
 - Duke's requested schedule for NRC approval of the LAR
 - Duke's schedule to resume Oconee dry storage loadings (currently suspended until the LAR is approved)

- **Discussion**
 - Obtain any NRC feedback and address initial questions
 - Determine how Duke might support the review process



Duke Representatives

- **Oconee Nuclear Site**

- Reene' Gambrell - Regulatory Compliance
- Carl Fago - Supervisor, Reactor Team

- **Nuclear General Office**

- Steve Nesbit - Mgr. Spent Fuel Management
- Joe Coletta - SFM (criticality analyst)
- William Murphy - SFM (criticality analyst)
- Gary Walden - SFM (lead for ONS ISFSI)



Overview

- **Background** (Nesbit)
- **LAR Overview** (Gambrell)
- **Criticality Analysis** (Coletta)
- **Closing** (Gambrell)
- **Discussion** (ALL)



Background

- **Pre-Submittal Meeting (November 1, 2005)**
 - **Informed NRC of Duke's Response to RIS 2005-05**
 - **Oconee dry storage systems had not been shown to meet requirement of 10 CFR 50.68(b) for subcriticality in unborated water**
 - **Planned dry storage loadings suspended**
 - **Informed NRC of Plan to Submit LAR**
 - **LAR scope: all dry storage systems used at Oconee**
 - **Technical approach: credit for fuel assembly burnup; partial soluble boron credit for SFP**
 - **Planned submittal date: March 1, 2006**
 - **Requested approval date: June 1, 2006**
 - **NRC provided feedback on LAR, technical approach, and schedule**



LAR Overview

- **General**
 - Submitted March 1, 2006
 - Requests Issuance of Amendment by June 1, 2006
- **Criticality Analysis**
- **Oconee Compliance with 10 CFR 50.68(b)**
 - NRC Recommendation from Pre-submittal Meeting
- **Technical Specifications (TS)**
 - **New 3.7.18 and Associated Bases (Dry Spent Fuel Storage Cask Loading and Unloading)**
 - Specifies minimum burnup and cooling time for fuel assemblies in dry spent fuel storage cask while in SFP
 - Covers all fuel types eligible for Oconee dry storage systems
 - Format similar to 3.7.13 for Fuel Assembly Storage (for spent fuel storage racks)

LAR Overview

- **Technical Specifications (Cont'd)**
 - **New 4.4 (Dry Spent Fuel Storage Cask Loading and Unloading)**
 - **Specifies design features associated with criticality**
 - **Similar to 4.3 for Fuel Storage**
 - **NUHOMS®-24P and NUHOMS®-24PHB specified rather than center-to-center pitch**
 - **Revised 3.7.12 and Associated Bases (Spent Fuel Pool Boron Concentration)**
 - **Current limits maintained**
 - **Applicability revised to include when fuel assemblies are in a dry spent fuel storage cask located in the SFP**
 - **Revised B3.7.12 provides revised basis for TS**
- **Commitments**
 - **Oconee UFSAR to be updated prior to June 30, 2007**




Criticality Analysis

- Addresses All Oconee Dry Fuel Storage Systems

License	Storage System	Soluble Boron Required During Loading?	Number of Canisters	Time Period
Site-Specific	NUHOMS®-24P	yes	40 (loaded)	1990-1996
General	NUHOMS®-24P	yes	44 (loaded)	1999-2005
General	NUHOMS®-24PHB	yes	28 (to be loaded)	2005-2009

Criticality Analysis


- **NUHOMS®-24P and NUHOMS®-24PHB Systems Have Common Basket Design** (Encl 3, Sec 2)



Source: NUHOMS® FSAR, Rev. 8, June 2004

Criticality Analysis

- Roadmap to Fuel Burnup Requirements (Encl 3, Secs 6.3 and 6.4)





Criticality Analysis

- **Codes Used for Analysis** (Encl 3, Secs 6.3 and 6.4)
 - **SCALE 4.4 / KENO V.a**
 - 3-D full detail canister model with fresh fuel
 - Used to demonstrate conservatism of CASMO-3 (and validate CASMO-3 2-D fresh-fuel cases)
 - **CASMO-3**
 - Base 2-D model calculations
 - Burnup credit computations
 - Reactor depletion
 - 2-D dry storage canister “rack” calculations with burned fuel
 - **SIMULATE-3**
 - 3-D axial burnup bias determination
 - Axial bias applied to 95/95 k-eff calculations where positive

Criticality Analysis

- **Geometric Models** (Encl 3, Sec 6.3)



1 representative spacing
for infinite lattice
(CASMO-3)

3 different fuel assembly spacings (KENO V.a)

Criticality Analysis

- **CASMO-3 Computational Canister Model** (Encl 3, Secs 3 and 6.2)
 - 2-D infinite lattice
 - No axial or radial canister leakage credited
 - Single representative fuel assembly spacing
 - Conservatism is demonstrated
 - Full density moderator in dry storage canister
 - Water temperature up to 150°F ("off-normal" up to 212°F)
 - Fuel designs: Mark B2-B8; B9; B10; B10L
 - Conservative reactor depletion parameters
 - Credit for 5 years post-irradiation cooling time

Criticality Analysis


- **Criticality Analysis Results** (Encl 3, Sec 6.5)
 - Criticality calculations performed per 10 CFR 50.68 (b) and Kopp guidance
 - Credit for 430 ppm soluble boron (same as current Oconee SFP licensing basis)
 - Max 95/95 k_{eff} s for normal conditions:
 - No boron – 0.9980
 - 430 ppm boron credit – 0.9264
 - Worst-case accident condition (per Kopp) is misload
 - Single 5.0 wt % unirradiated fuel assembly “misloaded” in NUHOMS®-24P/24PHB canister
 - Requires 630 ppm soluble boron (2220 ppm available)

Criticality Analysis

● Analysis Results

[continued] (Encl 3, Sec 6.5)

- Curve specifies minimum burnup based on maximum initial enrichment / minimum 5 years cooling time
- Single “region” within dry storage canister
- Applies to all eligible fuel types analyzed
- Applicable to NUHOMS®-24P and NUHOMS®-24PHB



Criticality Analysis

- **Conservatism in Analysis** (Encl 3, Sec 6.2)
 - Infinite lattice (radial and axial) canister model ($\sim 0.04 \Delta k$)
 - Mechanical and burnup-related uncertainties ($> 0.01 \Delta k$)
 - In-reactor depletion parameters
 - Boron concentration (700 ppm)
 - Moderator temperature (630 °F)
 - Discrete BP presence (25 GWD/MTU exposure, max B_4C poison loading)
 - Fuel temperature (1054 °F)
 - Axial burnup bias (linear function of assembly burnup)
 - Most reactive eligible fuel assembly design



Closing

- **Pre-Submittal Meeting** 11/1/05 ✓
- **LAR Submitted** 3/1/06 ✓
- **Requested NRC approval** 6/1/06
- **Load 4 Dry Storage Canisters** 6/19 - 8/18/06
- **Outage Preparation Starts*** 8/21/06
- **Unit 1, EOC 23 Refuel Outage** Fall 2006

* Must load 2 canisters to avoid outage impacts