

May 3, 2006

Mr. Randall K. Edington
Vice President-Nuclear and CNO
Nebraska Public Power District
P. O. Box 98
Brownville, NE 68321

SUBJECT: COOPER NUCLEAR STATION - CORRECTION TO AMENDMENT
NO. 218 (TAC NO. MC6760)

Dear Mr. Edington:

By letter dated March 30, 2006, the Commission issued Amendment No. 218 to Facility Operating License No. DPR-46 for the Cooper Nuclear Station. The amendment, in response to your application dated April 13, 2005, as supplemented by letter dated September 29, 2005, revised various sections in the CNS Technical Specifications (TSs). The TS changes: (1) revised the frequency for performing control rod scram time surveillance following outages; (2) allowed insertion of a control rod withdrawal block and verification that all rods are fully inserted in lieu of suspending fuel movement when a refueling equipment interlock is inoperable; (3) clarified which Emergency Core Cooling System (ECCS) instrumentation must be operable when in shutdown; and (4) eliminated the need to require automatic start of the emergency diesel generators when the ECCS does not need to be operable.

Nebraska Public Power District submitted the license amendment request with markup and final typed TS pages. The revised TS page 3.1-12 contained an error in the frequency of Surveillance Requirement 3.1.4.1 that was introduced during printing. Enclosed is the corrected page. The page to be replaced is page 3.1-12 of the TS issued in the letter dated March 30, 2006.

Sincerely,

/RA/

Brian J. Benney, Project Manager
Plant Licensing Branch IV
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-298

Enclosure: Page 3.1-12 of the TSs

cc w/encl: See next page

May 3, 2006

Mr. Randall K. Edington
Vice President-Nuclear and CNO
Nebraska Public Power District
P. O. Box 98
Brownville, NE 68321

SUBJECT: COOPER NUCLEAR STATION - CORRECTION TO AMENDMENT
NO. 218 (TAC NO. MC6760)

Dear Mr. Edington:

By letter dated March 30, 2006, the Commission issued Amendment No. 218 to Facility Operating License No. DPR-46 for the Cooper Nuclear Station. The amendment, in response to your application dated April 13, 2005, as supplemented by letter dated September 29, 2005, revised various sections in the CNS Technical Specifications (TSs). The TS changes: (1) revised the frequency for performing control rod scram time surveillance following outages; (2) allowed insertion of a control rod withdrawal block and verification that all rods are fully inserted in lieu of suspending fuel movement when a refueling equipment interlock is inoperable; (3) clarified which Emergency Core Cooling System (ECCS) instrumentation must be operable when in shutdown; and (4) eliminated the need to require automatic start of the emergency diesel generators when the ECCS does not need to be operable.

Nebraska Public Power District submitted the license amendment request with markup and final typed TS pages. The revised TS page 3.1-12 contained an error in the frequency of Surveillance Requirement 3.1.4.1 that was introduced during printing. Enclosed is the corrected page. The page to be replaced is page 3.1-12 of the TS issued in the letter dated March 30, 2006.

Sincerely,

/RA/

Brian J. Benney, Project Manager
Plant Licensing Branch IV
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-298

Enclosure: Page 3.1-12 of the TSs

cc w/encl: See next page

DISTRIBUTION:

PUBLIC GHill, OIS (2)
LPLIV R/F RidsNrrDorlDpr
RidsNrrDorl (CHaney/CHolden)
RidsNrrDorlLpl4 (DTerao)
RidsNrrPMBBenney
RidsNrrLALFeizollahi
RidsAcraAcnwMailCenter
RidsOgcRp
RidsRgn4MailCenter (KKennedy)

PKG: ML061240137

TS Page: ML061240377

ADAMS Accession No.: ML061230051

NRR-106

OFFICE	NRR/LPL4/PM	NRR/LPL4/LA	NRR/LPL4/BC
NAME	BBenney;mxr4	LFeizollahi	DTerao
DATE	5/3/06	5/3/06	5/3/06

OFFICIAL RECORD COPY

Cooper Nuclear Station

cc:

Mr. William J. Fehrman
President and Chief Executive Officer
Nebraska Public Power District
1414 15th Street
Columbus, NE 68601

Mr. Gene Mace
Nuclear Asset Manager
Nebraska Public Power District
P.O. Box 98
Brownville, NE 68321

Mr. John C. McClure
Vice President and General Counsel
Nebraska Public Power District
P. O. Box 499
Columbus, NE 68602-0499

Mr. Paul V. Fleming
Licensing Manager
Nebraska Public Power District
P.O. Box 98
Brownville, NE 68321

Mr. Michael J. Linder, Director
Nebraska Department of Environmental
Quality
P. O. Box 98922
Lincoln, NE 68509-8922

Chairman
Nemaha County Board of Commissioners
Nemaha County Courthouse
1824 N Street
Auburn, NE 68305

Ms. Julia Schmitt, Manager
Radiation Control Program
Nebraska Health & Human Services R & L
Public Health Assurance
301 Centennial Mall, South
P.O. Box 95007
Lincoln, NE 68509-5007

Mr. H. Floyd Gilzow
Deputy Director for Policy
Missouri Department of Natural Resources
P. O. Box 176
Jefferson City, MO 65102-0176

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P. O. Box 218
Brownville, NE 68321

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011

Director, Missouri State Emergency
Management Agency
P. O. Box 116
Jefferson City, MO 65102-0116

Chief, Radiation and Asbestos
Control Section
Kansas Department of Health
and Environment
Bureau of Air and Radiation
1000 SW Jackson
Suite 310
Topeka, KS 66612-1366

Mr. Daniel K. McGhee
Bureau of Radiological Health
Iowa Department of Public Health
Lucas State Office Building, 5th Floor
321 East 12th Street
Des Moines, IA 50319

Mr. Keith G. Henke, Planner
Division of Community and Public Health
Office of Emergency Coordination
930 Wildwood P.O. Box 570
Jefferson City, MO 65102

Jerry C. Roberts, Director of Nuclear
Safety Assurance
Nebraska Public Power District
P.O. Box 98
Brownville, NE 68321

Mr. John F. McCann, Director
Licensing, Entergy Nuclear Northeast
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601-1813

February 2006