

3. WCAP-10216-P-A, Rev. 1A, "Relaxation of Constant Axial Offset Control / FQ Surveillance Technical Specification," February 1994.  
(Methodology for LCO 3.2.1 and LCO 3.2.3.)
  4. WCAP-12610-P-A, "VANTAGE + Fuel Assembly Reference Core Report," April 1995.  
(Methodology for LCO 3.2.1.)
  5. WCAP 11397-P-A, "Revised Thermal Design Procedure," April 1989.  
(Methodology for LCO 3.4.1 when using RTDP.)
  6. WCAP-10054-P-A and WCAP-10081-A, "Westinghouse Small Break ECCS Evaluation Model Using the NOTRUMP Code," August 1985.  
(Methodology for LCO 3.2.1.)
  7. WCAP-10924-P-A, Volume 1, Revision 1, "Westinghouse Large-Break LOCA Best-Estimate Methodology, Volume 1: Model Description and Validation Responses to NRC Questions," and Addenda 1,2,3, December 1988.  
(Methodology for LCO 3.2.1.)
  8. WCAP-10924-P-A, Volume 2, Revision 2, "Westinghouse Large-Break LOCA Best-Estimate Methodology, Volume 2: Application to Two-Loop PWRs Equipped with Upper Plenum Injection," and Addendum 1, December 1988.  
(Methodology for LCO 3.2.1.)
  9. WCAP-10924-P-A, Volume 1, Revision 1, Addendum 4, "Westinghouse Large-Break LOCA Best-Estimate Methodology, Volume 1: Model Description and Validation, Addendum 4: Model Revisions," March 1991.  
(Methodology for LCO 3.2.1.)
  10. WCAP-8745, "Design Basis for the Thermal Overpower Delta T and Thermal Overtemperature Delta T Trip Functions," March 1977.  
(Methodology for LCO 3.3.1.)
- c. The core operating limits shall be determined such that all applicable limits (e.g., fuel thermal mechanical limits, core thermal hydraulic limits, Emergency Core Cooling Systems (ECCS) limits, nuclear limits such as SDM, transient analysis limits, and accident analysis limits) of the safety analysis are met.
- d. The COLR, including any midcycle revisions or supplements, shall be provided upon issuance for each reload cycle to the NRC.