



FPL Energy
Seabrook Station

FPL Energy Seabrook Station
P.O. Box 300
Seabrook, NH 03874
(603) 773-7000

May 1, 2006

Docket No. 50-443
SBK-L-06101

U.S. Nuclear Regulatory Commission
Attn.: Document Control Desk
Washington, DC 20555-0001

Seabrook Station
2005 Annual Radioactive Effluent Release Report

Pursuant to 10CFR 50.36(a)(2) and Technical Specification 6.8.1.4, FPL Energy Seabrook, LLC submits the Annual Radioactive Effluent Release Report for 2005. A copy of the Offsite Dose Calculation Manual (ODCM) is also provided pursuant to Technical Specification 6.13.c. A summary of the changes to the ODCM is included in Enclosure 1, Appendix A.


The following information is provided in the enclosures:

- | | |
|-------------|---|
| Enclosure 1 | Effluent release data as required by Regulatory Guide 1.21 |
| Enclosure 2 | Joint frequency distributions of wind speed, wind direction and atmospheric stability |
| Enclosure 3 | Radiation dose assessment |
| Enclosure 4 | Offsite Dose Calculation Manual (ODCM), Revision 29 |

Should you have any questions regarding this letter, please contact Peter J. Harvey, Chemistry Department Manager, at (603) 773-7320.

Very truly yours,

FPL Energy Seabrook, LLC



Gene St. Pierre
Site Vice President

JE48
A009

cc: S.J. Collins, NRC Region I Administrator
G.E. Miller, NRC Project Manager, Project Directorate I-2
G.T. Dentel, NRC Senior Resident Inspector
Robert A. Oliveira, ANI

ENCLOSURE 1 TO SBK-L-06101

Effluent Release Data
as Required by Regulatory Guide 1.21

EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT
Supplemental Information 2005

Facility: Seabrook Station Unit 1

Licensee: FPL Energy Seabrook, LLC

1. Regulatory Limits

A. Gaseous Effluents

- a. 5.0 mrad per quarter gamma air dose.
- b. 10.0 mrad per quarter beta air dose.
- c. 7.5 mrem per quarter to any organ.

B. Liquid Effluents

- a. 1.5 mrem per quarter total body.
- b. 5.0 mrem per quarter any organ.
- c. 2.0E-04 $\mu\text{Ci/ml}$ dissolved or entrained gas.

2. Effluent Concentration Limits

Provide the ECL's used in determining allowable release rates or concentrations.

- a. Fission and activation gases: 10 ECL
- b. Iodines: 10 ECL
- c. Particulates, half-lives >8 days: 10 ECL
- d. Liquid Effluents: 10 ECL

3. Average Energy

Not applicable

4. Measurements and Approximations of Total Radioactivity

Provide the methods used to measure or approximate the total radioactivity in effluents and the methods used to determine radionuclide composition.

- A. Fission and activation gases: Determined by gamma spectroscopy. Total error is based on stack flow error, analytical error, and calculated sampling error.
- B. Iodines: Determined by collection on charcoal with subsequent gamma spectroscopy analysis. Total error is based on stack flow error, analytical error, and calculated sampling error.

- C. Particulates: Determined by collection on fixed filter with subsequent gamma spectroscopy analysis. Strontium is determined by composite analysis of filters by liquid scintillation, gross alpha by proportional counter and iron 55 by liquid scintillation. Total error is based on stack flow error, analytical error, and calculated sampling error.
- D. Liquid Effluents: Determined by gamma spectroscopy. A composite sample is analyzed for strontium by liquid scintillation, tritium by liquid scintillation, gross alpha by proportional counter and iron 55 by liquid scintillation. Total error is based on the volume discharge error and analytical error.
- E. ND: None Detected or No Detectable Activity

5. Batch Releases

Provide the following information relating to batch releases of radioactive materials in liquid and gaseous effluents.

- A. Liquid
 - a. Number of batch releases: 164
 - b. Total time for batch releases: 32816 minutes
 - c. Maximum time period for batch release: 780 minutes
 - d. Average time period for batch release: 200 minutes
 - e. Minimum time period for batch release: 11 minutes
 - f. Average stream flow during periods of release of effluents into a flowing stream: 1.52E+06 liters per minute
- B. Gaseous
 - a. Number of batch releases: 73
 - b. Total time for batch releases: 43405 minutes
 - c. Maximum time period for batch release: 5430 minutes
 - d. Average time period for batch release: 679 minutes
 - e. Minimum time period for batch release: 1 minute

6. Abnormal Releases

- A. Liquid
 - a. Number of releases: 0
 - b. Total activity released: N/A
- B. Gaseous
 - a. Number of releases: 0
 - b. Total activity released: N/A

TABLE 1A

EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT 2005

GASEOUS EFFLUENTS-SUMMATION OF ALL RELEASES

Unit	Quarter 1	Quarter 2	Quarter 3	Quarter 4	Est. Total Error, %
------	-----------	-----------	-----------	-----------	---------------------

A. Fission and activation gases

1. Total releases	Ci	7.37E-02	1.48E-01	1.84E-02	2.72E-02	1.70E+01
2. Average release rate for period	uCi/sec	9.34E-03	1.88E-02	2.33E-03	3.45E-03	
3. Percent of applicable Technical Specification limit	%	4.44E-03	2.40E-03	1.32E-04	7.82E-04	

B. Iodines

1. Total release	Ci	5.38E-07	ND	ND	ND	1.50E+01
2. Average release rate for period	uCi/sec	6.82E-08	N/A	N/A	N/A	
3. Percent of applicable Technical Specification limit	%	3.29E-01	3.29E+00	3.21E-01	2.55E-01	

C. Particulates

1. Total release	Ci	5.83E-08	1.94E-02	ND	ND	1.30E+01
2. Average release rate for period	uCi/sec	7.39E-09	2.46E-03	N/A	N/A	
3. Percent of applicable Technical Specification limit	%	2.35E-03	1.74E-03	4.56E-05	1.68E-04	
4. Total alpha radioactivity	Ci	ND	ND	ND	ND	

D. Tritium

1. Total release	Ci	2.40E+01	2.92E+01	2.37E+01	1.88E+01	1.30E+01
2. Average release rate for period	uCi/sec	3.04E+00	3.70E+00	3.00E+00	2.38E+00	
3. Percent of applicable Technical Specification limit	%	2.35E-03	1.74E-03	4.56E-05	1.68E-04	

TABLE 1B
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT (2005)
GASEOUS EFFLUENTS-ELEVATED RELEASES

BATCH

Nuclides Released	Unit	Quarter 1	Quarter 2	Quarter 3	Quarter 4
-------------------	------	--------------	--------------	--------------	--------------

1. Fission and activation gases

argon-41	Ci	3.72E-02	8.77E-02	3.67E-03	2.66E-02
krypton-85	Ci	ND	ND	1.45E-02	ND
krypton-85m	Ci	ND	1.19E-03	ND	ND
krypton-87	Ci	2.04E-04	ND	ND	ND
krypton-88	Ci	ND	ND	ND	ND
xenon-131m	Ci	ND	ND	ND	ND
xenon-133	Ci	3.80E-03	7.01E-03	ND	4.33E-04
xenon-133m	Ci	ND	ND	ND	ND
xenon-135	Ci	6.82E-04	7.17E-03	2.62E-04	1.71E-04
xenon-135m	Ci	ND	ND	ND	ND
xenon-138	Ci	ND	ND	ND	ND
	Ci				
unidentified	Ci	ND	ND	ND	ND
Total for period	Ci	4.19E-02	1.03E-01	1.84E-02	2.72E-02

2. Iodines

iodine-131	Ci	ND	ND	ND	ND
iodine-133	Ci	ND	ND	ND	ND
iodine-135	Ci	ND	ND	ND	ND
Total for period	Ci	0.00E+00	0.00E+00	0.00E+00	0.00E+00

3. Particulates

strontium-89	Ci	ND	ND	ND	ND
strontium-90	Ci	ND	ND	ND	ND
cesium-134	Ci	ND	ND	ND	ND
cesium-137	Ci	ND	ND	ND	ND
barium-lanthanum-140	Ci	ND	ND	ND	ND
	Ci				
unidentified	Ci	ND	ND	ND	ND
Total for period	Ci	0.00E+00	0.00E+00	0.00E+00	0.00E+00

TABLE 1B
 EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT (2005)
 GASEOUS EFFLUENTS-ELEVATED RELEASES
 CONTINUOUS

Nuclides Released	Unit	Quarter 1	Quarter 2	Quarter 3	Quarter 4
-------------------	------	--------------	--------------	--------------	--------------

1. Fission and activation gases

argon-41	Ci	ND	ND	ND	ND
krypton-85	Ci	ND	ND	ND	ND
krypton-85m	Ci	ND	ND	ND	ND
krypton-87	Ci	ND	ND	ND	ND
krypton-88	Ci	ND	ND	ND	ND
xenon-131m	Ci	ND	ND	ND	ND
xenon-133	Ci	ND	ND	ND	ND
xenon-133m	Ci	ND	ND	ND	ND
xenon-135	Ci	ND	ND	ND	ND
xenon-135m	Ci	ND	ND	ND	ND
xenon-138	Ci	ND	ND	ND	ND
	Ci				
	Ci				
unidentified	Ci	ND	ND	ND	ND
Total for period	Ci	0.00E+00	0.00E+00	0.00E+00	0.00E+00

2. Iodines

iodine-131	Ci	ND	ND	ND	ND
iodine-133	Ci	ND	ND	ND	ND
iodine-135	Ci	ND	ND	ND	ND
Total for period	Ci	0.00E+00	0.00E+00	0.00E+00	0.00E+00

3. Particulates

strontium-89	Ci	ND	ND	ND	ND
strontium-90	Ci	ND	ND	ND	ND
cesium-134	Ci	ND	ND	ND	ND
cesium-137	Ci	ND	ND	ND	ND
barium-lanthanum-140	Ci	ND	ND	ND	ND
cobalt-58	Ci	ND	ND	ND	ND
cobalt-60	Ci	ND	ND	ND	ND
chromium-51	Ci	ND	ND	ND	ND
manganese-54	Ci	ND	ND	ND	ND
niobium-95	Ci	ND	ND	ND	ND
iron-59	Ci	ND	ND	ND	ND
unidentified	Ci	ND	ND	ND	ND
Total for period	Ci	0.00E+00	0.00E+00	0.00E+00	0.00E+00

TABLE 1C
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT (2005)
GASEOUS EFFLUENTS-GROUND LEVEL RELEASES

BATCH

Nuclides Released	Unit	Quarter 1	Quarter 2	Quarter 3	Quarter 4
-------------------	------	--------------	--------------	--------------	--------------

1. Fission and activation gases

argon-41	Ci	3.10E-02	ND	ND	ND
krypton-85	Ci	ND	ND	ND	ND
krypton-85m	Ci	ND	ND	ND	ND
krypton-87	Ci	ND	ND	ND	ND
krypton-88	Ci	ND	ND	ND	ND
xenon-131m	Ci	ND	ND	ND	ND
xenon-133m	Ci	ND	ND	ND	ND
xenon-133	Ci	ND	3.85E-02	ND	ND
xenon-135	Ci	7.88E-04	6.76E-03	ND	ND
xenon-135m	Ci	ND	ND	ND	ND
xenon-138	Ci	ND	ND	ND	ND
	Ci				
	Ci				
unidentified	Ci	ND	ND	ND	ND
Total for period	Ci	3.18E-02	4.53E-02	0.00E+00	0.00E+00

2. Iodines

iodine-131	Ci	7.32E-08	ND	ND	ND
iodine-132	Ci	ND	ND	ND	ND
iodine-133	Ci	4.65E-07	ND	ND	ND
iodine-135	Ci	ND	ND	ND	ND
Total for period	Ci	5.38E-07	0.00E+00	0.00E+00	0.00E+00

3. Particulates

strontium-89	Ci	ND	ND	ND	ND
strontium-90	Ci	ND	ND	ND	ND
cesium-134	Ci	ND	ND	ND	ND
cesium-136	Ci	ND	ND	ND	ND
cesium-137	Ci	ND	ND	ND	ND
barium-lanthanum-140	Ci	ND	ND	ND	ND
cobalt-57	Ci	ND	ND	ND	ND
cobalt-58	Ci	ND	1.94E-02	ND	ND
cobalt-60	Ci	ND	ND	ND	ND
manganese-54	Ci	ND	ND	ND	ND
iron-59	Ci	ND	ND	ND	ND
niobium/zirconium-95	Ci	ND	ND	ND	ND
chromium-51	Ci	ND	ND	ND	ND
technetium-99m	Ci	ND	ND	ND	ND
bromine-82	Ci	ND	ND	ND	ND
unidentified	Ci	ND	ND	ND	ND
Total for period	Ci	0.00E+00	1.94E-02	0.00E+00	0.00E+00

TABLE 1C
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT (2005)
GASEOUS EFFLUENTS-GROUND LEVEL RELEASES
CONTINUOUS

Nuclides Released	Unit	Quarter 1	Quarter 2	Quarter 3	Quarter 4
-------------------	------	--------------	--------------	--------------	--------------

1. Fission and activation gases

argon-41	Ci	ND	ND	ND	ND
krypton-85	Ci	ND	ND	ND	ND
krypton-85m	Ci	ND	ND	ND	ND
krypton-87	Ci	ND	ND	ND	ND
krypton-88	Ci	ND	ND	ND	ND
xenon-133	Ci	ND	ND	ND	ND
xenon-135	Ci	ND	ND	ND	ND
xenon-135m	Ci	ND	ND	ND	ND
xenon-138	Ci	ND	ND	ND	ND
	Ci				
	Ci				
unidentified	Ci	ND	ND	ND	ND
Total for period	Ci	0.00E+00	0.00E+00	0.00E+00	0.00E+00

2. Iodines

iodine-131	Ci	ND	ND	ND	ND
iodine-133	Ci	ND	ND	ND	ND
	Ci				
Total for period	Ci	0.00E+00	0.00E+00	0.00E+00	0.00E+00

3. Particulates

strontium-89	Ci	ND	ND	ND	ND
strontium-90	Ci	ND	ND	ND	ND
cesium-134	Ci	ND	ND	ND	ND
cesium-136	Ci	ND	ND	ND	ND
cesium-137	Ci	7.67E-08	ND	ND	ND
barium-lanthanum-140	Ci	ND	ND	ND	ND
cobalt-58	Ci	5.83E-08	2.39E-07	ND	ND
cobalt-60	Ci	ND	ND	ND	ND
chromium-51	Ci	ND	ND	ND	ND
unidentified	Ci	ND	ND	ND	ND
Total for period	Ci	1.35E-07	2.39E-07	0.00E+00	0.00E+00

TABLE 2A

EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT 2005

LIQUID EFFLUENTS-SUMMATION OF ALL RELEASES

Unit	Quarter 1	Quarter 2	Quarter 3	Quarter 4	Est. Total Error, %
------	-----------	-----------	-----------	-----------	---------------------

A. Fission and activation products

1. Total releases	Ci	1.36E-03	2.39E-02	5.22E-03	2.91E-03	6.00E+00
2. Average diluted concentration during period	uCi/ml	3.50E-12	6.46E-11	1.13E-11	6.27E-12	
3. Percent of applicable limit	%	2.13E-02	7.80E-02	2.83E-03	1.75E-03	

B. Tritium

1. Total release	Ci	9.50E+02	2.83E+02	3.68E+01	3.05E+01	8.00E+00
2. Average diluted concentration during period	uCi/ml	2.44E-06	7.65E-07	7.93E-08	6.57E-08	
3. Percent of applicable limit	%	8.30E-03	5.82E-02	3.46E-03	2.18E-03	

C. Dissolved and entrained gases

1. Total release	Ci	ND	ND	ND	ND	1.90E+01
2. Average diluted concentration during period	uCi/ml	N/A	N/A	N/A	N/A	
3. Percent of applicable limit	%	N/A	N/A	N/A	N/A	

D. Gross alpha radioactivity

1. Total release	Ci	ND	ND	ND	ND	1.00E+01
------------------	----	----	----	----	----	----------

E. Volume of waste released (prior to dilution)	liters	2.46E+07	9.49E+07	1.62E+07	1.72E+07	1.30E+00
F. Volume of dilution water used during period	liters	3.89E+11	3.70E+11	4.64E+11	4.64E+11	9.00E+00

TABLE 2B
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT 2005
LIQUID EFFLUENTS
BATCH MODE

Nuclides Released	Unit	Quarter 1	Quarter 2	Quarter 3	Quarter 4
strontium-89	Ci	ND	ND	ND	ND
strontium-90	Ci	ND	ND	ND	ND
cesium-134	Ci	ND	ND	ND	ND
cesium-137	Ci	1.56E-05	ND	ND	2.64E-05
iodine-131	Ci	ND	ND	ND	ND
iodine-133	Ci	ND	ND	ND	ND
cobalt-57	Ci	ND	ND	1.86E-06	2.11E-05
cobalt-58	Ci	9.32E-05	9.34E-03	2.82E-03	2.22E-03
cobalt-60	Ci	5.79E-05	3.80E-04	1.58E-04	1.16E-04
chromium-51	Ci	ND	2.39E-04	ND	ND
iron-55	Ci	1.17E-03	9.70E-04	1.69E-03	4.83E-04
iron-59	Ci	ND	1.92E-05	ND	ND
zinc-65	Ci	ND	ND	ND	ND
manganese-54	Ci	2.15E-06	1.36E-05	ND	1.73E-05
zirconium-niobium-95	Ci	ND	1.87E-05	ND	ND
molybdenum-99	Ci	ND	ND	ND	ND
technetium-99m	Ci	ND	ND	ND	ND
silver-110m	Ci	ND	ND	ND	ND
barium-lanthanum-140	Ci	ND	ND	ND	ND
cerium-141	Ci	ND	ND	ND	ND
antimony-124	Ci	ND	9.80E-05	ND	ND
antimony-125	Ci	2.95E-05	1.66E-03	5.53E-04	2.57E-05
antimony-126	Ci	ND	ND	ND	ND
niobium-97	Ci	ND	ND	ND	ND
tin-117m	Ci	ND	8.74E-06	ND	ND
sodium-24	Ci	ND	ND	ND	ND
Tellurium-129m	Ci	ND	ND	ND	ND
Tellurium-132	Ci	ND	ND	ND	ND
unidentified	Ci	ND	ND	ND	ND
Total for period(above)	Ci	1.37E-03	1.27E-02	5.22E-03	2.91E-03
xenon-133	Ci	ND	ND	ND	ND
xenon-135	Ci	ND	ND	ND	ND

TABLE 2B
 EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT 2005
 LIQUID EFFLUENTS
 CONTINUOUS MODE

Nuclides Released	Unit	Quarter 1	Quarter 2	Quarter 3	Quarter 4
strontium-89	Ci	ND	ND	ND	ND
strontium-90	Ci	ND	ND	ND	ND
cesium-134	Ci	ND	ND	ND	ND
cesium-137	Ci	ND	ND	ND	ND
iodine-131	Ci	ND	ND	ND	ND
iodine-133	Ci	ND	ND	ND	ND
cobalt-58	Ci	ND	1.12E-02	ND	ND
cobalt-60	Ci	ND	1.37E-06	ND	ND
iron-55	Ci	ND	ND	ND	ND
iron-59	Ci	ND	ND	ND	ND
zinc-65	Ci	ND	ND	ND	ND
manganese-54	Ci	ND	1.32E-06	ND	ND
chromium-51	Ci	ND	ND	ND	ND
zirconium-niobium-95	Ci	ND	ND	ND	ND
molybdenum-99	Ci	ND	ND	ND	ND
technetium-99m	Ci	ND	ND	ND	ND
barium-lanthanum-140	Ci	ND	ND	ND	ND
cerium-141	Ci	ND	ND	ND	ND
unidentified	Ci	ND	ND	ND	ND
Total for period(above)	Ci	0.00E+00	1.12E-02	0.00E+00	0.00E+00
xenon-131m	Ci	ND	ND	ND	ND
xenon-133m	Ci	ND	ND	ND	ND
xenon-133	Ci	ND	ND	ND	ND
xenon-135	Ci	ND	ND	ND	ND

**EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT 2005
SOLID WASTE AND IRRADIATED FUEL SHIPMENTS**

A. SOLID WASTE SHIPPED OFFSITE FOR BURIAL OR DISPOSAL (Not irradiated fuel)

1. Type of waste	Unit	1 year Period	Est. Total Error, %
a. Spent resins, filter sludges, evaporator Bottoms, etc.	m ³ Ci	1.49E+01 1.01E+00	2.50E+01
b. Dry compressible waste, contaminated Equip, etc.	m ³ Ci	6.97E+01 3.10E+00	2.50E+01
c. Irradiated components, control Rods, etc.	m ³ Ci	N/A	N/A
d. Other (describe): Cartridge Filters	m ³ Ci	4.72E+00 3.10E+01	2.50E+01

2. Estimate of major nuclide composition (by type of waste)

a. Fe-55	%	3.27E+01
Ni-63	%	2.19E+01
H-3	%	1.84E+01
Sb-125	%	1.63E+01
Co-60	%	6.63E+00
Co-58	%	2.07E+00
C-14	%	7.94E-01
Cs-137	%	6.42E-01
Mn-54	%	2.09E-01
Cs-134	%	1.79E-01
Co-57	%	1.52E-01

b. Fe-55	%	5.62E+01
Ni-63	%	2.71E+01
Co-60	%	1.22E+01
Co-58	%	1.03E+00
Sb-125	%	8.07E-01
Mn-54	%	7.48E-01
C-14	%	6.85E-01
Cs-137	%	6.66E-01
Cs-134	%	2.28E-01
Sr-90	%	8.91E-02
Co-57	%	7.74E-02
Zr-95	%	3.36E-02
Nb-95	%	2.41E-02
H-3	%	2.25E-02
Ag-110m	%	1.66E-02
Cr-51	%	1.65E-02
Sn-113	%	6.66E-03
Sr-89	%	6.42E-03
Tc-99	%	4.38E-03
I-129	%	3.32E-03
Zn-65	%	2.25E-03

c.	N/A	%	N/A
d.	Fe-55	%	5.34E+01
	Ni-63	%	3.19E+01
	Co-60	%	1.07E+01
	H-3	%	1.79E+00
	Mn-54	%	8.42E-01
	Co-58	%	6.94E-01
	Cs-137	%	2.45E-01
	Co-57	%	1.92E-01
	Sb-125	%	1.82E-01
	Zr-95	%	1.14E-02
	Cs-134	%	1.12E-02
	Sn-113	%	6.83E-03
	Zn-65	%	4.44E-03
	Be-7	%	4.30E-03
	Nb-95	%	4.29E-03
	Pu-241	%	3.20E-03
	Sr-90	%	2.53E-03
	Ce-144	%	1.24E-03

3. Solid Waste Disposition

Number of Shipments	Waste Class	Container Type	Solidification Agent	Mode of Transportation	Destination
5	A	General Design	N/A	Truck	Duratek, Kingston, TN
3	A	General Design	N/A	Truck	Duratek, Oak Ridge, TN
1	B	General Design	N/A	Truck	Duratek, Oak Ridge, TN
1	B	General Design	N/A	Truck	CNS, Barnwell, SC
1	C	General Design	N/A	Truck	CNS, Barnwell, SC
1	A	General Design	N/A	Truck	ALARON, Wampum, PA
1	A	General Design	N/A	Truck	RACE, Memphis, TN

B. IRRADIATED FUEL SHIPMENTS (Disposition)

Number of Shipments	Mode of Transportation	Destination
N/A	N/A	N/A

C. REVIEW AND APPROVAL

Prepared By: Fred Hart Date: 3/29/2006
 Reviewed By: B. Cox Date: 3-30-06
 Approved By: W. O. Coleman Date: 04-21-2006

LIST OF APPENDICES

<u>Appendix</u>	<u>Title</u>
A	Offsite Dose Calculation Manual
B	Process Control Program
C	Liquid Holdup Tanks
D	Radwaste Treatment Systems
E	Unplanned Releases

Appendix A

Offsite Dose Calculation Manual

Requirement: Technical Specification 6.13.2c requires that licensee initiated changes to the Offsite Dose Calculation Manual be submitted to the Commission in the Annual Radioactive Effluent Release Report for the period in which the change(s) was made effective. Include in this changes to the Radiological Environmental Program in accordance with Offsite Dose Calculation Manual (ODCM)-C.9.1.1 and -C.9.2.1.

Response: The ODCM was changed in 2005.

The Change incorporated the following items:

1. Incorporated a provision that permits applying a 25% extension to the frequency of surveillance requirements and
2. Eliminated the reporting requirements for effluent monitoring instrumentation that are inoperable for more than 30 days and replaced with guidance to restore the inoperable instrumentation to Operable status within a time period determined by an evaluation conducted in accordance with the requirements of the Corrective Action Program. The evaluation is not required if the noncompliance is a consequence of surveillance testing or planned maintenance.

Appendix B

Process Control Program

Requirement: Technical Specification 6.12.2a requires that licensee initiated changes to the Process Control Program be submitted to the Commission in the Annual Radioactive Effluent Release Report for the period in which the change(s) was made.

Response: No changes were made to the process control program in 2005.

Appendix C

Liquid Holdup Tanks

Requirement: Technical Specification 3.11.1.4 limits the quantity of radioactive material contained in any outside temporary tank. With the quantity of radioactive material in any outside temporary tank exceeding the limits of Technical Specification 3.11.1.4, a description of the events leading to this condition is required in the next Annual Effluent Release Report in accordance with Tech. Spec. 6.8.1.4.

Response: From January 1, 2005 to December 31, 2005, there was no radioactive material stored in any temporary outdoor tank that exceeded the limits of T. S. 3.11.1.4.

Appendix D

Radwaste Treatment Systems

Requirement: Technical Specification 6.14.1a requires that licensee initiated changes to the Radwaste Treatment Systems (liquid, gaseous, and solid) be submitted to the Commission in the Annual Radioactive Effluent Release Report for the period in which the change was made.

Response: For 2005, FPL Energy Seabrook LLC, will submit any changes to the Radwaste Treatment Systems (liquid, gaseous and solid) as part of the FSAR update.

Appendix E

Unplanned Releases

Requirement: Technical Specification 6.8.1.4 requires a list and description of unplanned releases from the site to UNRESTRICTED AREAS of radioactive materials in gaseous and liquid effluents made during the reporting period.

Response: A review of the January 1, 2005 to December 31, 2005 time period indicated there were no unplanned, unanticipated or abnormal releases from the site to unrestricted areas of radioactive materials of gaseous or liquid effluents.

ENCLOSURE 2 TO SBK-L-06101

**Joint Frequency Distributions of Wind Speed,
Wind Direction and Atmospheric Stability**

SEABROOK JAN05-DEC05 MET DATA JOINT FREQUENCY DISTRIBUTION (210-FOOT TOWER)

43.0 FT WIND DATA STABILITY CLASS A CLASS FREQUENCY (PERCENT) = .89

WIND DIRECTION FROM

SPEED MPH	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	VRBL	TOTAL
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
C-3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
4-7	0	1	0	0	1	0	2	0	0	0	0	0	1	1	0	0	0	6
(1)	.00	1.30	.00	.00	1.30	.00	2.60	.00	.00	.00	.00	.00	1.30	1.30	.00	.00	.00	7.79
(2)	.00	.01	.00	.00	.01	.00	.02	.00	.00	.00	.00	.00	.01	.01	.00	.00	.00	.07
8-12	0	0	1	0	1	5	36	4	0	0	3	2	3	2	0	0	0	57
(1)	.00	.00	1.30	.00	1.30	6.49	46.75	5.19	.00	.00	3.90	2.60	3.90	2.60	.00	.00	.00	74.03
(2)	.00	.00	.01	.00	.01	.06	.42	.05	.00	.00	.03	.02	.03	.02	.00	.00	.00	.66
13-18	0	0	0	0	0	0	6	0	0	0	3	1	0	1	2	1	0	14
(1)	.00	.00	.00	.00	.00	.00	7.79	.00	.00	.00	3.90	1.30	.00	1.30	2.60	1.30	.00	18.18
(2)	.00	.00	.00	.00	.00	.00	.07	.00	.00	.00	.03	.01	.00	.01	.02	.01	.00	.16
19-24	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
GT 24	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
ALL SPEEDS	0	1	1	0	2	5	44	4	0	0	6	3	4	4	2	1	0	77
(1)	.00	1.30	1.30	.00	2.60	6.49	57.14	5.19	.00	.00	7.79	3.90	5.19	5.19	2.60	1.30	.00	100.00
(2)	.00	.01	.01	.00	.02	.06	.51	.05	.00	.00	.07	.03	.05	.05	.02	.01	.00	.89

(1) = PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD
 (2) = PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE
 C = CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

SEABROOK JAN05-DEC05 MET DATA JOINT FREQUENCY DISTRIBUTION (210-FOOT TOWER)

43.0 FT WIND DATA STABILITY CLASS B CLASS FREQUENCY (PERCENT) = 1.46

WIND DIRECTION FROM

SPEED MPH	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	VRBL	TOTAL
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
C-3	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
(1)	.00	.00	.79	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.79
(2)	.00	.00	.01	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.01
4-7	0	0	0	0	2	2	6	0	0	0	1	0	0	0	0	0	0	0
(1)	.00	.00	.00	.00	1.57	1.57	4.72	.00	.00	.00	.79	.00	.00	.00	.00	.00	.00	8.66
(2)	.00	.00	.00	.00	.02	.02	.07	.00	.00	.00	.01	.00	.00	.00	.00	.00	.00	.13
8-12	1	1	0	5	3	6	36	6	0	5	6	6	9	5	4	0	0	0
(1)	.79	.79	.00	3.94	2.36	4.72	28.35	4.72	.00	3.94	4.72	4.72	7.09	3.94	3.15	.00	.00	73.23
(2)	.01	.01	.00	.06	.03	.07	.42	.07	.00	.06	.07	.07	.10	.06	.05	.00	.00	1.07
13-18	0	0	0	0	3	0	1	0	0	1	6	2	3	1	4	0	0	0
(1)	.00	.00	.00	.00	2.36	.00	.79	.00	.00	.79	4.72	1.57	2.36	.79	3.15	.00	.00	16.54
(2)	.00	.00	.00	.00	.03	.00	.01	.00	.00	.01	.07	.02	.03	.01	.05	.00	.00	.24
19-24	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
GT 24	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
(1)	.00	.00	.79	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.79
(2)	.00	.00	.01	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.01
ALL SPEEDS	1	1	2	5	8	8	43	6	0	6	13	8	12	6	8	0	0	127
(1)	.79	.79	1.57	3.94	6.30	6.30	33.86	4.72	.00	4.72	10.24	6.30	9.45	4.72	6.30	.00	.00	100.00
(2)	.01	.01	.02	.06	.09	.09	.50	.07	.00	.07	.15	.09	.14	.07	.09	.00	.00	1.46

(1) = PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE
 (2) = PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD
 C = CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

SEABROOK JAN05-DEC05 MET DATA JOINT FREQUENCY DISTRIBUTION (210-FOOT TOWER)

43.0 FT WIND DATA STABILITY CLASS C CLASS FREQUENCY (PERCENT) = 4.65

WIND DIRECTION FROM

SPEED MPH	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	VRBL	TOTAL
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
C-3	0	1	0	0	0	1	0	0	1	0	0	0	0	0	0	0	0	3
(1)	.00	.25	.00	.00	.00	.25	.00	.00	.25	.00	.00	.00	.00	.00	.00	.00	.00	.74
(2)	.00	.01	.00	.00	.00	.01	.00	.00	.01	.00	.00	.00	.00	.00	.00	.00	.00	.03
4-7	1	6	2	3	3	2	6	4	0	1	5	5	4	9	4	1	0	56
(1)	.25	1.49	.50	.74	.74	.50	1.49	.99	.00	.25	1.24	1.24	.99	2.23	.99	.25	.00	13.90
(2)	.01	.07	.02	.03	.03	.02	.07	.05	.00	.01	.06	.06	.05	.10	.05	.01	.00	.65
8-12	2	3	5	20	35	13	38	11	3	8	22	34	33	26	16	5	0	274
(1)	.50	.74	1.24	4.96	8.68	3.23	9.43	2.73	.74	1.99	5.46	8.44	8.19	6.45	3.97	1.24	.00	67.99
(2)	.02	.03	.06	.23	.40	.15	.44	.13	.03	.09	.25	.39	.38	.30	.18	.06	.00	3.16
13-18	0	0	5	3	5	1	2	2	0	2	11	8	9	10	9	1	0	68
(1)	.00	.00	1.24	.74	1.24	.25	.50	.50	.00	.50	2.73	1.99	2.23	2.48	2.23	.25	.00	16.87
(2)	.00	.00	.06	.03	.06	.01	.02	.02	.00	.02	.13	.09	.10	.12	.10	.01	.00	.78
19-24	0	0	0	0	0	0	0	0	0	0	0	0	1	1	0	0	0	2
(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.25	.25	.00	.00	.00	.50
(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.01	.01	.00	.00	.00	.02
GT 24	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
ALL SPEEDS	3	10	12	26	43	17	46	17	4	11	38	47	47	46	29	7	0	403
(1)	.74	2.48	2.98	6.45	10.67	4.22	11.41	4.22	.99	2.73	9.43	11.66	11.66	11.41	7.20	1.74	.00	100.00
(2)	.03	.12	.14	.30	.50	.20	.53	.20	.05	.13	.44	.54	.54	.53	.33	.08	.00	4.65

(1)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE
 (2)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD
 C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

SEABROOK JAN05-DEC05 MET DATA JOINT FREQUENCY DISTRIBUTION (210-FOOT TOWER)

43.0 FT WIND DATA STABILITY CLASS D CLASS FREQUENCY (PERCENT) = 49.09
 WIND DIRECTION FROM

SPEED MPH	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	VNW	NW	NNW	VRBL	TOTAL
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
C-3	29	15	15	17	16	10	4	10	15	13	11	18	19	21	27	26	0	266
(1)	.68	.35	.35	.40	.38	.23	.09	.23	.35	.31	.26	.42	.45	.49	.63	.61	.00	6.25
(2)	.33	.17	.17	.20	.18	.12	.05	.12	.17	.15	.13	.21	.22	.24	.31	.30	.00	3.07
4-7	128	83	82	92	119	52	92	53	63	78	90	105	130	126	134	131	0	1558
(1)	3.01	1.95	1.93	2.16	2.80	1.22	2.16	1.25	1.48	1.83	2.11	2.47	3.05	2.96	3.15	3.08	.00	36.60
(2)	1.48	.96	.95	1.06	1.37	.60	1.06	.61	.73	.90	1.04	1.21	1.50	1.45	1.55	1.51	.00	17.97
8-12	78	39	151	102	138	82	67	36	17	57	156	141	113	292	204	89	0	1762
(1)	1.83	.92	3.55	2.40	3.24	1.93	1.57	.85	.40	1.34	3.66	3.31	2.65	6.86	4.79	2.09	.00	41.39
(2)	.90	.45	1.74	1.18	1.59	.95	.77	.42	.20	.66	1.80	1.63	1.30	3.37	2.35	1.03	.00	20.32
13-18	32	26	91	38	25	10	4	2	10	19	15	17	31	138	81	8	0	547
(1)	.75	.61	2.14	.89	.59	.23	.09	.05	.23	.45	.35	.40	.73	3.24	1.90	.19	.00	12.85
(2)	.37	.30	1.05	.44	.29	.12	.05	.02	.12	.22	.17	.20	.36	1.59	.93	.09	.00	6.31
19-24	0	3	44	8	13	3	0	0	0	2	2	1	3	11	5	0	0	95
(1)	.00	.07	1.03	.19	.31	.07	.00	.00	.00	.05	.05	.02	.07	.26	.12	.00	.00	2.23
(2)	.00	.03	.51	.09	.15	.03	.00	.00	.00	.02	.02	.01	.03	.13	.06	.00	.00	1.10
GT 24	0	0	19	0	9	0	0	0	0	0	0	0	0	0	1	0	0	29
(1)	.00	.00	.45	.00	.21	.00	.00	.00	.00	.00	.00	.00	.00	.00	.02	.00	.00	.68
(2)	.00	.00	.22	.00	.10	.00	.00	.00	.00	.00	.00	.00	.00	.00	.01	.00	.00	.33
ALL SPEEDS	267	166	402	257	320	157	167	101	105	169	274	282	296	588	452	254	0	4257
(1)	6.27	3.90	9.44	6.04	7.52	3.69	3.92	2.37	2.47	3.97	6.44	6.62	6.95	13.81	10.62	5.97	.00	100.00
(2)	3.08	1.91	4.64	2.96	3.69	1.81	1.93	1.16	1.21	1.95	3.16	3.25	3.41	6.78	5.21	2.93	.00	49.09

(1)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE
 (2)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD
 C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

SEABROOK JAN05-DEC05 MET DATA JOINT FREQUENCY DISTRIBUTION (210-FOOT TOWER)

43.0 FT WIND DATA STABILITY CLASS E CLASS FREQUENCY (PERCENT) = 28.99

WIND DIRECTION FROM

SPEED MPH	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	VRBL	TOTAL
CALM	0	0	0	0	0	0	0	0	0	0	1	0	1	1	3	0	0	6
(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.04	.00	.04	.04	.12	.00	.00	.24
(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.01	.00	.01	.01	.03	.00	.00	.07
C-3	19	26	16	20	22	11	21	19	32	34	48	50	75	50	57	26	0	526
(1)	.76	1.03	.64	.80	.88	.44	.84	.76	1.27	1.35	1.91	1.99	2.98	1.99	2.27	1.03	.00	20.92
(2)	.22	.30	.18	.23	.25	.13	.24	.22	.37	.39	.55	.58	.86	.58	.66	.30	.00	6.07
4-7	30	14	21	41	43	26	74	59	63	49	150	294	210	206	109	49	0	1438
(1)	1.19	.56	.84	1.63	1.71	1.03	2.94	2.35	2.51	1.95	5.97	11.69	8.35	8.19	4.34	1.95	.00	57.20
(2)	.35	.16	.24	.47	.50	.30	.85	.68	.73	.57	1.73	3.39	2.42	2.38	1.26	.57	.00	16.58
8-12	6	5	27	29	21	7	14	26	7	21	55	91	41	70	21	9	0	450
(1)	.24	.20	1.07	1.15	.84	.28	.56	1.03	.28	.84	2.19	3.62	1.63	2.78	.84	.36	.00	17.90
(2)	.07	.06	.31	.33	.24	.08	.16	.30	.08	.24	.63	1.05	.47	.81	.24	.10	.00	5.19
13-18	0	0	16	19	5	3	2	3	0	13	7	4	0	5	4	1	0	82
(1)	.00	.00	.64	.76	.20	.12	.08	.12	.00	.52	.28	.16	.00	.20	.16	.04	.00	3.26
(2)	.00	.00	.18	.22	.06	.03	.02	.03	.00	.15	.08	.05	.00	.06	.05	.01	.00	.95
19-24	0	0	3	2	4	1	0	0	0	1	0	0	0	0	0	0	0	11
(1)	.00	.00	.12	.08	.16	.04	.00	.00	.00	.04	.00	.00	.00	.00	.00	.00	.00	.44
(2)	.00	.00	.03	.02	.05	.01	.00	.00	.00	.01	.00	.00	.00	.00	.00	.00	.00	.13
GT 24	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1
(1)	.00	.00	.04	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.04
(2)	.00	.00	.01	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.01
ALL SPEEDS	55	45	84	111	95	48	111	107	102	118	261	439	327	332	194	85	0	2514
(1)	2.19	1.79	3.34	4.42	3.78	1.91	4.42	4.26	4.06	4.69	10.38	17.46	13.01	13.21	7.72	3.38	.00	100.00
(2)	.63	.52	.97	1.28	1.10	.55	1.28	1.23	1.18	1.36	3.01	5.06	3.77	3.83	2.24	.98	.00	28.99

(1) = PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE
 (2) = PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD
 C = CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

SEABROOK JAN05-DEC05 MET DATA JOINT FREQUENCY DISTRIBUTION (210-FOOT TOWER)

43.0 FT WIND DATA STABILITY CLASS F CLASS FREQUENCY (PERCENT) = 8.86

WIND DIRECTION FROM

SPEED MPH	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	VRBL	TOTAL
CALM	0	2	3	0	0	0	0	0	0	0	2	1	6	0	0	2	0	16
(1)	.00	.26	.39	.00	.00	.00	.00	.00	.00	.00	.26	.13	.78	.00	.00	.26	.00	2.08
(2)	.00	.02	.03	.00	.00	.00	.00	.00	.00	.00	.02	.01	.07	.00	.00	.02	.00	.18
C-3	22	7	15	20	10	8	7	8	5	12	46	45	68	65	46	19	0	403
(1)	2.86	.91	1.95	2.60	1.30	1.04	.91	1.04	.65	1.56	5.99	5.86	8.85	8.46	5.99	2.47	.00	52.47
(2)	.25	.08	.17	.23	.12	.09	.08	.09	.06	.14	.53	.52	.78	.75	.53	.22	.00	4.65
4-7	7	2	1	3	7	7	6	5	1	12	23	72	56	60	63	16	0	341
(1)	.91	.26	.13	.39	.91	.91	.78	.65	.13	1.56	2.99	9.38	7.29	7.81	8.20	2.08	.00	44.40
(2)	.08	.02	.01	.03	.08	.08	.07	.06	.01	.14	.27	.83	.65	.69	.73	.18	.00	3.93
8-12	0	0	0	0	1	0	1	0	0	0	0	0	0	2	3	0	0	7
(1)	.00	.00	.00	.00	.13	.00	.13	.00	.00	.00	.00	.00	.00	.26	.39	.00	.00	.91
(2)	.00	.00	.00	.00	.01	.00	.01	.00	.00	.00	.00	.00	.00	.02	.03	.00	.00	.08
13-18	0	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1
(1)	.00	.13	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.13
(2)	.00	.01	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.01
19-24	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
GT 24	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
ALL SPEEDS	29	12	19	23	18	15	14	13	6	24	71	118	130	127	112	37	0	768
(1)	3.78	1.56	2.47	2.99	2.34	1.95	1.82	1.69	.78	3.13	9.24	15.36	16.93	16.54	14.58	4.82	.00	100.00
(2)	.33	.14	.22	.27	.21	.17	.16	.15	.07	.28	.82	1.36	1.50	1.46	1.29	.43	.00	8.86

(1)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE
 (2)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD
 C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

SEABROOK JPN05-DEC05 MET DATA JOINT FREQUENCY DISTRIBUTION (210-FOOT TOWER)

43.0 FT WIND DATA STABILITY CLASS G CLASS FREQUENCY (PERCENT) = 6.05

WIND DIRECTION FROM

SPEED MPH	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	VRBL	TOTAL
CALM	0	0	0	1	0	0	0	0	0	0	0	3	0	1	3	1	0	9
(1)	.00	.00	.00	.19	.00	.00	.00	.00	.00	.00	.00	.57	.00	.19	.57	.19	.00	1.71
(2)	.00	.00	.00	.01	.00	.00	.00	.00	.00	.00	.00	.03	.00	.01	.03	.01	.00	.10
C-3	7	4	6	8	4	2	2	2	0	8	23	63	118	121	34	15	0	417
(1)	1.33	.76	1.14	1.52	.76	.38	.38	.38	.00	1.52	4.38	12.00	22.48	23.05	6.48	2.86	.00	79.43
(2)	.08	.05	.07	.09	.05	.02	.02	.02	.00	.09	.27	.73	1.36	1.40	.39	.17	.00	4.81
4-7	1	0	0	0	2	0	0	0	1	0	3	10	12	41	27	2	0	99
(1)	.19	.00	.00	.00	.38	.00	.00	.00	.19	.00	.57	1.90	2.29	7.81	5.14	.38	.00	18.86
(2)	.01	.00	.00	.00	.02	.00	.00	.00	.01	.00	.03	.12	.14	.47	.31	.02	.00	1.14
8-12	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
13-18	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
19-24	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
GT 24	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
ALL SPEEDS	8	4	6	9	6	2	2	2	1	8	26	76	130	163	64	18	0	525
(1)	1.52	.76	1.14	1.71	1.14	.38	.38	.38	.19	1.52	4.95	14.48	24.76	31.05	12.19	3.43	.00	100.00
(2)	.09	.05	.07	.10	.07	.02	.02	.02	.01	.09	.30	.88	1.50	1.88	.74	.21	.00	6.05

(1)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE
 (2)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD
 C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

SEABROOK JAN05-DEC05 MET DATA JOINT FREQUENCY DISTRIBUTION (210-FOOT TOWER)

43.0 FT WIND DATA STABILITY CLASS ALL CLASS FREQUENCY (PERCENT) = 100.00

WIND DIRECTION FROM

SPEED MPH	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	VRBL	TOTAL
CALM	0	2	3	1	0	0	0	0	0	0	3	4	7	2	6	3	0	31
(1)	.00	.02	.03	.01	.00	.00	.00	.00	.00	.00	.03	.05	.08	.02	.07	.03	.00	.36
(2)	.00	.02	.03	.01	.00	.00	.00	.00	.00	.00	.03	.05	.08	.02	.07	.03	.00	.36
C-3	77	53	53	65	52	32	34	39	53	67	128	176	280	257	164	86	0	1616
(1)	.89	.61	.61	.75	.60	.37	.39	.45	.61	.77	1.48	2.03	3.23	2.96	1.89	.99	.00	18.64
(2)	.89	.61	.61	.75	.60	.37	.39	.45	.61	.77	1.48	2.03	3.23	2.96	1.89	.99	.00	18.64
4-7	167	106	106	139	177	89	186	121	128	140	272	486	413	443	337	199	0	3509
(1)	1.93	1.22	1.22	1.60	2.04	1.03	2.15	1.40	1.48	1.61	3.14	5.60	4.76	5.11	3.89	2.30	.00	40.47
(2)	1.93	1.22	1.22	1.60	2.04	1.03	2.15	1.40	1.48	1.61	3.14	5.60	4.76	5.11	3.89	2.30	.00	40.47
8-12	87	48	184	156	199	113	192	83	27	91	242	274	199	397	248	103	0	2643
(1)	1.00	.55	2.12	1.80	2.30	1.30	2.21	.96	.31	1.05	2.79	3.16	2.30	4.58	2.86	1.19	.00	30.48
(2)	1.00	.55	2.12	1.80	2.30	1.30	2.21	.96	.31	1.05	2.79	3.16	2.30	4.58	2.86	1.19	.00	30.48
13-18	32	27	112	60	38	14	15	7	10	35	42	32	43	155	100	11	0	733
(1)	.37	.31	1.29	.69	.44	.16	.17	.08	.12	.40	.48	.37	.50	1.79	1.15	.13	.00	8.45
(2)	.37	.31	1.29	.69	.44	.16	.17	.08	.12	.40	.48	.37	.50	1.79	1.15	.13	.00	8.45
19-24	0	3	47	10	17	4	0	0	0	3	2	1	4	12	5	0	0	108
(1)	.00	.03	.54	.12	.20	.05	.00	.00	.00	.03	.02	.01	.05	.14	.06	.00	.00	1.25
(2)	.00	.03	.54	.12	.20	.05	.00	.00	.00	.03	.02	.01	.05	.14	.06	.00	.00	1.25
GT 24	0	0	21	0	9	0	0	0	0	0	0	0	0	0	1	0	0	31
(1)	.00	.00	.24	.00	.10	.00	.00	.00	.00	.00	.00	.00	.00	.00	.01	.00	.00	.36
(2)	.00	.00	.24	.00	.10	.00	.00	.00	.00	.00	.00	.00	.00	.00	.01	.00	.00	.36
ALL SPEEDS	353	239	526	431	492	252	427	250	218	336	689	973	946	1266	861	402	0	8671
(1)	4.19	2.76	6.07	4.97	5.67	2.91	4.92	2.88	2.51	3.87	7.95	11.22	10.91	14.60	9.93	4.64	.00	100.00
(2)	4.19	2.76	6.07	4.97	5.67	2.91	4.92	2.88	2.51	3.87	7.95	11.22	10.91	14.60	9.93	4.64	.00	100.00

(1)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE
 (2)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD
 C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

SEABROOK JAN05-DEC05 MET DATA JOINT FREQUENCY DISTRIBUTION (210-FOOT TOWER)

209.0 FT WIND DATA STABILITY CLASS A CLASS FREQUENCY (PERCENT) = .88

WIND DIRECTION FROM

SPEED MPH	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	VRBL	TOTAL
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
(1)	.30	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
(2)	.30	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
C-3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
(1)	.30	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
(2)	.30	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
4-7	0	0	0	0	0	1	0	0	0	0	0	0	1	1	0	0	0	3
(1)	.00	.00	.00	.00	.00	1.37	.00	.00	.00	.00	.00	.00	1.37	1.37	.00	.00	.00	4.11
(2)	.00	.00	.00	.00	.00	.01	.00	.00	.00	.00	.00	.00	.01	.01	.00	.00	.00	.04
8-12	0	1	1	0	1	0	15	0	0	0	2	0	0	1	0	0	0	21
(1)	.00	1.37	1.37	.00	1.37	.00	20.55	.00	.00	.00	2.74	.00	.00	1.37	.00	.00	.00	28.77
(2)	.00	.01	.01	.00	.01	.00	.18	.00	.00	.00	.02	.00	.00	.01	.00	.00	.00	.25
13-18	1	0	0	0	0	0	24	9	0	0	2	3	1	2	0	1	0	43
(1)	1.37	.00	.00	.00	.00	.00	32.88	12.33	.00	.00	2.74	4.11	1.37	2.74	.00	1.37	.00	58.90
(2)	.01	.00	.00	.00	.00	.00	.29	.11	.00	.00	.02	.04	.01	.02	.00	.01	.00	.52
19-24	0	0	0	0	0	0	4	0	0	0	0	0	0	1	1	0	0	6
(1)	.00	.00	.00	.00	.00	.00	5.48	.00	.00	.00	.00	.00	.00	1.37	1.37	.00	.00	8.22
(2)	.00	.00	.00	.00	.00	.00	.05	.00	.00	.00	.00	.00	.00	.01	.01	.00	.00	.07
GT 24	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
ALL SPEEDS	1	1	1	0	1	1	43	9	0	0	4	3	2	5	1	1	0	73
(1)	1.37	1.37	1.37	.00	1.37	1.37	58.90	12.33	.00	.00	5.48	4.11	2.74	6.85	1.37	1.37	.00	100.00
(2)	.01	.01	.01	.00	.01	.01	.52	.11	.00	.00	.05	.04	.02	.06	.01	.01	.00	.88

(1)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE
 (2)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD
 C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

SEABROOK JAN05-DEC05 MET DATA JOINT FREQUENCY DISTRIBUTION (210-FOOT TOWER)

209.0 FT WIND DATA STABILITY CLASS B CLASS FREQUENCY (PERCENT) = 1.43

WIND DIRECTION FROM

SPEED MPH	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	VRBL	TOTAL
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
C-3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
4-7	0	1	0	0	0	3	1	0	0	0	0	0	0	0	0	0	0	5
(1)	.00	.84	.00	.00	.00	2.52	.84	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	4.20
(2)	.00	.01	.00	.00	.00	.04	.01	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.06
8-12	0	1	0	2	1	5	20	2	0	3	2	1	4	1	1	0	0	43
(1)	.00	.84	.00	1.68	.84	4.20	16.81	1.68	.00	2.52	1.68	.84	3.36	.84	.84	.00	.00	36.13
(2)	.00	.01	.00	.02	.01	.06	.24	.02	.00	.04	.02	.01	.05	.01	.01	.00	.00	.52
13-18	1	0	0	3	3	1	11	10	0	2	6	8	7	4	6	0	0	62
(1)	.84	.00	.00	2.52	2.52	.84	9.24	8.40	.00	1.68	5.04	6.72	5.88	3.36	5.04	.00	.00	52.10
(2)	.01	.00	.00	.04	.04	.01	.13	.12	.00	.02	.07	.10	.08	.05	.07	.00	.00	.74
19-24	0	0	0	0	0	0	0	1	0	0	0	2	0	1	0	1	0	5
(1)	.00	.00	.00	.00	.00	.00	.00	.84	.00	.00	.00	1.68	.00	.84	.00	.84	.00	4.20
(2)	.00	.00	.00	.00	.00	.00	.00	.01	.00	.00	.00	.02	.00	.01	.00	.01	.00	.06
GT 24	0	0	1	0	0	0	0	0	0	0	0	0	3	0	0	0	0	4
(1)	.00	.00	.84	.00	.00	.00	.00	.00	.00	.00	.00	.00	2.52	.00	.00	.00	.00	3.36
(2)	.00	.00	.01	.00	.00	.00	.00	.00	.00	.00	.00	.00	.04	.00	.00	.00	.00	.05
ALL SPEEDS	1	2	1	5	4	9	32	13	0	5	8	11	14	6	7	1	0	119
(1)	.84	1.68	.84	4.20	3.36	7.56	26.89	10.92	.00	4.20	6.72	9.24	11.76	5.04	5.88	.84	.00	100.00
(2)	.01	.02	.01	.06	.05	.11	.38	.16	.00	.06	.10	.13	.17	.07	.08	.01	.00	1.43

(1)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE
 (2)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD
 C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

SEABROOK JAN05-DEC05 MET DATA JOINT FREQUENCY DISTRIBUTION (210-FOOT TOWER)

209.0 FT WIND DATA STABILITY CLASS C CLASS FREQUENCY (PERCENT) = 4.53

WIND DIRECTION FROM

SPEED MPH	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	VRBL	TOTAL
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
C-3	0	0	1	0	1	0	0	0	0	0	1	0	0	0	0	0	0	3
(1)	.00	.00	.27	.00	.27	.00	.00	.00	.00	.00	.27	.00	.00	.00	.00	.00	.00	.80
(2)	.00	.00	.01	.00	.01	.00	.00	.00	.00	.00	.01	.00	.00	.00	.00	.00	.00	.04
4-7	1	2	1	3	1	2	3	1	0	0	1	1	0	0	1	0	0	17
(1)	.27	.53	.27	.80	.27	.53	.80	.27	.00	.00	.27	.27	.00	.00	.27	.00	.00	4.51
(2)	.01	.02	.01	.04	.01	.02	.04	.01	.00	.00	.01	.01	.00	.00	.01	.00	.00	.20
8-12	5	1	3	13	30	8	25	9	2	3	7	13	16	15	4	1	0	155
(1)	1.33	.27	.80	3.45	7.96	2.12	6.63	2.39	.53	.80	1.86	3.45	4.24	3.98	1.06	.27	.00	41.11
(2)	.06	.01	.04	.16	.36	.10	.30	.11	.02	.04	.08	.16	.19	.18	.05	.01	.00	1.86
13-18	1	4	7	7	2	4	11	16	1	2	18	18	25	25	11	3	0	155
(1)	.27	1.06	1.86	1.86	.53	1.06	2.92	4.24	.27	.53	4.77	4.77	6.63	6.63	2.92	.80	.00	41.11
(2)	.01	.05	.08	.08	.02	.05	.13	.19	.01	.02	.22	.22	.30	.30	.13	.04	.00	1.86
19-24	0	0	2	1	0	0	1	1	1	2	3	8	11	9	4	1	0	44
(1)	.00	.00	.53	.27	.00	.00	.27	.27	.27	.53	.80	2.12	2.92	2.39	1.06	.27	.00	11.67
(2)	.00	.00	.02	.01	.00	.00	.01	.01	.01	.02	.04	.10	.13	.11	.05	.01	.00	.53
GT 24	0	0	0	0	0	0	0	0	0	0	0	0	1	2	0	0	0	3
(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.27	.53	.00	.00	.00	.80
(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.01	.02	.00	.00	.00	.04
ALL SPEEDS	7	7	14	24	34	14	40	27	4	7	30	40	53	51	20	5	0	377
(1)	1.86	1.86	3.71	6.37	9.02	3.71	10.61	7.16	1.06	1.86	7.96	10.61	14.06	13.53	5.31	1.33	.00	100.00
(2)	.08	.08	.17	.29	.41	.17	.48	.32	.05	.08	.36	.48	.64	.61	.24	.06	.00	4.53

(1)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE
 (2)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD
 C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

SEABROOK JAN05-DEC05 MET DATA JOINT FREQUENCY DISTRIBUTION (210-FOOT TOWER)

209.0 FT WIND DATA STABILITY CLASS D CLASS FREQUENCY (PERCENT) = 49.27

WIND DIRECTION FROM

SPEED MPH	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	VRBL	TOTAL
CALM	0	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	1
(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.02	.00	.00	.00	.00	.00	.00	.02
(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.01	.00	.00	.00	.00	.00	.00	.01
C-3	7	1	11	14	5	8	3	5	5	2	9	4	1	4	13	5	0	97
(1)	.17	.02	.27	.34	.12	.20	.07	.12	.12	.05	.22	.10	.02	.10	.32	.12	.00	2.37
(2)	.08	.01	.13	.17	.06	.10	.04	.06	.06	.02	.11	.05	.01	.05	.16	.06	.00	1.17
4-7	69	45	37	62	68	56	50	24	24	25	34	36	45	35	46	63	0	719
(1)	1.68	1.10	.90	1.51	1.66	1.37	1.22	.59	.59	.61	.83	.88	1.10	.85	1.12	1.54	.00	17.53
(2)	.83	.54	.44	.74	.82	.67	.60	.29	.29	.30	.41	.43	.54	.42	.55	.76	.00	8.64
8-12	134	81	103	115	81	85	89	46	45	68	110	119	111	124	143	90	0	1544
(1)	3.27	1.98	2.51	2.80	1.98	2.07	2.17	1.12	1.10	1.66	2.68	2.90	2.71	3.02	3.49	2.19	.00	37.65
(2)	1.61	.97	1.24	1.38	.97	1.02	1.07	.55	.54	.82	1.32	1.43	1.33	1.49	1.72	1.08	.00	18.55
13-18	87	48	108	34	20	17	29	35	27	34	91	90	93	238	144	59	0	1154
(1)	2.12	1.17	2.63	.83	.49	.41	.71	.85	.66	.83	2.22	2.19	2.27	5.80	3.51	1.44	.00	28.14
(2)	1.05	.58	1.30	.41	.24	.20	.35	.42	.32	.41	1.09	1.08	1.12	2.86	1.73	.71	.00	13.87
19-24	34	22	51	27	26	9	7	1	5	7	4	11	23	109	60	4	0	400
(1)	.83	.54	1.24	.66	.63	.22	.17	.02	.12	.17	.10	.27	.56	2.66	1.46	.10	.00	9.75
(2)	.41	.26	.61	.32	.31	.11	.08	.01	.06	.08	.05	.13	.28	1.31	.72	.05	.00	4.81
GT 24	14	23	56	10	15	2	1	0	1	2	2	2	22	26	9	1	0	186
(1)	.34	.56	1.37	.24	.37	.05	.02	.00	.02	.05	.05	.05	.54	.63	.22	.02	.00	4.54
(2)	.17	.28	.67	.12	.18	.02	.01	.00	.01	.02	.02	.02	.26	.31	.11	.01	.00	2.23
ALL SPEEDS	345	220	366	262	215	177	179	111	107	138	251	262	295	536	415	222	0	4101
(1)	8.41	5.36	8.92	6.39	5.24	4.32	4.36	2.71	2.61	3.37	6.12	6.39	7.19	13.07	10.12	5.41	.00	100.00
(2)	4.15	2.64	4.40	3.15	2.58	2.13	2.15	1.33	1.29	1.66	3.02	3.15	3.54	6.44	4.99	2.67	.00	49.27

(1) = PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE
 (2) = PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD
 C = CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

SEABROOK JAN05-DEC05 MET DATA JOINT FREQUENCY DISTRIBUTION (210-FOOT TOWER)

209.0 FT WIND DATA STABILITY CLASS E CLASS FREQUENCY (PERCENT) = 28.88

WIND DIRECTION FROM

SPEED MPH	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	VRBL	TOTAL
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0	0	0	1
(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.04	.00	.00	.00	.04
(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.01	.00	.00	.00	.01
C-3	5	5	7	12	10	5	11	3	11	8	5	3	4	4	4	5	0	102
(1)	.21	.21	.29	.50	.42	.21	.46	.12	.46	.33	.21	.12	.17	.17	.17	.21	.00	4.24
(2)	.06	.06	.08	.14	.12	.06	.13	.04	.13	.10	.06	.04	.05	.05	.05	.06	.00	1.23
4-7	28	19	27	21	28	26	38	21	24	25	30	21	17	27	19	17	0	388
(1)	1.16	.79	1.12	.87	1.16	1.08	1.58	.87	1.00	1.04	1.25	.87	.71	1.12	.79	.71	.00	16.14
(2)	.34	.23	.32	.25	.34	.31	.46	.25	.29	.30	.36	.25	.20	.32	.23	.20	.00	4.66
8-12	56	26	17	21	8	17	21	70	78	72	106	143	117	141	114	37	0	1044
(1)	2.33	1.08	.71	.87	.33	.71	.87	2.91	3.24	3.00	4.41	5.95	4.87	5.87	4.74	1.54	.00	43.43
(2)	.67	.31	.20	.25	.10	.20	.25	.84	.94	.87	1.27	1.72	1.41	1.69	1.37	.44	.00	12.54
13-18	13	12	22	21	6	2	5	46	20	21	68	149	151	136	60	14	0	746
(1)	.54	.50	.92	.87	.25	.08	.21	1.91	.83	.87	2.83	6.20	6.28	5.66	2.50	.58	.00	31.03
(2)	.16	.14	.26	.25	.07	.02	.06	.55	.24	.25	.82	1.79	1.81	1.63	.72	.17	.00	8.96
19-24	2	2	12	11	6	1	0	5	0	13	9	7	11	10	8	2	0	99
(1)	.08	.08	.50	.46	.25	.04	.00	.21	.00	.54	.37	.29	.46	.42	.33	.08	.00	4.12
(2)	.02	.02	.14	.13	.07	.01	.00	.06	.00	.16	.11	.08	.13	.12	.10	.02	.00	1.19
GT 24	0	1	2	8	3	5	2	0	0	1	0	0	2	0	0	0	0	24
(1)	.00	.04	.08	.33	.12	.21	.08	.00	.00	.04	.00	.00	.08	.00	.00	.00	.00	1.00
(2)	.00	.01	.02	.10	.04	.06	.02	.00	.00	.01	.00	.00	.02	.00	.00	.00	.00	.29
ALL SPEEDS	104	65	87	94	61	56	77	145	133	140	218	323	302	319	205	75	0	2404
(1)	4.33	2.70	3.62	3.91	2.54	2.33	3.20	6.03	5.53	5.82	9.07	13.44	12.56	13.27	8.53	3.12	.00	100.00
(2)	1.25	.78	1.05	1.13	.73	.67	.93	1.74	1.60	1.68	2.62	3.88	3.63	3.83	2.46	.90	.00	28.88

(1)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE
 (2)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD
 C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

SEABROOK JAN05-DEC05 MET DATA JOINT FREQUENCY DISTRIBUTION (210-FOOT TOWER)

209.0 FT WIND DATA STABILITY CLASS F CLASS FREQUENCY (PERCENT) = 8.81

WIND DIRECTION FROM

SPEED MPH	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	VRBL	TOTAL
CALM	0	0	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	1
(1)	.30	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.14	.00	.00	.00	.00	.00	.14
(2)	.30	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.01	.00	.00	.00	.00	.00	.01
C-3	5	3	1	3	6	3	4	8	5	3	1	2	1	1	1	2	0	49
(1)	.58	.41	.14	.41	.82	.41	.55	1.09	.68	.41	.14	.27	.14	.14	.14	.27	.00	6.68
(2)	.36	.04	.01	.04	.07	.04	.05	.10	.06	.04	.01	.02	.01	.01	.01	.02	.00	.59
4-7	9	10	13	8	2	6	9	21	19	16	19	12	11	14	8	11	0	188
(1)	1.23	1.36	1.77	1.09	.27	.82	1.23	2.86	2.59	2.18	2.59	1.64	1.50	1.91	1.09	1.50	.00	25.65
(2)	.11	.12	.16	.10	.02	.07	.11	.25	.23	.19	.23	.14	.13	.17	.10	.13	.00	2.26
8-12	31	13	8	0	0	0	3	21	20	28	31	42	29	53	37	25	0	341
(1)	4.23	1.77	1.09	.00	.00	.00	.41	2.86	2.73	3.82	4.23	5.73	3.96	7.23	5.05	3.41	.00	46.52
(2)	.37	.16	.10	.00	.00	.00	.04	.25	.24	.34	.37	.50	.35	.64	.44	.30	.00	4.10
13-18	17	4	0	1	0	0	0	0	1	4	12	31	20	23	23	17	0	153
(1)	2.32	.55	.00	.14	.00	.00	.00	.00	.14	.55	1.64	4.23	2.73	3.14	3.14	2.32	.00	20.87
(2)	.20	.05	.00	.01	.00	.00	.00	.00	.01	.05	.14	.37	.24	.28	.28	.20	.00	1.84
19-24	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1
(1)	.30	.00	.14	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.14
(2)	.30	.00	.01	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.01
GT 24	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
(1)	.30	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
(2)	.30	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
ALL SPEEDS	52	30	23	12	8	9	16	50	45	51	63	88	61	91	69	55	0	733
(1)	8.46	4.09	3.14	1.64	1.09	1.23	2.18	6.82	6.14	6.96	8.59	12.01	8.32	12.41	9.41	7.50	.00	100.00
(2)	.74	.36	.28	.14	.10	.11	.19	.60	.54	.61	.76	1.06	.73	1.09	.83	.66	.00	8.81

(1)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE
 (2)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD
 C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

SEABROOK JAN05-DEC05 MET DATA JOINT FREQUENCY DISTRIBUTION (210-FOOT TOWER)

209.0 FT WIND DATA STABILITY CLASS G CLASS FREQUENCY (PERCENT) = 6.20

WIND DIRECTION FROM

SPEED MPH	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	VRBL	TOTAL
CALM	0	0	0	0	0	0	0	1	0	0	0	0	0	1	0	0	0	2
(1)	.30	.00	.00	.00	.00	.00	.00	.19	.00	.00	.00	.00	.00	.19	.00	.00	.00	.39
(2)	.30	.00	.00	.00	.00	.00	.00	.01	.00	.00	.00	.00	.00	.01	.00	.00	.00	.02
C-3	6	2	6	3	2	2	4	0	6	2	2	4	2	5	3	2	0	51
(1)	1.16	.39	1.16	.58	.39	.39	.78	.00	1.16	.39	.39	.78	.39	.97	.58	.39	.00	9.88
(2)	.37	.02	.07	.04	.02	.02	.05	.00	.07	.02	.02	.05	.02	.06	.04	.02	.00	.61
4-7	16	12	11	3	3	3	2	7	7	8	22	19	14	7	12	15	0	161
(1)	3.10	2.33	2.13	.58	.58	.58	.39	1.36	1.36	1.55	4.26	3.68	2.71	1.36	2.33	2.91	.00	31.20
(2)	.19	.14	.13	.04	.04	.04	.02	.08	.08	.10	.26	.23	.17	.08	.14	.18	.00	1.93
8-12	20	6	4	2	2	1	1	3	12	24	27	29	31	38	27	27	0	254
(1)	3.38	1.16	.78	.39	.39	.19	.19	.58	2.33	4.65	5.23	5.62	6.01	7.36	5.23	5.23	.00	49.22
(2)	.24	.07	.05	.02	.02	.01	.01	.04	.14	.29	.32	.35	.37	.46	.32	.32	.00	3.05
13-18	2	1	1	0	0	0	0	0	1	1	2	8	4	13	7	8	0	48
(1)	.39	.19	.19	.00	.00	.00	.00	.00	.19	.19	.39	1.55	.78	2.52	1.36	1.55	.00	9.30
(2)	.32	.01	.01	.00	.00	.00	.00	.00	.01	.01	.02	.10	.05	.16	.08	.10	.00	.58
19-24	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
(1)	.30	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
(2)	.30	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
GT 24	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
(1)	.30	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
(2)	.30	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
ALL SPEEDS	44	21	22	8	7	6	7	11	26	35	53	60	51	64	49	52	0	516
(1)	8.53	4.07	4.26	1.55	1.36	1.16	1.36	2.13	5.04	6.78	10.27	11.63	9.88	12.40	9.50	10.08	.00	100.00
(2)	.53	.25	.26	.10	.08	.07	.08	.13	.31	.42	.64	.72	.61	.77	.59	.62	.00	6.20

(1) = PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE
 (2) = PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD
 C = CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

SEABROOK JAN05-DEC05 MET DATA JOINT FREQUENCY DISTRIBUTION (210-FOOT TOWER)

209.0 FT WIND DATA STABILITY CLASS ALL CLASS FREQUENCY (PERCENT) = 100.00

WIND DIRECTION FROM

SPEED MPH	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	VRBL	TOTAL
CALM	0	0	0	0	0	0	0	1	0	0	1	1	0	2	0	0	0	5
(1)	.00	.00	.00	.00	.00	.00	.00	.01	.00	.00	.01	.01	.00	.02	.00	.00	.00	.06
(2)	.00	.00	.00	.00	.00	.00	.00	.01	.00	.00	.01	.01	.00	.02	.00	.00	.00	.06
C-3	23	11	26	32	24	18	22	16	27	15	18	13	8	14	21	14	0	302
(1)	.28	.13	.31	.38	.29	.22	.26	.19	.32	.18	.22	.16	.10	.17	.25	.17	.00	3.63
(2)	.28	.13	.31	.38	.29	.22	.26	.19	.32	.18	.22	.16	.10	.17	.25	.17	.00	3.63
4-7	123	89	89	97	102	97	103	74	74	74	106	89	88	84	86	106	0	1481
(1)	1.48	1.07	1.07	1.17	1.23	1.17	1.24	.89	.89	.89	1.27	1.07	1.06	1.01	1.03	1.27	.00	17.79
(2)	1.48	1.07	1.07	1.17	1.23	1.17	1.24	.89	.89	.89	1.27	1.07	1.06	1.01	1.03	1.27	.00	17.79
8-12	246	129	136	153	123	116	174	151	157	198	285	347	308	373	326	180	0	3402
(1)	2.96	1.55	1.63	1.84	1.48	1.39	2.09	1.81	1.89	2.38	3.42	4.17	3.70	4.48	3.92	2.16	.00	40.87
(2)	2.96	1.55	1.63	1.84	1.48	1.39	2.09	1.81	1.89	2.38	3.42	4.17	3.70	4.48	3.92	2.16	.00	40.87
13-18	122	69	138	66	31	24	80	116	50	64	199	307	301	441	251	102	0	2361
(1)	1.47	.83	1.66	.79	.37	.29	.96	1.39	.60	.77	2.39	3.69	3.62	5.30	3.02	1.23	.00	28.37
(2)	1.47	.83	1.66	.79	.37	.29	.96	1.39	.60	.77	2.39	3.69	3.62	5.30	3.02	1.23	.00	28.37
19-24	36	24	66	39	32	10	12	8	6	22	16	28	45	130	73	8	0	555
(1)	.43	.29	.79	.47	.38	.12	.14	.10	.07	.26	.19	.34	.54	1.56	.88	.10	.00	6.67
(2)	.43	.29	.79	.47	.38	.12	.14	.10	.07	.26	.19	.34	.54	1.56	.88	.10	.00	6.67
GT 24	14	24	59	18	18	7	3	0	1	3	2	2	28	28	9	1	0	217
(1)	.17	.29	.71	.22	.22	.08	.04	.00	.01	.04	.02	.02	.34	.34	.11	.01	.00	2.61
(2)	.17	.29	.71	.22	.22	.08	.04	.00	.01	.04	.02	.02	.34	.34	.11	.01	.00	2.61
ALL SPEEDS	554	346	514	405	330	272	394	366	315	376	627	787	778	1072	766	411	0	8323
(1)	6.78	4.16	6.18	4.87	3.96	3.27	4.73	4.40	3.78	4.52	7.53	9.46	9.35	12.88	9.20	4.94	.00	100.00
(2)	6.78	4.16	6.18	4.87	3.96	3.27	4.73	4.40	3.78	4.52	7.53	9.46	9.35	12.88	9.20	4.94	.00	100.00

(1)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE
 (2)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD
 C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

ENCLOSURE 3 TO SBK-L-06101

Radiation Dose Assessment

**Seabrook Station
Radiological Effluent Impact Assessment For 2005
(Annual Radioactive Effluent Release Report)**

I. Summary

Seabrook Technical Specification Sections 6.7.6.g.4 & 9 require that limitations be placed on the quarterly and annual doses or dose commitments to Members of the Public from radioactive materials in liquid and gaseous effluents released from the station to Unrestricted Areas at or beyond the site boundary conforming to the dose objectives of Appendix I to 10 CFR Part 50. Technical Specification 6.7.6.g.3 requires that limitations on the quarterly and annual air doses resulting from noble gases released in gaseous effluents to areas beyond the site boundary also conform to Appendix I to 10 CFR Part 50. In a similar fashion, Technical Specification 6.7.6.g.11 requires limitations on the annual dose or dose commitment to any Member of the Public due to radioactivity and radiation from uranium fuel cycle sources conforming to the EPA Radiation Standards in 40 CFR Part 190. The following table details the above referenced effluent dose limits.

DOSE OBJECTIVE CRITERIA FOR COMPLIANCE

EFFLUENT TYPE	DOSE TYPE	QUARTERLY LIMITS	ANNUAL LIMITS
LIQUIDS (10CFR50, APP. I)	Total Body	1.5 mrem	3 mrem
	Max. Organ	5 mrem	10 mrem
NOBLE GAS (10CFR50, APP. I)	Gamma Air	5 mrad	10 mrad
	Beta Air	10 mrad	20 mrad
GAS PARTICULATE (10CFR50, APP. I)	Max. Organ	7.5 mrem	15 mrem
TOTAL DOSE (40CFR190) [liquids, gas, direct]	Total Body & organ		25 mrem
	Thyroid	---	75 mrem

Technical Specification 6.8.1.4 and the Seabrook Offsite Dose Calculation Manual (ODCM) Part A, Section 10.2, provides that the Station's Annual Radioactive Effluent Release Report include a demonstration of compliance with the above off-site dose limitations, as well as the determination of dose impacts to Members of the Public who may be associated with permitted activities inside the site boundary.

Doses resulting from actual liquid and gaseous effluents from Seabrook Station during 2005 were calculated in accordance with Method II as defined in the Station Offsite Dose Calculation Manual. The calculation methods follow the models in Regulatory Guide 1.109 (Reference 1). The assessments included maximum whole body doses and organ doses from all liquid releases, maximum offsite organ doses resulting from airborne iodines, tritium and particulate radionuclides with half-lives greater than eight days, and maximum offsite beta air and gamma air doses from airborne noble gases. Calculated dose impacts from airborne effluents included atmospheric dispersion estimates utilizing concurrent meteorology recorded by the Seabrook's on-site meteorological tower. In addition, the potential direct

dose from fixed radiation sources from plant operations was evaluated as part of the assessment required under 40 CFR Part 190 for doses from the uranium fuel cycle.

Doses were also calculated for the special receptor locations inside the site boundary where the public might be granted access for recreational or educational purposes. The Science and Nature Center is located in the southwest portion of the site and offers educational opportunities on nuclear power and the environment. The "Rocks" is an area northeast of the main plant facilities with access to Brown's Creek and the tidal marsh that borders the site.

All calculated liquid and gaseous pathway doses for the 2005 reporting period are well below the dose criteria of 10CFR50, Appendix I, and the dose limits for effluent releases stated in the ODCM. In addition, the total dose to the most limiting Member of the Public due to the combined exposure to plant-related direct radiation, and liquid and gaseous effluents, was below the dose standards of 40CFR190.

II. Method for Calculating the Total Body and Maximum Organ Doses Resulting from Liquid Releases

Liquid waste generated during plant operations is processed and discharged to the environment via the station's circulating water-cooling system. The cooling system utilizes an offshore-submerged multiport diffuser discharge for rapid dissipation and mixing of liquid effluents in the ocean environment. A 22-port diffuser section of the discharge system is located in approximately 50 to 60 feet of water with each nozzle 7 to 10 feet above the sea floor. Eleven riser shafts, with two diffuser nozzles each for the diffuser, are spaced about 100 feet apart over a distance of about 1000 feet. Water is discharged in a generally eastward direction away from the shoreline through the multiport diffuser, beginning at a location over one mile offshore. During power operations, these high velocity jets passively entrain about ten volumes of fresh water into the near field jet-mixing region before the plume reaches the water surface. This arrangement also effectively prevents the discharge plume (at least to the 1 degree or 40 to 1 dilution isopleth) from impacting the shoreline over the tidal cycle.

During shutdown periods, the high velocity jet mixing created by the normal circulating water flow at the diffuser nozzles is reduced. However, mixing within the discharge tunnel water volume is significantly increased due to the long transit time for batch discharges to travel the three miles from the plant through the 19-foot diameter tunnels to the diffuser nozzles. Additional mixing of the effluent in the near field assures that an equivalent overall 10 to 1 dilution occurs by the time the effluent reaches the ocean surface.

The exposure pathways considered in the calculations of total body and maximum organ doses resulting from liquid discharges from Seabrook Station are limited to ingestion of aquatic foods and exposure to shoreline deposits. The dose calculations do not include the ingestion of potable water or irrigated vegetation as potential exposure pathways because the liquid effluents from the plant are discharged into salt water.

The dose assessment models utilized in the Offsite Dose Calculation Manual (ODCM) (Reference 2) are taken from Regulatory Guide 1.109 (Reference 1). The total body and organ doses are evaluated for each of the four age groups (i.e., infant, child, teen and adult) to determine the maximum total body dose and maximum organ dose via all existing exposure pathways (i.e., fish and aquatic invertebrate ingestion, and shoreline exposure) to an age-dependent individual from all detected radionuclides in plant releases. The values for the various factors considered in the model equations are provided in Regulatory Guide 1.109 and the ODCM (see Table D). The flow rate of the liquid effluent (F) and the radionuclide activities (Q_i) are measured specifically prior to each liquid release. The values for half-lives for radionuclides ($T_{1/2}$) and their radioactive decay constants (λ_i) have been taken from Koehler (Reference 3).

Table A presents the calculated liquid pathway doses for each calendar quarter and total for the year. The calculated annual doses as a percent of the applicable regulatory limits are shown in Table C. The estimated quarterly and annual doses resulting from liquid effluents to members of the public are well below all dose limit criteria.

III. Method for Calculating the Gamma and Beta Air Doses from Noble Gases

Gamma and beta air doses due to noble gases in gaseous effluents are calculated for several receptor locations when noble gases are recorded in effluents. Those locations include the points of estimated highest off-site ground level air concentration of radioactive material, site boundary (or closest point or the opposite shoreline in directions which are bordered by the tidal marsh), nearest resident, nearest vegetable garden, and nearest milk animal within five miles for each of the sixteen principle compass directions. The special on-site receptor locations (Science and Nature Center and the "Rocks") are also included.

Atmospheric dispersion factors (i.e., X/Q factors) calculated from recorded concurrent site meteorological data (i.e., meteorological data measurements taken during the time of the release) are used in the estimation of receptor specific air concentrations due to station effluents. The atmospheric dispersion estimations utilize methodology generally consistent with US NRC Regulatory Guide 1.111 (Reference 4). Beta air doses use undepleted X/Q's and assumes a semi-infinite plume at the point of exposure. Gamma air doses are calculated using the finite cloud model presented in "Meteorology and Atomic Energy - 1968" (Reference 5). That model is implemented through the definition of an effective gamma atmospheric dispersion factor $[X/Q^*]$ (Reference 6) and the replacement of the undepleted X/Q in the infinite cloud dose equation by $[X/Q^*]$.

The release point of effluents is also considered in the atmospheric dispersion calculation. The primary vent stack is treated as a "mixed-mode" release, as defined in Regulatory Guide 1.111. These effluents are considered to be part-time ground level / part-time elevated releases depending on the ratio of primary vent stack exit velocity relative to the speed of prevailing wind. All other release points (e.g., Turbine Building and Chemistry lab hoods) are considered ground-level releases. The beta air and gamma air dose calculations are consistent with the models presented in Regulatory Guide 1.109 (Reference 1). The values for the dose factors, DF_i^γ and DF_i^β , have been taken from Table B-1 in Regulatory Guide 1.109.

Table A presents the calculated maximum off-site gamma air and beta air doses for each calendar quarter and year. The calculated annual doses as a percent of the applicable regulatory limit are shown in Table C. The estimated quarterly and annual air doses resulting from noble gas effluents are well below all dose limit criteria.

IV. Method for Calculating the Critical Organ Dose Resulting from Iodines, Tritium and Particulates with T_{1/2} Greater than 8 Days in Gaseous Releases

Regulatory Guide 1.109 dose models are applied in the calculation of the critical organ doses from iodines, tritium and particulate radionuclides released into the atmosphere during reporting period. Atmospheric dispersion and deposition factors (i.e., depleted X/Q and D/Q factors) calculated with concurrent meteorological data (i.e., meteorological data measurements taken during the time of the release) are used in the determination of gaseous pathway doses. The dispersion models are described in Section B.7.3.2 & B.7.3.3 of the Seabrook ODCM.

Potential exposure pathways associated with gaseous effluent are (i) external irradiation from radioactivity deposited on the ground surface, (ii) inhalation, and (iii) ingestion of vegetables (both fresh leafy and stored), meat, and milk. Dose estimates were determined for the site boundary and for the locations of the nearest resident, vegetable garden, and milk animal in each of the sixteen principle compass directions. The locations of the nearest resident, vegetable garden and milk animal in each sector were identified by the 2005 Annual Land Use Census as required by ODCM Control C.9.2.1 (see Table F). Additionally, doses were calculated at the point of approximate maximum ground level air concentration of radioactive materials in gaseous effluent. Conservatism in the dose estimates was maintained by assuming that the vegetable garden pathway was active at each milk animal location. Though not required to be part of the land use census, meat animal (cattle) locations are included in the assessment when identified. Meat and milk animals were assumed to receive their entire intake from pasture during the second and third quarters. This is a conservative assumption because most dairy operations utilize supplemental feeding when animals are on pasture, or actually restrict animals to full time silage feeding throughout the entire year. Table E provides the reference sources for dose model parameter assumptions used in the dose assessment.

The maximum organ doses were determined by summing the contributions from all exposure pathways at each location, and sorting in descending order. Doses were calculated for the whole body, GI-LLI, bone, liver, kidney, thyroid, lung, and skin for adults, teenagers, children, and infants. The estimated quarterly and annual organ doses due to iodines, tritium and particulates at the location of the maximally exposed individual are reported in Table A.

The estimated organ doses from iodines, tritium and particulates in gaseous effluents are well below the 10CFR50, Appendix I dose criteria for the reporting period (See Table C for calculated dose as a percentage of annual limits).

V. Total Dose (40 CFR Part 190)

40 CFR 190 states that the annual dose equivalent should not exceed 25 mrem to the whole body, 75 mrem to the Thyroid, or 25 mrem to any other organ of any Member of the Public from all uranium fuel cycle sources. To show compliance with this standard, the maximum doses for both the liquid and gaseous pathways from Seabrook Station are added together with the whole body dose from noble gas releases and any direct radiation component attributed to plant fixed sources to the maximum receptor location. Since there are no other uranium fuel cycle facilities within five miles of Seabrook, no additional impacts from sources beyond Seabrook Station need be considered.

The sum of the maximum annual whole body doses to Members of the Public from all exposure pathways for liquid and gaseous effluents, plus the direct external dose from station fixed sources, was $3.11\text{E-}02$ mrem to a hypothetical individual at or beyond the site boundary. The maximum organ dose (including the thyroid) to any age group from all exposure pathways including direct radiation was $5.14\text{E-}02$ mrem.

Table B illustrates the total dose projections from all station sources to the maximum potential off-site individual for the year 2005 and demonstrates compliance with the EPA's environmental radiation standard for the uranium fuel cycle per 40 CFR Part 190 (See Table C for total dose as a percentage of annual limit).

VI. References

1. Regulatory Guide 1.109, Revision 1, "Calculation of Annual Doses to Man from Routine Releases of Reactor Effluents for the Purposes of Evaluating Compliance with 10CFR Part 50, Appendix I", USNRC, October 1977.
2. Seabrook Station Offsite Dose Calculation Manual (ODCM), Revision 29, Effective Date 06-09-05.
3. Kocher, D.C., Dose-Rate Conversion Factors for Exposure to Photons and Electrons, Health Physics, Vol. 45, No. 3, Sept. 1983.
4. Regulatory Guide 1.111, Revision 1, "Method for Estimating Atmospheric Transport and Dispersion of Gaseous Effluents in Routine Releases from Light-Water Cooled Reactors", USNRC, July 1977.
5. Slade, D.H., "Meteorology and Atomic Energy – 1968", USAEC, July 1968.
6. Hamawi, J.N., "AEOLUS-2 A computer Code for the Determination of Continuous and Intermittent-Release Atmospheric Dispersion and Deposition of Nuclear Power Plant Effluents in Open-Terrain Sites, Coastal Sites, and Deep-River Valleys for the Assessment of Ensuing Doses and Finite-Cloud Gamma Radiation Exposures", Entech Engineering, Inc., March 1988.

Table A

Seabrook Station
2005 Annual Radioactive Effluent Release Report

Maximum^(a) Off-Site Doses and Dose Commitments to Members of the Public

		Dose (mrem) ^(b)				
Release Type		1st Quarter	2nd Quarter	3rd Quarter	4th Quarter	Year ^(c) 2005
Liquid Effluents:						
Total Body Dose		3.10E-04 (1)	8.51E-04 (1)	2.97E-05 (2)	1.61E-05 (1)	1.21E-03
Organ Dose		3.45E-04 (3)	2.56E-03 (4)	1.14E-04 (5)	4.77E-05 (4)	3.07E-03
Airborne Effluents:						
Organ Dose from Iodines, Tritium, and Particulates		3.95E-03 (6)	3.80E-02 (7)	3.02E-03 (8)	3.27E-03 (8)	4.82E-02
Noble Gases	Beta Air (mrad)	7.03E-05 (9)	8.37E-05 (10)	9.14E-07 (12)	3.70E-06 (14)	1.59E-04
	Gamma Air (mrad)	8.30E-05 (9)	4.17E-05 (11)	1.14E-06 (13)	7.36E-06 (14)	1.33E-04
Direct Dose Offsite From Plant Operation ^(e)						0
Doses (mrem) at Receptor Locations Inside Site Boundary^(d):						
Science and Nature Center (SW, 488m): Organ Dose (mrem)		1.14E-06 (d3)	1.15E-05 (d2)	2.32E-06 (d1)	2.66E-06 (d1)	1.76E-05
The "Rocks" (NE/ENE, 244m): Organ Dose (mrem)		9.50E-05 (d1)	2.71E-03 (d2)	1.04E-04 (d1)	1.31E-04 (d1)	3.04E-03

Table A (continued)

Seabrook Station
2005 Annual Radioactive Effluent Release Report

Maximum^(a) Off-Site Doses and Dose Commitments to Members of the Public

NOTES:

- (a) "Maximum means the largest fraction of corresponding 10CFR50, Appendix I, dose design objective.
- (b) The numbered footnotes indicate the age group, organ, and location (compass sector and distance from the primary vent in meters) of the dose receptor, where appropriate.
- (1) Adult
 - (2) Child
 - (3) Liver of an adult.
 - (4) GI-LLI of an adult.
 - (5) Bone of a child.
 - (6) Liver of a child, S 1212 m.
 - (7) Lung of a Teen, SSE 914 m.
 - (8) Liver, kidney, lung, GI-LLI, thyroid, and whole body of a Child, SW 1130 m.
 - (9) SSE 914 m
 - (10) S 930 m
 - (11) W 974 m
 - (12) N 914 m
 - (13) E 2438 m
 - (14) ESE 2276 m
- (c) "Maximum" dose for the year is the sum of the maximum doses for each quarter. This results in a conservative yearly dose estimate, but still well within the limits of 10CFR50.
- (d) For each special receptor location, the whole body and organ doses calculated for the airborne effluent releases were adjusted by the occupancy factor provided in Seabrook's ODCM (i.e., 0.0014 for the Science and Nature Center and 0.0076 for the "Rocks"). It should also be noted that for 2005 actual occupancy factors were much lower (close to zero) since access to the site by the general public has been greatly restricted for security reasons following the terrorist attacks on America on 09/11/01. For conservatism, the previous factors as listed in the ODCM were applied for an estimate of upper bound doses and comparison with calculated impacts for year's pre September 11, 2001. Where appropriate, the numbered footnotes indicate the organ and age group of the dose receptor:
- (d1) Liver, kidney, lung, GI-LLI, thyroid, and whole body of a teen.
 - (d2) Lung of a teen.
 - (d3) Thyroid of a teen.

- (e) Only station sources are considered since there are no other facilities within five miles of Seabrook Station. 2005 data for the closest off-site environmental TLD locations in each sector (as listed in Table B.4-1 of Seabrook's ODCM) were compared to preoperation data from 1986-1988 for the same locations. No statistical difference, which could be attributed to station sources, was identified.

Table B

Seabrook Station
2005 Annual Radioactive Effluent Release Report

Total Dose to Maximum Off-Site Individual
(40CFR190)

Release Source	Total Body (mrem)	Maximum Organ ^(a) (mrem)
Liquids	1.21E-03	3.07E-03
Noble Gases	8.84E-05	8.84E-05
Gas Iodines, Tritium & Particulates	2.98E-02	4.82E-02
Direct Radiation	0	0
Annual Total	3.11E-02	5.14E-02

(a) Maximum organ includes consideration of the thyroid.

Table C

Seabrook Station
2005 Annual Radioactive Effluent Release Report

Calculated 2005 Maximum Doses Versus Applicable Limits

Receptor	Applicable ODCM Control	ODCM Annual Limit	Calculated Annual (2005) Dose	Percent of Limit
Offsite				
Liquid Effluents				
Whole Body Dose	C.6.2.1	3 mrem	1.21E-03 mrem	0.040%
Organ Dose	C.6.2.1	10 mrem	3.07E-03 mrem	0.031%
Airborne Effluents				
Organ Dose (iodines, tritium, and part.)	C.7.3.1	15 mrem	4.82E-02 mrem	0.32%
Gamma Air Dose (noble gases)	C.7.2.1	10 mrad	1.33E-04 mrad	0.0013%
Beta Air Dose (noble gases)	C.7.2.1	20 mrad	1.59E-04 mrad	0.0008%
All Plant Sources ^(a)				
Whole Body Dose	C.8.1.1	25 mrem	3.11E-02 mrem	0.12%
Organ Dose	C.8.1.1	25 mrem	5.14E-02 mrem	0.21%
Onsite (Science and Nature Center, 488m SW)				
Airborne Effluents				
Organ Dose (iodines, tritium, and part.)	C.7.3.1 ^(b)	15 mrem	1.76E-05 mrem	0.00012%
Onsite (The "Rocks", 244m NE/ENE)				
Airborne Effluents				
Organ Dose (iodines, tritium, and part.)	C.7.3.1 ^(b)	15 mrem	3.04E-03 mrem	0.020%

(a) The "all plant sources" doses are the sum of the whole body doses and maximum organ doses from liquid, noble gas, and iodines/tritium/particulate releases as well as direct radiation from fixed station sources.

(b) ODCM Part A, Section 10.2 states that the annual effluent report shall include an assessment of the radiation doses from radioactive liquids and gaseous effluents to members of the public due to their activities inside the site boundary during the report period. The referenced limits (C.7.2.1 & C.7.3.1) are the acceptable doses from liquid and gaseous effluents to areas at and beyond the site boundary and are considered to be appropriate for comparison purposes.

Table D

Seabrook Station
2005 Annual Radioactive Effluent Release Report

Sources of the Values of Factors Used in Liquid Dose Equations

Factor	Definition	Source
U_{ap}	Usage factor	Table B.7-1, Station ODCM
M_p	Mixing ratio	Section B.7.1, Station ODCM (value=0.1 for aquatic foods and 0.025 for shoreline)
B_{ip}	Equilibrium bioaccumulation factor	Table A-1, Reg. Guide 1.109
D_{aipj}	Dose factor	Tables E-11 through E-14, R.G. 1.109
t_p	Nuclide transit time	Table E-15, Reg. Guide 1.109
K_c	Transfer coefficient from water to sediment	Reg. Guide 1.109
t_b	Period of activity buildup in sediment or soil	Table B.7-2, Station ODCM
W	Shoreline width factor	Table A-2, Reg. Guide 1.109 (value=0.5)

Table E
Seabrook Station
2005 Annual Radioactive Effluent Release Report

Sources of Values for the Factors Used in Dose Equations for Gaseous Releases

Factor	Definition	Source
t_b	Period of activity buildup in sediment or soil	Table B.7-2, Station ODCM
λ_i	Nuclide decay constant	Kocher (Reference 3)
DFG _{ij}	Ground plane dose factor	Table E-6, Reg. Guide 1.109
[X/Q] ^D	Atmospheric dispersion factor	Calculated following Reg. Guide 1.111
F_a	Breathing rate	Table B.7-3, Station ODCM
DFA _{ijja}	Inhalation dose factor	Tables E-7 through E-10, Reg. Guide 1.109
d_i	Nuclide deposition rate	Reg. Guide 1.109
p	Soil surface density	Table B.7-2, Station ODCM
t_e	Crop, leafy vegetable, or pasture grass exposure period	Table B.7-2, Station ODCM
t_h	Average time from crop harvest to consumption	Table B.7-2, Station ODCM
Y_v	Agricultural productivity by unit area	Table B.7-2, Station ODCM
r	Fraction of deposited activity retained on crops, leafy vegetables, or pasture grass	Table E-15, Reg. Guide 1.109
B_{iv}	Stable element transfer coefficient from soil to produce, leafy vegetable, or pasture grass	Table E-1, Reg. Guide 1.109
p	Fractional equilibrium ratio	Reg. Guide 1.109
H	Ambient absolute humidity	Table B.7-2, Station ODCM
F_m	Stable element transfer coefficient from feed to milk	Tables E-1 and E-2, Reg. Guide 1.109

Table E (continued)

Seabrook Station
2005 Annual Radioactive Effluent Release Report

Sources of Values for the Factors Used in Dose Equations for Gaseous Releases

Factor	Definition	Source
t_f	Average time from feed to milk to consumption	Reg. Guide 1.109
f_p	Fraction of the year that animals graze on pasture	Table B.7-2, Station ODCM
f_s	Fraction daily feed pasture grass	Table B.7-2, Station ODCM
F_f	Stable element transfer coefficient from feed to meat	Table E-1, Reg. Guide 1.109
t_s	Average time from meat animal slaughter to consumption	Table E-15, Reg. Guide 1.109
DF_{Iija}	Ingestion dose factor	Tables E-11 through E-14, R.G.1.109
U_a^v	Annual intake of produce	Table B.7-3, Station ODCM
U_a^m	Annual intake of milk	Table B.7-3, Station ODCM
U_a^F	Annual intake of meat	Table B.7-3, Station ODCM
U_a^L	Annual intake of leafy vegetables	Table B.7-3, Station ODCM
f_g	Ingestion rate fractions for garden produce	Reg. Guide 1.109
f_l	Ingestion rate fractions for garden leafy vegetables	Reg. Guide 1.109
λ_w	Rate constant for activity removal from plant and leaf surfaces by weathering	Table E-15, Reg. Guide 1.109
Q_F	Animal consumption rate	Table E-3, Reg. Guide 1.109

Table F
 Seabrook Station
 2005 Annual Radioactive Effluent Release Report

Receptor Locations* for Seabrook Station

Sector	Nearest Resident	Nearest Garden	Milk Animals within 5 Mile Radius
	mile (km)	mile (km)	mile (km)
N	2.21 (3.55)	2.47 (3.97)	---
NNE	1.89 (3.04)	1.89 (3.04)	---
NE	1.82 (2.92)	2.80 (4.51)	---
ENE	1.44 (2.31)	---	---
E	1.60 (2.58)	---	---
ESE	1.70 (2.73)	---	---
SE	1.46 (2.36)	---	---
SSE	1.02 (1.65)	---	---
S	0.75 (1.21)	0.76 (1.22)	---
SSW	0.69 (1.12)	0.88 (1.42)	---
SW	0.70 (1.13)	1.20 (1.94)	---
WSW	1.16 (1.87)	1.43 (2.31)	---
W	0.82 (1.32)	0.87 (1.40)	---
WNW	0.69 (1.11)	0.94 (1.52)	---
NW	0.79 (1.27)	0.79 (1.27)	4.30 (6.93)
NNW	0.63 (1.01)	0.64 (1.04)	3.30 (5.32)

* Locations based on 2005 Land Use Census.