

**NUCLEAR REGULATORY COMMISSION**

ORIGINAL

Title: Advisory Committee on Reactor Safeguards  
Reliability and Probabilistic Risk Assessment  
Subcommittee

Docket Number: (not applicable)

Location: Rockville, Maryland

Date: Friday, April 21, 2006

Work Order No.: NRC-981

PROCESS USING ADAMS  
TEMPLATE: ACRS/ACNW-005  
SISP - REVIEW COMPLETE

Pages 1-137

NEAL R. GROSS AND CO., INC.  
Court Reporters and Transcribers  
1323 Rhode Island Avenue, N.W.  
Washington, D.C. 20005  
(202) 234-4433

TROY

**ACRS OFFICE COPY  
RETAIN FOR THE LIFE OF THE COMMITTEE**

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S  
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

April 21, 2006

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, taken on April 21, 2006, as reported herein, is a record of the discussions recorded at the meeting held on the above date.

This transcript has not been reviewed, corrected and edited and it may contain inaccuracies.

1 UNITED STATES OF AMERICA  
2 NUCLEAR REGULATORY COMMISSION

3 + + + + +

4 ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

5 (ACRS)

6 SUBCOMMITTEE ON RELIABILITY AND PROBABILISTIC  
7 RISK ASSESSMENT

8 + + + + +

9 FRIDAY, APRIL 21, 2006

10 + + + + +

11 ROCKVILLE, MARYLAND

12 The Subcommittee met at the  
13 Nuclear Regulatory Commission, Two White Flint North,  
14 Room T-2B1, 11545 Rockville Pike, at 8:30 a.m., George  
15 E. Apostolakis, Chairman, presiding.

16 COMMITTEE MEMBERS:

17	GEORGE E. APOSTOLAKIS	Chairman
18	J. SAM ARMIJO	Member
19	MARIO V. BONACA	Member
20	RICHARD S. DENNING	Member
21	THOMAS S. KRESS	Member
22	OTTO L. MAYNARD	Member
23	WILLIAM J. SHACK	Member
24	JOHN D. SIEBER	Member
25	GRAHAM B. WALLIS	Member

NEAL R. GROSS  
COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

## 1 NRC STAFF PRESENT:

2 Sud Basu, RES/DRASP

3 Amy Cubbage, NRR

4 Jim Gaslevic, NRR/DNRL

5 Bob Palla, NRR/DNA

6 Marie Pohida, NRR/DRA/APOB

7 Larry Rossbach, NRR/DNRL/NESB

8 Nick Saltos, NRR/DNA

9 See Meng Wong, NRR/DRA/APOB

10

## 11 ALSO PRESENT:

12 David Hinds, GE

13 Mohsen Khatib-Rahbar

14 Theo Theofanous, GE

15 Rick Wachowiak, GE

16 Zhe Yuan, REI

17

18

19

20

21

22

23

24

25

## I N D E X

	<u>AGENDA ITEM</u>	<u>PAGE</u>
1		
2		
3	External Events Risk Management, GE	5
4	Fire Analysis	
5	Flood Analysis	
6	High Wind Analysis	
7	Seismic analysis	
8	Shutdown Events Risk Management, GE	81
9	Design features to prevent core damage	
10	Analysis methodology	
11	System success criteria	
12	Results and conclusions	
13	ESBWR Risk Management Insights, GE	96
14	Overall results and conclusions	
15	Review of commitments from the meeting	
16	Requests for Additional Information, NRR	101
17	ESBWR Severe Accident Analysis, RES	122
18	Adjourn	137
19		
20		
21		
22		
23		
24		
25		

## P R O C E E D I N G S

Time: 8:33 a.m.

CHAIRMAN APOSTOLAKIS: The meeting will now come to order. This is the second day of the meeting of the Advisory Committee on Reactor Safeguards, Subcommittee on Probabilistic Risk Assessment. I am George Apostolakis, Chairman of the Subcommittee.

Members in attendance are Graham Wallis, William Shack, Sam Armijo, Mario Bonaca, Rich Denning, Tom Kress, Otto Maynard, and Jack Sieber.

The purpose of the meeting is to begin our review of the ESBWR probabilistic risk assessment. The Subcommittee will gather information, analyze relevant issues and facts, and formulate proposed positions and actions, as appropriate, for deliberation by the full Committee.

Eric Thornsbury is the designated Federal official for this meeting.

The rules for participation in today's meeting have been announced as part of the notice of this meeting, previously published in the Federal Register on April 4, 2006.

A transcript of the meeting is being kept and will be made available, as stated in the Federal

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Register notice. It is requested that speakers first  
2 identify themselves and speak with sufficient clarity  
3 and volume so that they can be readily heard.

4 We have received no written comments or  
5 requests for time to make oral statements from members  
6 of the public regarding today's meeting.

7 We will now proceed with the meeting, and  
8 I call upon Mr. Rick Wachowiak to begin the  
9 presentations. Rick.

10 MR. WACHOWIAK: All right. I would like  
11 also to say that from GE this morning, we have David  
12 Hinds and Sid Bhatt in attendance also.

13 Well, this morning we are going to talk  
14 about a couple of things. We are going to talk about  
15 external events in the DCD PRA, and then a little  
16 later on this morning we are going to talk about the  
17 shutdown PRA.

18 Now these are kind of intermingled,  
19 because in our -- the way that we are writing the  
20 document now in the fire and flood analysis we've got  
21 the fire and the shutdown fire in the same chapter,  
22 and then the flood and the shutdown flood in the same  
23 chapter. So it may seem like I am jumping around a  
24 little bit, but I am trying to keep it in the spirit  
25 of how we arranged the presentation here.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1           So let's start out with the probabilistic  
2 fire analysis. We have done a screening analysis to  
3 show that the contribution of risk due to fire is  
4 going to be not significant in the ESBWR design. We  
5 chose the five methodologies to provide the basis for  
6 identifying the fire compartments, defining the fire  
7 ignition frequencies. Those are consistent with what  
8 we have done in the rest of the PRA where we used  
9 generic --

10           MR. WALLIS: Well, you don't explain how  
11 you reached this conclusion, because in existing  
12 plants fire risk is often comparable with the regular  
13 risks, and I'm not sure why your plant is any  
14 different. What is it that makes it different was not  
15 clear to me.

16           CHAIRMAN APOSTOLAKIS: Not only that, but  
17 to find something insignificant when your base is  $10^{-8}$   
18 <sup>8</sup>. This is now, what,  $10^{-11}$ .

19           MR. WACHOWIAK: Well, we are going to  
20 cover exactly those things.

21           One of the things that, and it probably  
22 prompts your question, is this definition here. Risk  
23 of core damage due to fire in each of the area groups  
24 -- and we will talk about area groups in a minute --  
25 should be lower than the risk of core damage due to

1 internal events.

2 Now thinking about that, is that the right  
3 way to pose that? I would say that, no, we didn't  
4 pose that quite right. What we should have said here  
5 was that either the total of the fire risk in the  
6 screening analysis needs to be much less than the  
7 internal event CDF or each individual group, using  
8 this conservative screening analysis, needs to be  
9 much, much less than.

10 In Rev-0 it turned out that each  
11 individual group was much, much less, and we will talk  
12 about one sequence in Rev-1 that doesn't come out  
13 quite that way, and we can explain why.

14 So this was in Rev-0 of the document. We  
15 will be changing that to be the correct one. Now when  
16 we come into how does the ESBWR get to have a lower  
17 fire risk or a lower contribution than existing  
18 plants, there's a couple of different things that play  
19 into this.

20 Number one, at the design phase it is  
21 pretty easy to say that everything is separated, and  
22 it was easy to say that in the existing plants when  
23 they were at the design phase. Right? And it was  
24 when they actually pulled the cables and set things  
25 out in the actual field that caused some of the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 problems that are associated with fire risk.

2 We understand that now in the industry.  
3 that is a well known issue. So as part of the  
4 detailed design of the ESBWR, we are saying you don't  
5 get to field route stuff the way you did before. It's  
6 got to match the fire hazards analysis and the routing  
7 that we put into the design. That is a criteria that  
8 we have to meet. It can't be deviated, and it leads  
9 to being able to preserve the types of risk levels  
10 that we are going to see here.

11 The other thing is that many of the -- The  
12 instrument control system that we are using in this  
13 plant, the digital instrument control system connected  
14 by fiber optics, is not subject to the same kind of  
15 failure modes and adverse actions that the actual  
16 cable connections do.

17 Now there's some other issues with what  
18 happens to printed circuit cards and things like that,  
19 but we think that we are less susceptible to things  
20 like hot shorts and other things that cause actions  
21 that you wouldn't necessarily consider. So that's  
22 some of the reasons.

23 CHAIRMAN APOSTOLAKIS: You show here that  
24 fire is indeed a negligible contributor. That means  
25 that at the COL stage they will not have to worry

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 about fire? If the design is certified, fires are  
2 out.

3 MR. WACHOWIAK: That would help me out.

4 CHAIRMAN APOSTOLAKIS: Sorry?

5 MR. WACHOWIAK: That would help me out in  
6 meeting the schedule, but I expect that we will have  
7 to provide a similar sort of analysis at the COL stage  
8 to show that it remains negligible, and I would expect  
9 as we go forward and build the plant, we will continue  
10 to have to show that it remains negligible or include  
11 it, if for some reason there is some component that we  
12 actually have to buy, implement something that has a  
13 failure mode that we never thought of before.

14 CHAIRMAN APOSTOLAKIS: I understand that.  
15 The question is more from the legal side. When you  
16 set the fire down, then I guess you are not allowed to  
17 revisit certain issues. That's the whole idea.  
18 Otherwise, you start everything from scratch.

19 So I am wondering, if you have a situation  
20 like this, is it -- Yes, Amy, please?

21 DR. DENNING: She is afraid to get up.

22 MS. CUBBAGE: Well, this would be more in  
23 the mode of verification through the ITAAC that they  
24 have implemented the design as certified.

25 DR. KRESS: Well, it would have to show up

1 in an ITAAC.

2 MS. CUBBAGE: We would have to have  
3 sufficient ITAACs that we could verify that the as-  
4 built plan conforms to the regulations and the  
5 license.

6 DR. WALLIS: Now you said that you got  
7 this low risk by using fiber optics instead of copper,  
8 but I believe your PRA assumes copper. It says you  
9 are not taking credit for fiber optics.

10 MR. WACHOWIAK: Well, what we said -- What  
11 I believe we said was that --

12 DR. WALLIS: It assumes copper conductors  
13 is what I read, instead of fiber optics.

14 MR. WACHOWIAK: In Revision 0 we did say  
15 that we assumed copper.

16 DR. WALLIS: But you are not assuming  
17 fiber optics?

18 MR. WACHOWIAK: What we are assuming is  
19 that, even though we have fiber optics, we are going  
20 to include a -- what we will call bounding or worst  
21 case spurious actuation due to some unknown means.

22 DR. DENNING: Now is that only the  
23 actuation of one SRV? Is that the only actuation,  
24 spurious actuation, you are saying?

25 MR. WACHOWIAK: It's a spurious actuation

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 of a relief valve. It doesn't necessarily have to be  
2 an SRV. It can be an SRV or a DPV, but the reason  
3 that one is more remedying than, let's say, all is  
4 that one is sufficient to remove the isolation  
5 condenser as a viable heat removal source; or that is  
6 also not sufficient to depressurize the plant so that  
7 GDS can come in without further depressurization.

8 So if we assume one, it gets us into a  
9 situation where it is essentially the worst case. If  
10 we assume a whole bunch, then GDCS can come on all by  
11 itself, and we don't have to worry about the passive  
12 syndrome. If we assume none, then isolation  
13 condensers work just fine.

14 So we chose to use limited  
15 depressurization in this, just for that purpose.

16 DR. DENNING: As far as the controlling of  
17 cables and things like that in isolation, does that  
18 only relate to the passive safety systems? It isn't  
19 clear to me. What happens to those active systems  
20 that you use for asset protection? Are they trained  
21 in the same sense and do they have separation or is  
22 that not relevant to that?

23 MR. WACHOWIAK: It is relevant, and we  
24 will see through some of these analyses where it can  
25 make a difference. It determines how much credit we

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 can get for some of these things.

2 In our composite spec for the plant, which  
3 is the like overarching design spec, it's got some  
4 things that we need to meet. There is a list of  
5 systems in there that we call the plant asset  
6 protection systems, and what we specified is that, to  
7 the degree possible, we will provide electrical  
8 separation, physical separation, purchased to seismic  
9 pipe specifications for those pieces of equipment to  
10 provide reasonable assurance that we are not going to  
11 have a single fire event or flood event that is going  
12 to take out all those pieces of equipment.

13 So -- and the list of equipment is, in  
14 general, the stuff that, if we had the active systems,  
15 that are modeled in the PRA. So we do have separation  
16 of the nondivisional side for those.

17 So far, the design implements that. Now  
18 once again, this is where we are early in the design  
19 phase, and I guess I understand now that this is  
20 something that is -- we have to deal with as we add  
21 the detail to the design, and everything on the  
22 drawing board now shows that they are separated, and  
23 I guess we need to maintain that.

24 DR. BONACA: I have a question regarding  
25 the ITAAC, just to understand it. You cannot impose

1 on GE more than the Code of Regulations protections  
2 applies. So if GE comes in with an analysis and the  
3 fire risk of, we could say, two percent for CDF, and  
4 then later on it goes out to five percent or eight  
5 percent --

6 MS. CUBBAGE: We would be in the position  
7 of verifying that they are in conformance with the  
8 regulations.

9 DR. BONACA: That's right. So they still  
10 really can change the results quite significantly and  
11 still be in conformance with the regulations. So I  
12 can't understand --

13 MS. CUBBAGE: Nick Saltos, come on up  
14 here, Nick, to the mike, please.

15 MR. SALTOS: This is Nick Saltos from NRR.  
16 What we do at this stage, we identify those design  
17 features. For example, separation, diversity,  
18 redundancy are the features that make the risk be so  
19 low, as they said, and those become part of the ITAAC  
20 or become action items.

21 So the plant has to meet these  
22 requirements.

23 CHAIRMAN APOSTOLAKIS: But if it does,  
24 then there is a presumption that the results of this  
25 preliminary analysis are correct, and how do we know

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 that, if they do a fire assessment, risk assessment of  
2 the plant as it is being built will actually conform  
3 with this.

4 MR. SALTOS: The fire analysis right now  
5 should be conservative. Yes.

6 CHAIRMAN APOSTOLAKIS: So we are not going  
7 back to it. That's the thing. As long as they meet  
8 what they are saying --

9 MR. SALTOS: Well, there are many uses to  
10 address before these numbers stay the way they are.  
11 There is propagation of fire in the adjacent fire  
12 areas which have not been addressed. There is smoke.  
13 It can propagate also in the back, in the front.

14 MS. CUBBAGE: Those issues will be  
15 reviewed -

16 MR. SALTOS: There are several arteries.  
17 There is regulatory treatment of non-safety system,  
18 doing the fire PRA without the non-safety systems. So  
19 out of all these exercises they are going through,  
20 this risk might increase; but in any case, we are  
21 going to capture all these features that make this  
22 risk be gone.

23 Now, hell, no, we are not speaking to a  
24 number like that. What is important is for the fire,  
25 the design features that make these number low, but

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 how low we don't know yet.

2 MS. CUBBAGE: All of that happens as part  
3 of the certification process.

4 CHAIRMAN APOSTOLAKIS: Well, it's Part 52  
5 that applies here. Right? All it says is that they  
6 have to cut a PRA. Isn't that what it says?

7 MS. CUBBAGE: Right, but all it says --

8 CHAIRMAN APOSTOLAKIS: It doesn't say  
9 anything else.

10 MR. SALTOS: It says that they have to  
11 have a PRA, 35 important -- But also we use the PRA to  
12 identify requirements for the design.

13 CHAIRMAN APOSTOLAKIS: I understand that.

14 MR. SALTOS: All the assumptions that are  
15 made in the PRA are important assumptions that make  
16 the risk be low. We are making sure that they go into  
17 the ITAAC, all serial action items or liabilities to  
18 a problem or tech specs. So when they identify them,  
19 it will be according to those requirements -- will  
20 meet those requirements.

21 MS. CUBBAGE: And don't forget, this is  
22 the risk aspect of your review. We also have the fire  
23 protection engineering review.

24 CHAIRMAN APOSTOLAKIS: I understand. I  
25 guess it is not very clear to me. You certify the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 design, that you are not allowed -- I mean, the whole  
2 idea of the certification process is not to start the  
3 process all over again when an applicant comes with a  
4 real application, but is the PRA part of that or  
5 should you say, yes, the design has been certified,  
6 but we would like the PRA to be really updated as we  
7 move on?

8 MR. SALTOS: The PRA is part of it.

9 CHAIRMAN APOSTOLAKIS: Part of that  
10 certification?

11 MR. SALTOS: Yes, because ensuring that  
12 all the design features wanted in the PRA that make  
13 the risk -- the applicant below. They are going to be  
14 there, and the design is -- The plant is going to be  
15 built according to those requirements.

16 CHAIRMAN APOSTOLAKIS: Fine. That's one  
17 part. The other part is, yeah, you have built it that  
18 way, but update your PRA to take into account now  
19 details that were not in the original design  
20 certification phase, because we didn't have all that  
21 information.

22 MR. SALTOS: Oh, yes.

23 MS. CUBBAGE: I think we are still working  
24 through the issues of what would be reviewed at the  
25 COL stage of our NPRA, and I think that is kind of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 offline.

2 MR. SALTOS; Yes, but the PRA also makes  
3 assumptions, for example, about if there is some  
4 failure caused by cables being close together, we come  
5 up with requirements that the cables have to be  
6 separated up to a certain distance or in different  
7 fire areas.

8 So all this information goes in there.  
9 Now unless we miss something, the PRA is high, top  
10 level assumptions that make the PRA conservative,  
11 bounding, so in an average sense at least.

12 DR. SHACK: A licensee, if he is coming in  
13 for a 1174 action, he is going to have his own PRA.  
14 Now presumably, it is going to be built on this PRA,  
15 but it is going to have to be verified that it is  
16 plant specific and been reviewed.

17 MS. CUBBAGE: Right. I think the issue  
18 you are getting to is what will change at the COL  
19 stage, and I think Rick was speaking more to the fact  
20 that this PRA is going to have to evolve with this as-  
21 built plan so that it can be a tool used by the  
22 licensee. But whether we get it back into the review  
23 again at the COL stage, I think, in general is no.

24 MR. SALTOS: Well, it has to meet the  
25 requirements.

1 MS. CUBBAGE: Right, and that's --

2 MR. SALTOS: That's what we said. Now if  
3 they want to argue the case about how they route some  
4 cables or some other design details, but they still  
5 will have to meet those requirements, high level  
6 requirements.

7 MS. CUBBAGE: But the question is an  
8 updated PRA.

9 MR. SALTOS: They may choose not to update  
10 it.

11 CHAIRMAN APOSTOLAKIS: That is what  
12 worries me.

13 MR. SIEBER: Well, there is no rule that  
14 makes anybody do that.

15 CHAIRMAN APOSTOLAKIS: Or not do that.  
16 See, that's the point. The rule is not specific.

17 MR. SIEBER: That's right. You can do it  
18 if you wanted to or --

19 CHAIRMAN APOSTOLAKIS: Well, the question  
20 is -- Rick showed yesterday a very nice slide where  
21 you had five or six columns, the evolution of the  
22 design. right? You start with a very conceptual  
23 stage, and then you move on.

24 As you move on, then, obviously, the PRA  
25 changes, too, because you have more information. So

1 what is it -- My question is: Let's say we all  
2 certify this. You guys agree, and your SER, the ACRS  
3 agrees with the letter and so on.

4 That means then that at a later stage, if  
5 we raise a question about, say, common cause failure,  
6 you can come back and say, wait a minute now, you  
7 reviewed that last time and you have certified it;  
8 don't even raise questions anymore.

9 MR. SIEBER: I don't think that's right,  
10 John.

11 CHAIRMAN APOSTOLAKIS: Well, I don't  
12 understand. That's what I am trying to understand.

13 MR. SIEBER: Well, the NRC is going to  
14 certify a design. They are not going to certify the  
15 PRA.

16 CHAIRMAN APOSTOLAKIS: Well, that's  
17 exactly the question.

18 MR. SIEBER: Okay.

19 CHAIRMAN APOSTOLAKIS: Is the PRA part of  
20 the certification?

21 MR. SIEBER: No, only in how it resulted  
22 in design of the thing. That's what we certify, is  
23 the design. The PRA is just a tool they use with  
24 designing. We aren't going to certify that.

25 CHAIRMAN APOSTOLAKIS: But what if, in the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 COL things, they don't even submit a PRA?

2 MR. SIEBER: Well, they don't have to, but  
3 if there is something that shows up --

4 MS. CUBBAGE: I think it is a  
5 requirement.

6 MR. SIEBER: Well, maybe.

7 CHAIRMAN APOSTOLAKIS: It is a  
8 requirement. Why do you say it is not?

9 MR. WACHOWIAK: It is on the list of  
10 documents to be provided by the applicant.

11 CHAIRMAN APOSTOLAKIS: That's right. The  
12 question is how up to date should it be? I'm sorry,  
13 go ahead.

14 MS. CUBBAGE: Yes, there is a whole other  
15 effort going on to look at what would need to be  
16 submitted in the COL.

17 CHAIRMAN APOSTOLAKIS: Okay. So it is  
18 kind of open right now.

19 MS. CUBBAGE: Yes. That's why I'm kind --  
20 and they are still -- We are in the process of a Part  
21 52 rulemaking right now, and we are in the comment  
22 period.

23 CHAIRMAN APOSTOLAKIS: Well, that is the  
24 one where -- Sorry, Nick. go ahead.

25 MR. SIEBER It's a good question.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. SALTOS: Any difference that exists  
2 between the specification, the PRA and the actual  
3 plant here -- it has to be submitted, site specific  
4 characteristics. So any design changes, more details  
5 about the route of cabling and the piping and things  
6 like that have to be submitted at the COL stage. But  
7 it does not mean that they have to be updated for  
8 everything. If there is no PRA at the certification  
9 period, it is bounding.

10 MS. CUBBAGE: And you are saying, if you  
11 identified a common cause of failure that was not  
12 reviewed as part of the certification, if it rose to  
13 the level of an adequate protection issue or a  
14 compliance issue, we would have the forms back that  
15 certify the design.

16 CHAIRMAN APOSTOLAKIS: Well, let's say  
17 that it is not an issue of adequate protection. I  
18 mean, to reach that level is really hard. But suppose  
19 that we look more carefully. We have a plant specific  
20 PRA, and the core damage frequency now is  $10^{-7}$ . Okay?  
21 An order of magnitude greater, still very low but --

22 MS. CUBBAGE: That's an issue, a  
23 compliance issue, and they have met the ITAAC. We're  
24 done.

25 CHAIRMAN APOSTOLAKIS: So the only chance

1 in the future will be if the licensee wants to come  
2 back and invoke Regulatory Guide 1174, in which case,  
3 of course, they have to have a good PRA.

4 MR. SIEBER: That's a choice.

5 MR. SALTOS: But they can demonstrate,  
6 though -- They can demonstrate that the assumptions  
7 they were making in the certification PRA, they were  
8 bounding, and any details having to do with -- about  
9 piping and cabling and things like that, and site  
10 characteristics, they are in the law by the  
11 assumptions they are making in the certification PRA,  
12 and the only way there is to go is down, not up. Then  
13 they conclude not to make changes to the PRA.

14 CHAIRMAN APOSTOLAKIS: Well, yes, what you  
15 are saying is that, even if they do all these things,  
16 and even if they update it, it would be the same.  
17 That's really what you are saying.

18 DR. WALLIS: Well, this may be true of  
19 fires, but I am not at all sure that the assumption  
20 that this core capture works with 99 percent  
21 efficiency is bounding. You keep using the word  
22 bounding, but I mean --

23 DR. BONACA: That opens up the issue of,  
24 again, what is within the licensing basis and even  
25 beyond the licensing basis. Are they bound, you know,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 in the results for --

2 MS. CUBBAGE: If the design feature is a  
3 BiMAC, they would be bound to that. That was provided  
4 in the whole document, and they would have to.

5 DR. BONACA: Yes, and I understand that.  
6 Of course, they wrote that. But the results of  
7 whatever they configure, I mean they vary once you  
8 begin to do more accurate calculations. So --

9 MS. CUBBAGE: That's a regulatory issue we  
10 will have to deal with during the review, and you will  
11 be hearing about it then.

12 MR. WACHOWIAK: One of the things that I  
13 had to save for my second or third to last slide for  
14 the day -- One of the things that is difficult with  
15 using the PRA in this manner or including it in the  
16 submittal at this point in the design is that the PRA  
17 is a little bit of a different animal than the design  
18 basis analysis.

19 In the design basis analysis, you say what  
20 has to happen, and you impose on that nonmechanistic  
21 failures of a limited manner and you say, okay, if you  
22 have any one failure -- And so it is easy going from  
23 a preliminary design to a final design and keep that  
24 framework intact.

25 CHAIRMAN APOSTOLAKIS: That's correct.

1 MR. WACHOWIAK: In the PRA, though, we are  
2 trying to figure out -- We know what is supposed to  
3 happen, but what we also try to figure out is what can  
4 go wrong, and changing the details can change what can  
5 go wrong.

6 So if we, for example, which we may talk  
7 about later, we have our turbine building, and we had  
8 everything laid out. We looked at what the worst case  
9 flood scenario is, and on paper originally it looked  
10 like it was a circ water line break -- okay? --  
11 because so much water can get to anything. But now we  
12 see as they are building the actual rooms and things  
13 inside the building design, we find out that that  
14 flood has been isolated and ported to the outside.

15 This interior wall that wasn't originally  
16 part of the design now greatly affects in this  
17 particular one in a good direction what is in the PRA.

18 DR. SHACK: Was that wall added to address  
19 that?

20 MR. WACHOWIAK: No, no. It was added,  
21 because they were putting the walls in the building  
22 now. We didn't have that at the original. We are  
23 finishing in the details on the picture.

24 Then there are other places where we may  
25 find that there is some failure mode inherent to

1 equipment that is able to be purchased that we didn't  
2 think about before. So this failure mode would have  
3 to go in, and it could take us the other direction.

4 Now what we have tried to do in these  
5 uncertain things with external events -- Let me back  
6 up. With internal events, I think we have been  
7 working with PRA internal events on the mechanical  
8 systems and these electrical systems for -- I don't  
9 know. I've been messing with it for almost 20 years,  
10 and people have been working on it for a long time,  
11 and we think we know what we are going to see when we  
12 go and actually put equipment in.

13 On some of these new systems like the  
14 digital I&C and things like that, we are not quite  
15 sure what is going to happen. So we try to do things  
16 like this where we bound it.

17 We say, we will use what we think are  
18 bounding assumptions and come up with values that are  
19 low using bounding assumptions, so that later when we  
20 rough in the details or fill in the details from our  
21 rough idea that, yeah, maybe we have to refine some of  
22 this. We can't just use five. Maybe we have to do  
23 some fire propagation modeling or something, but in  
24 the end the conclusion still comes out to be the same.

25 Your point is a good one, though. If we

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 do this certification using this method and then, to  
2 get to the final answer we have to use a different  
3 method, where does that put Nick, the reviewer, in  
4 this then?

5 MR. SALTOS: Well, you still have to meet  
6 the assumptions. You are going to meet the  
7 assumptions that you make in the certification. You  
8 will not change this afterward.

9 CHAIRMAN APOSTOLAKIS: No, but they will  
10 make a difference, because --

11 MR. SALTOS: We might have to make some  
12 different assumptions.

13 CHAIRMAN APOSTOLAKIS: Then you review it  
14 again.

15 MR. SALTOS: We will come up with some  
16 additional requirements at the COL stage.

17 DR. BONACA: I need to understand better.  
18 You said something about the core capture now, and  
19 there will be commitments based on that, because they  
20 put it in their design. So now there is another  
21 manufacturer that comes in tomorrow and has a design  
22 that still has a core damage frequency of  $10^{-8}$  and has  
23 no core capture. Okay, are you certifying that  
24 design?

25 MS. CUBBAGE: Do you mean different plant

1 altogether?

2 DR. BONACA: Say there is another BWR  
3 designer that comes in with a design, and there is no  
4 core capture, but -- What is the regulation? I mean,  
5 you probably would certify that, too, because I mean,  
6 if you can convince yourself that there is such a low  
7 risk.

8 So I am trying to understand, you know.  
9 Until now, it seems to me, the regulation was very  
10 specific on what you had to do, and what you do beyond  
11 that was like out of the -- discretionary. But it  
12 seems to me now that the process we are using to  
13 define different requirements is based on what the  
14 promise from the designer is.

15 I can't understand. What is the  
16 requirement for a core capture?

17 MS. CUBBAGE: Well, I guess Rick is going  
18 to speak to -- maybe not today, but at some point in  
19 the future, what happens if the core capture doesn't  
20 work, and what would happen to the PRA results, the  
21 Level II results. I don't know.

22 MR. SIEBER: What does the NRC require?  
23 I guess -- I think that's the question Mario is  
24 asking.

25 MS. CUBBAGE: We can do this later when --

1 Let Rick get through this. We will come back to this.

2 DR. KRESS: It seems to me, though, it is  
3 something akin to ice condenser or suppression tube.  
4 They are not required, but if a designer chooses to  
5 come in with them, the staff will evaluate it and see  
6 if it meets the design basis.

7 DR. BONACA: Well, I heard something  
8 different here. I heard that the core capture, which  
9 we have seen, was not required for -- really is not  
10 required for the criteria we use to license plants  
11 today, because you have a core value --

12 DR. KRESS: Why wouldn't that invoke  
13 defensiveness?

14 MS. CUBBAGE: At Part 52, there are  
15 requirements to address failure accidents. So it has  
16 to address it, and the manner in which they do it is  
17 up to the choice of the designer.

18 MR. WACHOWIAK: There is all sorts of  
19 interesting questions associated with that now. Let's  
20 say, hypothetically, we come up with a way between now  
21 and when we build the plant to eliminate that 90  
22 percent of the CDF that is associated with those low  
23 pressure events, and all the ones that we remove,  
24 though, are the ones that have low water level in the  
25 drywell, and all that's left are the ones with high

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 water level in the drywell. What does that mean?

2 We have improved the plant, but we have  
3 challenged one of the acceptance criteria of a  
4 conditional containment failure probability. So how  
5 does that play into any of this?

6 DR. DENNING: Although, we don't really  
7 have a conditional -- I mean, people have talked about  
8 it, but we don't really have a conditional. We have  
9 an absolute at the moment. So you haven't made it  
10 worse in that respect.

11 CHAIRMAN APOSTOLAKIS: So why don't we go  
12 ahead now, and maybe we can come back to this.

13 MR. WACHOWIAK: The scope of the analysis  
14 that we have included basically are these particular  
15 buildings, and the reason that we picked these  
16 buildings are these are the buildings that contain the  
17 equipment that is modeled in the PRA. So we assume  
18 that any other buildings that are out there, they can  
19 burn.

20 One thing that is maybe a little different  
21 than that is where the diesel driven firewater pump  
22 is. We did screen that one out based on that not  
23 causing an initiating event. So even though it is in  
24 the PRA, it could give us a degraded state, it doesn't  
25 lead to any sort of challenge to the plant, and in the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealgross.com](http://www.nealgross.com)

1 end that would be something like an A4 evaluation  
2 would need to deal with, with the operation.

3 CHAIRMAN APOSTOLAKIS: Let me understand  
4 that. It doesn't lead to any sort of initiating  
5 event?

6 MR. WACHOWIAK: The diesel driven fire  
7 pump is used as a backup to the backup to injection  
8 into the vessel and into the pools up on top. If we  
9 have a fire in that room, we may lose that level of  
10 redundancy, but it doesn't affect anything to do with  
11 the operation of the plant. So there is no  
12 perturbation there.

13 CHAIRMAN APOSTOLAKIS: The plant would not  
14 be shut down?

15 MR. WACHOWIAK: The plant would not be  
16 shut down. They would probably go into an LCO based  
17 on some fire protection thing, and they would have to  
18 get that repaired based on fire protection rules. We  
19 might go into a manual shutdown if they can't get it  
20 repaired in 30 days or something like that.

21 CHAIRMAN APOSTOLAKIS: But that's when you  
22 would do an A4 analysis.

23 MR. WACHOWIAK: We may do an A4 analysis.  
24 That would be -- I believe that is required of the  
25 Part 52 plans. I don't think 50-69 goes away, or does

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 it?

2 In Rev. 1 they are including full power  
3 and shutdown modes, plant operation. We have added  
4 the shutdown -- or are in the process of adding the  
5 shutdown in response to an REI. it was pointed out,  
6 and I believe correctly, that we should have  
7 considered the shutdown mode for fire and flood, and  
8 that is ongoing.

9 We use bounding assumptions here. Now we  
10 are trying to compensate for the level of design  
11 detail where we are not really sure where things are,  
12 but we know in the design from the fire hazards  
13 analysis where they are supposed to go. So we don't  
14 know if a cable goes through this Div. 1 chase or this  
15 Div. 1 chase, but we know it is in one of those Div.  
16 1 chases.

17 So what we did was we said that let's  
18 start with the fire. We will use a fire ignition  
19 frequency. We are not going to do any fire modeling  
20 at the first cut. Any fire that starts in any fire  
21 zone is going to cover everything in that fire zone.  
22 But then to cover the uncertainty of what is in each  
23 particular room in those zones, we are just going to  
24 say it gets everything in that division.

25 So even though the division may be on this

1 corner, this corner or this corner -- they are not  
2 really like that, but even if it was like that, we  
3 would say it gets all of those, mainly because we  
4 don't really know the routing. So that is a bounding  
5 assumption that we have there.

6 We also didn't credit the fire protection  
7 system for suppressing the fire at this point. That  
8 is a detail that is unknown and, as we mentioned  
9 earlier, we postulated our worst case spurious  
10 actuation, which in the reactor building is the  
11 inadvertent open relief valve. In the -- trying to  
12 remember if there are any other buildings that have  
13 those. I don't believe -- Now in the control room we  
14 also postulated the inadvertent open relief valve.

15 DR. DENNING: What happens if you activate  
16 the squib that drains the gravitational -- the water  
17 pool?

18 MR. WACHOWIAK: Actuate the squib that  
19 drains the pool to actuate the BiMAC?

20 DR. DENNING: Yes.

21 MR. WACHOWIAK: That's a good question.

22 DR. WALLIS: It drains.

23 MR. WACHOWIAK: It would drain, and I  
24 think we would have to look at that, and we will have  
25 to look at how we protect against that. Right now,

1 that is kind of covered under our blanket design  
2 assumption that it's got to be reliable under all  
3 credible sequences to actuate and to not spuriously  
4 actuate. So we would have to address that in the  
5 design and how that -- Maybe that equipment needs to  
6 be in separate special fire zones. I don't know.

7 DR. WALLIS: Does the explosive ignite in  
8 the scope valve in a fire?

9 MR. WACHOWIAK: Not necessarily. It  
10 depends on how the control system is set up.

11 MR. SIEBER: No, he is talking about the  
12 heat on the explosive.

13 MR. WACHOWIAK: Oh, the explosive is  
14 inside the drywell, inside the containment. The fire  
15 wouldn't be there, because that is a nitrogen  
16 environment. The fires are in other buildings outside  
17 your --

18 DR. WALLIS: So they don't affect the  
19 valving?

20 MR. WACHOWIAK: They don't affect the  
21 squib itself. it affects the control system.

22 DR. ARMIJO: The control system could  
23 activate the squib. Right?

24 MR. WACHOWIAK: The control system could  
25 activate the squib, and that is why that it needs to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 be diverse; because otherwise we would have a  
2 potentially greater impact if we, let's say, hook  
3 these squib valves into the normal ECCS digital  
4 control system. Then maybe some of those fires could  
5 cause activation of the deluge system, but the current  
6 thinking is that we are probably not going to be able  
7 to meet our goals if we connect it into the existing  
8 ECCS digital control system.

9 DR. DENNING: Now your assumption is the  
10 fire barriers are perfect. There is no -- You don't  
11 have any probability of failure or fault in a --

12 MR. WACHOWIAK: Let me put up this slide.  
13 In Revision 0, that was correct. We asserted that  
14 this assumption was bounding, and we didn't need to go  
15 there.

16 Now the question is, though, is there a  
17 worse case if the fire goes from this one compartment  
18 of Div. 1 to this other compartment of Div. 2? Is  
19 that worse than all of Div. 1 together going?

20 So in this current revision what we have  
21 done is we have postulated the failure of one fire  
22 barrier, and we have given a probability based on the  
23 latest EPRI fire PRA methodology. There is a table of  
24 data for fire barriers. We included that for the  
25 failure probability, and looked at propagating.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1           Now we also -- and this is probably  
2 overkill, I think, but we used the same assumption.  
3 if it propagated from 1 to 2, then we lose everything  
4 in 2, when in fact, it really would be a subset that  
5 I am not sure how we define at this point.

6           So we start getting into a place where we  
7 do that. Yeah, I understand that it is a realistic  
8 concern, but we made -- The conservative assumption  
9 here may be a little too conservative by the time we  
10 get to that point. So we got to figure out how to  
11 deal with that.

12           What we find in -- and I think in our  
13 results -- in the reactor building, for example, where  
14 we would have thought that that was the biggest  
15 concern, it didn't cause us a problem. All of these  
16 fire scenarios -- in all but one place, they are all  
17 3 times  $10^{-10}$ , 2 times  $10^{-10}$ , -11, 12, truncated. they  
18 are all very small things except for one, the fire in  
19 the turbine building.

20           The fire in the turbine building is an  
21 interesting thing. the turbine building is huge. It  
22 contains a lot of equipment that can initiate fire.  
23 So it has a fairly high initiating frequency, but as  
24 we said before, we didn't have a lot of details on  
25 what was there.

1                   So we said, okay, we will apply our  
2 assumptions: Fire in the turbine building gets  
3 everything. If that happens, what would that act  
4 like? The loss of feedwater. What was our highest or  
5 one of our highest core damage events? Loss of  
6 feedwater. And basically, what this does is, using  
7 all those assumptions, we end up with this sequence  
8 here that basically is a ratio of the loss of  
9 feedwater initiating event to the fire ignition in the  
10 turbine building initiating event. It is basically  
11 that same thing.

12                   So we are trying to figure out what we  
13 need to do with this under that original statement  
14 there that the sum of all these needs to be less than  
15 the internal events CDF. It meant we didn't have to  
16 deal with this.

17                   DR. WALLIS; I'm puzzled by this. I read  
18 the document. I felt the control room was the -9  
19 event. I don't understand why all the fire scenarios  
20 have the lower than 3 and  $10^{-10}$ .

21                   MR. WACHOWIAK: We've looked at the fire  
22 in the control room event.

23                   DR. WALLIS: Something changed since --

24                   MR. WACHOWIAK: And it has changed since  
25 then.

1 DR. WALLIS: It's changed since the  
2 document I read. Okay.

3 MR. WACHOWIAK: Right. And unfortunately,  
4 that is one of the documents that we are still working  
5 on.

6 DR. WALLIS: So this is clearly a  
7 preliminary meeting.

8 MR. WACHOWIAK: For the most part, yes.

9 DR. WALLIS: We are going through the  
10 details.

11 MR. WACHOWIAK: And for us, this --

12 DR. WALLIS: It would be better if I  
13 hadn't read it at all, I think.

14 MS. CUBBAGE: Well, it is preliminary,  
15 because the staff hasn't reviewed it. There may be a  
16 lot of changes that may come from this, additionally.

17 MR. DENNING: But it is still worthwhile.

18 MS. CUBBAGE: So this was supposed to be  
19 an introductory.

20 MR. WACHOWIAK: We went through it in Rev.  
21 0. We have got some feedback from the staff. As we  
22 were implementing this feedback, we made some changes  
23 to the model, and the changes that we made during that  
24 time frame affected the fire in the control room.

25 DR. WALLIS: If you have a fire in the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 turbine building, it affects the entire building?  
2 I don't see how that can happen.

3 MR. WACHOWIAK: It can't. It can't. This  
4 is bounding assumption here. In this particular  
5 scenario, that bounding assumption is not appropriate.  
6 So we know it is lower than that. How much lower is  
7 something that we haven't gotten into yet, and that is  
8 part of the issue with trying to do these things in a  
9 bounding manner and trying to go through these with as  
10 little perturbation on the people who are adding in  
11 the detailed design of things. We don't want to have  
12 to force things to happen inside that building that  
13 really aren't going to -- we don't want to be a  
14 requirement later on.

15 We tried the bounding assumption. Maybe  
16 we will keep the bounding assumption. We don't know,  
17 and maybe we will keep it going on at 4 times  $10^{-8}$  for  
18 CDF. That could be okay.

19 DR. DENNING: But if there is anyplace you  
20 can have a huge fire, that's where it is.

21 MR. WACHOWIAK: If there is anyplace for  
22 one, that's where it is. The question, though, is:  
23 Is a huge fire a sudden loss of feedwater? So there  
24 may be some small subset of fires that become a loss  
25 of feedwater, and the others are a loss of condenser.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 Loss of condenser is clearly a more benign accident.

2 That's the kind of thing we would want to  
3 look at, but once again, the question is do we need to  
4 pursue it or is there some reason that we would want  
5 to look at that for optics? You know, let's say we  
6 get rid of all the internal events things, and now  
7 we've got fire. CDF is 10 times the internal events,  
8 CDF again and, you know, what does that do to what we  
9 -- It's really a balancing act to try to figure out  
10 how to do things with these external events at this  
11 stage.

12 DR. WALLIS: So you redesign the turbine  
13 building.

14 MR. SIEBER: It's pretty tough.

15 DR. WALLIS: Put another wall in there.

16 MR. WACHOWIAK: Maybe.

17 MR. SIEBER: You could have a lot of  
18 little turbines.

19 MR. WACHOWIAK: Well, but what we could do  
20 in that case is do a better separation of the  
21 feedwater room from the turbine building. That could  
22 be done, and maybe it is being done. We just don't  
23 know.

24 MR. SIEBER: It still comes from the hot  
25 well, which is connected to the turbines. That's

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 where all the oil is.

2 MR. WACHOWIAK: Well, the issue that we  
3 have with the loss of feedwater isn't just because we  
4 lose feedwater. It's the sudden loss of feedwater  
5 that causes the problem in the PRA -- or that causes  
6 the scenario that leads to the numbers in the PRA.

7 So if we could somehow delay the total  
8 loss of feedwater, make it a staged loss of feedwater,  
9 we could make it better, too.

10 CHAIRMAN APOSTOLAKIS: What happens in the  
11 scenario that you are preventing -- with the squib  
12 valves? Did you dismiss that or you said you are  
13 going to look into it?

14 MR. WACHOWIAK: We are going to look into  
15 it. We don't -- didn't have any information yet on  
16 where any of that control equipment was. So now we've  
17 got the design requirement that it's got to be  
18 reliable to actuate and reliable to not actuate when  
19 it is not supposed to, and that would clearly fall  
20 into this fire category, not actuating when it is not  
21 supposed to.

22 The shutdown results: These are still for  
23 fire. They are still too preliminary for me to  
24 present at this point. We do have one insight from  
25 that that I will present in the shutdown -- as much as

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 people don't like the word insight, but it --

2 MR. MAYNARD: Some of us don't like it.

3 MR. WACHOWIAK: Okay, but we think we have  
4 learned something from what we have done so far in the  
5 fire -- shutdown fire PRA.

6 MS. CUBBAGE: That's coming later today?

7 MR. WACHOWIAK: Later today? No, the  
8 shutdown discussion is coming later.

9 MS. CUBBAGE: Yes, okay.

10 MR. WACHOWIAK: Yes, and I put the insight  
11 from the fire during shutdown in the shutdown  
12 discussion.

13 CHAIRMAN APOSTOLAKIS: So but you are  
14 still doing this analysis?

15 MR. WACHOWIAK: We are still doing this  
16 analysis.

17 CHAIRMAN APOSTOLAKIS: So you are using  
18 the word insight correct. That means we are not done.

19 MR. WACHOWIAK: That's right. We are not  
20 done.

21 CHAIRMAN APOSTOLAKIS: It isn't real yet.

22 MR. WACHOWIAK: Okay. So let me move on  
23 to the probabilistic flooding analysis. Once again,  
24 we don't know a real lot about where everything goes  
25 in the building. So we had to make some sort of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 estimates, and we used experience with flooding in  
2 existing BWRs.

3 So there's data on there about how often  
4 there is a fire main break. There is data on there  
5 how often there is a circ water line break, and we  
6 applied those to our different buildings.

7 This is a little bounding here where the  
8 data says that the probability of a fire main break is  
9 -- I'm trying to remember the numbers -- somewhere  
10 around 3 times  $10^{-3}$  per year, and what we did was we  
11 applied that 3 times  $10^{-3}$  to every building. So we  
12 didn't try to apportion it, like you would if you  
13 tried to say what is the total.

14 CHAIRMAN APOSTOLAKIS: Let me raise  
15 another question here regarding the fire before we go  
16 on.

17 You said that a fire in the turbine  
18 building basically will cause loss of feedwater flow  
19 and that you go to that event tree.

20 MR. WACHOWIAK: It is that event tree with  
21 some other effects in there, too.

22 CHAIRMAN APOSTOLAKIS: Oh, that was the  
23 adjustments to the other --

24 MR. WACHOWIAK: Yes, there are other.

25 CHAIRMAN APOSTOLAKIS: -- and may be

1 possibly affected by the fire. Right?

2 MR. WACHOWIAK: Right. The reactor closed  
3 cooling water system is in there. So that system  
4 would be affected. The instrument air system is in  
5 there. So that system would be affected.

6 CHAIRMAN APOSTOLAKIS: Okay, because I was  
7 looking at the sequence. So you did that, and even if  
8 you do that, it's still  $10^{-8}$ ?

9 MR. WACHOWIAK: Yes. There are really  
10 secondary effects. It's the things that are contained  
11 in the reactor building are what are providing our  
12 protection in that scenario.

13 CHAIRMAN APOSTOLAKIS: Okay.

14 MR. WACHOWIAK: Okay. So the initiator  
15 for this is somewhat bounding, because now, instead of  
16 using the industry experience, we are using one, two,  
17 three, four, five, six times the industry experience,  
18 in effect. But we don't know where to apply all those  
19 things. So we just did them all and let it go at  
20 that.

21 We did include full power in shutdown  
22 modes for this, and we will talk about both of those  
23 modes here. We are far enough along in the shutdown  
24 to talk about it, at least.

25 MR. DENNING: What about design

1 principles? I mean, that's what is so great about the  
2 fire analysis, is that it tells you what design  
3 principle should I use. I mean other than separation,  
4 but are there design principles to minimize the impact  
5 of floods on risk that you are taking into account?

6 MR. WACHOWIAK: Yes, and I'm not sure  
7 exactly where I got to this on the slide, but for  
8 example, one of the things that we found is that the  
9 fire code is not necessarily helpful to us in  
10 preventing floods.

11 It is there looking at one specific thing,  
12 and when they make the regulations for the one  
13 specific thing, they tend to affect other things in a  
14 way we don't like.

15 In our control building, which is mostly  
16 underground, we have to have a fire protection system.  
17 Now the equipment that is in there we have minimized -  
18 - or we have eliminated anything that needs sprinklers  
19 or anything like that, but the code still says you  
20 have to have hose stations, and the typical design is  
21 you go into your stairwells and you run your fire main  
22 through the stairwell, and you have hose stations at  
23 the various things that nobody is ever going to use.

24 When we looked at that, we said, well,  
25 wait a minute. If you have a break of one of these

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 fire mains and you fill up the stairwell, you exceed  
2 the capacity of your flood doors if you put those down  
3 in there. They will open, and that will affect  
4 everything in that building. What can we do? What  
5 can we do to fix this?

6 Well, after some discussions with the  
7 designers, we said, well, let's not put the fire main  
8 inside the building. Let's put the fire main outside  
9 the building in its own chase, and then we just have  
10 a little two-inch stub tube that comes through the  
11 wall.

12 So we have effectively minimized the  
13 probability that we are going to have a large fire  
14 main break in that control building, because we were  
15 able to take our insight and move the pipe outside.  
16 So that is one of the cases where we --

17 DR. WALLIS: As long as the pipe breaks  
18 and not the stub connection.

19 MR. WACHOWIAK: The stub connection --  
20 One, it is very short. So we were able to reduce the  
21 probability there, and that's what we did, was by  
22 reducing the frequency.

23 DR. WALLIS: Usually, it's a break from an  
24 inadvertent water hammer. That can pop the stub off  
25 or it could break the pipe.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. SIEBER: Or a seismic event.

2 MR. WACHOWIAK: Cause a seismic event?

3 MR. SIEBER: Differential movement between  
4 the pipes.

5 DR. WALLIS: The things that have happened  
6 in plants have usually been water hammer related, I  
7 think.

8 MR. WACHOWIAK: Right.

9 DR. WALLIS: Someone inadvertently drained  
10 the main and then turned the water on.

11 MR. SIEBER: Pressure is pretty low.

12 MR. WACHOWIAK: Some of the things that  
13 mitigate those, though, are that there are sumps  
14 there, and there are ways to get the water out. If it  
15 is a two-inch line, we can get the water out with  
16 ease. If it is a six-inch line, we would have a  
17 pretty hard time with that.

18 So we have tried to look at these things  
19 and make it reasonable. We are not trying to impose  
20 requirements that could never be met. So anyway --  
21 So that is one of the ways that we have addressed some  
22 of those.

23 Other ways are that cables have to come  
24 from the control building or connections have to come  
25 from the control building into the reactor building.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 We don't want to have a flood that can affect both of  
2 those buildings. We would like it to be confined to  
3 one or the other.

4 So as part of the PRA, we are specifying  
5 the minimum height that that connection can be, and we  
6 don't have water sources on site that can flood up to  
7 that level. So there are several places where we are  
8 folding what we know from the flood PRA back into the  
9 design.

10 MR. SIEBER: I have a question. If you  
11 look at this picture, which is on the cover, most of  
12 this is underground?

13 MR. WACHOWIAK: Much of that is  
14 underground.

15 MR. SIEBER: So how do you get the water  
16 out of a flooded compartment? You have sump pumps?

17 MR. WACHOWIAK: There are sump pumps.

18 CHAIRMAN APOSTOLAKIS: Which part is  
19 underground, Jack?

20 MR. SIEBER: If you look at where the  
21 steam piping comes out, right below -- It's right  
22 below where those pipes run.

23 MR. WACHOWIAK: The core is underground.  
24 Right?

25 MR. SIEBER: Most of what is on this

1 picture is underground. So you have to have sump  
2 pumps, which means that you are dependent in the flood  
3 scenario on providing electric power to operate the  
4 sump pumps. Otherwise, everything will flood up.  
5 Right?

6 MR. WACHOWIAK: Right. Now what we did in  
7 the flood PRA is we didn't -- Other than places like  
8 where we looked at that in the control building, for  
9 the reactor building we didn't take credit for the  
10 sump pumps. What we looked at was, if you had a pipe  
11 break and you put all the water from that pipe break  
12 in there, where does it go? And we failed the  
13 equipment that is associated with those levels.

14 Now what we did look at is, if you have  
15 flood doors -- let's say they are rated for some  
16 elevation of water, and we greatly exceed that  
17 elevation of water. We'll say that the door will open  
18 to allow it to spread to the different rooms, but we  
19 didn't take credit for the sump pumps.

20 MR. SIEBER: Have you analyzed to see the  
21 extent to which you can flood a room to the point  
22 where everything becomes inoperable, since you don't  
23 have gravity drains?

24 MR. WACHOWIAK: In the PRA our assumption  
25 is that, if the room is flooded, the equipment will

1 fail.

2 MR. SIEBER: Right.

3 MR. WACHOWIAK: Okay. That's our  
4 assumption. In the deterministic flood analysis, they  
5 look at whether the equipment will fail due to  
6 specific things like water being sprayed on it or  
7 other things. But the deterministic flood analysis  
8 really has some different set of ground rules applied  
9 to it.

10 For example, a fire main can't break in  
11 that analysis. It can only leak, and there's various  
12 other things in the rules for that. So that we didn't  
13 try to take credit for it here.

14 CHAIRMAN APOSTOLAKIS: Let's go on.

15 MR. WACHOWIAK: Okay. Once again, I  
16 explained, I think, where I got the number for at  
17 power. For shutdown, we had to look around for that.  
18 We didn't really have a flood during shutdown  
19 reference that we could use.

20 We found some operating experience for  
21 BWRs in a NUREG, and we looked through the different  
22 flooding events and came up with a flooding  
23 probability based on those.

24 CHAIRMAN APOSTOLAKIS: Maybe you said it,  
25 Rick, and I missed it. But based on the general

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 information contained in these reports, these reports  
2 presumably have flooding frequencies for existing  
3 BWRs. Correct?

4 MR. WACHOWIAK: Yes.

5 CHAIRMAN APOSTOLAKIS: These plants don't  
6 have gravity driven pools and so on. So I mean, I  
7 wonder whether these frequencies are applicable.

8 MR. WACHOWIAK: We don't have gravity  
9 driven pools in any of the buildings that we are  
10 looking at here either. Those are in the -- Those are  
11 all in the reactor building.

12 CHAIRMAN APOSTOLAKIS: Right. So I mean,  
13 shouldn't you be doing something about the flooding  
14 frequencies, since you got so much water now all over  
15 the place?

16 MR. WACHOWIAK: The water that we have all  
17 over the place is inside the containment. We will  
18 talk about that during shutdown. That's the time when  
19 the water can get out of the containment and into the  
20 reactor building. But in general, though, the water  
21 sources are the same as existing plants. We've got --

22 CHAIRMAN APOSTOLAKIS: It comes back to  
23 the question from Rich. What if these squib valves  
24 are actuated?

25 MR. WACHOWIAK: That's all inside the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           containment.

2                   DR. WALLIS:   It's just all the water in  
3           the sump. That's all. That's all there is.

4                   MR. SIEBER:   Yes. You've got to have  
5           water in containment someplace. You can have it  
6           anywhere.

7                   CHAIRMAN APOSTOLAKIS: All right.

8                   MR. WACHOWIAK:   But we do have other  
9           gravity driven -- or gravity draining things that we  
10          looked at. If we break off a CRD suction line inside  
11          the reactor building, our assumption is that the whole  
12          CST goes into the reactor building. Okay? That's  
13          pretty much a bounding assumption there.

14                   MR. SIEBER:   And how big is the CST for  
15          this plant?

16                   MR. WACHOWIAK:   Oh, that's a question I  
17          wasn't prepare to answer. It floods --

18                   MR. SIEBER:   A quarter million gallons?

19                   MR. WACHOWIAK:   It's a substantial flood  
20          in the reactor building. Matter of fact, it moves all  
21          the way to the --

22                   CHAIRMAN APOSTOLAKIS: Rick, can I show my  
23          ignorance here. You guys dismissed it, you know. The  
24          water goes down the sump. Big deal. I mean, don't you  
25          have anything there? Where are the control rod

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 drives? Or is it too high? You said yesterday it is  
2 what, several meters?

3 MR. WACHOWIAK: If we -- If two of the  
4 GDCS pools are drained into the lower dry well, we do  
5 know that it will flood up above the core inside the  
6 dry well.

7 CHAIRMAN APOSTOLAKIS: Okay. So there is  
8 no --

9 MR. WACHOWIAK: We might lose the fine  
10 motion control rod drives, but the hydraulic actuation  
11 of the control rods would not be affected by that.

12 DR. WALLIS: That's water on water.

13 MR. SIEBER: Yes.

14 MR. WACHOWIAK: So it is not discounted.  
15 It is just not specifically there yet.

16 CHAIRMAN APOSTOLAKIS: Oh, it will be?

17 MR. WACHOWIAK: Yes. I think we have to  
18 look at the spurious operation of those, and what we  
19 would do once we got to the spurious -- Maybe the  
20 answer is nothing, but it's still something that --

21 I hit the wrong key. There we go.

22 The major water sources that we -- We went  
23 through, and we looked at the water sources in the  
24 different buildings. We've got the fuel and aux. pool  
25 cooling system that is connected to various pools

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 there.

2 That actually is one way that you might be  
3 able to get water from one of these pools outside of  
4 the dry well and into the reactor building, if there  
5 is a break and we turn that system on. But once  
6 again, that would be something where it would be an  
7 infrequent event, and it would be an event that was  
8 being controlled by the operators during that time,  
9 and isolable. So it's recoverable.

10 Reactor water cleanup and shutdown  
11 cooling: That is operating all the time. Once again,  
12 that is provided with safety related automatic  
13 isolations there. So there would be a limited water  
14 source from that.

15 Reactor component cooling water system:  
16 It is a closed cooling water system. It's got a  
17 limited inventory. We have taken a look at what kind  
18 of floods we can get from that, and that is included  
19 in the analysis.

20 Fire protection system is also a fairly  
21 large source, and in the various places we looked at  
22 what was specified, whether it was wet pipe, dry pipe,  
23 what kind of alarms and isolations we would get to see  
24 where they would be effective. But those are included  
25 in the analysis.

1                   Feedwater system: If we have a feedwater  
2 pipe break, what does that do to these various  
3 scenarios? The feedwater pipe break outside  
4 containment -- or in the steam tunnel would not be  
5 much different from what we have seen in the rest of  
6 our analysis, but once again we are looking into what  
7 those different feedwater pipe breaks might mean to  
8 the different scenarios.

9                   Again, the feedwater pipe break, we don't  
10 think, will cause a total loss of feedwater, because  
11 we will lose that one train. The other train comes up  
12 to speed with our aux. -- our adjustable speed drives  
13 very quickly. That is what they are designed to do,  
14 to make up for that before we would get any flooding  
15 from this feedwater system that would affect multiple  
16 trains.

17                   In the control building, our major water  
18 source --

19                   DR. WALLIS: What do you use for frequency  
20 of feedwater pipe breaks? Where do you get that from?  
21 Get it from a NUREG? Just count all the -- or only  
22 for BWRs? Do you just count all the PWR line breaks?

23                   MR. WACHOWIAK: The way we did the  
24 feedwater line break was we got the number from our  
25 LOCA analysis from internal events for the feedwater.

1 From the NUREG we got things like fire pipe breaks and  
2 service water pipe breaks and circ water pipe breaks.

3 DR. WALLIS: Your feedwater design is the  
4 same as it would be for existing BWRs?

5 MR. WACHOWIAK: No. It is much better.

6 DR. WALLIS: It's much better? You know,  
7 in feedwater design you got to be careful about water  
8 hammer when you are putting cold water into the steam  
9 area. I assume that you have done it right, but who  
10 knows? I'm a bit concerned about applying sort of  
11 existing old data to a new design.

12 MR. WACHOWIAK: In the control building  
13 we've got a chilled water system, very limited amount  
14 of water there, potable water, small; fire protection  
15 system, and we talked about that earlier, how we  
16 arranged that so that the big pipes are outside the  
17 building.

18 Fuel building: Once again, we can go  
19 through these. I don't know if we need to go in  
20 detail through each of the different areas.

21 DR. WALLIS: No, we don't.

22 MR. WACHOWIAK: The turbine building here  
23 -- the circ water that we think may have already been  
24 addressed in the detailed design.

25 Service water building: We looked at that

1 as a separate area, and kind of determined that that  
2 really acts like a loss of service water. So we  
3 didn't model it further.

4 The way we did these were we identified  
5 all these various scenarios that could potentially  
6 have floods and damage equipment. So for each given  
7 building, we applied the total flood frequency and  
8 calculated each of those three scenarios, and then we  
9 took the maximum of those three scenarios and said  
10 this is the reactor building flooding core damage  
11 frequency. We didn't try to split things apart for  
12 those different buildings.

13 So it is kind of a maximum type analysis  
14 where we had multiple for different -- for the same  
15 building.

16 Shutdown flooding scenarios: Once again  
17 we looked at different things, applied basically the  
18 same type of parameters -- or same type of method.

19 So what did we come up with? Internal  
20 flooding: It is not a dominant feature or factor in  
21 overall plant risk. Contribution is an order of  
22 magnitude less. So maybe you want to say this is, you  
23 know, 3.4 now or whatever.

24 CHAIRMAN APOSTOLAKIS: When did the events  
25 become 2.9? It was 3.1.

1 MR. WACHOWIAK: Rev. 0, it was 3.1.

2 CHAIRMAN APOSTOLAKIS: And meanwhile it  
3 was 8. The trend is right. Right? It's probably an  
4 earlier version I have.

5 MR. WACHOWIAK: It is.

6 DR. WALLIS: Now what I read -- again, I  
7 must have the earlier version. Was I --

8 MR. WACHOWIAK: This one went up. Right?

9 DR. WALLIS: Two orders of magnitude since  
10 I read it.

11 MR. WACHOWIAK: Okay. Now this is what  
12 happened since you read it. I'm thinking that the  
13 number that you have is probably better.

14 DR. WALLIS: And it might go up two orders  
15 of magnitude again.

16 MR. WACHOWIAK: Since you -- When you --  
17 or we created the document that you have, we didn't  
18 recognize what the -- We did not recognize that  
19 scenario with the loss of feedwater as having the  
20 sequence of events that it did, when we did the  
21 flooding analysis early on.

22 Later in the -- I guess this is the PRA  
23 phase -- we recognized that change to the loss of  
24 feedwater event and, when we got to Rev. 1, we had not  
25 gone back and fed that back in.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 DR. WALLIS: That overwhelms my thought,  
2 all the other events.

3 MR. WACHOWIAK: That's right. Just like  
4 fire, that is where the most of the flood probability  
5 comes from, is from that turbine building.

6 DR. WALLIS: So you got an insight from  
7 that, that maybe you should do something about the  
8 design.

9 MR. WACHOWIAK: And the designers, we  
10 think, may have already taken care of it for us before  
11 we even got it.

12 DR. WALLIS: Now I would not go into the  
13 details here, but when I looked at the event tree, I  
14 found that you had sort of had numbers that  $1E^{-2}$  for  
15 drains not obstructed, just appeared,  $1E^{-3}$  for water  
16 type drains intact, which means presumably someone  
17 didn't leave them open.

18 These numbers look to me like engineering  
19 guesses.

20 MR. WACHOWIAK: We have removed those from  
21 Rev. 1.

22 DR. WALLIS: You removed all that stuff?

23 MR. WACHOWIAK: Right. We just looked at  
24 what the total flooding volume would be.

25 DR. WALLIS: Oh, you took out all the

1 stuff I read.

2 CHAIRMAN APOSTOLAKIS: Well, it seems to  
3 me they are going to have to revisit this.

4 MR. WACHOWIAK: I think so, and especially  
5 after the staff reviews what we have.

6 CHAIRMAN APOSTOLAKIS: We understand. Is  
7 there going to be a Rev. 2?

8 MS. CUBBAGE: Oh, yes.

9 DR. WALLIS: So we shouldn't read anything  
10 until we get to Rev. 10 or something?

11 CHAIRMAN APOSTOLAKIS: What should we  
12 review?

13 MS. CUBBAGE: AP1000, which was a delta  
14 above AP600. In AP1000 there are 15 revisions of the  
15 design control document and eight or 10 revs of the  
16 PRA.

17 DR. WALLIS: So what do we read?

18 CHAIRMAN APOSTOLAKIS: Well, there is an  
19 issue here, because we cannot have 10 supplementary  
20 meetings.

21 MS. CUBBAGE: This is an introductory  
22 meeting and --

23 CHAIRMAN APOSTOLAKIS: I understand that,  
24 but --

25 MS. CUBBAGE: -- when we get to the point

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 of the staff has completed their evaluation, that is  
2 when we are asking for your --

3 DR. WALLIS: Well, but then why did you  
4 give us something to read, assuming we wouldn't read  
5 it? We read it intelligently.

6 MS. CUBBAGE: If we hadn't given you  
7 something to read, then you would have --

8 DR. WALLIS: For the moment, we are asking  
9 about the details.

10 CHAIRMAN APOSTOLAKIS: But they are sure  
11 it is going to be a BWR. Right? Well, let me ask  
12 something I have here. When should the subcommittee  
13 meet again? I mean, we were thinking originally late  
14 September/early October. Now Rev. 1 will be ready by  
15 then. Right?

16 MS. CUBBAGE: We will have all of Rev. 1  
17 of the PRA within two weeks.

18 CHAIRMAN APOSTOLAKIS: No. We don't need  
19 it in two weeks. The question is: The document we  
20 will be reviewing in October is subject to more  
21 changes. I mean, should we postpone the subcommittee  
22 meeting then?

23 MS. CUBBAGE: I think it is beneficial to  
24 have the committee identify issues as early as  
25 possible, but there is also the risk of wasting time

1 with cycling through. So I think we will have to take  
2 a look at our review schedule for this area, see when  
3 it is convenient and the staff has maybe developed  
4 their FTR with open item input.

5 CHAIRMAN APOSTOLAKIS: Yes, but on the  
6 other hand, Rick also said yesterday that he is not in  
7 a position to change the PRA anytime we find  
8 something. I mean, we have to do our reviews in a  
9 relatively timely manner. Right?

10 MR. WACHOWIAK: Yes. I would like to have  
11 still in September the discussion on the methods for  
12 HRA and the methods for common cause, things that we  
13 think methodologically that you may want to see  
14 different in the PRA.

15 MS. CUBBAGE: Right.

16 MR. WACHOWIAK: But discussing which  
17 particular sequence happens to be the dominant  
18 sequence today may not be the most productive thing.

19 DR. WALLIS: I find a difficulty with  
20 that, because very often you get credibility by doing  
21 the details right. The devil often is in the details,  
22 and if your details keep changing or just being  
23 whisked away, then what do we review? How do you gain  
24 -- You are not going to gain credibility with an  
25 overview of stuff. We've got to be able to dig into

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 some examples in enough detail to be sure you've done  
2 a good job, and if those examples keep changing all  
3 the time, what are we going to review?

4 MS. CUBBAGE: Graham, I think -- Rick,  
5 correct me if I am wrong, but we are hoping that the  
6 delta from Rev. 0 to Rev. 1 will be the most  
7 significant one, and the increment will be smaller as  
8 we go on. And if now, we've got a big problem.

9 DR. WALLIS: Well, someday we are going to  
10 review something and then say yes or no, and we can't  
11 review it and you say, oh, but it's changed. That's  
12 no good. We are going to say no in that case. You  
13 will bring us something, and we are going to say yes  
14 or no. We are going to say yes or no on what we see,  
15 not on something that is going to be changed. Someday  
16 we are going to do that.

17 CHAIRMAN APOSTOLAKIS: I think what they  
18 are implying is that we may have to meet again more  
19 than once. I thought we were going to meet only once.

20 MS. CUBBAGE: I think we need an interim  
21 meeting to talk about methodologies, I think, would be  
22 useful. But when we get down to the point where the  
23 staff has an SER with open items, there will be the  
24 details and PRA that that is based on. So we will be  
25 looking to get feedback in a more concrete form at

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 that time.

2 CHAIRMAN APOSTOLAKIS: Okay. So we will  
3 probably have more than one supplementary meeting. So  
4 we will schedule one for sometime September/October.

5 DR. WALLIS: Well, I guess when you've  
6 got a committee letter, a committee letter will  
7 probably be based on something that is not going to  
8 whimsically change.

9 CHAIRMAN APOSTOLAKIS: That will be again  
10 informational.

11 DR. BONACA: But it seems to me that, you  
12 know, my expectation at this stage was, you know, how  
13 did the PRA lead you to certain things, and here we  
14 are interactively working design.

15 DR. WALLIS: That's good.

16 DR. BONACA: In October, it will be  
17 interesting to know -- to have some perspective of how  
18 you -- I think you gave it to us already today, but in  
19 part you just came in and you described the results of  
20 a configuration you have analyzed which is still up  
21 there. It will be interesting to see how you went  
22 into that, particularly with the design process, to  
23 get these results.

24 Yes, you did some of that today and  
25 yesterday, but --

1 DR. ARMIJO: I don't think that the  
2 details are changing whimsically at all. I believe it  
3 is part of the process. As they go through, they  
4 learn more. They make some changes, and I think it's  
5 all part of the process for where the design stands  
6 right now, and I don't think there is anything  
7 whimsical about it.

8 DR. WALLIS: When the numbers are changed  
9 by over two orders of magnitude -- there is a new  
10 event appears which wasn't there before. this seems  
11 to me a significant change, whether it is whimsical or  
12 not. It's something that might appear whimsical,  
13 since we didn't know it was going to happen.

14 DR. ARMIJO: But I would -- The fact that  
15 they have a few significant changes doesn't surprise  
16 me at this stage of the design and the stage of going  
17 through it.

18 CHAIRMAN APOSTOLAKIS: I think another way  
19 of looking at it is that we got involved too early,  
20 but we are learning.

21 MS. CUBBAGE: Well, I don't believe -- I  
22 think in the near future I need to meet with Eric and  
23 all of the other ACRS staff members and plot out more  
24 of a complete plan for interaction.

25 Just as a matter of reference, on AP600

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 there were six full Committee meetings, 37  
2 subcommittee meetings.

3 CHAIRMAN APOSTOLAKIS: Yes, but 36 of them  
4 were thermodynamics.

5 MS. CUBBAGE: And AP1000, 8 full  
6 committee, nine sub, again heavily weighted on the  
7 thermal hydraulics. So --

8 CHAIRMAN APOSTOLAKIS: No, I don't mind  
9 having more subcommittee meetings, because it really  
10 helps us.

11 DR. WALLIS: Well, we are going to apply  
12 thermal hydraulic standards to the PRA now.

13 MS. CUBBAGE: Oh, we are looking at it.

14 DR. WALLIS: When the things change by two  
15 orders of magnitude from one day to another --

16 MS. WACHOWIAK: I also want to say, yes,  
17 once again we didn't change -- we are not changing  
18 things whimsically. It's like they were saying. As  
19 we learn more, we incorporate it in. We are hoping  
20 that we won't see anymore two order of magnitude  
21 increases on anything. However, remember, we are  
22 playing around down here in the  $10^{-8}$ - $10^{-10}$  range, and  
23 you know, you can hiccough and you can move to  $10^{-10}$ .

24 CHAIRMAN APOSTOLAKIS: I repeat what I  
25 said yesterday. The age of the earth's crust is  $3^{10}$ ,

1 10<sup>9</sup> years. So you know, maybe we should stop a little  
2 bit and --

3 DR. WALLIS: If you were a creationist,  
4 you would say it was a lot less than that.

5 DR. ARMIJO: Just a quick question. Is  
6 there a chance as the design progresses that that 3 x  
7 10<sup>-9</sup> might flip back to the 10<sup>-11</sup>?

8 MR. WACHOWIAK: What I have seen is it is  
9 very likely that that will happen. As they added  
10 detail to the turbine building, it looks like -- for  
11 other reasons than the PRA, it looks like they have  
12 addressed the particular circ water pipe break that  
13 caused us to get that two order magnitude change.

14 So that one, I may expect to go down.

15 CHAIRMAN APOSTOLAKIS: Rick, what is wrong  
16 with having the external events contribute to core  
17 damage frequency? The attitude here, it seems to me:  
18 No, we must dismiss that. I don't understand that.  
19 You are down to the 3 times 10<sup>-8</sup> or 7, whatever it is.  
20 I don't see any problem saying, yes, and 10 percent,  
21 30 percent of that is due to fire. Why go out of your  
22 way to dismiss those?

23 MR. WACHOWIAK: The main reason is that  
24 the analysis isn't really on the same footing as what  
25 we have done with the internal events.

1 CHAIRMAN APOSTOLAKIS: Well, if you do the  
2 bounding analysis, then it's not.

3 MR. WACHOWIAK: Right. So that -- What we  
4 are trying to avoid is, if we have these numbers close  
5 to each other, then some people may tend to forget  
6 that this is our best estimate number, albeit with  
7 uncertainties, but this is a bounding number, and this  
8 number really isn't 4 times  $10^{-9}$ . It is something  
9 different from that.

10 Then when we go back in, and if we just  
11 say, well, then let's put it altogether in one big  
12 model and solve everything in our one big model like  
13 some plants have done, now you get a different --  
14 maybe a different maintenance rule, risk significant  
15 list than if you had kept them separate, or maybe you  
16 get a different --

17 CHAIRMAN APOSTOLAKIS: But they do take  
18 into account these things when they establish the  
19 maintenance rule, the criteria and so on.

20 MR. WACHOWIAK: Right.

21 CHAIRMAN APOSTOLAKIS: So I don't think  
22 that is a problem. In fact, I remember even in the  
23 case of special treatment requirements, they kept  
24 external events separate, see what kinds of insights  
25 we can get from those.

1 MR. WACHOWIAK: That's right. But then we  
2 run into the problems with having to have all the  
3 expert panels and having to have the separate rules  
4 and move things into one bin or the other. So we  
5 think that it might be cleaner if could just show that  
6 it is not going to be --

7 CHAIRMAN APOSTOLAKIS: I understand that,  
8 but I mean, thinking of a little higher plane, you are  
9 down to such incredibly low numbers, and to say that  
10 the events that cause dependencies are dismissed, and  
11 then there are other failures that dominate, it  
12 doesn't gel. Right? I mean, you are down to very  
13 insignificant --

14 DR. WALLIS: What is most likely to happen  
15 in terms of event is something that isn't in this  
16 picture at all.

17 CHAIRMAN APOSTOLAKIS: Oh, no. This does  
18 not include acts of God.

19 DR. WALLIS: No, it doesn't include  
20 something like the Davis-Besse. If anything does  
21 happen, it is going to be probably of that type.

22 CHAIRMAN APOSTOLAKIS: But as Rick said --  
23 you put it very nicely yesterday, that you are  
24 addressing in this design things that have happened  
25 before, we can think of. You are not getting into

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 things that are outside. I mean, whether the safety  
2 culture of the plant is good or not is way beyond your  
3 capability to control it. Right?

4 MR. WACHOWIAK: At least now, yes.

5 CHAIRMAN APOSTOLAKIS: Anyway, are you  
6 done?

7 MR. WACHOWIAK: Quickly, I think we have  
8 talked about all these different things here at one  
9 point or another. From the flooding, we looked at  
10 layout of where things should be.

11 Safety redundancy and separation: We want  
12 to try to move things around. Just like in fire, we  
13 used our best principles to put things where the  
14 floods won't interact so much between different  
15 systems.

16 DR. WALLIS: Someday we are going to get  
17 to the point where you are going to explain how you  
18 predict the probability of a full drain getting  
19 blocked. You are going to get to that detail someday?

20 MR. WACHOWIAK: No. I don't think we are  
21 going to include the floor drains.

22 DR. WALLIS: Well, it is a  $10^{-2}$  event.  
23 According to you, you could easily get a factor of 10  
24 out of that one, and you get a few more factors of 10,  
25 then things stop being so insignificant.

1 MR. SIEBER: I think the floor drains are  
2 important.

3 DR. DENNING: Well, I guess how you treat  
4 them. Are you saying that you will assume that the  
5 drains don't work and that you will plug them stably  
6 or are you assuming that they always work?

7 DR. WALLIS: They have a  $10^{-2}$ .

8 MR. WACHOWIAK: In Revision 1 we have  
9 assumed that they don't work.

10 DR. DENNING: They don't work? So it is  
11 a conservative assumption.

12 MR. WACHOWIAK: It's conservative.

13 DR. DENNING: In substance.

14 MR. WACHOWIAK: Yes. The only place where  
15 it would be nonconservative is if we have a floor  
16 drain here where the flood is in this room, and there  
17 is nothing bad in that room, but it can go down into  
18 the room where there is something that could be a  
19 problem. We looked at those. In that case, the floor  
20 drain always works.

21 MR. SIEBER: The drains communicate with  
22 one another, too.

23 MR. WACHOWIAK: That's right. So I  
24 believe we've got backflow devices and things.

25 MR. SIEBER: That's an opportunity plug.

1 Any device you put the drain is an opportunity plug.

2 MR. WACHOWIAK: I will move on to the last  
3 couple of slides here before, I think, we might be at  
4 a break.

5 The high wind risk is basically our  
6 tornado analysis. We treat it as a loss of preferred  
7 power with no recovery in the first 24 hours, and we  
8 also assume that the condensate storage tank would  
9 fail. So that wouldn't be there as a water source.

10 Initiating frequency, though, turns out to  
11 be much, much lower than what we have already assumed  
12 in the loss of preferred power.

13 CHAIRMAN APOSTOLAKIS: Why this  
14 assumption, Rick?

15 MR. WACHOWIAK: Why? Because the tank  
16 itself is subject to tornado missiles.

17 CHAIRMAN APOSTOLAKIS: It's outside?

18 MR. WACHOWIAK: It's outside, and we could  
19 potentially drain that tank.

20 We treat it this way. When we run through  
21 the calculation for it, though, it turned out to be  
22 rather small. We will be readdressing that again when  
23 we update through, but we think it is still going to  
24 be small. the initiating frequency is not --

25 DR. WALLIS: It makes a bit of difference

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 where you put the plant, doesn't it? High wind risks  
2 are certainly much greater in certain parts of the  
3 country than others.

4 MR. WACHOWIAK: High wind or tornado?

5 DR. WALLIS: Or both.

6 MR. WACHOWIAK: There's little difference.  
7 The highest rate winds are already built into the loss  
8 of preferred power scenario. So that's already in  
9 there. But if we are talking about tornadoes, things  
10 that can have this other effect on top of it, those  
11 tend to be a much lower probability than a loss of  
12 off-site power, which is in the one in five years.

13 DR. WALLIS: It makes a difference where  
14 you put the plant. For a plant in Oklahoma, it is  
15 very different from putting it in Alaska.

16 DR. DENNING: For your initiator  
17 frequency, what was your assumption on the tornado?

18 DR. WACHOWIAK: I'd have to look at that.  
19 I don't remember. It probably came from URD, which  
20 was drawn from industry averages. I would be  
21 surprised if it came from anywhere other than the URD.

22 MR. SIEBER: You can actually construct a  
23 plant so that it won't receive damage.

24 DR. BONACA: Why is the plant designed to  
25 be so much underground?

1 MR. WACHOWIAK: Why is it designed to be  
2 underground?

3 DR. BONACA: Yes.

4 MR. SIEBER: It's a good idea. Don't  
5 change that.

6 MR. WACHOWIAK: There may be several  
7 reasons. I'm not sure that I know.

8 MR. SIEBER: It's easier to build.

9 MR. WACHOWIAK: There are probably many  
10 thoughts that went into that. The PRA was not one of  
11 them.

12 DR. DENNING: Continue.

13 MR. WACHOWIAK: Okay. We did do a seismic  
14 margins analysis to address the capability of the  
15 safety systems. Now this is safety systems only where  
16 we've looked here. We looked at the design fragility  
17 for these systems. Once again, those things would  
18 have to be confirmed when the plant was built.

19 We have an entry for the sequence of  
20 events. It looks kind of like a loss of off-site  
21 power type of event. We assigned the safety systems  
22 onto there. Non-safety systems, basically, are  
23 assumed to fail in this scenario, and then we looked  
24 at along every success path -- or along every path in  
25 the sequence what has to fail -- what do we have in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 each of those sequences that can prevent the core from  
2 being damaged and the minimum -- the maximum fragility  
3 for that -- for anything in the path is the fragility  
4 for the sequence, and then the minimum fragility for  
5 all the sequences, the fragility for the plant. It is  
6 not an overly detailed or overly complicated thing.

7 It turns out that all the sequences are at  
8 least two times the safe shutdown earthquake. I think  
9 it is a little higher than that, 2-point-something.  
10 We looked at it for both full power and shutdown, and  
11 because of this, we are asserting that it is unlikely  
12 that seismic will be a vulnerability.

13 Now will that mean that -- What will it  
14 mean for overall risk numbers if we ever do a seismic  
15 PRA? That's uncertain at this point. We can't say.

16 MR. SIEBER: Well, it gets some insights.  
17 It's all you can do.

18 MR. WACHOWIAK: We can probably get  
19 insights.

20 DR. DENNING: So you have no intent to do  
21 seismic -- to take a couple of sites and to do a real  
22 seismic PRA? Because I think that you are headed  
23 toward -- When we wind up with an operating plant,  
24 then this is the risk dominant for many plants. This  
25 is dominaturist. Am I wrong? Because there is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 implicit risk associated with the seismic margins  
2 analysis that is more like the traditional risks we  
3 have had.

4 Now here you are designing a plant to be  
5 a  $10^{-7}$ ,  $10^{08}$  plant, but you are using more the  
6 historical seismic logic here. Am I wrong?

7 MR. WACHOWIAK: I wouldn't say that you  
8 are wrong. At this point, though, from my  
9 understanding of DCD and what goes into a COL  
10 application, PRA is at seismic margins would be what  
11 we have.

12 CHAIRMAN APOSTOLAKIS: I still have a  
13 problem -- what I said earlier. You have a plan that  
14 has internally been core analysis frequency way down  
15 there,  $10^{-6}$ , and the major common cause failures have  
16 dismissed as being insignificant compared to this  
17 insignificant number. I have a problem with  
18 understanding that.

19 I mean, you could have a strong  
20 earthquake. It is going to shake the whole thing, and  
21 yet we are saying, oh, no, no, the sequence -- and  
22 also preferred power is still dominating, and that  
23 involves random failures. That's a little hard to  
24 digest. But maybe at another subcommittee meeting we  
25 can go more deeply into it.

1                   You are already way down there at  $10^{-6}$ ,  
2                   and you are saying there is a strong earthquake, and  
3                   that is insignificant compared to the random failure  
4                   of components. How can that be? There is a reason  
5                   why earthquakes and fires are usually significant  
6                   contributors to risk for existing LWRs. The reason is  
7                   they are contributing events, and the plants are so  
8                   redundant that, unless you have these big sources of  
9                   dependency, you don't see much action. But here it  
10                  seems to be the other way. I am still bothered.

11                  I don't have a specific comment that says,  
12                  hey, guys, here you really overdid it, but I sure  
13                  would like to have a subcommittee meeting going into  
14                  this more carefully, and see whether you -- Maybe your  
15                  results are fine. I don't know, but geez, it just  
16                  doesn't make sense to me, you know, without getting  
17                  into the details.

18                  I don't know how all the other members  
19                  feel about it.

20                  DR. DENNING: Well, the fire I understand.  
21                  Fire is a different animal in that you really can  
22                  design a plant with true separation. Seismic is a  
23                  different animal.

24                  CHAIRMAN APOSTOLAKIS: It's just shaking  
25                  the whole thing.

1 MS. CUBBAGE: You are talking about an  
2 earthquake of a lower probability than the SSE, which  
3 could be dominant, because --

4 CHAIRMAN APOSTOLAKIS: Yes, because we are  
5 already down to  $10^{-6}$ .

6 MS. CUBBAGE: You could have a  $10^{-8}$   
7 earthquake that would be different than anything they  
8 have analyzed.

9 CHAIRMAN APOSTOLAKIS: Yes. Just kills  
10 everything.

11 MS. CUBBAGE: So something like that could  
12 be dominant.

13 CHAIRMAN APOSTOLAKIS: It could be. Well,  
14 it doesn't have to be the dominant in the sense that  
15 it would come out  $10^{-7}$ , but to actually say that it's  
16 dismissed, compared to  $3 \cdot 10^{-8}$  -- I mean, wow.

17 DR. DENNING: I'm not sure it's exactly  
18 said that it was. But that's okay.

19 CHAIRMAN APOSTOLAKIS: Are you there,  
20 Rick?

21 MR. WACHOWIAK: This one, I did not say  
22 that it was dismissed. I said we don't expect it to  
23 be a vulnerability. Now how you define a  
24 vulnerability is in the details.

25 CHAIRMAN APOSTOLAKIS: We are very clever.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. WACHOWIAK: I think that's it for  
2 break time.

3 CHAIRMAN APOSTOLAKIS: We still have your  
4 shutdown management.

5 MR. WACHOWIAK: That will be short.

6 CHAIRMAN APOSTOLAKIS: Because members  
7 will start disappearing -- In fact, everybody will  
8 leave at twelve. All right?

9 DR. DENNING: Well, Graham is actually  
10 about to leave. Is that true, Graham?

11 CHAIRMAN APOSTOLAKIS: Graham is leaving  
12 a little earlier.

13 DR. WALLIS: After the break.

14 CHAIRMAN APOSTOLAKIS: After the break?  
15 You are here for the break?

16 DR. DENNING: The alternative would be to  
17 do the shutdown now, and then Graham can take off.

18 CHAIRMAN APOSTOLAKIS: You guys, you are  
19 asking me to violate my principles.

20 DR. WALLIS: It's supposed to be at 10:30.  
21 the break is on the schedule for 10:30.

22 (Whereupon, the foregoing matter went off  
23 the record at 10:03 a.m. and went back on the record  
24 at 10:17 a.m.)

25 CHAIRMAN APOSTOLAKIS: The next

1 presentation is on the shutdown events, and I noticed  
2 that you never use the word risk assessment. You  
3 always say risk management. Is that a conscious  
4 decision or it just happened?

5 MR. WACHOWIAK: Yes, it is. It's a  
6 conscious decision.

7 CHAIRMAN APOSTOLAKIS: It's a conscious  
8 decision. Okay.

9 MR. WACHOWIAK: In the process where we  
10 are in the design, at least we have the great  
11 opportunity that we can manage the risk.

12 MR. SIEBER: So you haven't built anything  
13 yet. So you can change the plant to manage the risk.

14 MR. WACHOWIAK: David has a couple of  
15 answers to some questions that came up previously.  
16 Been doing some research here.

17 MR. HINDS: This is David Hinds with GE.  
18 Just a couple of quick answers to the questions that  
19 came up, at least a couple of them that we had to  
20 table. In fact, one of them is an actual correction.

21 The question related to grade elevation  
22 and what is below grade elevation. If you look at  
23 those cutaways -- I think they are on your handouts --  
24 the grade elevation is approximately equal to the  
25 bottom of the suppression pool, similar to the bottom

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 of the core. So the bottom of the suppression pool is  
2 equivalent with grade elevation, as per the plan.

3 Now there will be slight -- potentially  
4 slight differences on site specifics, but that's the  
5 approximate grade elevation right now, at the bottom  
6 of the suppression pool. Okay.

7 Additionally -- it's actually a correction  
8 from one of the questions that was asked, and we made  
9 a quick answer to, and I need to correct a little bit,  
10 in that it wasn't exactly correct. We have also a  
11 question that you had related to quickly do we  
12 depressurize when we get an actuation signal or SRD.

13 We do not depressurize that quickly. Our  
14 design is that, if we get an actuation signal to  
15 depressurize, there is a time sequence such that all  
16 valves do not open immediately. First the SRVs, the  
17 ADS valves -- the SRVs that are ADS valves, five of  
18 them open immediately, and then five additional ones  
19 open 10 seconds later, and then 50 seconds within the  
20 event three of the depressurization valves will open.

21 So there is a time delay such that the  
22 initial depressurization begins with SRVs to the  
23 suppression pool, and then the complete  
24 depressurization begins with the DPVs,  
25 depressurization valves, 50 seconds into the event.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           It begins with three opening, and then a  
2 sequence continues on with two more opening at 100  
3 seconds, two more opening at 150 and one more opening  
4 at 200, eight total DPVs, but they are staggered in  
5 50-second increments to bring pressure down totally.

6           I looked at one of the loss of feedwater  
7 sequence, and at approximately 280 seconds into the  
8 event pressure is low enough for the gravity driven  
9 system to eject the vessel. So we were incorrect on  
10 our timing sequence.

11           CHAIRMAN APOSTOLAKIS: Okay.

12           MR. HINDS: Thank you.

13           MR. WACHOWIAK: Okay. I want to talk  
14 about shutdown. The scope of our shutdown analysis --  
15 and once again, this is in Rev. 1. You have Rev. 0  
16 now. We don't have all of this in there. In Rev. 0  
17 it's there.

18           Internal events, external events: We  
19 talked about some of the external events earlier.  
20 Seismic margins we talked about.

21           The scope is that we included Mode 5,  
22 which is called Shutdown, Mode 6 which is refueling.  
23 there are two modes that -- and the power operation is  
24 clearly Mode 1. So what happens to Modes 3 and 4, Hot  
25 Shutdown and Safe Shutdown?

1                   We have taken a look at those two modes  
2                   and decided that they really are enveloped by what we  
3                   did in the Mode 1 PRA, and didn't elaborate on these  
4                   in detail anymore.

5                   We will probably, before we are completely  
6                   done, readdress that to look at specific things like  
7                   what is the actual sequence during a shutdown for  
8                   refueling, and also our other colleagues are working  
9                   on tech specs, and they have a question for us about  
10                  end stage: Should you have to go to cold shutdown all  
11                  the time? I think we are going to have to look at  
12                  that to answer some of their questions.

13                  Timing of when those questions will be  
14                  answered, I'm just not sure. But our scope now is  
15                  Mode 5, Cold Shutdown; Mode 6, Refueling, and Mode 6  
16                  is really split into with the cavity flooded and the  
17                  cavity unflooded, different responses there.

18                  Pretty much you have the same level of  
19                  detail in the shutdown model as we did in the power  
20                  operation model. We've got event trees. The system  
21                  models are nearly the same with just some tweaks on  
22                  them. So it's the same kind of level of detail.

23                  I kind of went through which events we are  
24                  going to look at. Manual shutdown -- there is an  
25                  event for manual shutdown there. LOCAs, we only

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 considered in Mode 6. Once again, we are saying that  
2 the Mode 5 LOCAs are probably enveloped by or bounded  
3 by what we did in the at-power scenarios.

4 Now these other ones, loss of power, loss  
5 of shutdown cooling, fires and floods -- we didn't  
6 look at those in Mode 6 with the reactor cavity  
7 flooded. The main reason is before -- if we are  
8 flooded, we've got 72 hours or more before we have to  
9 regain the shutdown cooling function.

10 So with that long period of time,  
11 something can be done, and from the data that we have  
12 seen from plants, existing plants, three days  
13 certainly would be an adequate amount of time to do  
14 something about recovering that function.

15 One of the things that we did differently  
16 for the three models during the shutdown are in the  
17 area of the maintenance activities. What did we  
18 assume different from the configuration of the plant  
19 for the Mode 1 operation?

20 Multiple pumps and trains of feedwater and  
21 condensate can be unavailable when we are in shutdown,  
22 and that is factored in for all the modes of the  
23 shutdown evaluations.

24 A question came up: What about flood and  
25 fire barriers? Could any of those be disabled during

1 shutdown? Typically, we see some of that in the  
2 existing plants, and how do we want to address that?

3 So as part of our shutdown external events  
4 analysis, we looked at the effect of having those  
5 barriers disabled. In Mode 6 we assumed that  
6 isolation condensers have been taken out of service  
7 for maintenance.

8 We allow one GDCS pool to be out of  
9 service for maintenance of its valves during Mode 6.  
10 PCCS is unavailable in Mode 6, mainly because the  
11 containment is open at that point, and it wouldn't do  
12 us any good. SRVs and DPVs are assumed to be  
13 undergoing maintenance in Mode 6. Therefore, they  
14 will be -- Well, the lines to those will probably be  
15 blocked off after the event -- or after the flood-up  
16 occurs.

17 Now we did look at recovery actions in  
18 Mode 6. Shutdown events tend to move slower than the  
19 power events, mainly because we are starting from a  
20 lower decay heat level, got more time to recover the  
21 initiating event.

22 So what we looked at were industry data on  
23 loss of shutdown cooling events, loss of offsite power  
24 events, loss of service water events, and created a  
25 nonrecovery curve similar to what's been published for

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 loss of offsite power for these other systems, and  
2 applied a five-hour recovery to our initiating events.

3 So we will just right now jump over to the  
4 results. The manual shutdown is very low. Loss of  
5 decay heat removal is very low, and we looked into  
6 whether adding that recovery factor is what is driving  
7 this; because if the recovery factor is driving it,  
8 then I'm not sure we want to -- We will at least want  
9 to put that into our sensitivity analysis, but that is  
10 not doing it.

11 It would only come up to something times  
12  $10^{-12}$  if we removed the recovery factor. So that is  
13 not what is driving that there. I think it is just  
14 the overall time to respond.

15 Loss of service water is also low. Loss  
16 of preferred power is getting into the -- or we are  
17 starting to see some things in the scenario, and LOCAs  
18 tend to be the highest. We will talk about the LOCAs.  
19 It is two specific LOCA scenarios that are the  
20 dominant factors here.

21 DR. KRESS: Is there something on how long  
22 you will be in shutdown mode?

23 MR. WACHOWIAK: Yes. These are all  
24 weighted for the two-year refueling cycle with the  
25 refueling outage link that we have stated to the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 customers that they would have. So it is weighted to  
2 that -- another reason why it is low.

3 In our containment we got all these pools  
4 of water here. For now, assume that there is a head  
5 up on top of that. But in the shutdown events, we  
6 still can flood the reactor up from these other pools.  
7 Now the breaks that are giving us most of the risk in  
8 shutdown are the breaks that would occur in instrument  
9 lines and the reactor water cleanup lines down low on  
10 the vessel, these lines that come out underneath the  
11 core.

12 If those lines break, then all the water  
13 we've got in here comes out and, if it gets down too  
14 low, it shuts off shutdown cooling. We lose decay  
15 heat. If the lower drywell is intact or these hatches  
16 aren't open, we've got enough water in the GDCS pools  
17 and every place else to keep this all flooded up so  
18 that the decay heat removal can keep on operating.  
19 That is not a problem, if we've got this cup here to  
20 contain all the water.

21 Certainly, if we've got the refueling pool  
22 open up on top, there is enough water there without  
23 activating any of the GDCS pools, once again to keep  
24 the core covered and keep the shutdown cooling system  
25 operating.

1                   The problem with that is one of the things  
2 we do in the refueling is get under here to maintain  
3 the control rod drive mechanisms that are in here.  
4 Historically, what plants do is they will open up  
5 these hatches. They will run cables through there and  
6 airhoses through there and all sorts of things through  
7 that, and if this door is open, it doesn't matter what  
8 happens with the rest of these things.

9                   The water comes out, goes out through the  
10 reactor building, floods up everything in the reactor  
11 building, and there is not enough left there for the  
12 core, even to potentially affect the equipment that  
13 could -- like FAPCS that we could be using to pump  
14 water back in, that magnitude of flood would affect  
15 the FAPCS. So we really don't have any recovery from  
16 that event other than getting out and closing the  
17 doors.

18                   DR. WALLIS:     With the water pouring  
19 through?

20                   MR. WACHOWIAK:   Well, yes, and depending  
21 on the size, it's anywhere from about an hour and a  
22 half to about three hours before the water starts  
23 pouring out. So anybody working in there is going to  
24 recognize that this is happening. It is going to be  
25 a dramatic event for them, and they are going to be

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 out, and people will know about it, and you could get  
2 the hatch back on.

3 The problem is all of this stuff that is  
4 running through the doors that you have to disconnect  
5 before you can get the hatch back on.

6 DR. WALLIS: Well, they may have to walk  
7 through some hot water and steam to get to the door.

8 MR. WACHOWIAK: This would be refueling.  
9 So it would be warm water. Like I said, it would be  
10 a dramatic event for anyone who is in there.

11 In our number that we have there, we have  
12 taken credit for the operators and the crew that's out  
13 there being able to get that door closed in some --

14 DR. WALLIS: Does the water come down in  
15 a way that it would cascade down past the hatch or is  
16 it somewhere else? If there is a break, is it going  
17 to come --

18 MR. WACHOWIAK: Oh, is it going to come  
19 out here? Is it going to come out there?

20 DR. WALLIS: Near the hatch. Is it going  
21 to impede the sort of action of shutting the hatch?

22 MR. WACHOWIAK: We don't know that right  
23 now, because those pipes have not necessarily been  
24 routed. So we wouldn't know. But once again, that's  
25 a good question, and we have a new insight now that we

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 can write down and say don't put the pipes over there  
2 so that it would cascade.

3 So that is an issue that goes into that.  
4 And here is one of our examples of a PRA as a design  
5 tool in process. We've noticed that we could live  
6 with a  $10^{-9}$  CDF -- an addition to CDF  $10^{-9}$  CDF, but you  
7 know, the thing is that is one of these things where  
8 it's a containment bypass also, and do we want to live  
9 with a  $10^{-9}$  containment bypass? I don't think that  
10 that's someplace where we are going to want to end up.

11 So we are looking at various options.  
12 What do we do -- I think I talked about that. What do  
13 we do to address this? And we've got several things,  
14 brainstorming ideas that we are running past the  
15 designer, and we are coming up with an optimized way  
16 of making the -- either making it so that that hatch  
17 doesn't have to be open. If it's already closed, what  
18 do you about the people inside? There's also sorts of  
19 different considerations there.

20 Well, and there's ways to address that,  
21 too. That's not just a given there, but there's  
22 things to do with the hatch. There's things to do  
23 with maybe providing service penetrations or maybe a  
24 special hatch that goes on during outage that has the  
25 service penetrations. We don't really know yet. We

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 are in the process of determining what we can do.

2 DR. WALLIS: Don't you have lines going  
3 through the hatch? You have compressed air or  
4 something going through there?

5 MR. WACHOWIAK: That's the problem that we  
6 have.

7 DR. WALLIS: Push it out of the way to  
8 close the hatch.

9 MR. WACHOWIAK: That's what we are trying  
10 to do.

11 DR. WALLIS: Now did you say before there  
12 is no recovery from this and that the water is  
13 draining out, and it's gone into the reactor building.  
14 There is no way to recovery cooling, is there? I  
15 mean, you are going to eventually drain the core.

16 MR. WACHOWIAK: Eventually, you are going  
17 to drain the core.

18 DR. WALLIS: There is no recovery.

19 MR. WACHOWIAK: We don't like those kind  
20 of events.

21 DR. WALLIS: No, I don't like it either.

22 MR. WACHOWIAK: You can stop it.

23 MR. SIEBER: You can stop the event, but  
24 like closing the doors.

25 MR. WACHOWIAK: But that's where the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 question comes in. At what point does the flooding in  
2 the reactor building prevent you from keeping on  
3 trying to close that door. How long does it take to  
4 close the door? Is there some level of water in the  
5 drywell that you can't get the door back on anymore?  
6 All those things need to be --

7 DR. WALLIS: Or there is some equipment  
8 blocking it in some way.

9 MR. WACHOWIAK: I think the equipment we  
10 could probably deal with procedures, but once again it  
11 is something that I don't know that we want to have  
12 hanging over our maintenance and operators' heads  
13 there. I think we would prefer a more elegant  
14 solution to this.

15 As I said, the design team is looking into  
16 what can happen or what we can do in a reasonable  
17 manner that provides not necessarily a pressure  
18 boundary for containment there anymore but a water  
19 tight boundary that we can use so that we can flood up  
20 and provide our thing. So this is a PRA insight to  
21 the design in progress.

22 MR. MAYNARD: Well, you could also at  
23 least clearly limit it to smaller breaks.

24 MR. WACHOWIAK: It is limited to smaller  
25 breaks.

1 MR. MAYNARD: You could also have pumps  
2 down there.

3 MR. WACHOWIAK: Those are things that in  
4 the consideration mix. One of the problems with the  
5 pumps down here is, when we are flooded all the way up  
6 to the reactor well, we've got 40 meters of water head  
7 on top of that hole, and you get quite a bit of water  
8 out through a three-inch line with 40 meters of water  
9 up on top of it. But we have in the consideration is  
10 maybe we bring in some big portable sump pumps that  
11 deal with that.

12 MR. SIEBER: Well, you've got to be able  
13 to pump it back up to the top.

14 MR. WACHOWIAK: Right. So there are a  
15 whole myriad of things that we are looking at to  
16 address this, and we are going to try to come to the  
17 best solution for both certifying the design, because  
18 we want to do that, and for our customers who have to  
19 operate this plant.

20 DR. WALLIS: Well, this is a LOCA. You  
21 don't go into that hole when the pressure is high, do  
22 you?

23 MR. WACHOWIAK: It's not a high -- It's  
24 not a LOCA that's caused by pressure in the system.  
25 It is a LOCA that mainly is kind of influenced by

1 people being down there.

2 DR. WALLIS: They cause the break?

3 MR. WACHOWIAK: Depends on where it is.

4 There are some valves in there that the break is far  
5 enough away in the line that it can be isolated there.

6 MR. MAYNARD: You could have some type of  
7 maintenance activity going on in there that breaks the  
8 pipe.

9 MR. WACHOWIAK: There's all sorts of  
10 things there. Hopefully, when we start building this,  
11 we won't be doing those kind of things.

12 MR. SIEBER: Well, the service penetration  
13 is a good idea, but I don't think putting it in the  
14 hatch is a good idea.

15 MR. MAYNARD: Does the containment -- the  
16 equipment hatch up above, does it have a way to close  
17 in a fairly rapid manner? I take it, you have some  
18 type of equipment hatch up.

19 MR. WACHOWIAK: We have one up on top and  
20 one down below.

21 MR. MAYNARD: If you needed to close off  
22 containment like in Mode 5 when people have it open,  
23 bringing stuff in and out, if you had a LOCA it is at  
24 a point. The idea is to be able to get that hatch  
25 closed. Do you put any special mechanisms in for

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 closing that hatch?

2 MR. WACHOWIAK: For the upper drywell?  
3 I'm not aware of any scenarios where we would have to  
4 close the upper drywell hatch.

5 DR. ARMIJO: Is this a unique problem with  
6 this design? I mean, has this issue been in front of  
7 BWRs before?

8 MR. WACHOWIAK: It's possible that it has  
9 been, but if we look at, let's say, a Mark I plant,  
10 the hatch is down low, but the suppression pool is  
11 down lower. When you start doing this draining,  
12 you've got a long time to fill up the suppression pool  
13 before you get to a point where you would have to  
14 close the hatch. Also, the ECCS pumps take a suction  
15 off that suppression pool and pump it back into the  
16 reactor.

17 So this is -- I think this is something  
18 that is unique to moving the suppression pool up  
19 higher with respect to the reactor. So it's a  
20 challenge, and it is -- The main challenge is trying  
21 to figure out what is the best option for the  
22 customer, because we know we can do it somehow. We  
23 just haven't figured out how yet.

24 CHAIRMAN APOSTOLAKIS: Let's move on.

25 MR. WACHOWIAK: Okay. The next thing I

1 want to bring up is that, based on what we have seen  
2 so far in our fire analysis, we are not going to be  
3 able to say that fire barriers can be uncontrolled  
4 during outages. During the outages, we are going to  
5 have to do something with the fire barriers.

6 We are either going to have to specify  
7 that you don't break them or, if you do, you apply  
8 appropriate compensatory measures so that the fire  
9 barriers remain reliable. So that was a good thing  
10 that was brought up to take a look at during outages,  
11 and I think it is something that is going to bear out.

12 There is a possibility that, when we get  
13 the detailed routing and layout and fire modeling  
14 done, we might be able to relax that, but I don't see  
15 that happening anytime during this certification  
16 phase. So we will be adding that into our operation  
17 and maintenance requirements.

18 Once again, on shutdown it is an iterative  
19 process with the design still going forward. Some of  
20 the things that -- details that we are dealing with  
21 could affect the dominant sequence. Well, they will.  
22 We want them to affect the dominant sequence. We  
23 don't think there is much left that is going to affect  
24 the other sequences and bring them up, but we are  
25 continuing to look at that.

1           As I said before, fire and flood for  
2 shutdown is still under development. Flood, we pretty  
3 well have nailed down to where we are going to come  
4 out for the DCD. Fire, we still have a little bit of  
5 work yet to do to get that to the place where we are  
6 comfortable releasing it.

7           Now on my last item -- Is there any  
8 shutdown questions yet? I'll just move right along  
9 into the last one.

10           We saw this earlier yesterday. ESBWR risk  
11 management program: We support the goals that we need  
12 for this DCD. I think we've got the right scope for  
13 what we are trying to do here. We believe we have  
14 enhanced the defense in depth of the plant, and  
15 through some of the various examples you can see we  
16 are using it as a design tool to address things that  
17 we are discovering and things that are, in some cases,  
18 unique.

19           We are going to continue to modify this  
20 thing all the way up to and past plant operation, and  
21 this question of where does it fall into whose hands  
22 for approval -- I can't answer that, but I do know  
23 that we are -- Our goal is to keep advancing this PRA  
24 to be state of the art by the time we are operating as  
25 a plant.

1                   A couple of observations that I have.  
2           ESBWR, once again: Robust design; results in a low  
3           CDF based on the things that we know about; but as we  
4           have been talking for most of this morning, we are  
5           testing the limits of what we can do with the  
6           techniques that we have here.

7                   DR. WALLIS: By the way, while you were  
8           talking about what happens underneath the vessel  
9           during shutdown, and if these squib valves -- or you  
10          break the deluge system when there are people standing  
11          around under there, they get a big surprise, too.

12                  MR. WACHOWIAK: There's maintenance block  
13          valves. Those would be closed.

14                  DR. WALLIS: Those were going to be all  
15          blocked off, so that that couldn't happen?

16                  MR. WACHOWIAK: That's right.

17                  DR. WALLIS: Okay, thank you.

18                  MR. WACHOWIAK: We looked at that one.

19                  The unknowns may be as important as the  
20          knowns in some of these cases. I think we've talked  
21          about that. So what we are addressing in this PRA is  
22          the things that we know about and the things that we  
23          can know about.

24                  Some screening methods that -- and we've  
25          talked about this with the fire stuff. It doesn't

1 seem to be as effective here. Things that we could --  
2 If we could show a  $10^{-8}$  sequence using five and a  
3 building in an existing plant, we would say, okay, we  
4 are done, that's as good as we can get.

5 Here, that's not quite what we can do, and  
6 it looks like the thresholds to screen things end up  
7 being so low that the unknowns are affecting what we  
8 can get to with these thresholds. So that is a  
9 difficult question.

10 The other thing that is coming up in the  
11 use in the rest of the approval process for this DCD  
12 of the PRA -- and here it is looking at risk  
13 significant items for the D-RAP and looking at how we  
14 do things in the tech specs. Using a relative risk  
15 ranking approach and the thresholds that have been  
16 used for existing plants can be a problem, I think,  
17 for us with the CDF the way we are and with some of  
18 the things that we are doing in this analysis.

19 The risk achievement worth value of 2,  
20 which has been used for maintenance rule things in the  
21 past, gets just about everything in this plant;  
22 because everything has some sort of a contribution to  
23 keeping the risk low.

24 We've got the function. It's passive  
25 function surrounding by the active function with the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 support systems, and those things are duplicated over  
2 and over throughout -- and all the event trees look  
3 fairly much the same. The same equipment is  
4 providing things there, and we tend to have everything  
5 contributing here, at least somewhat, to risk.

6 An increase by a factor of 2 on  $10^{-8}$  is  
7 not the same thing as an increase by a factor of 2 on  
8 a  $10^{-5}$ . So that is one of the things there, and so in  
9 moving toward passive plants, I am wondering about the  
10 relative risk ranking that has been used in the past  
11 and how applicable it is for the future.

12 CHAIRMAN APOSTOLAKIS: Well, if the  
13 utility decides to make a risk informed change to the  
14 plant after it is built, and they use Regulatory Guide  
15 1174 -- I mean, geez, even the  $10^{-6}$  would overwhelm  
16 everything else.

17 DR. SHACK: They could build 100 new  
18 units.

19 MR. SIEBER: You can't make any changes  
20 once you get low enough.

21 CHAIRMAN APOSTOLAKIS: The changes there  
22 would be even down to the  $10^{-7}$  or 8 range. So we have  
23 to change the figure in the Regulatory Guide.

24 MR. WACHOWIAK: So that is one of these  
25 things that it's out there on the horizon or just past

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 the horizon that we ought to be thinking about when we  
2 move into approving those other phases of the DCD.

3 CHAIRMAN APOSTOLAKIS: So the main reason  
4 why your CDF is so low is because it's a passive  
5 plant.

6 MR. WACHOWIAK: Because it's a passive  
7 backed up by active backed up by more active.

8 DR. WALLIS: Just by the passive by itself  
9 -- You don't get that by the passive by itself.

10 CHAIRMAN APOSTOLAKIS: You get 10<sup>-5</sup>.

11 DR. WALLIS: That's right.

12 CHAIRMAN APOSTOLAKIS: You did it, right?  
13 You did the focused PRA.

14 MR. WACHOWIAK: Right.

15 CHAIRMAN APOSTOLAKIS: Okay. Anything  
16 else? You done?

17 MR. WACHOWIAK: I just want to make sure  
18 I put this page back up again. The words are there.  
19 We think that, when we compare to other plants using  
20 the same methods and the same techniques, we've  
21 provided the best level of safety that we've seen so  
22 far.

23 DR. WALLIS: Not just for the old fellows.

24 MR. WACHOWIAK: So the next ones will come  
25 in after us and say something else. Now it's my turn.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 DR. WALLIS: That's been very useful. I  
2 thought it was a good overview of the PRA, and we will  
3 examine the details, I guess, at some future date.  
4 Very useful.

5 MR. WACHOWIAK: Thank you.

6 DR. WALLIS: Thank you.

7 CHAIRMAN APOSTOLAKIS: So who is next?  
8 Amy?

9 MS. CUBBAGE: Yes, and we are a few  
10 minutes ahead of schedule, and I will review these  
11 quickly.

12 CHAIRMAN APOSTOLAKIS: Yes, but it's  
13 better if you stood up.

14 MS. CUBBAGE: Okay. I'm getting the  
15 computer ready here. I'd like to ask our review team:  
16 Bob Palla, Marie Pohida, and Nick Saltos, to come and  
17 join me up here in case you have any specific  
18 questions about these RAIs.

19 I know that you have received a copy of  
20 the RAI letter itself which goes into all these  
21 questions in more detail. So this is just intended to  
22 provide a quick overview of what questions the staff  
23 asked in their preliminary round of questions when the  
24 application was first received.

25 We have received responses to some of

1 these questions, but we are waiting for the final  
2 Revision 1 to address all of them.

3 The first 10 questions were Bob Palla's  
4 questions. They relate to severe accident design  
5 features and primarily Level 2 RPA. The first  
6 question was regarding the ROAAM methodology. He  
7 requested the peer review results to support  
8 assessment of the severe accident analysis.

9 We also requested an equipment  
10 survivability assessment. We requested additional  
11 information regarding the accident management program  
12 for guidance and training on the design features, and  
13 we requested a more rigorous evaluation of severe  
14 accident mitigation design alternatives. That came up  
15 a little bit yesterday with the purpose of GE doing a  
16 Level 3 PRA, and the results do feed into this  
17 analysis.

18 We requested GE to include the  
19 contribution from all accident classes in the  
20 containment performance. We requested additional  
21 information about the lower drywell flooding. This  
22 relates to the asbestos steam explosion probability.  
23 We requested information about the timing and when the  
24 level of water in the lower drywell -- when that would  
25 happen.

1           We requested additional detail on the  
2 BiMAC system. I think that is going to be a major  
3 topic in the review. Additional details were  
4 requested regarding corium splash shield and  
5 protection of the lower drywell sumps by the BiMAC.

6           Let's see. We requested expanded  
7 assessment of PRA uncertainty and importance analysis  
8 addressing -- This relates to key containment related  
9 features, assumptions and operator actions, and  
10 detailed information regarding containment isolation  
11 provisions related to containment failure modes.

12           Those were the questions that we had on  
13 Level 2. Then the additional questions are Level 1  
14 questions. The first set were primarily for at power,  
15 and then some additional questions at the end will be  
16 regarding shutdown. That's Marie's area.

17           So the first question on Level 1 was a  
18 systematic assessment of the impact of thermal  
19 hydraulic uncertainty in the PRA models and results,  
20 and the main issue there is assessing the MAAP Code  
21 for use against the TRACG Code.

22           CHAIRMAN APOSTOLAKIS: I thought there was  
23 -- the main issue was passive systems. That's what it  
24 is.

25           MR. SALTOS: Nick Saltos. -- with passive

1 systems because of the nature of the guided forces in  
2 the Maxus model compared to the plant systems, and  
3 errors and uncertainties in the thermal hydraulic  
4 parameters can be compared to the guided forces  
5 themselves.

6 CHAIRMAN APOSTOLAKIS: What kind of  
7 parameters do you have in mind?

8 MR. SALTOS: Decay heat --

9 CHAIRMAN APOSTOLAKIS: But if you have  
10 water flowing down, you know, from a height of several  
11 meters at least, don't you have enough force there?  
12 Do you really care about these?

13 MR. SALTOS: But it's not just that. It's  
14 natural circulation. It's gravity. We want a  
15 systematic approach, because everything with  
16 hydraulics depends -- with a valve here, what happened  
17 before? What succeeded? What failed?

18 CHAIRMAN APOSTOLAKIS: Are you focusing on  
19 the uncertainties in the various parameters or are you  
20 also raising the question of maybe some of the basic  
21 assumptions are bounding the geometry of the system,  
22 for example?

23 MR. SALTOS: That, too. Yes, all those  
24 can be. Geometry, numerical methods could be. Those  
25 are -- MAAP, how good MAAP is.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 DR. DENNING: But you are also -- I mean,  
2 I think that this question really also addresses the  
3 question of the probability of failure of the system  
4 that is associated with phenomenological uncertainty  
5 as opposed to what's happening now for the passive  
6 systems. Their failures are all being determined by  
7 the failures of certain components.

8 MR. SALTOS: Yes.

9 DR. DENNING: I think this is really an  
10 important issue and one that I think the committee  
11 ought to have a presentation on later. I think it's  
12 a good question.

13 MR. SALTOS: Yes. GE is preparing a  
14 topical report on that.

15 MS. CUBBAGE: All right. There has been  
16 significant discussion, and we've already had one  
17 meeting just on this one RAI.

18 CHAIRMAN APOSTOLAKIS: I know this is an  
19 issue for core designs that are based on gas cooled.  
20 When are we going -- I mean, I would like to  
21 supplement -- get involved in this. Is October too  
22 soon? That's okay.

23 MR. WACHOWIAK: I'm not prepared to answer  
24 that.

25 CHAIRMAN APOSTOLAKIS: Okay. The real

1 question here, I think, is whether these uncertainties  
2 you mentioned may, in fact, change the success  
3 criteria. As you say here, the assumed success  
4 criteria will change.

5 MR. SALTOS; We don't know that. It may  
6 change, and the change could be important or it might  
7 not change. We don't know that.

8 CHAIRMAN APOSTOLAKIS: I suspected as  
9 much.

10 MS. CUBBAGE: Okay. We requested more  
11 documentation of the process for selecting the RTNSS  
12 systems. The initial submittal included only the fuel  
13 pool and auxiliary system connection to refill the PCC  
14 and IC pools with the firewater system, and they have  
15 also recently added the BiMAC system. So we want to  
16 look more closely at what other systems could or  
17 should be included in RTNSS control.

18 CHAIRMAN APOSTOLAKIS: Isn't the whole  
19 idea behind this -- how do you pronounce it, RTNSS? --  
20 to do something -- to take some structural defense in  
21 depth measures, because the uncertainty is so much.  
22 I think that's the whole idea.

23 MS. CUBBAGE: That's part of it, and also  
24 from a probability standpoint you look at systems that  
25 are risk significant, non-safety systems.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1. MR. SALTOS: Nick Saltos again. The idea  
2 is that the non-safety systems are not regulated.  
3 They are no regulations for that, and we want them to  
4 meet the safety goals, the associated safety goals  
5 pretty much for CDF without these systems. And if  
6 they cannot meet those goals without these systems,  
7 considering even uncertainties, then they will have to  
8 take credits for those systems, and then we get  
9 regulation for those systems, some kind of regulation.

10 CHAIRMAN APOSTOLAKIS: Wait a minute.  
11 Wait a minute. The focus PRA without the active  
12 systems shows  $10^{-5}$ .

13 MR. SALTOS: So 5 times  $10^{-5}$  taking credit  
14 for the fire pumps which already came in as a  
15 candidate for regulation. So then there are  
16 uncertainties on top of that that we haven't  
17 considered yet, and this number could increase and go  
18 up, and some other systems might come in.

19 MS. CUBBAGE: And I think I really wanted  
20 to mention that the shutdown aspects here are  
21 important as well.

22 MS. POHIDA: I asked this RAI, because no  
23 RTNSS evaluation was done for shutdown, and the  
24 shutdown -- The focus PRA was done for two reasons.  
25 One is to look at the risk impact of only grading

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 safety related systems. Second of all is in shutdown  
2 the decay heat removal function is provided by a non-  
3 safety related system. It is not covered in tech  
4 specs. Okay?

5 So if you have multiple challenges or  
6 multiple challenges to the loss of the RHR function in  
7 this plant, that is going to change the shutdown risk.

8 What I'm saying is the likelihood of  
9 losing the RHR function, the decay function, could be  
10 increased, but it is being provided by a non-safety  
11 related system that is not covered in tech specs.

12 In the AP1000 plant, because the decay  
13 heat removal function also is not provided by a safety  
14 related system, we had availability controls -- okay?  
15 -- that were done to maximize the availability of the  
16 RHR function during shutdown conditions and its  
17 support systems. That type of assessment was not done  
18 yet.

19 CHAIRMAN APOSTOLAKIS: But is it possible  
20 that you find yourself in a situation where you say,  
21 no, the system is too important, it should be a safety  
22 related system?

23 MS. POHIDA: Could be. This analysis  
24 hasn't been completed yet. The output of the RTNSS  
25 process for AP1000 was that the decay heat removal --

1 I mean the RHR system at shutdown and its support  
2 systems were not covered in tech specs, but they had  
3 availability controls placed on these systems.

4 CHAIRMAN APOSTOLAKIS: I mean, with a  
5 RTNSS system is not to declare something safety  
6 related, but do something about it. That's really  
7 what it is.

8 MS. POHIDA: Especially, it can influence  
9 the likelihood or increased likelihood of initiating  
10 events, which are challenges to the decay heat  
11 function.

12 MS. CUBBAGE: Okay. We requested a lot of  
13 additional supporting information to be submitted by  
14 GE, including cut sets and --

15 CHAIRMAN APOSTOLAKIS: Excuse me. Has  
16 anybody ever used the PRA in, as you say here, the  
17 RTNSS process?

18 MS. CUBBAGE: Yes.

19 MR. SALTOS: This review is for the AP600  
20 and AP1000.

21 MS. CUBBAGE: The process was established  
22 during the --

23 CHAIRMAN APOSTOLAKIS: I know the process.

24 MS. CUBBAGE: And was used on the -- and  
25 it is a passive plant issue, and this is the only

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 other passive design that we have reviewed in addition  
2 to AP600.

3 CHAIRMAN APOSTOLAKIS: AP600 was not as  
4 passive as this one. Right? Was it?

5 MS. CUBBAGE: I guess you could consider  
6 this plant to be more passive, yes.

7 We are waiting for GE to identify the  
8 design requirements in the DCD that came out of the  
9 PRA so that we could set ITAAC, if necessary or see  
10 all action items to verify the assumptions in the PRA.

11 We have requested references for component  
12 reliability data. We have requested evaluations of  
13 important human actions and associated human errors  
14 probabilities.

15 You heard a lot today about the fire  
16 analysis. A lot of what Rick is doing now is in  
17 response to this RAI. We asked about the fire  
18 analysis.

19 CHAIRMAN APOSTOLAKIS: Good.

20 MS. CUBBAGE: And again, fire and floods  
21 at shutdown, which was an issue that Rick covered in  
22 detail today. That came out of this RAI.

23 We also requested some information about  
24 the large release frequency risk during shutdown. Do  
25 you want to elaborate on that one at all, Marie?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN APOSTOLAKIS: Let me understand  
2 something here. You keep referring to the goals, the  
3 subsidiary goals. The way I know them is that the CDF  
4 should be less than  $10^{-4}$ , and the LRF for existing  
5 reactors should be less than  $10^{-5}$ .

6 Now you guys sometimes say LRF should be  
7 less than  $10^{-6}$ . Is that a new thing?

8 MR. SALTOS: Yes. Well, this was  
9 developed in a SECY paper back then when we were  
10 developing the policy for the AP600, and it was set to  
11 six.

12 CHAIRMAN APOSTOLAKIS: Is that the new  
13 thing now?

14 MR. SALTOS: It was developed in late  
15 Eighties, early Nineties.

16 CHAIRMAN APOSTOLAKIS: I know t he  
17 original was  $10^{-6}$ . Then somehow it became  $10^{-5}$ , and  
18 now we are back to  $10^{-6}$ .

19 MR. SALTOS: Yes. Well, not changed  
20 since then. That was in the early Nineties.

21 CHAIRMAN APOSTOLAKIS: Well, it's  $10^{-5}$ ,  
22 isn't it? It goes up and down.

23 MS. CUBBAGE: We will look up the SECY  
24 paper. We can provide a reference on that.

25 DR. KRESS: The new reactors will now be

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 10<sup>-6</sup>.

2 DR. DENNING: Yes. An order of magnitude  
3 on both CDF and LRF.

4 CHAIRMAN APOSTOLAKIS: Yes, but these guys  
5 are -- at 10<sup>-4</sup> for core damage frequency.

6 DR. KRESS: Yes, that ought to be 10<sup>-5</sup>.

7 DR. DENNING: What did you say they were  
8 doing? You mean, because they talked about when they  
9 didn't take credit for the passive safety systems they  
10 got?

11 CHAIRMAN APOSTOLAKIS: No, several times  
12 people have referred to the goals, and it's 10<sup>-4</sup>, and  
13 10<sup>-6</sup> for LRF, and I don't understand.

14 DR. KRESS: I don't either.

15 CHAIRMAN APOSTOLAKIS: Nick said it.

16 MR. SALTOS: This is more conservative.

17 CHAIRMAN APOSTOLAKIS: Yes. The 10<sup>-4</sup> is  
18 not conservative.

19 MR. SALTOS: 10<sup>-4</sup> -- Well, this is without  
20 the defense in depth, the active systems. That was  
21 the agreement at that time to meet these goals without  
22 taking credit of the defense in depth active systems.

23 CHAIRMAN APOSTOLAKIS: So the goal is for  
24 evolutionary -- a 10<sup>-4</sup> without the active systems,  
25 and 10<sup>-6</sup>.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. SALTOS: Yes. Those were the criteria  
2 for bringing in for regulation non-safety active  
3 systems.

4 MS. CUBBAGE: You said evolutionary.  
5 That's a term that gets thrown around a lot. ABWR  
6 would be evolutionary, and these are advanced.

7 CHAIRMAN APOSTOLAKIS: Yes, but they are  
8 not Gen. 4. They are not the Gen. 4 stuff.

9 MS. CUBBAGE: Right.

10 CHAIRMAN APOSTOLAKIS: It's just way into  
11 the future.

12 MS. POHIDA: Was there anymore questions  
13 on RAI-02, the large release frequency? The reason  
14 why I asked that question was--

15 DR. KRESS: That's not LE RAI. That's RTL  
16 RAI. Right?

17 MS. CUBBAGE: Yes. The large release  
18 frequency at this plant is drawn in by events at  
19 shutdown. So that's a little bit of a different risk  
20 profile than what we've been accustomed to in a plant,  
21 and we want to understand this risk profile. So I  
22 want to understand about this containment closure, if  
23 other events could influence that frequency, and what-  
24 not. So --

25 DR. KRESS: But it doesn't have to be

1 early?

2 DR. DENNING: There is no such thing as  
3 early.

4 MS. CUBBAGE: I think GE just want it all  
5 as LRF rather than trying to differentiate the timing.

6 MR. WACHOWIAK: That's correct.  
7 Everything tends to be longer. We weren't trying to  
8 try to split hairs to say something is early versus  
9 late. We said, if it's a release, it's a release.

10 We actually didn't do much on the LARC.

11 MS. CUBBAGE: Just a release.

12 These additional issues that are listed  
13 here were identified in meetings subsequent to  
14 issuance of that RAI letter, and they have addressed  
15 those in the PRA Rev. We were asking questions about  
16 the RCS strain valve path and free seals. Again, the  
17 LRF contribution with the containment open; the impact  
18 of whether the BiMAC is available or not on the --

19 CHAIRMAN APOSTOLAKIS: Why would that be  
20 an issue?

21 MS. CUBBAGE: Which one?

22 CHAIRMAN APOSTOLAKIS: The BiMAC.

23 MR. PALLA: This is Bob Palla with staff.  
24 What we were trying to look at is the relationship  
25 between the Level 2 and the ability of this design to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 meet the safety goals, if one didn't credit the BiMAC  
2 system.

3 Now it's basically a system that at this  
4 point is conceptual. There is a lot of technical  
5 details that would still need to be worked through,  
6 and the way that GE has proposed to do this would  
7 basically transfer the responsibility for a lot of  
8 that to the COL applicant, like the testing program.

9 So -- and another element of this was the  
10 ROAAM process in -- The traditional reliance of that  
11 process on peer review is quite heavy. In fact, from  
12 what we can tell from what GE has submitted regarding  
13 the peer review process, it really was not very  
14 robust.

15 So we have called into question the degree  
16 to which we should be crediting this BiMAC system.  
17 Obviously, a number of you have expressed some  
18 reservations about a 99 percent reliability of a  
19 system that is still conceptual. So we are kind of  
20 considering how we are going to approach that in this  
21 design certification, and we are going to consider the  
22 amount -- you know, perhaps backing off, what if you  
23 only assume this thing worked 50 percent of the time.  
24 How would that impact the results?

25 Now the way that GE has modeled it, it is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 kind of a simplified approach, and I think that  
2 basically all of -- If you did that "what if" and  
3 didn't credit for BiMAC, basically those releases  
4 would go to preventive release. Now if you credited  
5 an overlying water pool as having some effectiveness,  
6 then you could slice it and dice it, and a fraction of  
7 that would still be coolable even without BiMAC. But  
8 the reason for asking this question is just to try to  
9 parse out how much of the -- how significant would the  
10 results change if you didn't credit it at all.

11 We are going to consider looking at some  
12 other -- What if you considered less credit for it?

13 CHAIRMAN APOSTOLAKIS: Well, you said, you  
14 know, what if it is 50 percent.

15 MR. PALLA: What if it is not there?

16 CHAIRMAN APOSTOLAKIS: Why don't we put  
17 just the distribution? Well, I understand that.

18 MR. PALLA: Well, if it's not there, it  
19 would be nothing different than ABWR was and we  
20 certified a design without the system.

21 CHAIRMAN APOSTOLAKIS: No, I know it is  
22 not there, but instead of being sensitivities,  
23 assuming different -- I mean, just for the  
24 distribution. But the rest of it doesn't include any  
25 uncertainty analysis. Right?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. PALLA: I mean, to me, you have to  
2 know a lot more to do an uncertainty analysis than you  
3 do to do a sensitivity.

4 CHAIRMAN APOSTOLAKIS: Yes.

5 MR. PALLA: I wouldn't know how to put a  
6 distribution on it. We could try, but I think a  
7 sensitivity study is easier to understand and easier  
8 for them.

9 CHAIRMAN APOSTOLAKIS: What I mean is --

10 MR. PALLA: Maybe we could have Theo put  
11 a distribution on it.

12 CHAIRMAN APOSTOLAKIS: No, but I think you  
13 do that, wouldn't you have to consider the  
14 uncertainties in the rest of the analysis, though?  
15 Why single out -- You would take the whole sequences  
16 where that appears.

17 MR. PALLA: Well, we are not looking at --

18 CHAIRMAN APOSTOLAKIS: I'm not  
19 criticizing.

20 MR. PALLA: I think a lot of the way that  
21 this has been handled in the Level 2 analysis is  
22 through more of a bounding approach. I'm not going to  
23 say that 99 percent is bounding, but --

24 CHAIRMAN APOSTOLAKIS: You said there was  
25 no peer review of the ROAAM process. What do you

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 mean? The actual application of the methodology to  
2 this problem? Is that what you mean?

3 MR. PALLA: Yes.

4 CHAIRMAN APOSTOLAKIS: Because ROAAM, I  
5 believe, has been reviewed, has it not?

6 MR. PALLA: The ROAAM as a methodology has  
7 been reviewed.

8 MR. THEOFANOUS: This is Theo Theofanous.

9 I do want to say that the ROAAM not only  
10 has been reviewed, but it has been used very  
11 extensively in the past to resolve the issues for the  
12 CH Mark 1 liner attack, and in those reviews, as some  
13 of you may recall, they were very contested issues.

14 So when we finished the study, we had  
15 something like 20 people internationally to review the  
16 process, review the results, write reports, and the  
17 reports are documented in the same documents in which  
18 they had the study.

19 Now on this one here, as far as the stuff  
20 that was put in yesterday, it looked to us that they  
21 were so -- I don't want to use the word trivial, but  
22 it was so simple, and the treatment was so  
23 straightforward that we didn't think -- We didn't want  
24 to try to review this again, but we picked two people  
25 that are independent experts outside of GE, outside of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 us, and then GE, to follow their procedures they  
2 picked, I think, four people from inside GE, just to  
3 follow their own procedures.

4 So we had something like six reviewers,  
5 and those are documented in the back of that document  
6 that you are supposed to have gotten in December and  
7 didn't get it. But I understand it actually came to  
8 you inadvertently.

9 In the back there the reports and our  
10 responses are in there also, and as you will see from  
11 there, our judgment there were no contested issues was  
12 actually correct, because there is nothing that was  
13 contested by any of those reviews, not even remotely.

14 So maybe what he meant, I think, is that  
15 we didn't have the same extent of peer review as in  
16 the past, like getting 20 people, and that is correct.  
17 So in that respect, it is correct. However, we did  
18 have two people independent and four people inside GE,  
19 and those reviews indicate there is nothing really to  
20 fuss about.

21 CHAIRMAN APOSTOLAKIS: Well, anyway you  
22 guys would respond to the RAI.

23 MS. CUBBAGE: Okay. It looks like we only  
24 have a couple of issues left here. One would be  
25 vulnerability --

1 CHAIRMAN APOSTOLAKIS: Ah, wait a minute  
2 now. Modeling of the digital I&C system in the PRA.  
3 Is that a fair question, guys? I mean, let's be  
4 reasonable.

5 MS. CUBBAGE: Nick, you added that one.

6 CHAIRMAN APOSTOLAKIS: The state of the  
7 art does not allow you to do this, and you are asking  
8 an applicant to do this, and are they going to  
9 establish a research program to do it? What exactly  
10 are you asking them to do?

11 MR. SALTOS: Well, the modeling is in a  
12 high bounded level. We did that for -- we did that  
13 for APR Falmouth. It is modeled in the same way. The  
14 actuation failures that we were using -- they are  
15 using this passive systems using digital I&C -- are  
16 much -- is lower compared to the actuation failure --  
17 systems. Therefore, we wanted to see why are those  
18 smaller.

19 So they got four trees down to the basic  
20 events to where the knowledge we have support the  
21 data, and whatever the knowledge does not support make  
22 conservative assumptions based on knowledge in modern  
23 industry that we can use to support the data, for  
24 example, on the software.

25 CHAIRMAN APOSTOLAKIS: Well, I mean maybe

1 what you investigate failures of the digital I&C in  
2 the PRA.

3 MR. SALTOS: It was a lot of sensitivity  
4 and bounding.

5 CHAIRMAN APOSTOLAKIS: You probably know  
6 that lots of research is ongoing right now, one  
7 element of which is -- I mean, you guys know how to do  
8 it.

9 MR. SALTOS: Well, we don't do it at that  
10 point of the day. We need to certify this design, and  
11 we certified the AP600 APR a long time ago before the  
12 research program is going to be finalized. So we  
13 needed to do something about that.

14 CHAIRMAN APOSTOLAKIS: Yes. You are not  
15 asking them to model. You are asking them to see  
16 whether the -- what is the input.

17 MR. SALTOS: Exactly, and we tried to  
18 identify those high level assumptions that would  
19 become requirements.

20 CHAIRMAN APOSTOLAKIS: You really like  
21 that word, don't you? Every time you stand up, you  
22 use it 10 times, requirements. You are with NRR,  
23 aren't you?

24 MR. SALTOS: Yes.

25 MS. CUBBAGE: All right. Well, that is

1 all I had. Unless you have any other questions, we  
2 are going to turn it over to --

3 CHAIRMAN APOSTOLAKIS: No, there are no  
4 other questions.

5 MS. CUBBAGE: Okay.

6 CHAIRMAN APOSTOLAKIS: I'm sorry.  
7 Members? I'm sorry.

8 MS. CUBBAGE: Again, this is our  
9 preliminary set of questions. We will have additional  
10 questions once the staff has an opportunity to review  
11 Revision 1 in detail.

12 CHAIRMAN APOSTOLAKIS: I would like to  
13 also be brief on this. All these issues are very  
14 interesting. So, you know, since we decided to have  
15 36 more meetings, we want to get to every single one  
16 of them. Okay.

17 MS. CUBBAGE: All right. Office of  
18 Research, and actually the contractor, ERI, will be  
19 making the next presentation.

20 MR. KHATIB-RAHBAR: For those of you who  
21 don't know me, my name is Mohsen Khatib-Rahbar. I'm  
22 the principal for Energy Research, which is a company.  
23 We are supporting NRC in the severe accident area for  
24 ESBWRs.

25 This presentation is very similar to what

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 we gave actually a few weeks ago. So there is very  
2 little new information on it other than keeping --  
3 Wow, look at this. Okay.

4 I will give you an overview of what we are  
5 doing for the NRC, specifically what is the objective  
6 of this work. Today, primarily we are focusing on the  
7 work which has been going on for the past few months  
8 in the MELCOR development activity. So we have not  
9 really started very much in the other issues of the  
10 accidents, and the current work that we will be  
11 speaking of is the MELCOR work and the confirmatory  
12 calculations to verify the applicant's calculations.

13 I will share with you some preliminary  
14 results and then discuss some planned analysis and the  
15 review of activities.

16 The objective of this work is to support  
17 the design certification, review of the severe  
18 accident risk by the NRC. We are intending to do an  
19 independent assessment of severe accident response.  
20 Because it is a new reactor, NRC is trying to learn  
21 something about the new specific features that makes  
22 it unique.

23 We will also intend to look at some  
24 accident source terms as a way to verify the GE based  
25 -- MAAP based analysis General Electric has proposed

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 for the Level 2 analysis.

2 The resolution of severe accident issues  
3 that was presented yesterday, of course, is primarily  
4 General Electric's responsibility, and one of the  
5 things that NRC would want to do here is to try to  
6 develop the uncertainties and initial bounding  
7 conditions. From what we have learned in the past,  
8 this is the essence of really resolving the severe  
9 accident issues.

10 It is not so much as whether we can  
11 calculate event clearing or not. It is an important  
12 issue. What are the uncertainties in specific  
13 conditions? How big is the hole size? How much  
14 debris you get out? What is the condition in  
15 containment, etcetera, etcetera?

16 So the idea here is to try to resolve or  
17 try to subjectively develop the solutions and perhaps  
18 even subject it to peer review, as it was done for  
19 AP600 and AP1000. Then finally, to look at some of  
20 the severe accident issues -- as an example, steam  
21 explosions -- and to see if NRC considers that to be  
22 something significant DCH, etcetera.

23 Let me also give a little bit of the  
24 MELCOR activity. The MELCOR model was developed based  
25 on the information which was submitted by General

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 Electric back in late 2005, and the Sandia National  
2 Laboratories, which is the developer of the code,  
3 issued the latest version of MELCOR, and we got  
4 marching orders from the NRC to use that for the  
5 analysis.

6 So we developed the initial MELCOR deck  
7 for 1.86. This was subjected to independent peer  
8 review by Purdue and Sandia and one of their  
9 subcontractors. The review comments was provided to  
10 us. We addressed the comments. We documented how we  
11 addressed the comments, and recognizing that we have  
12 problems with MELCOR 1.86, -- these are primarily  
13 numerical problems, performance problems -- the  
14 decision was made that we will stop that and shift  
15 back to 1.85 until these problems are resolved. Then  
16 we could come back to that.

17 So what we will discuss today is some  
18 preliminary results based on the older version of the  
19 code, and we have just received some revisions to  
20 1.86, and we are trying to update this input.

21 You may want to know what's the major  
22 difference between 1.85 and 1.86 as far as the ESBWR  
23 is concerned. One of the things they have done in  
24 1.86 is they have developed a molten pool model for  
25 within the reactor core, and there is also molten pool

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 model for the lower half of the reactor pressure  
2 vessel.

3 How significant are these in terms of  
4 overall picture for the ESBWR, I cannot tell, but  
5 those are the recent modeling issues. Otherwise,  
6 thermal hydraulics in the codes are basically the  
7 same.

8 Other features of this model they have  
9 developed: It has the built into containment spray  
10 system, the venting system, all the nine yards. Of  
11 course, the BiMAC system has not been explicitly  
12 modeled, because I am not so sure that it could be  
13 modeled within MELCOR, just thinking of the  
14 sensitivity.

15 Also in order demonstrate that we are  
16 basically taking the correct design conditions from  
17 the reactor, we have done three accident steady state  
18 calculations with the code and compared that with the  
19 DCD results.

20 For some reason this does not show up.  
21 The table doesn't show up. Anyway, in your handouts  
22 you have some calculation result that shows MELCOR  
23 against the DCD results. What you will see there is  
24 the biggest difference comes in from the pressure  
25 drops across the core plate, and we requested some

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 additional information from General Electric.  
2 Hopefully, we can resolve that, but that is really not  
3 a major concern for severe accidents, because pressure  
4 drops are really not a concern, just as far as that is  
5 concerned.

6 The scenario that we have just picked up  
7 to analyze as a preliminary case is a dominant  
8 scenario risk contributor in ESBWR. We have zero, and  
9 in the short term -- It's a lot of feedwater. Short  
10 term and long term fuel and injection -- is not  
11 available. The ADS is activated on level. The heat  
12 removal by isolation condenser is not corrected, and  
13 the PCC and IC pool makeup is available, and is in  
14 our analysis. We assumed different makeup of these,  
15 and also GDCS deluge system is available and credited  
16 in the analysis.

17 We considered two cases, you know, one  
18 case where MCCI was suppressed, basically affecting,  
19 I think, a perfect BiMAC system; and the second case,  
20 which is an obvious case that MCCI is credited. This  
21 behaved very much like other small volume  
22 containments.

23 Again, for some reason the picture doesn't  
24 show up in here, but what does show up --

25 CHAIRMAN APOSTOLAKIS: It doesn't.

1 MR. KHATIB-RAHBAR: Maybe the font is  
2 different than the --

3 CHAIRMAN APOSTOLAKIS: Oh, okay.

4 MR. KHATIB-RAHBAR: Maybe I can go  
5 through.

6 CHAIRMAN APOSTOLAKIS: No, that's okay.  
7 That's all right. You can see it here now.

8 MR. KHATIB-RAHBAR: Can you all see this?  
9 Really, the differences in results primarily coming  
10 from some of the uncertainty in the assumptions that -  
11 - As documented in the DCD, we don't really have  
12 enough information, and modular electric and other  
13 calculations were run, and most showed actual  
14 differences in the code.

15 These are not really significant, but  
16 basically, the position of the team, the comparisons  
17 are remarkably good, given the fact that they were  
18 done with two different codes and so forth. For  
19 example, fission product releases -- this is intact  
20 containment -- are as close as one can expect to get.  
21 They are fairly reasonable.

22 DR. DENNING: Why would the deluge system  
23 be -- Why do you have the delay in the activation of  
24 the deluge system?

25 MR. KHATIB-RAHBAR: Yes. There are couple

1 of other things. One is in the MAAP calculations, it  
2 had stayed intact for a long time after relocation of  
3 core debris to the lower half. We don't know the  
4 reasons for that. So that substantially changes the  
5 time of reactor pressure vessel failure.

6 MR. DENNING: Right.

7 MR. KHATIB-RAHBAR: The other thing is  
8 that the deluge system has a temperature sensor on the  
9 containment floor. When the temperature is --  
10 specific temperature is reached, then the system is  
11 activated. That is currently modeled in the MELCOR  
12 that we have modeled here. We are not so sure whether  
13 that is included in the MAAP or not or whether that  
14 is, you know, manually injected or not.

15 DR. DENNING: Presumably, at the time of  
16 lower head penetration, you have molten debris. Why  
17 didn't it immediately activate when --

18 MR. KHATIB-RAHBAR: Because the  
19 thermocouple is supposed to be buried under the  
20 concrete. It's not on the surface of the concrete.  
21 Is that correct?

22 MR. YUAN: Zhe, you could perhaps comment  
23 on that. We assumed it to be the way the thermocouple  
24 location, at least you have assumed for your  
25 calculations.

1 DR. DENNING: Assume it's four hours.

2 CHAIRMAN APOSTOLAKIS: Speak to the  
3 microphone, please. Say who you are.

4 MR. KHATIB-RAHBAR: Why did it take so  
5 long for the temperature to be reached for the deluge  
6 to become activated?

7 MR. YUAN: I'm Zhe Yuan from ERI. I think  
8 we checked that results, because at the rate of mass  
9 and the time of mass to come down through the cavity  
10 is not sufficient enough to bring up the temperature  
11 of the floor.

12 MR. KHATIB-RAHBAR: Initially, you get a  
13 small quantity of debris coming out, but the debris  
14 has to accumulate to reach enough mass so it can  
15 affect the temperature. That is at least what the  
16 code calculates.

17 DR. DENNING: Thank you.

18 MR. KHATIB-RAHBAR: This just shows a  
19 comparison between --basically the containment  
20 pressurization between MELCOR and MAAP, and the  
21 results are generally okay.

22 If you were to assume that the BiMAX  
23 system is not there, this is a no-brainer. You will  
24 clear this containment in 24 hours.

25 What we plan to do is NRC has asked us to

1 look at the risk --

2 CHAIRMAN APOSTOLAKIS: I'm sorry, Mohsen.  
3 Go back.

4 MR. KHATIB-RAHBAR: Which one?

5 CHAIRMAN APOSTOLAKIS: The next. Is that  
6 what Bob Palla wanted to see? Assuming that there is  
7 no BiMAC there, what happens? So you guys come down.  
8 I'm trying to understand what's going on, by the way.

9 MR. PALLA: Yes. This is Bob Palla.  
10 We've known that this would happen. I think there is  
11 a sensitivity study in the ESBWR PRA that would show  
12 us a similar result.

13 I was asking for the impact on the PRA  
14 results. This is just one sequence. I wanted to look  
15 at the sensitivity of the overall results.

16 CHAIRMAN APOSTOLAKIS: Very good. Thank  
17 you.

18 DR. DENNING: Mohsen, with MCCI what kind  
19 of cesium iodide release did you get in that case?

20 MR. KHATIB-RAHBAR: This is intact  
21 containment. This is an intact containment case. So  
22 the releases, again, are driven by the designed  
23 leakage rates. But of course, what gets released to  
24 the containment is -- you know, for BWR what controls  
25 the release is -- Since you get the dominant amount of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 cesium iodide coming in during the in-vessel phase,  
2 that's mostly going to the pool. So it's going to be  
3 contained by the pool. So very little amount of  
4 cesium iodide comes out. It's not any different than  
5 what you see in other plants.

6 In addition, you have a lot of water on  
7 top of the core debris heat on the containment floor.  
8 So the rest of it is stopped by that anyway.

9 MR. DENNING: Okay.

10 MR. KHATIB-RAHBAR: The rationale for  
11 selection of the scenarios that will be analyzed is to  
12 provide bounding conditions for the NRC's analysis --  
13 for example, the FCI analysis; to enable limited  
14 comparisons to the MELCOR calculations; and also MAAP  
15 calculations also to assess the sensitivity design  
16 operational aspects, like sprays -- NRC is interested  
17 in this issue; and also to support any other  
18 objectives that NRC may have.

19 So this is like a moving thing, and we do  
20 calculations NRC asks us to do.

21 In terms of the rationale for selection of  
22 the scenarios, we have looked at the -- There's  
23 dominant scenarios, frequency dominant scenarios, and  
24 in some cases consequence dominant scenarios. So the  
25 idea is to cover the whole spectrum.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN APOSTOLAKIS: We're getting  
2 insights, right?

3 MR. KHATIB-RAHBAR: The word that you  
4 hate.

5 The MELCOR deck has been completed. There  
6 is also -- Some typical calculations have been done,  
7 are available. We have identified the scenarios to be  
8 analyzed based on the draft Zero and, of course, they  
9 may change; and based on MELCOR calculations, for the  
10 most part, have been completed, but we are awaiting  
11 additional responses from General Electric on specific  
12 issues before these are finalized.

13 In terms of the ex-vessel analysis, we  
14 have just started looking at this issue. Initial  
15 conditions are aimed at confirming the GE calculations  
16 under identical conditions. In fact, we are going to  
17 be using a code which was developed many years ago.

18 We will formulate initial conditions for  
19 ex-vessel analysis, lower head failure location,  
20 typical things that one does in ex-vessel analysis,  
21 and we will perform an analysis on a wide range of  
22 conditions and parameters similar to those which were  
23 done for AP600 when we did the reviews for AP600.

24 That basically concludes my presentation.  
25 If there any questions, I will be happy to respond to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 them.

2 CHAIRMAN APOSTOLAKIS: With lightning  
3 speed, Mohsen.

4 MR. KHATIB-RAHBAR: Because I know you  
5 guys want to get to the airport. So I don't want to  
6 hold you here.

7 CHAIRMAN APOSTOLAKIS: Oh, you've been in  
8 this situation yourself. Any questions from the  
9 members? Okay. Thank you very much. Yes? Go  
10 ahead.

11 MR. WACHOWIAK: I have one point on that.  
12 I usually talk loud enough, but I don't have to do  
13 that.

14 CHAIRMAN APOSTOLAKIS: You always talk  
15 loud enough.

16 MR. WACHOWIAK: Okay. The one question  
17 about did that curve answer Bob Palla's question. The  
18 answer is no.

19 CHAIRMAN APOSTOLAKIS: Yes. He said it.

20 MR. WACHOWIAK: Okay. That curve and the  
21 other ones are just like what we had. It ignores that  
22 question. So I just want to be clear on that. That  
23 was not to represent what would happen. It's a  
24 sensitivity.

25 CHAIRMAN APOSTOLAKIS: We understand that,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 Rick. Thank you.

2 Any comments from the members? Okay. So  
3 then we will arrange, and Eric here will take care of  
4 it.

5 MS. CUBBAGE: He knows where to find me.

6 CHAIRMAN APOSTOLAKIS: We have a meeting.

7 Usually the first week of October, we have the full  
8 Committee meeting. So it would have to be after.  
9 Yes, sir?

10 DR. DENNING: I did have a question, and  
11 that is: You are assuming no letter until after that  
12 next meeting?

13 CHAIRMAN APOSTOLAKIS: I hadn't thought  
14 about it. It's up to the committee, of course. We  
15 can write an interim letter, if we have anything  
16 important to say.

17 DR. DENNING: Everything I am seeing so  
18 far is quite constructive. So I'm not sure it changes  
19 the course of the direction. So I wouldn't see any  
20 reason to write it.

21 CHAIRMAN APOSTOLAKIS: Yes. Right now I  
22 am not inclined to write an interim letter, but if the  
23 members feel otherwise, we can always change our  
24 minds.

25 DR. BONACA: I wouldn't. I don't see

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 anything.

2 CHAIRMAN APOSTOLAKIS: There is nothing.

3 MS. CUBBAGE: Too preliminary. We were  
4 not expecting a letter at this time but, of course, if  
5 you do have any significant issues, the earlier we  
6 hear about them, the better.

7 CHAIRMAN APOSTOLAKIS: So we will probably  
8 write a letter after we receive the SER, as usual.

9 MS. CUBBAGE: Right.

10 CHAIRMAN APOSTOLAKIS: Typically, there is  
11 a separate letter on the PRA. As I recall, for AP600  
12 we did write a separate letter, did we not? I'm not  
13 really sure.

14 So, no, it is not an issue of letter.  
15 It's really an issue of participatory peer review.  
16 Right? Educating the committee, raising concerns,  
17 getting the feedback from the applicant -- that's the  
18 normal way of doing business.

19 MS. CUBBAGE: Right. If we waited until  
20 the end of the process to get you involved, it's too  
21 late.

22 CHAIRMAN APOSTOLAKIS: The ACRS has  
23 changed its modus operandi for a long time now. This  
24 is participatory review.

25 Okay, there is nothing else then? I would

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 like to thank the speakers. This was a very  
2 informative meeting, and I learned a lot. I gained a  
3 lot of insights.

4 Thank you very much.

5 (Whereupon, the foregoing matter went off  
6 the record at 11:30 a.m.)

7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

CERTIFICATE

This is to certify that the attached proceedings before the United States Nuclear Regulatory Commission in the matter of:

Name of Proceeding: Advisory Committee on  
Reactor Safeguards  
Reliability and Risk  
Assessment Subcommittee

Docket Number: n/a

Location: Rockville, MD

were held as herein appears, and that this is the original transcript thereof for the file of the United States Nuclear Regulatory Commission taken by me and, thereafter reduced to typewriting by me or under the direction of the court reporting company, and that the transcript is a true and accurate record of the foregoing proceedings.



---

Eric Mollen  
Official Reporter  
Neal R. Gross & Co., Inc.


**NEAL R. GROSS**  
COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealgross.com](http://www.nealgross.com)

## ESBWR External Events Risk Management

Fire, Flood, High Wind,  
and Seismic Analyses



Presented By:  
Rick Wachowiak  
General Electric  
April 21, 2006

imagination at work 

## Probabilistic Fire Analysis

FIVE Methodology Provides the Bases for:

- > Identifying fire compartments
- > Defining fire ignition frequencies
- > Performing quantitative screening analyses of fire risk

Risk of Core Damage due to Fire in Each of the Area Groups Should be Lower than the Risk of Core Damage due to Internal Events

 imagination at work

GE Energy / ESBWR External Events Risk Management  
April 20, 2006 <sup>2</sup>

## Scope of Analysis

Fire scenarios in:

- > Reactor Building
- > Control Building
- > Fuel Building
- > Turbine Building
- > Electrical Building
- > Service Water Building

Full Power and Shutdown Modes of plant operation

 imagination at work

GE Energy / ESBWR External Events Risk Management  
April 20, 2006 <sup>3</sup>

## Bounding Assumptions

Fires Grow Within A Building to Non-Mechanistically Affect All Equipment In A Division

- > Any Fire in a Division I Room In the Reactor Building is Assumed to Damage All Division I Equipment in the Reactor Building

Fire Protection is Not Credited


Worst Case Spurious Actuation is Postulated

 imagination at work

GE Energy / ESBWR External Events Risk Management  
April 20, 2006 <sup>4</sup>

## Fire Results

All Fire Scenarios But One Have CDF  $< 3 \times 10^{-10}$   
Turbine Building Considered One Fire Area  
Turbine Building Fire Treated as Loss of Feedwater  
This Sequence Has a CDF of  $1 \times 10^{-8}$   
Similar to Loss Of Feedwater in Internal Events



GE Energy / ESBWR External Events Risk Management  
April 20, 2006

## Shutdown Fire Results

Still Under Development



GE Energy / ESBWR External Events Risk Management  
April 20, 2006


## Probabilistic Flooding Analysis

Initiation frequency based upon BWR experience

Flood scenarios in:

- > Reactor Building
- > Control Building
- > Fuel Building
- > Turbine Building
- > Electrical Building
- > Service Water Building

Full Power and Shutdown Modes of plant operation



GE Energy / ESBWR External Events Risk Management  
April 20, 2006

## Flooding Frequencies

### At-Power Flooding Frequencies

Based on the general information contained in NUREG/CR-5750 and NUREG/CR-2300

### Shutdown Flooding Frequencies

Shutdown frequencies are calculated based on the data for BWR plants for the years 1980-1996. Provided in NUREG/CR-5496.

The ESBWR flooding frequency values also accounts for a 24 month refueling outage cycle.




GE Energy / ESBWR External Events Risk Management  
April 20, 2006

## Reactor Building

Major water sources:

- (1) Fuel Auxiliary Pool Cooling System (FAPCS)
- (2) Reactor water Cleanup / Shutdown Cooling (RWCU/SDC)
- (3) Reactor Component Cooling Water System: (RCCWS)
- (4) Fire Protection System: (FPS)
- (5) Feedwater System: FW pipe breaks are LOCA initiators. FW lines outside containment are located in the steam tunnel. A FW line break in the steam tunnel flood progression into the Turbine Building.



GE Energy / ESWR External Events Risk Management  
April 20, 2006

## Control Building

Major water sources:

- (1) Chilled Water System: Limited volume of water is not sufficient to cause an initiating event.
- (2) Potable Water and Sanitary Waste System (PWSWS): Small water volume released.
- (3) Fire Protection System (FPS): Pipes are of short length and small diameters (2-1/2 inches). The frequency and the impact of the water released is small.




GE Energy / ESWR External Events Risk Management  
April 20, 2006

## Fuel Building

Potential flooding sources:

- (1) Fuel and Auxiliary Pools Cooling System (FAPCS): Check valves and vacuum breaker valves eliminate potential siphon effect discharge from the fuel pool. Flooding requires a system pipe break and failure of at least one vacuum breaker valve.
- (2) Reactor Component Cooling Water (RCCW):
- (3) Fire Protection System (FPS): Larger FPS pipes. Water released to the FB lower floor can progress through an open doorway. Large volume of released water could cause the loss of the RWCU/SDC.



GE Energy / ESWR External Events Risk Management  
April 20, 2006

## Turbine Building

Flooding sources considered are:

- (1) Circulating Water System (CWS)  
Flooding from a break in the circulating water system is the bounding scenario in the TB
- (2) Condensate and Feedwater System (C&FS)
- (3) Reactor Component Cooling Water (RCCWS)
- (4) Plant Service Water System (PSWS)
- (5) Fire Protection System (FPS)




GE Energy / ESWR External Events Risk Management  
April 20, 2006

## Electrical Building

Flooding sources considered are:

- (1) FPS system: FPS flow rate is low.
- (2) RCCW: Flooding due to diesel generator cooling water system leak in a single diesel generator room is considered to be a negligible risk. Flooding in one diesel generator room would not affect the other diesel generator, and flooding in a DG room would not affect external power supplies, or cause an initiating event.



13  
GE Energy / ESBWR External Events Risk Management  
April 20, 2006

## Service Water Building

The Plant Service Water System (PSWS) is the primary flood source in the Service Water Building.

The loss of service water scenario is included and analyzed in the ESBWR PRA internal events analysis by use of the Complete Loss of PSWS initiator.

The frequency of service water floods in the Service Water Building is inherently included in the Complete Loss of PSWS initiator frequency.



14  
GE Energy / ESBWR External Events Risk Management  
April 20, 2006

## At Power Flooding Scenarios


- AP-1: Reactor Building Outside Containment - CRDS pipe breaks outside containment.
- AP-2: Reactor Building Outside Containment - FPS pipe breaks.
- AP-3: Reactor Building Outside Containment - RWCU/SDCS line break outside of containment.
- AP-4: Reactor Building Outside Containment - FPS line break and general transient
- AP-5: Turbine Building - Complete loss of feedwater
- AP-6: Turbine Building - Loss of Plant Service Water
- AP-7: Electrical Building - Loss of Power Conversion System
- AP-8: Diesel Generator Room - General Transient with Loss of One Diesel Generator



15  
GE Energy / ESBWR External Events Risk Management  
April 20, 2006

## Shutdown Flooding Scenarios

- SD-1 and SD-3: Reactor Building - CRDS pipe breaks outside containment
- SD-2 and SD-4: Reactor Building Outside Containment Shutdown Flooding Scenario
- SD-5 and SD-6: Reactor Coolant System Inventory Control
- SD-7 and SD-8: Fuel Building Shutdown Flooding Scenarios




16  
GE Energy / ESBWR External Events Risk Management  
April 20, 2006

## CDF for internal flooding

CDF for internal flooding is a not a dominant contributor to the overall plant CDF.

The contribution due to flood to the CDF is one order of magnitude less than the CDF due to internal events:

Contribution Description	CDF (per calendar year)
Internal Events	2.9E-08
Flood At-Power	3.7E-09
Flood Shutdown	1.6E-09



## Key Features Important to Flood Results

- Layout and safety design features
- Safety system redundancy and physical separation provide protection from flooding by large water sources
- Alternate safe shutdown features in buildings separated from flooding of safety systems
- Watertight doors on the Control and Reactor Buildings
- Floor drains in the Reactor and Control Buildings
- Automatic CWS pump trip and valve closure on high water level in the condenser pit



## High Wind Risk - Tornado

Treated as Loss of Preferred Power with No Recovery within 24 Hours

Condensate Storage Tank is Assumed Failed

Initiating Event Frequency is Much Lower than LOPP without Recovery

Risk Due to this Scenario is Very Small  $\sim 10^{-12}$



## Seismic Margins

Addresses the Capability of Safety Systems for Seismic Response

Determined Fragility for All Safety Systems

Assigned That Fragility To Each Branch of The Event Tree

> Non-Safety assigned  $0.0 \times SSE$  fragility value

Fragility for the Sequence is the Maximum of Each Branch

Total Fragility is the Minimum of All the Sequences




## Seismic Margins Results

All Sequences Show At Least 2 \* SSE Capability


Full Power and Shutdown

Unlikely the Seismic Will Be a Vulnerability




21  
GE Energy / ESWR External Events Risk Management  
April 26, 2006

# ESBWR Shutdown Risk Management



Presented By:  
Rick Wachowiak  
General Electric  
April 21, 2006



# Scope of Shutdown Analysis

- Internal Events & External Events
- Seismic Margins
- Mode 5 (Cold Shutdown)
- Mode 6 (Refuel)
- Same Level of Detail as Power Operation PRAs




GE Energy / ESBWR Shutdown Risk Management  
April 21, 2006

# Initiating Events During Shutdown

- Manual Shutdown
- LOCA – Mode 6 Only
- Loss of Power
- Loss of Shutdown Cooling
- Fires
- Floods

Not Applicable for  
Mode 6 With Reactor  
Cavity Flooded


There is More than  
72 Hours to Recover  
DHR



GE Energy / ESBWR Shutdown Risk Management  
April 21, 2006

# Maintenance Activities During Shutdown

- Multiple Pumps / Trains of Feedwater And  
Condensate May be Unavailable
- Some Fire and Flood Barriers May Be Open
- ICS Out of Service in Mode 6
- 1 GDSCS Pool Allowed Unavailable in Mode 6
- PCCS Unavailable in Mode 6
- SRVs and DPVs Unavailable in Mode 6



GE Energy / ESBWR Shutdown Risk Management  
April 21, 2006


## Recovery Actions During Shutdown

Shutdown Events Tend to Move Slower  
 More Time to Recover Initiating Event  
 Recovery Events Added to Shutdown Model

- > Recovery of Shutdown Cooling
- > Recovery of Offsite Power
- > Recovery of Service Water.

Approximately 5 Hours to Recover

Non-Recovery Value Based on Industry Events that Have Occurred During Shutdown



imagination at work

GE Energy / ESBWR Shutdown Risk Management  
 April 21, 2006

## Shutdown CDF Results

Manual Shutdown	$2 \times 10^{-12}$
Loss of DHR	$< 10^{-12}$
Loss of Service Water	$3 \times 10^{-12}$
Loss of Preferred Power	$4 \times 10^{-10}$
LOCA	$4 \times 10^{-9}$





imagination at work

GE Energy / ESBWR Shutdown Risk Management  
 April 21, 2006

Containment Water  
 Capacity During  
 Shutdown LOCA

Approximate Water  
 Level With Hatch  
 Closed

Elevation of Hatch



imagination at work

GE Energy / ESBWR Shutdown Risk Management  
 April 21, 2006

## Shutdown PRA As A Design Tool Example

LOCA Dominated by Pipes Connected Below the Core  
 PRA Assumes Hatches are Open During Mode 5  
 PRA Assumes Containment is Open During Mode 5

GE is Considering Options to Address This Scenario




imagination at work

GE Energy / ESBWR Shutdown Risk Management  
 April 21, 2006

## Shutdown PRA Input to Operational Programs Example

Fire Barriers Should Be Controlled During Shutdown  
Remaining Intact is Best Option  
Compensatory Measures (e.g. Fire Watch) are Adequate

Detailed Layout / Routing and Fire Modeling Needed to Relax This Requirement



GE Energy / ESBWR Shutdown Risk Management  
April 21, 2006

## Final Remarks on Shutdown


Iterative Process with Design Still in Progress for Shutdown

Fire and Flood Models For Shutdown Still Under Development



GE Energy / ESBWR Shutdown Risk Management  
April 21, 2006


## ESBWR Risk Management Insights



GE Energy / ESBWR Shutdown Risk Management  
April 21, 2006

## ESBWR Risk Management Program

Supports Desired Goals  
Scope is Appropriate  
Enhanced Defense-in-Depth  
PRA is a Valuable Design Tool  
PRA Will Continue to Grow Through Plant Operation




GE Energy / ESBWR Shutdown Risk Management  
April 21, 2006

## Overall Results and Observations

ESBWR Robust Design Results in Low CDF and LRF  
We Are Testing The Limits of Current PRA Techniques

- > Unknowns may be as important as the known
- Some Screening Methods Not as Effective
  - > Thresholds too low to screen anything
- Relative Risk Ranking Could Be A Significant Issue
  - > Also a threshold problem

When Compared to Other Plants, Using the Same Methods,  
ESBWR Provides the Best Level of Safety Available



# ESBWR DESIGN CERTIFICATION PRA AND SEVERE ACCIDENTS OVERVIEW

ACRS - Reliability and Probabilistic Risk Assessment  
Subcommittee

April 20 & 21, 2006

## PRA and Severe Accident RAIs

**RAI 19.0.0-1:** Requested peer review results for ROAAM methodology used to support the assessment of direct containment heating, steam explosions, and core concrete interactions for ESBWR.

**RAI 19.2.3-1:** Requested equipment survivability assessment.

**RAI 19.2.4-1:** Requested information regarding the accident management program under which guidance and training would be provided on the use of such features as containment venting, drywell sprays, and fire pumps for isolation condenser make-up.

**RAI 19.4.0-1:** Requested more rigorous evaluation of Severe Accident Mitigation Design Alternatives (SAMDA).

## PRA and Severe Accident RAIs (cont.)

**RAI 19.0.0-2:** GE was requested to include the contribution from all accident classes when characterizing the overall containment performance and risk for severe accidents.

**RAI 19.0.0-3:** Additional information was requested regarding lower drywell flooding to assess probability of containment failure due to ex-vessel steam explosion.

**RAI 19.0.0-4:** Additional design details were requested regarding Basemat Internal Melt Arrest and Coolability (BiMAC) system.

**RAI 19.0.0-5:** Additional details were requested regarding the the corium splash shield and protection of the lower drywell sumps by the BiMAC cooling jacket.

3

## PRA and Severe Accident RAIs (cont.)

**RAI 19.0.0-6:** Requested expanded assessment of PRA uncertainty and importance analysis addressing the uncertainty and sensitivity of results to key containment-related features, assumptions, and operator actions.

**RAI 19.0.0-7:** Requested detailed information regarding containment isolation provisions/failures related to review of containment failure modes.

**RAI 19.1.0-1:** Requested a systematic assessment of the impact of thermal-hydraulic uncertainty on the PRA models and results.

**RAI 19.1.0-2:** Requested more documentation/analyses of the process for selecting RTNSS systems (regulatory treatment of non-safety systems) including systems used during shutdown conditions.

4

## PRA and Severe Accident RAIs (cont.)

RAI 19.1.0-3: Requested submittal of additional cutsets and a discussion on the use of uncertainty, sensitivity and importance analyses.

RAI 19.1.0-4: Requested that GE Identify design requirements based on PRA insights and assumptions.

RAI 19.1.0-5: Requested references for component reliability data base.

RAI 19.1.0-6: Requested detailed evaluations of important human actions and their associated human error probabilities.

RAI 19.1.0-7: Requested additional details regarding GE's fire risk analysis.

5

## PRA and Severe Accident RAIs (cont.)

RAI 19.3.0-1: Requested risk assessment for fires and floods during shutdown.

RAI 19.3.0-2: Requested discussion of large release frequency (LRF) risk during shutdown.

### Additional issues identified during meetings:

- Assessment of potential RCS draindown paths through the RWCU/SDC system and risk of using freeze seals
- LRF contribution from cold shutdown operations when the containment can be open
- Impact on level 2 PRA results if BiMAC is not credited
- Effect of impingement of molten core debris on the lower drywell equipment/personnel hatch
- Drywell water level at time of vessel breach
- Modeling of the digital I&C system in the PRA

6



## **CONFIRMATORY ANALYSIS OF SEVERE ACCIDENTS FOR ESBWR**

Advisory Committee on Reactor Safeguards

U. S. Nuclear Regulatory Commission

April 21, 2006

by:

M. Khatib-Rahbar, Z. Yuan, M. Zavisca, A. Krall and H. Esmaili

Energy Research, Inc.

6167 Executive Blvd.

Rockville, Maryland 20852



### OUTLINE

- Objectives
- MELCOR Modeling of ESBWR
- Preliminary Results
- Planned Analyses





## OBJECTIVES

- To support the design certification review of severe accident risk by NRC in
  - Independent assessment of severe accident response
  - Confirmatory assessment of representative radiological release estimates
  - Development of uncertainties in the initial and boundary conditions for analysis of selected severe accident issues
  - Confirmatory analysis of selected severe accident issues (e.g., ex-vessel steam explosion, MCCI, etc.)

## MELCOR Model Development

- Developed initial input decks for MELCOR 1.8.6 using GE design data
- MELCOR 1.8.6 deck subjected to an independent QA and review (Purdue & SNL/JTA)
- Review comments factored in the modification to the MELCOR 1.8.6 deck
- Due to code performance issues, the deck was finalized for MELCOR 1.8.5
- The initial baseline calculations were performed with MELCOR 1.8.5 & work is underway to finalize MELCOR 1.8.6 deck as performance issues are being resolved by SNL




### OTHER FEATURES

- Containment spray system and the venting system included
- Refill of PCC/IC pool included.
- BiMAC system not explicitly modeled
- Pre-accident steady state calculation performed prior to simulation of accidents

### MELCOR Steady-State Results vs. GE DCD Values

<u>Parameters</u>	<u>Design value</u>	<u>Simulated value</u>
Steam flow rate (kg/s)	2433	2436
Feedwater flow rate (kg/s)	2451	2452
Core coolant flow rate (kg/s)	9034-10584	9452
Control Rod Drive flow rate (kg/s)	5.9	5.9
Cleanup demineralizer system flow rate (kg/s)	24.3	24.3
System pressure, nominal in steam dome (kPa)	7171	7177
System pressure, nominal core design (kPa)	7240	7243
Core inlet temperature (°C)	543-545	543
Total core pressure drop (from bottom of the core support plate to top of the core) (kPa)	70.0	47.0
Core plate pressure drop (kPa)	41.3	31.5
Core maximum exit void fraction	0.916	0.90
Downcomer liquid level (m)	17.27	17.6



### MELCOR-Simulated Accident Scenario

- Transient event initiated by a loss of feedwater (i.e., scenario T\_DP\_nIN of the ESBWR PRA):
  - Short or long-term coolant injection to RPV not available (i.e., GDCS injection to RPV & wetwell injection through equalization lines not available).
  - ADS is assumed to be actuated if downcomer water level drops below 11 m.
  - Heat removal by ICs not credited.
  - PCC & PCC/IC pool makeup available (thereby allowing long-term containment heat removal).
  - GDCS deluge system is also available for injection onto the lower drywell floor.

### MELCOR-Simulated Accident Scenario (Cont.)

- Two cases considered:
  - ❖ Case 1: MCCI suppressed (Perfect BiMAC)
  - ❖ Case 2: MCCI allowed to occur (assuming MELCOR standard basaltic concrete composition).




### Comparison With MAAP Results (Case 1: Without MCCI)

Event	MAAP <sup>a</sup>	MELCOR
RPV depressurization starts (DPVs open), hour	$8.6 \times 10^{-3}$	0.33
Start of core uncover, hour	0.36	0.86
Onset of core damage (i.e., fuel temperature exceeds 2500 K), hour	0.97	1.69
RPV lower head penetration failure, hour	6.3	3.91
Deluge system actuated, hour	6.3	7.9
Containment (upper drywell) pressure at 24 hours, bar-abs	5.0	4.8
Containment (lower drywell) temperature at 24 hours, K	425	427
Containment fail/vent, hour	N/A	N/A
PCCS heat removal at 24 hours, MW	18.5	22.7
Water level in drywell at 24 hours (relative to bottom of the RPV), m	13.1	12.5
Axial concrete erosion in 24 hours, m	0.07	0.0
Mass fraction of noble gases released to environment	$9.0 \times 10^{-4}$	$8.7 \times 10^{-4}$
Mass fraction of CsI released to environment	$7.4 \times 10^{-5}$	$1.8 \times 10^{-5}$



ERI Energy Research, Inc. <sup>a</sup>MAAP results taken from NEDC-33201P (Rev 0)

### Upper Drywell and Wetwell Pressure (Case 1: Without MCCI)



ERI Energy Research, Inc.

MAAP results taken from NEDC-33201P (Rev 0)



### Planned Calculations

- Rationale for selection of scenarios:
  - To provide initial & boundary conditions for NRC confirmatory analyses (e.g., FCI)
  - To enable limited comparison to MAAP predictions
  - To assess sensitivity to design/operational aspects (e.g., sprays)
  - To support other NRC objectives
- “Risk-dominant”, “frequency-dominant”, and “consequence-dominant” scenarios will be examined, together with influence of various assumptions and sensitivity cases

ERI  
Energy Research, Inc.

12



## STATUS

- MELCOR model completed and initial confirmatory calculations are underway.
  - Results of a representative accident scenario with limited comparisons to the GE submittal completed
  - Identified representative scenarios to be analyzed
  - Baseline MELCOR calculations for the most part, have been completed with the available data; however, final calculations await the receipt of requested data from GE.

## STATUS (Cont.)

- Ex-Vessel FCI analyses have been started:
  - Initial calculations aimed at confirming the GE calculations under identical conditions
  - Will formulate initial conditions for ex-vessel analyses:
    - Lower head failure size and location
    - Debris mass, composition and temperature
    - Etc.
  - Perform analyses to span a wide range of conditions and parameters (similar to those of AP1000)