

May 12, 2006

LICENSEE: Nebraska Public Power District (NPPD)

FACILITY: Cooper Nuclear Station (CNS)

SUBJECT: SUMMARY OF MAY 5, 2006, MEETING WITH NPPD ON CNS TORNADO CONCERNS (TAC NO. MC8236)

On May 5, 2006, a Category 1 public meeting was held between the U.S. Nuclear Regulatory Commission (NRC) and representatives of NPPD at the NRC Headquarters, One White Flint North, 11555 Rockville Pike, Rockville, Maryland. The purpose of the meeting was to discuss concerns related to the design of components and systems inside the diesel generator (DG) building and their ability to withstand tornado pressurization loads. The concerns were identified and documented as an unresolved item in a Safety System Design and Performance Capability inspection conducted in May 2005. The licensee presented its venting analysis of the DG building and discussed its calculations that demonstrated the structural adequacy of the heating, ventilation, and air conditioning ducting during depressurization and repressurization phases of the tornado event.

The NRC staff determined that there was not an immediate safety concern for components inside the DG building at CNS. However, the NRC staff still intends to look at this on a generic basis. The NRC staff felt that the alternate calculation performed was reasonable and practical, but the staff had not reviewed the venting details. Region IV should close the unresolved item in the next resident integrated inspection report.

Members of the public were not in attendance. A list of meeting attendees is enclosed. A copy of the licensee's slides presented at the meeting has been placed in the NRC Agencywide Documents Access and Management System Accession Number ML061290460.

Please direct any inquiries to me at 301-415-3764, or bjb@nrc.gov.

/RA/

Brian Benney, Project Manager
Plant Licensing Branch IV
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-298

Enclosure: List of Attendees

cc w/encl: See next page

May 12, 2006

LICENSEE: Nebraska Public Power District (NPPD)

FACILITY: Cooper Nuclear Station (CNS)

SUBJECT: SUMMARY OF MAY 5, 2006, MEETING WITH NPPD ON CNS TORNADO CONCERNS (TAC NO. MC8236)

On May 5, 2006, a Category 1 public meeting was held between the U.S. Nuclear Regulatory Commission (NRC) and representatives of NPPD at the NRC Headquarters, One White Flint North, 11555 Rockville Pike, Rockville, Maryland. The purpose of the meeting was to discuss concerns related to the design of components and systems inside the diesel generator (DG) building and their ability to withstand tornado pressurization loads. The concerns were identified and documented as an unresolved item in a Safety System Design and Performance Capability inspection conducted in May 2005. The licensee presented its venting analysis of the DG building and discussed its calculations that demonstrated the structural adequacy of the heating, ventilation, and air conditioning ducting during depressurization and repressurization phases of the tornado event.

The NRC staff determined that there was not an immediate safety concern for components inside the DG building at CNS. However, the NRC staff still intends to look at this on a generic basis. The NRC staff felt that the alternate calculation performed was reasonable and practical, but the staff had not reviewed the venting details. Region IV should close the unresolved item in the next resident integrated inspection report.

Members of the public were not in attendance. A list of meeting attendees is enclosed. A copy of the licensee's slides presented at the meeting has been placed in the NRC Agencywide Documents Access and Management System Accession Number ML061290460.

Please direct any inquiries to me at 301-415-3764, or bjb@nrc.gov.

/RA/

Brian Benney, Project Manager
Plant Licensing Branch IV
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-298

Enclosure: List of Attendees

cc w/encl: See next page

DISTRIBUTION:

PUBLIC	RidsOgcRp	JClark, RIV
LPLIV Reading	RidsRgn4MailCenter	SSamaddar, NRR/ADES
RidsNrrDorLpl4	RJasinski, NRR	GImbro, NRR/ADES
RidsNrrPMBBenney	RidsNrrDeEmb	MHartzman, NRR/ADES
RidsNrrLALFeizollahi	HWalker, NRR/ADES	SO'Connor, RIV EDO
RidsAcrsAcnwMailCenter		

Package: **ML06130077**

Meeting Notice: **ML061000041**

Mtg Summary No: **ML061300112**

Handout No.: **ML061290460**

Mtg Reschedule No: **ML061080032**

Mtg Postponement Reason: **ML061080105**

OFFICE	LPL4/PM	LPL4/LA	PD4/BC
NAME	BBenney;mxr4	LFeizollahi	DTerao
DATE	5/11/06	5/11/06	5/12/06

OFFICIAL RECORD COPY

Cooper Nuclear Station
Tornado Concerns

May 5, 2006

Attendees

<u>NAME</u>	<u>ORGANIZATION</u>
G. Kline	NPPD
J. Lechner	NPPD
A. Mitchell	NPPD
T. Stevens	NPPD
J. Roberts	NPPD
R. Yantz	NPPD
D. Terao	NRC
B. Benney	NRC
J. Clark	NRC
S. Samaddar	NRC
M. Hartzman	NRC
K. Manoly	NRC
H. Walker	NRC
G. Imbro	NRC
A. Marion	NEI
J. McCan	Entergy

NEI - Nuclear Energy Institute
NPPD - Nebraska Public Power District
NRC - Nuclear Regulatory Commission

Enclosure

Cooper Nuclear Station

cc:

Mr. William J. Fehrman
President and Chief Executive Officer
Nebraska Public Power District
1414 15th Street
Columbus, NE 68601

Mr. Gene Mace
Nuclear Asset Manager
Nebraska Public Power District
P.O. Box 98
Brownville, NE 68321

Mr. John C. McClure
Vice President and General Counsel
Nebraska Public Power District
P. O. Box 499
Columbus, NE 68602-0499

Mr. Paul V. Fleming
Licensing Manager
Nebraska Public Power District
P.O. Box 98
Brownville, NE 68321

Mr. Michael J. Linder, Director
Nebraska Department of Environmental
Quality
P. O. Box 98922
Lincoln, NE 68509-8922

Chairman
Nemaha County Board of Commissioners
Nemaha County Courthouse
1824 N Street
Auburn, NE 68305

Ms. Julia Schmitt, Manager
Radiation Control Program
Nebraska Health & Human Services R & L
Public Health Assurance
301 Centennial Mall, South
P.O. Box 95007
Lincoln, NE 68509-5007

Mr. H. Floyd Gilzow
Deputy Director for Policy
Missouri Department of Natural Resources
P. O. Box 176
Jefferson City, MO 65102-0176

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P. O. Box 218
Brownville, NE 68321

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011

Director, Missouri State Emergency
Management Agency
P. O. Box 116
Jefferson City, MO 65102-0116

Chief, Radiation and Asbestos
Control Section
Kansas Department of Health
and Environment
Bureau of Air and Radiation
1000 SW Jackson
Suite 310
Topeka, KS 66612-1366

Mr. Daniel K. McGhee
Bureau of Radiological Health
Iowa Department of Public Health
Lucas State Office Building, 5th Floor
321 East 12th Street
Des Moines, IA 50319

Mr. Keith G. Henke, Planner
Division of Community and Public Health
Office of Emergency Coordination
930 Wildwood P.O. Box 570
Jefferson City, MO 65102

Jerry C. Roberts, Director of Nuclear
Safety Assurance
Nebraska Public Power District
P.O. Box 98
Brownville, NE 68321

Mr. John F. McCann, Director
Licensing, Entergy Nuclear Northeast
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601-1813

Mr. Randall K. Edington
Vice President-Nuclear and CNO
Nebraska Public Power District
P. O. Box 98
Brownville, NE 68321