

From: "LARRY TEAHON" <daxmynus@msn.com>
To: <sjc7@nrc.gov>
Date: 5/5/06 7:06PM
Subject: Commercial Evaporation Pond #4
Crow Butte - 40-8943

Steve:

During routine weekly monitoring of Commercial Evaporation Pond #4, there was a substantial increase in the water levels in the NE, NM, SE, and SM underdrains. Water samples were collected from these underdrains and submitted to the Lab for analysis. The conductivity readings of these samples would indicate a leak in the upper liner of this pond. CBR has begun transferring water from Pond #4 to Pond #3. Once the level has been lowered, the liner will be examined for damage and all necessary repairs will be made. As per License Condition water samples will be collected from the underdrains every 7 days and analyzed for conductance, chloride, alkalinity, sodium and sulfate. Water levels in the underdrains will be monitored daily. If you have any questions please feel free to contact me at 308-665-2215 ext 114 or e-mail me at daxmynus@msn.com.

Thank you
Larry Teahon

Mail Envelope Properties (445BDA85.568 : 22 : 1384)

Subject: Commercial Evaporation Pond #4
Creation Date: 5/5/06 7:06PM
From: "LARRY TEAHON" <daxmynus@msn.com>

Created By: daxmynus@msn.com

Recipients

nrc.gov

OWGWPO01.HQGWDO01

SJC7 (Stephen Cohen)

Post Office

OWGWPO01.HQGWDO01

Route

nrc.gov

Files

MESSAGE

Mime.822

Size

903

2058

Date & Time

05/05/06 07:06PM

Options

Expiration Date:

None

Priority:

Standard

Reply Requested:

No

Return Notification:

None

Concealed Subject:

No

Security:

Standard