

From: "Robert P. Snyder" <rps02@health.state.ny.us>
To: <tbrice@gw.dec.state.ny.us>
Date: 2/16/06 10:27AM
Subject: Fw: IPEC Sample Results Summary - corrected

Tim, here's the corrected spreadsheet, Should have been an ND in Gamma Spec Column for the 10/21 MW-111, not NA.
(See attached file: IPEC H3 Invest Sample Summary.xls)
Thanks,
Robert

A/67

Sampling Date	Sample ID	Sample Location	Tritium pCi/l	Sr-90 pCi/l	Gamma Spec
10/21/05	200520855628	U2 CST	<110	NA	NA
10/21/05	200520855629	U3-T2	1420 +/- 160	NA	NA
10/21/05	200520855630	U3-2	510 +/- 130	NA	NA
10/21/05	200520855631	MW-111	267000 +/- 8000	3 +/- 2	ND
10/21/05	200520855632	U3-4	340 +/- 120	NA	NA
10/21/05	200520855633	U3-1	<110	NA	NA
10/21/05	200520855634	U3-3	<110	NA	NA
10/21/05	200520855535	U3-T1	<110	NA	NA
11/30/05	200520855645	Trap Rock Quarry	90 +/- 60	<0.4	ND
11/30/05	200520855646	Algonquin Creek	<60	0.7 +/- 0.4	RDP
11/30/05	200520855647	5th Street Well	<60	0.8 +/- 0.7	RDP
11/30/05	200520855648	Gypsum Plant Outfall	<60	0.8 +/- 0.4	RDP
12/06/05	200520855658	LaFarge Gypsum Well #1	<50	NA	NA
12/06/05	200520855659	LaFarge Gypsum Well #3	<50	NA	NA
12/08/05	200520855654	MW38	700 +/- 120	NA	NA
12/08/05	200520855655	MW101	<50	NA	NA
12/08/05	200520855656	MW105	100 +/- 90	NA	NA
12/08/05	200520855657	MW107	<50	NA	NA

NA - Not Applicable (This analysis was not performed)

ND - Non Detect (No readings at or above detection limits)

RDP - Dissolved Radon Decay Products