

**AGENDA FOR PUBLIC MEETING
WITH ENTERGY OPERATIONS, INCORPORATED
REGARDING SPENT FUEL POOL RACK CONFIGURATION
CHANGES AT ARKANSAS NUCLEAR ONE, UNIT 1 (ANO-1) AND
ARKANSAS NUCLEAR ONE, UNIT 2 (ANO-2)
ON WEDNESDAY 6-7-06**

- * Introduction
- * ANO-1 Metamic Poison Insert Assembly Project Overview
- * ANO-1 License Amendment Discussion

The ANO-1 License Amendment will include the following:

- 1) Changes to Tech Spec 3.7.15 which will define storage restrictions for Region 1 and 2
 - 2) Changes to Tech Spec 4.3.1.1
 - 3) Taking credit for boron to assure keff remains less than or equal to 0.95
 - 4) To accommodate future core reload plans fuel enrichment increased to 5.0wt.% from 4.1wt%. (Criticality analysis used 5.0 wt.%)
 - 5) The addition of a new Metamic* Coupon Sampling Program.
 - 6) Compliance with 10 CFR 50.68(b) to credit boron.
- * Discussion of ANO-1 issues by NRC and members of the public
 - * ANO-2 Re-rack Project Overview
 - * Discussion of ANO-2 issues by NRC and members of the public
 - * Adjourn