

Michael P. Gallagher, PE

Vice President
License Renewal Projects

Telephone 610.765.5958
www.exeloncorp.com
michaelp.gallagher@exeloncorp.com

An Exelon Company

AmerGen
200 Exelon Way
KSA/2-E
Kennett Square, PA 19348

10 CFR 50
10 CFR 51
10 CFR 54

2130-06-20332
May 15, 2006

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555

Oyster Creek Generating Station
Facility Operating License No. DPR-16
NRC Docket No. 50-219

Subject: Supplemental Information for Response to NRC Request for Additional Information, dated March 30, 2006, Related to Oyster Creek Generating Station License Renewal Application (TAC No. MC7624)

Reference: (1) "Request for Additional Information for the Review of the Oyster Creek Nuclear Generating Station, License Renewal Application (TAC No. MC7624)," dated March 30, 2006

(2) Response to NRC Request for Additional Information related to Sections 4.2 and 4.7 of the Oyster Creek Generating Station License Renewal Application (TAC No. MC7624), dated April 26, 2006

In the reference (1) letter, the NRC requested additional information related to Sections 4.2 and 4.7 of the Oyster Creek Generating Station License Renewal Application (LRA). Reference (2) provided the information requested by the NRC staff, however, as noted in the response to RAI 4.2.2-1, AmerGen planned to supplement the response with the results of the calculations of the Upper Shelf Energy equivalent margin analysis for non-limiting reactor vessel beltline materials. The results of these additional calculations are provided in the enclosure.

If you have any questions, please contact Fred Polaski, Manager License Renewal, at 610-765-5935.

I declare under penalty of perjury that the foregoing is true and correct.

Respectfully,

Executed on 05-15-06


Michael P. Gallagher
Vice President, License Renewal
AmerGen Energy Company, LLC

A117

U.S. Nuclear Regulatory Commission

May 15, 2006

Page 2 of 2

Enclosure: Upper Shelf Energy Equivalent Margin Analysis Results For Non-limiting Reactor Vessel Beltline Materials.

cc: Regional Administrator, USNRC Region I, w/o Enclosure
USNRC Project Manager, NRR - License Renewal, Safety, w/Enclosure
USNRC Project Manager, NRR - License Renewal, Environmental, w/o Enclosure
USNRC Project Manager, NRR - OCGS, w/o Enclosure
USNRC Senior Resident Inspector, OCGS, w/o Enclosure
Bureau of Nuclear Engineering, NJDEP, w/Enclosure
File No. 05040

Enclosure

Upper Shelf Energy Equivalent Margin Analysis Results

For

Non-limiting Reactor Vessel Beltline Materials

OCGS RPV Plate Equivalent Margin Analysis

R/2 PLATE
(OCGS Plate Number 564-03A)
(OCGS Code Number G-8-7)

Surveillance Plate USE:

$$\begin{aligned} \%Cu &= \frac{0.17}{0.746 \times 10^{18} \text{ n/cm}^2} \\ \text{Capsule Fluence} &= \frac{0.17}{0.746 \times 10^{18} \text{ n/cm}^2} \end{aligned}$$

$$\begin{aligned} \text{Measured \% Decrease} &= \frac{0.6}{14} && \text{(Charpy Curves)} \\ \text{R.G. 1.99 Predicted \% Decrease} &= \frac{0.6}{14} && \text{(R.G. 1.99, Figure 2)} \end{aligned}$$

Lower Intermediate Beltline Plate USE:

$$\begin{aligned} \%Cu &= \frac{0.21}{6.97 \times 10^{18} \text{ n/cm}^2} \\ 50 \text{ EFPY Peak ID Fluence} &= \frac{0.21}{6.97 \times 10^{18} \text{ n/cm}^2} \\ 50 \text{ EFPY 1/4T Fluence} &= \frac{0.21}{4.39 \times 10^{18} \text{ n/cm}^2} \end{aligned}$$

$$\text{R.G. 1.99 Predicted \% Decrease} = \frac{24.8}{29.5} \quad \text{(R.G. 1.99, Figure 2)}$$

$$\text{Adjusted \% Decrease} = \frac{\text{N/A}}{29.5} \quad \text{(R.G. 1.99, Position 2.2)}$$

24.8% ≤ 29.5%, so plate is bounded by equivalent margin analysis.

OCGS RPV Plate Equivalent Margin Analysis

BWR/2 PLATE
(OCGS Plate Number 564-03B)
(OCGS Code Number G-8-8)

Surveillance Plate USE:

$$\begin{aligned} \%Cu &= \frac{0.17}{0.746 \times 10^{18} \text{ n/cm}^2} \\ \text{Capsule Fluence} &= \frac{0.17}{0.746 \times 10^{18} \text{ n/cm}^2} \end{aligned}$$

$$\begin{aligned} \text{Measured \% Decrease} &= \frac{0.6}{14} && \text{(Charpy Curves)} \\ \text{R.G. 1.99 Predicted \% Decrease} &= \frac{0.6}{14} && \text{(R.G. 1.99, Figure 2)} \end{aligned}$$

Lower Intermediate Beltline Plate USE:

$$\begin{aligned} \%Cu &= \frac{0.18}{6.97 \times 10^{18} \text{ n/cm}^2} \\ 50 \text{ EFPY Peak ID Fluence} &= \frac{0.18}{6.97 \times 10^{18} \text{ n/cm}^2} \\ 50 \text{ EFPY 1/4T Fluence} &= \frac{0.18}{4.39 \times 10^{18} \text{ n/cm}^2} \end{aligned}$$

$$\text{R.G. 1.99 Predicted \% Decrease} = \frac{22.3}{29.5} \quad \text{(R.G. 1.99, Figure 2)}$$

$$\text{Adjusted \% Decrease} = \frac{\text{N/A}}{29.5} \quad \text{(R.G. 1.99, Position 2.2)}$$

22.3% ≤ 29.5%, so plate is bounded by equivalent margin analysis.

OCGS RPV Plate Equivalent Margin Analysis

BWR/2 PLATE
(OCGS Plate Number 564-03C)
(OCGS Code Number G-8-6)

Surveillance Plate USE:

$$\begin{aligned} \%Cu &= \frac{0.17}{0.746 \times 10^{18} \text{ n/cm}^2} \\ \text{Capsule Fluence} &= \frac{0.17}{0.746 \times 10^{18} \text{ n/cm}^2} \\ \text{Measured \% Decrease} &= \frac{0.6}{14} \quad (\text{Charpy Curves}) \\ \text{R.G. 1.99 Predicted \% Decrease} &= \frac{0.6}{14} \quad (\text{R.G. 1.99, Figure 2}) \end{aligned}$$

Lower Intermediate Beltline Plate USE:

$$\begin{aligned} \%Cu &= \frac{0.20}{6.97 \times 10^{18} \text{ n/cm}^2} \\ 50 \text{ EFPY Peak ID Fluence} &= \frac{0.20}{6.97 \times 10^{18} \text{ n/cm}^2} \\ 50 \text{ EFPY 1/4T Fluence} &= \frac{0.20}{4.39 \times 10^{18} \text{ n/cm}^2} \\ \text{R.G. 1.99 Predicted \% Decrease} &= \frac{24.0}{29.5} \quad (\text{R.G. 1.99, Figure 2}) \\ \text{Adjusted \% Decrease} &= \frac{24.0}{29.5} \quad (\text{R.G. 1.99, Position 2.2}) \end{aligned}$$

24.0% ≤ 29.5%, so plate is bounded by equivalent margin analysis.

OCGS RPV Plate Equivalent Margin Analysis

BWR/2 PLATE
(OCGS Plate Number 564-03D)
(OCGS Code Number G-307-1)

Surveillance Plate USE:

$$\begin{aligned} \%Cu &= \frac{0.17}{0.746 \times 10^{18} \text{ n/cm}^2} \\ \text{Capsule Fluence} &= \frac{0.17}{0.746 \times 10^{18} \text{ n/cm}^2} \\ \text{Measured \% Decrease} &= \frac{0.6}{14} \quad (\text{Charpy Curves}) \\ \text{R.G. 1.99 Predicted \% Decrease} &= \frac{0.6}{14} \quad (\text{R.G. 1.99, Figure 2}) \end{aligned}$$

Lower Beltline Plate USE:

$$\begin{aligned} \%Cu &= \frac{0.17}{3.76 \times 10^{18} \text{ n/cm}^2} \\ 50 \text{ EFPY Peak ID Fluence} &= \frac{0.17}{3.76 \times 10^{18} \text{ n/cm}^2} \\ 50 \text{ EFPY 1/4T Fluence} &= \frac{0.17}{2.37 \times 10^{18} \text{ n/cm}^2} \\ \text{R.G. 1.99 Predicted \% Decrease} &= \frac{18.6}{100} \quad (\text{R.G. 1.99, Figure 2}) \\ \text{Adjusted \% Decrease} &= \frac{\text{N/A}}{100} \quad (\text{R.G. 1.99, Position 2.2}) \end{aligned}$$

18.6% ≤ 29.5%, so plate is bounded by equivalent margin analysis.

OCGS RPV Plate Equivalent Margin Analysis

BWR/2 PLATE
(OCGS Plate Number 564-03E)
(OCGS Code Number G-308-1)

Surveillance Plate USE:

$$\begin{aligned} \%Cu &= \frac{0.17}{0.746 \times 10^{18} \text{ n/cm}^2} \\ \text{Capsule Fluence} &= \frac{0.17}{0.746 \times 10^{18} \text{ n/cm}^2} \\ \text{Measured \% Decrease} &= \frac{0.6}{14} \quad (\text{Charpy Curves}) \\ \text{R.G. 1.99 Predicted \% Decrease} &= \frac{0.6}{14} \quad (\text{R.G. 1.99, Figure 2}) \end{aligned}$$

Lower Beltline Plate USE:

$$\begin{aligned} \%Cu &= \frac{0.17}{3.76 \times 10^{18} \text{ n/cm}^2} \\ 50 \text{ EFPY Peak ID Fluence} &= \frac{0.17}{3.76 \times 10^{18} \text{ n/cm}^2} \\ 50 \text{ EFPY 1/4T Fluence} &= \frac{0.17}{2.37 \times 10^{18} \text{ n/cm}^2} \\ \text{R.G. 1.99 Predicted \% Decrease} &= \frac{18.6}{100} \quad (\text{R.G. 1.99, Figure 2}) \\ \text{Adjusted \% Decrease} &= \frac{\text{N/A}}{100} \quad (\text{R.G. 1.99, Position 2.2}) \end{aligned}$$

18.6% ≤ 29.5%, so plate is bounded by equivalent margin analysis.

OCGS RPV Plate Equivalent Margin Analysis

BWR/2 PLATE
(OCGS Plate Number 564-03F)
(OCGS Code Number G-307-5)

Surveillance Plate USE:

$$\begin{aligned} \%Cu &= \frac{0.17}{0.746 \times 10^{18} \text{ n/cm}^2} \\ \text{Capsule Fluence} &= \frac{0.17}{0.746 \times 10^{18} \text{ n/cm}^2} \\ \text{Measured \% Decrease} &= \frac{0.6}{14} \quad (\text{Charpy Curves}) \\ \text{R.G. 1.99 Predicted \% Decrease} &= \frac{0.6}{14} \quad (\text{R.G. 1.99, Figure 2}) \end{aligned}$$

Lower Beltline Plate USE:

$$\begin{aligned} \%Cu &= \frac{0.27}{3.76 \times 10^{18} \text{ n/cm}^2} \\ 50 \text{ EFPY Peak ID Fluence} &= \frac{0.27}{3.76 \times 10^{18} \text{ n/cm}^2} \\ 50 \text{ EFPY 1/4T Fluence} &= \frac{0.27}{2.37 \times 10^{18} \text{ n/cm}^2} \\ \text{R.G. 1.99 Predicted \% Decrease} &= \frac{26.0}{26.0} \quad (\text{R.G. 1.99, Figure 2}) \\ \text{Adjusted \% Decrease} &= \frac{\text{N/A}}{\text{N/A}} \quad (\text{R.G. 1.99, Position 2.2}) \end{aligned}$$

26.0% ≤ 29.5%, so plate is bounded by equivalent margin analysis.

OCGS RPV Weld Equivalent Margin Analysis

BWR/2 WELD, (OCGS Weld Numbers 2-564A, 2-564B, and 2-564C)
(OCGS Heat Number 86054B)

Surveillance Weld USE:

$$\begin{aligned} \%Cu &= \frac{0.28}{0.746 \times 10^{18} \text{ n/cm}^2} \\ \text{Capsule Fluence} &= \frac{0.746 \times 10^{18} \text{ n/cm}^2}{0.746 \times 10^{18} \text{ n/cm}^2} \end{aligned}$$

$$\begin{aligned} \text{Measured \% Decrease} &= \frac{\text{Not reported}}{\text{Not reported}} && \text{(Charpy Curves)} \\ \text{R.G. 1.99 Predicted \% Decrease} &= \frac{\text{Not reported}}{\text{Not reported}} && \text{(R.G. 1.99, Figure 2)} \end{aligned}$$

Beltline Lower Intermediate Shell Axial Weld USE:

$$\begin{aligned} \%Cu &= \frac{0.206}{6.16 \times 10^{18} \text{ n/cm}^2} \\ 50 \text{ EFPY Peak ID Fluence} &= \frac{6.16 \times 10^{18} \text{ n/cm}^2}{6.16 \times 10^{18} \text{ n/cm}^2} \\ 50 \text{ EFPY 1/4T Fluence} &= \frac{3.88 \times 10^{18} \text{ n/cm}^2}{3.88 \times 10^{18} \text{ n/cm}^2} \end{aligned}$$

$$\text{R.G. 1.99 Predicted \% Decrease} = \frac{28.6}{28.6} \quad \text{(R.G. 1.99, Figure 2)}$$

$$\text{Adjusted \% Decrease} = \frac{\text{N/A}}{\text{N/A}} \quad \text{(R.G. 1.99, Position 2.2)}$$

28.6% ≤ 39%, so weld is bounded by equivalent margin analysis.

OCGS Vessel RPV Welds Equivalent Margin Analysis

BWR/2 WELD, (OCGS Weld Numbers 2-564D, 2-564E, and 2-564F) (OCGS Heat Number 86054B)

Surveillance Weld USE:

$$\begin{aligned} \%Cu &= \frac{0.28}{0.746 \times 10^{18} \text{ n/cm}^2} \\ \text{Capsule Fluence} &= \end{aligned}$$

$$\begin{aligned} \text{Measured \% Decrease} &= \frac{\text{Not reported}}{\text{Not reported}} && \text{(Charpy Curves)} \\ \text{R.G. 1.99 Predicted \% Decrease} &= \frac{\text{Not reported}}{\text{Not reported}} && \text{(R.G. 1.99, Figure 2)} \end{aligned}$$

Beltline Lower Shell Axial Weld USE:

$$\begin{aligned} \%Cu &= \frac{0.214}{3.71 \times 10^{18} \text{ n/cm}^2} \\ 50 \text{ EFPY Peak ID Fluence} &= \frac{3.71 \times 10^{18} \text{ n/cm}^2}{2.34 \times 10^{18} \text{ n/cm}^2} \\ 50 \text{ EFPY 1/4T Fluence} &= \end{aligned}$$

$$\text{R.G. 1.99 Predicted \% Decrease} = \frac{25.5}{25.5} \quad \text{(R.G. 1.99, Figure 2)}$$

$$\text{Adjusted \% Decrease} = \frac{\text{N/A}}{\text{N/A}} \quad \text{(R.G. 1.99, Position 2.2)}$$

25.5% ≤ 39%, so weld is bounded by equivalent margin analysis.

OCGS Vessel RPV Weld Equivalent Margin Analyses

BWR/2 WELD, (OCGS Weld Number 3-564) (OCGS Heat Number 1248)

Surveillance Weld USE:

$$\begin{aligned} \%Cu &= \frac{0.28}{} \\ \text{Capsule Fluence} &= \frac{0.746 \times 10^{18} \text{ n/cm}^2}{\phantom{0.746 \times 10^{18} \text{ n/cm}^2}} \end{aligned}$$

$$\begin{aligned} \text{Measured \% Decrease} &= \frac{\text{Not reported}}{\phantom{\text{Not reported}}} \quad (\text{Charpy Curves}) \\ \text{R.G. 1.99 Predicted \% Decrease} &= \frac{\text{Not reported}}{\phantom{\text{Not reported}}} \quad (\text{R.G. 1.99, Figure 2}) \end{aligned}$$

Beltline Lower Shell to Lower Intermediate Shell Circumferential Weld USE:

$$\begin{aligned} \%Cu &= \frac{0.214}{} \\ 50 \text{ EFPY Peak ID Fluence} &= \frac{3.76 \times 10^{18} \text{ n/cm}^2}{\phantom{3.76 \times 10^{18} \text{ n/cm}^2}} \\ 50 \text{ EFPY 1/4T Fluence} &= \frac{2.37 \times 10^{18} \text{ n/cm}^2}{\phantom{2.37 \times 10^{18} \text{ n/cm}^2}} \end{aligned}$$

$$\text{R.G. 1.99 Predicted \% Decrease} = \frac{25.0}{} \quad (\text{R.G. 1.99, Figure 2})$$

$$\text{Adjusted \% Decrease} = \frac{\text{N/A}}{\phantom{\text{N/A}}} \quad (\text{R.G. 1.99, Position 2.2})$$

25.0% ≤ 39%, so weld is bounded by equivalent margin analysis.

Oyster Creek Document Distribution Sheet

TITLE/SUBJECT: Supplemental Information for Responses to NRC RAI 4.2.2-1 Related to OCGS License Renewal Application (TAC No. MC7624)

COGNIZANT INDIVIDUAL: Fred Polaski

SPECIAL HANDLING INSTRUCTIONS: * - already distributed, CC'd
 E - Electronically Distributed
 X - Hard Copy

FILE STRUCTURE:

OC VP & Direct Reports

OC VP: T. Rausch	OCAB-2	E
SVP EA: V. Aggarwal	OCAB-2	E
Plant Manager: J. Randich	MOB	E
Engineering: M. Button	OCAB-3	E
Maintenance: J. Magee	NMB	E
Training: J. Vaccaro	Bldg 12	E
Reg Assurance: J. Kandasamy	OCAB-2	E
HR: H. Behrens	OCAB-2	
Outage: W. Carter	OCAB-2	
Rad Pro/Chem:	AOB	
Work Management: C. Wilson	OCAB-2	

AmerGen/Exelon

VP L&RA: T. O'Neill	Cantera	E
Env. Dir Acting: S. Sklenar	KS	
Environmental: S. Sklenar	KS	
Licensing: P. Cowan	KSA3-E	X
Licensing: D. Helker	KSA 3-E	X
Licensing: V. Gallimore	KSA 3-E	
KS Document Ctr.	KSA 1-N	X
KS Emerg. Prep: J. Karkoska	KS	

External Distribution

NJBNE - P. Baldauf		X
NSRB		

Oyster Creek

Operations: R. Racholski	MOB	
Operations: J. Dostal	MOB	
Operations/Rx Engg.: F. Buckley	OCAB-3	
Work Control: P. Bloss	MOB	
Radiation Protection: J. Renda	AOB	
Env/Chemistry: C. Connelly	AOB	
Security: K. Dreher	OCAB-2	
Engineering: J. O'Rourke	OCAB-3	E
I&C/NSSS: J. Frank	OCAB-3	
BOP Engineering: J. Camire	OCAB-3	
Eng. Programs: R. Skelskey	OCAB-3	
Mech/Str Design: H. Ray	OCAB-3	E
E/I&C Des: D. Barnes	OCAB-3	
Maintenance: R. Laning	NMB	
Communications: R. Benson	OCAB-2	E
NOS: D. Peiffer	OCAB-2	
Emerg Prep : K. Poletti	OCAB-2	
Lic. Renewal: T. E. Quintenz		E
Chem/Env Dept Files	AOB	

Reg Assurance Dept Files

05040 E

Other

K. Barnes	OCAB-2	E
C. Duffy	OCAB-2	E
Guy DeBoo	Cantera	E
J. Hoddy	KSA2-E	E
M. Guthrie	KSA2-E	E

STANDARD RECORDS RETENTION SCHEDULE #	FILE CODE / (REFERENCE #)	RECORD NUMBER	RECORD NAME	RECORD DATE
		2130-06-20332	Supplemental Information for Responses to NRC RAI 4.2.2-1. Non-limiting Reactor Vessel Beltline Materials	5/15/06