

May 18, 2006

Mr. R. T. Ridenoure
Vice President - Chief Nuclear Officer
Omaha Public Power District
Fort Calhoun Station FC-2-4 Adm.
Post Office Box 550
Fort Calhoun, NE 68023-0550

SUBJECT: FORT CALHOUN STATION, UNIT NO. 1 - CORRECTION TO THE LETTER
REGARDING RELIEF REQUEST FOR THE USE OF RADIOGRAPHY USING
PHOSPHOR IMAGING PLATE

Dear Mr. Ridenoure:

By letter dated May 10, 2006, the Nuclear Regulatory Commission (NRC) issued a letter in response to Omaha Public Power District's (OPPD's) letter, dated October 28, 2005, submitting a relief request for its fourth 10-year inservice inspection program interval at the Fort Calhoun Station, Unit 1. The last sentence of the second paragraph of the May 10, 2006, letter erroneously omitted the word "neither."

This sentence should read as follows:

Therefore, for the purposes described in your October 28, 2005, letter, the NRC staff concludes that neither a request for relief from ASME Code requirements nor authorization of an alternative to NRC requirements in 10 CFR 50.55a is needed for OPPD to use phosphor imaging plates in lieu of film.

This letter should be a supplement to our initial letter dated May 10, 2006. This change helps to clarify the NRC's concluding statement.

We regret any inconvenience this error has caused you.

Sincerely,

/RA/

Alan B. Wang, Project Manager
Plant Licensing Branch IV
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

cc: See next page

May 18, 2006

Mr. R. T. Ridenoure
Vice President - Chief Nuclear Officer
Omaha Public Power District
Fort Calhoun Station FC-2-4 Adm.
Post Office Box 550
Fort Calhoun, NE 68023-0550

SUBJECT: FORT CALHOUN STATION, UNIT NO. 1 - CORRECTION TO THE LETTER
REGARDING RELIEF REQUEST FOR THE USE OF RADIOGRAPHY USING
PHOSPHOR IMAGING PLATE

Dear Mr. Ridenoure:

By letter dated May 10, 2006, the Nuclear Regulatory Commission (NRC) issued a letter in response to Omaha Public Power District's (OPPD's) letter, dated October 28, 2005, submitting a relief request for its fourth 10-year inservice inspection program interval at the Fort Calhoun Station, Unit 1. The last sentence of the second paragraph of the May 10, 2006, letter erroneously omitted the word "neither."

This sentence should read as follows:

Therefore, for the purposes described in your October 28, 2005, letter, the NRC staff concludes that neither a request for relief from ASME Code requirements nor authorization of an alternative to NRC requirements in 10 CFR 50.55a is needed for OPPD to use phosphor imaging plates in lieu of film.

This letter should be a supplement to our initial letter dated May 10, 2006. This change helps to clarify the NRC's concluding statement.

We regret any inconvenience this error has caused you.

Sincerely,

/RA/

Alan B. Wang, Project Manager
Plant Licensing Branch IV
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

cc: See next page

DISTRIBUTION:

PUBLIC

LPLIV Reading

RidsNrrDorl (CHaney/CHolden)

RidsNrrDorlLp4 (DTerao)

RidsNrrPMAWang

RidsNrrLALFeizollahi

RidsNrrDorlDpr

RidsOgcRp

RidsNrrDirsltsb

RidsAcrsAcnwMailCenter

RidsRegion4MailCenter (DGraves)

RidsNrrDciCpnb (TChan)

WKoo, NRR/ADES

ACCESSION NO.: ML061390097

OFFICE	NRR/LPL4/PM	NRR/LPL4/LA	NRR/LPL4/BC
NAME	AWang;mxr4	LFeizollahi	DTerao
DATE	5/17/06	5/17/06	5/18/06

OFFICIAL RECORD COPY

Ft. Calhoun Station, Unit 1

cc:

Winston & Strawn
ATTN: James R. Curtiss, Esq.
1700 K Street, N.W.
Washington, DC 20006-3817

Chairman
Washington County Board of Supervisors
P.O. Box 466
Blair, NE 68008

Mr. John Hanna, Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 310
Fort Calhoun, NE 68023

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011-4005

Ms. Julia Schmitt, Manager
Radiation Control Program
Nebraska Health & Human Services R & L
Public Health Assurance
301 Centennial Mall, South
P.O. Box 95007
Lincoln, NE 68509-5007

Mr. David J. Bannister, Manager
Fort Calhoun Station
Omaha Public Power District
Fort Calhoun Station FC-1-1 Plant
P.O. Box 550
Fort Calhoun, NE 68023-0550

Mr. Joe L. McManis
Manager - Nuclear Licensing
Omaha Public Power District
Fort Calhoun Station FC-2-4 Adm.
P.O. Box 550
Fort Calhoun, NE 68023-0550

Mr. Daniel K. McGhee
Bureau of Radiological Health
Iowa Department of Public Health
Lucas State Office Building, 5th Floor
321 East 12th Street
Des Moines, IA 50319

April 2006