

May 18, 2006

Mr. R. T. Ridenoure  
Vice President - Chief Nuclear Officer  
Omaha Public Power District  
Fort Calhoun Station FC-2-4 Adm.  
Post Office Box 550  
Fort Calhoun, NE 68023-0550

SUBJECT: FORT CALHOUN STATION, UNIT NO. 1 - CORRECTION TO THE LETTER  
REGARDING RELIEF REQUEST FOR THE USE OF RADIOGRAPHY USING  
PHOSPHOR IMAGING PLATE

Dear Mr. Ridenoure:

By letter dated May 10, 2006, the Nuclear Regulatory Commission (NRC) issued a letter in response to Omaha Public Power District's (OPPD's) letter, dated October 28, 2005, submitting a relief request for its fourth 10-year inservice inspection program interval at the Fort Calhoun Station, Unit 1. The last sentence of the second paragraph of the May 10, 2006, letter erroneously omitted the word "neither."

This sentence should read as follows:

Therefore, for the purposes described in your October 28, 2005, letter, the NRC staff concludes that neither a request for relief from ASME Code requirements nor authorization of an alternative to NRC requirements in 10 CFR 50.55a is needed for OPPD to use phosphor imaging plates in lieu of film.

This letter should be a supplement to our initial letter dated May 10, 2006. This change helps to clarify the NRC's concluding statement.

We regret any inconvenience this error has caused you.

Sincerely,

**/RA/**

Alan B. Wang, Project Manager  
Plant Licensing Branch IV  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

cc: See next page

May 18, 2006

Mr. R. T. Ridenoure  
Vice President - Chief Nuclear Officer  
Omaha Public Power District  
Fort Calhoun Station FC-2-4 Adm.  
Post Office Box 550  
Fort Calhoun, NE 68023-0550

SUBJECT: FORT CALHOUN STATION, UNIT NO. 1 - CORRECTION TO THE LETTER  
REGARDING RELIEF REQUEST FOR THE USE OF RADIOGRAPHY USING  
PHOSPHOR IMAGING PLATE

Dear Mr. Ridenoure:

By letter dated May 10, 2006, the Nuclear Regulatory Commission (NRC) issued a letter in response to Omaha Public Power District's (OPPD's) letter, dated October 28, 2005, submitting a relief request for its fourth 10-year inservice inspection program interval at the Fort Calhoun Station, Unit 1. The last sentence of the second paragraph of the May 10, 2006, letter erroneously omitted the word "neither."

This sentence should read as follows:

Therefore, for the purposes described in your October 28, 2005, letter, the NRC staff concludes that neither a request for relief from ASME Code requirements nor authorization of an alternative to NRC requirements in 10 CFR 50.55a is needed for OPPD to use phosphor imaging plates in lieu of film.

This letter should be a supplement to our initial letter dated May 10, 2006. This change helps to clarify the NRC's concluding statement.

We regret any inconvenience this error has caused you.

Sincerely,

**/RA/**

Alan B. Wang, Project Manager  
Plant Licensing Branch IV  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

cc: See next page

DISTRIBUTION:

PUBLIC

LPLIV Reading

RidsNrrDorl (CHaney/CHolden)

RidsNrrDorlLp4 (DTerao)

RidsNrrPMAWang

RidsNrrLALFeizollahi

RidsNrrDorlDpr

RidsOgcRp

RidsNrrDirsltsb

RidsAcrsAcnwMailCenter

RidsRegion4MailCenter (DGraves)

RidsNrrDciCpnb (TChan)

WKoo, NRR/ADES

**ACCESSION NO.: ML061390097**

OFFICE	NRR/LPL4/PM	NRR/LPL4/LA	NRR/LPL4/BC
NAME	AWang;mxr4	LFeizollahi	DTerao
DATE	5/17/06	5/17/06	5/18/06

OFFICIAL RECORD COPY

Ft. Calhoun Station, Unit 1

cc:

Winston & Strawn  
ATTN: James R. Curtiss, Esq.  
1700 K Street, N.W.  
Washington, DC 20006-3817

Chairman  
Washington County Board of Supervisors  
P.O. Box 466  
Blair, NE 68008

Mr. John Hanna, Resident Inspector  
U.S. Nuclear Regulatory Commission  
P.O. Box 310  
Fort Calhoun, NE 68023

Regional Administrator, Region IV  
U.S. Nuclear Regulatory Commission  
611 Ryan Plaza Drive, Suite 400  
Arlington, TX 76011-4005

Ms. Julia Schmitt, Manager  
Radiation Control Program  
Nebraska Health & Human Services R & L  
Public Health Assurance  
301 Centennial Mall, South  
P.O. Box 95007  
Lincoln, NE 68509-5007

Mr. David J. Bannister, Manager  
Fort Calhoun Station  
Omaha Public Power District  
Fort Calhoun Station FC-1-1 Plant  
P.O. Box 550  
Fort Calhoun, NE 68023-0550

Mr. Joe L. McManis  
Manager - Nuclear Licensing  
Omaha Public Power District  
Fort Calhoun Station FC-2-4 Adm.  
P.O. Box 550  
Fort Calhoun, NE 68023-0550

Mr. Daniel K. McGhee  
Bureau of Radiological Health  
Iowa Department of Public Health  
Lucas State Office Building, 5th Floor  
321 East 12th Street  
Des Moines, IA 50319

April 2006