

Robert A. Saccone
Vice President - Nuclear Operations

PPL Susquehanna, LLC
769 Salem Boulevard
Berwick, PA 18603
Tel. 570.542.3959 Fax 570.542.1504
rasaccone@pphweb.com



MAY 18 2006

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Mail Stop OP1-17
Washington, DC 20555

**SUSQUEHANNA STEAM ELECTRIC STATION
WITHDRAWAL OF PROPOSED LICENSE AMENDMENT
NUMBERS 285 FOR UNIT 1 OPERATING LICENSE NO. NPF-14
AND 253 FOR UNIT 2 OPERATING LICENSE NO. NPF-22
CONSTANT PRESSURE POWER UPRATE
PLA-6066**

**Docket Nos. 50-387
and 50-388**

- References: 1. PPL Letter PLA-6002, Britt T. McKinney (PPL) to USNRC,
"Susquehanna Steam Electric Station Proposed License Amendment
Numbers 285 for Unit 1 Operating License No. NPF-14 and 253 for Unit 2
Operating License No. NPF-22, Constant Pressure Power Uprate,"
dated March 31, 2006.*
- 2. PPL Letter PLA-6049, Britt T. McKinney (PPL) to USNRC,
"Susquehanna Steam Electric Station Proposed Amendment No. 289 to
Operating License NPF-14 and Proposed Amendment No. 257 to
Operating License NPF-22, Standby Liquid Control System," dated
April 28, 2006.*

By letter PLA-6002 (Reference 1), PPL Susquehanna LLC (PPL) requested an amendment to Facility Operating Licenses NPF-14 and NPF-22 and the Technical Specifications for the Susquehanna Steam Electric Station to increase the maximum authorized power level to 3952 megawatts thermal (MWt).

As a result of discussions with the Division of Operating Reactor Licensing, PPL is withdrawing the Reference 1 License Amendment Request (LAR) to revise the Standby Liquid Control portion of the LAR, which has now been requested in a separate LAR (Reference 2), and to address the issues resulting from completion of the acceptance review, described in a telecon with NRC staff on May 16, 2006.

A001

PPL understands that, in response to this request for withdrawal, the NRC will document the results of the staff's acceptance review of the CPPU LAR, indicating areas for which additional detail is required for acceptance.

If you have any questions or require additional information, please contact Mr. John M. Oddo at (610) 774-7596.



R. A. Saccone

Copy: NRC Region I
Mr. A. Blamey, NRC Sr. Resident Inspector
Mr. R. V. Guzman, NRC Project Manager
Mr. R. Janati, DEP/BRP