

Mark,

AT POD, the licensee mentioned that T-6 is going up AND they don't understand why. They said they may have a new leak in the HPCI SECTION PIPING.

Conversion to pCi/ L from uCi/L is multiply uCi/L result from DCP 3220-01, Data Sheet 2 times 1E3.

**Tritium Data for Well Map 1**

Sample 1 of 7 DSP-131		Sample 2 of 7 DSP-132		Sample 3 of 7 DSP-140		Sample 4 of 7 K		Sample 5 of 7 DSP-116		Sample 6 of 7 T6		Sample 7 of 7 E3	
Date	Activity	Date	Activity	Date	Activity	Date	Activity	Date	Activity	Date	Activity	Date	Activity
02/14/06	1400	02/14/06	900	02/14/06	18400	02/14/06	1900	02/14/06	0	02/14/06	134300	02/14/06	550400
02/15/06	1300	02/15/06	2100	02/15/06	2900	02/15/06	800	02/15/06	600	02/15/06	128300	02/15/06	1069400
02/16/06	1200	02/16/06	1500	02/16/06	7300	02/17/06	2000	02/16/06	0	02/16/06	102300	02/17/06	653000
02/17/06	900	02/17/06	2700	02/17/06	2100	02/18/06	2400	02/17/06	1100	02/17/06	11200	02/19/06	30000
02/18/06	2100	02/18/06	1900	02/20/06	4200	02/19/06	2200	02/18/06	1600	02/18/06	24800	02/20/06	47600
02/20/06	1900	02/19/06	1200	02/21/06	3000	02/20/06	2100	02/19/06	1700	02/19/06	48300	02/21/06	19900
02/21/06	1400	02/20/06	1300	02/22/06	3200	02/21/06	1900	02/20/06	1300	02/20/06	57600	02/22/06	17100
02/22/06	1100	02/21/06	1000	02/23/06	3800	02/22/06	900	02/21/06	1100	02/21/06	50100	02/23/06	36500
02/23/06	1300	02/22/06	300	02/24/06	4100	02/23/06	1100	02/22/06	800	02/22/06	47100	02/24/06	32000
02/24/06	1200	02/23/06	1100	02/25/06	3300	02/25/06	1400	02/23/06	400	02/23/06	35000	02/25/06	21900
02/25/06	1300	02/24/06	1100	02/26/06	3800	02/26/06	1800	02/24/06	1100	02/24/06	26000	02/26/06	13000
02/26/06	1400	02/25/06	900	02/27/06	3600	02/27/06	3600	02/25/06	1500	02/25/06	19000	03/01/06	11800
02/27/06	2000	02/26/06	1600	02/28/06	2100	02/28/06	0	02/26/06	1100	02/26/06	17000	03/05/06	7800
02/28/06	0	02/27/06	1300	03/01/06	4800	03/01/06	2300	02/27/06	900	02/27/06	11800	03/06/06	13400
03/01/06	1400	02/28/06	0	03/02/06	21100	03/02/06	2000	02/28/06	0	02/28/06	6300	03/08/06	21000
03/02/06	1400	03/01/06	2500	03/03/06	5000	03/03/06	2200	03/01/06	1500	03/01/06	6500	03/09/06	4500
03/03/06	1900	03/02/06	1400	03/04/06	6800	03/04/06	1700	03/03/06	2400	03/03/06	5600	03/16/06	54700
03/04/06	1500	03/03/06	1800	03/05/06	3300	03/05/06	0	03/04/06	1200	03/03/06	6200	03/17/06	800
03/05/06	300	03/04/06	1500	03/06/06	7100	03/06/06	1300	03/05/06	500	03/04/06	9100	03/18/06	19800
03/06/06	1600	03/05/06	1000	03/07/06	2400	03/07/06	1600	03/07/06	1700	03/05/06	7800	03/19/06	
03/07/06	1200	03/06/06	8700	03/08/06	2300	03/08/06	600	03/08/06	600	03/06/06	6000	03/20/06	
03/08/06	2500	03/07/06	1100	03/09/06	3900	03/09/06	500	03/09/06	1000	03/07/06	6000	03/21/06	
03/09/06	1100	03/08/06	1700	03/10/06	1000	03/10/06	300	03/10/06	0	03/08/06	5800	03/22/06	
03/10/06	200	03/09/06	800	03/11/06	2200	03/11/06	600	03/11/06	700	03/09/06	5200	03/23/06	12600
03/11/06	800	03/10/06	0	03/12/06	3400	03/12/06	0	03/12/06	0	03/10/06	4800	03/24/06	
03/12/06	0	03/11/06	800	03/13/06	1200	03/13/06	400	03/13/06	100	03/11/06	4900	03/25/06	
03/13/06	400	03/12/06	0	03/14/06	2100	03/14/06	300	03/14/06	12400	03/12/06	2600	03/26/06	
03/14/06	900	03/13/06	0	03/15/06	2500	03/15/06	1800	03/15/06	1300	03/13/06	1200	03/27/06	
03/15/06	1700	03/14/06	2200	03/16/06	2700	03/16/06	1200	03/16/06	600	03/14/06	2200	03/28/06	
03/16/06	800	03/15/06	1300	03/17/06	4300	03/17/06	500	03/17/06	100	03/15/06	2100	03/29/06	
03/17/06	1500	03/16/06	1100	03/18/06	2800	03/18/06	400	03/18/06	300	03/17/06	3400	03/30/06	
03/18/06	600	03/17/06	400	03/19/06	4000	03/19/06	500	03/19/06	600	03/18/06	4200	03/31/06	
03/19/06	700	03/18/06	700	03/20/06	2700	03/20/06	800	03/20/06	500	03/19/06	5600	04/01/06	
03/20/06	800	03/19/06	1200	03/21/06	2900	03/21/06	1000	03/21/06	500	03/20/06	7600	04/02/06	
03/21/06	1400	03/20/06	7900	03/22/06	2500	03/22/06	800	03/22/06	700	03/21/06	8700	04/03/06	
03/22/06	700	03/21/06	2200	03/23/06	3400	03/23/06	1300	03/23/06	400	03/22/06	11400	04/04/06	
03/23/06	1100	03/22/06	500	03/24/06	3800	03/24/06	1500	03/24/06		03/23/06	19800	04/05/06	
03/24/06	1100	03/23/06	800	03/25/06	3500	03/25/06	600	03/25/06	400	03/24/06	61000	04/06/06	
03/25/06	900	03/24/06	1000	03/26/06	2100	03/26/06	200	03/26/06	500	03/25/06		04/07/06	
03/26/06	200	03/25/06	900	03/27/06		03/27/06		03/27/06		03/26/06	56800	04/08/06	
03/27/06		03/26/06	1200	03/28/06		03/28/06		03/28/06		03/27/06		04/09/06	
03/28/06		03/27/06		03/29/06		03/29/06		03/29/06		03/28/06		04/10/06	
03/29/06		03/28/06		03/30/06		03/30/06		03/30/06		03/29/06		04/11/06	
03/30/06		03/29/06		03/31/06		03/31/06		03/31/06		03/30/06		04/12/06	
03/31/06		03/30/06		04/01/06		04/01/06		04/01/06		03/31/06		04/13/06	
04/01/06		03/31/06		04/02/06		04/02/06		04/02/06		04/01/06		04/14/06	
04/02/06		04/01/06		04/03/06		04/03/06		04/03/06		04/02/06		04/15/06	
04/03/06		04/02/06		04/04/06		04/04/06		04/04/06		04/03/06		04/16/06	
04/04/06		04/03/06		04/05/06		04/05/06		04/05/06		04/04/06		04/17/06	
04/05/06		04/04/06		04/06/06		04/06/06		04/06/06		04/05/06		04/18/06	
04/06/06		04/05/06		04/07/06		04/07/06		04/07/06		04/06/06		04/19/06	
04/07/06		04/06/06		04/08/06		04/08/06		04/08/06		04/07/06		04/20/06	
04/08/06		04/07/06		04/09/06		04/09/06		04/09/06		04/08/06		04/21/06	
04/09/06		04/08/06		04/10/06		04/10/06		04/10/06		04/09/06		04/22/06	
04/10/06		04/09/06		04/11/06		04/11/06		04/11/06		04/10/06		04/23/06	
04/11/06		04/10/06		04/12/06		04/12/06		04/12/06		04/11/06		04/24/06	
04/12/06		04/11/06		04/13/06		04/13/06		04/13/06		04/12/06		04/25/06	
04/13/06		04/12/06		04/14/06		04/14/06		04/14/06		04/13/06		04/26/06	
04/14/06		04/13/06		04/15/06		04/15/06		04/15/06		04/14/06		04/27/06	
04/15/06		04/14/06						04/15/06		04/15/06		04/28/06	

**Tritium Data for Well Map 2**

Sample 8 of 13 T1		Sample 9 of 13 E5		Sample 10 of 13 E10		Sample 11 of 13 DSP-124		Sample 12 of 13 CST Tank		Sample 13 of 13 DSP-125	
Date	Activity	Date	Activity	Date	Activity	Date	Activity	Date	Activity	Date	Activity
				12/06/05	28000	11/29/05	37200	02/14/06	7380800	02/14/06	1500
		02/15/06	200	01/03/06	3000	02/16/06	9300	02/15/06	7359800	02/15/06	
02/16/06	48400	02/16/06	0	01/31/06	17000	02/17/06	12000	02/16/06		02/16/06	
02/17/06	65900	02/17/06	1900	02/11/06	20000	02/18/06	10300	02/17/06		02/17/06	
02/18/06	47400	02/24/06	600	02/12/06	5000	02/19/06	10300	02/18/06		02/18/06	
02/19/06	47700	02/25/06	700	02/13/06	6300	02/20/06	9800	02/19/06		02/19/06	
02/20/06	43000	02/26/06	2700	02/14/06	6200	02/21/06	9500	02/20/06		02/20/06	
02/21/06	40100	02/28/06	0	02/15/06	4700	02/22/06	11100	02/21/06		02/21/06	
02/22/06	43100	03/01/06	900	02/16/06		02/23/06	9700	02/22/06		02/22/06	
02/23/06	39100	03/02/06	1800	02/17/06		02/24/06	9600	02/23/06		02/23/06	
02/24/06	34700	03/03/06	1100	02/18/06		02/25/06	8700	02/24/06		02/24/06	
02/25/06	36200	03/04/06	1600	02/19/06		02/26/06	9200	02/25/06		02/25/06	
02/26/06	37100	03/05/06	0	02/20/06		02/27/06	8900	02/26/06		02/26/06	
02/27/06		03/07/06	800	02/21/06		02/28/06	6600	02/27/06		02/27/06	
02/28/06	40200	03/08/06	600	02/22/06		03/01/06	9200	02/28/06		02/28/06	
03/01/06	57700	03/09/06	800	02/23/06		03/02/06	9000	03/01/06		03/01/06	1800
03/02/06	68800	03/10/06	0	02/24/06		03/03/06	8600	03/02/06		03/02/06	11400
03/03/06	89200	03/11/06	0	02/25/06		03/04/06	9300	03/03/06		03/03/06	1800
03/04/06	91800	03/12/06	0	02/26/06		03/05/06	8300	03/04/06		03/04/06	1700
03/05/06	113500	03/13/06	0	02/27/06		03/06/06	8800	03/05/06		03/05/06	400
03/07/06	217700	03/14/06	300	02/28/06		03/07/06	7600	03/06/06		03/06/06	1900
03/08/06	226300	03/15/06	1000	03/01/06		03/08/06	7500	03/07/06		03/07/06	1700
03/09/06	195200	03/16/06	100	03/02/06		03/09/06	7400	03/08/06		03/08/06	1000
03/10/06	201700	03/1									