

May 26, 2006

Mr. J. A. Stall
Senior Vice President, Nuclear and
Chief Nuclear Officer
Florida Power and Light Company
P.O. Box 14000
Juno Beach, Florida 33408-0420

SUBJECT: TURKEY POINT PLANT, UNIT 3 - WITHDRAWAL OF EMERGENCY LICENSE
AMENDMENT REQUEST REGARDING INTAKE COOLING WATER PUMP
(TAC NO. MD1811)

Dear Mr. Stall:

By letter dated May 20, 2006, Florida Power & Light Company (FPL) applied for an emergency license amendment to the Turkey Point Unit 3 Facility Renewed Operating License No. DPR-31. The proposed change would have modified the facility technical specifications pertaining to the intake cooling water (ICW) pumps. Specifically, the proposed amendment would have revised Technical Specification 3.7.3, Action a, to extend the allowed outage time (AOT) for an inoperable ICW pump from 7 days to 14 days on a one-time basis. FPL anticipated that the 7-day AOT would not be met for the 3B ICW pump due to unexpected circumstances that arose during system maintenance. Subsequently, by letter dated May 22, 2006, FPL notified the U.S. Nuclear Regulatory Commission (NRC) staff that the work was able to be accelerated, thereby eliminating the need for the AOT extension, and withdrew the amendment request.

The NRC staff plans no further action on this request.

Sincerely,

/RA/

Brendan T. Moroney, Project Manager
Project Licensing Branch II-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-250

cc w/encl: See next page

May 26, 2006

Mr. J. A. Stall
Senior Vice President, Nuclear and
Chief Nuclear Officer
Florida Power and Light Company
P.O. Box 14000
Juno Beach, Florida 33408-0420

SUBJECT: TURKEY POINT PLANT, UNIT 3 - WITHDRAWAL OF EMERGENCY LICENSE
AMENDMENT REQUEST REGARDING INTAKE COOLING WATER PUMP
(TAC NO. MD1811)

Dear Mr. Stall:

By letter dated May 20, 2006, Florida Power & Light Company (FPL) applied for an emergency license amendment to the Turkey Point Unit 3 Facility Renewed Operating License No. DPR-31. The proposed change would have modified the facility technical specifications pertaining to the intake cooling water (ICW) pumps. Specifically, the proposed amendment would have revised Technical Specification 3.7.3, Action a, to extend the allowed outage time (AOT) for an inoperable ICW pump from 7 days to 14 days on a one-time basis. FPL anticipated that the 7-day AOT would not be met for the 3B ICW pump due to unexpected circumstances that arose during system maintenance. Subsequently, by letter dated May 22, 2006, FPL notified the U.S. Nuclear Regulatory Commission (NRC) staff that the work was able to be accelerated, thereby eliminating the need for the AOT extension, and withdrew the amendment request.

The NRC staff plans no further action on this request.

Sincerely,

/RA/

Brendan T. Moroney, Project Manager
Project Licensing Branch II-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-250

cc w/encl: See next page

Distribution:

PUBLIC	LPL2-2 R/F	RidsNrrDorLpl2-2	RidsNrrPMBMoroney
RidsNrrLABClayton		RidsOgcRp	RidsAcrsAcnwMailCenter
RidsRgn2MailCenter		RidsNrrDorIDpr	

ADAMS Accession No.: ML061450505

NRR-106

ORGANIZATION	LPL2-2/PM	LPL2-2/LA	LPL2-2/BC
NAME	BMoroney	BClayton	MMarshall
DATE	05/25/06	05/26/06	05/26/06

OFFICIAL RECORD COPY

Mr. J. A. Stall
Florida Power and Light Company

cc:

Mr. William E. Webster
Vice President, Nuclear Operations
Florida Power & Light Company
P.O. Box 14000
Juno Beach, FL 33408-0420

M. S. Ross, Managing Attorney
Florida Power & Light Company
P.O. Box 14000
Juno Beach, FL 33408-0420

Marjan Mashhadi, Senior Attorney
Florida Power & Light Company
801 Pennsylvania Avenue, NW.
Suite 220
Washington, DC 20004

T. O. Jones, Site Vice President
Turkey Point Nuclear Plant
Florida Power and Light Company
9760 SW. 344th Street
Florida City, FL 33035

County Manager
Miami-Dade County
111 Northwest 1 Street, 29th Floor
Miami, Florida 33128

Senior Resident Inspector
Turkey Point Nuclear Plant
U.S. Nuclear Regulatory Commission
9762 SW. 344th Street
Florida City, Florida 33035

Mr. William A. Passetti, Chief
Department of Health
Bureau of Radiation Control
2020 Capital Circle, SE, Bin #C21
Tallahassee, Florida 32399-1741

Mr. Craig Fugate, Director
Division of Emergency Preparedness
Department of Community Affairs
2740 Centerview Drive
Tallahassee, Florida 32399-2100

TURKEY POINT PLANT

Attorney General
Department of Legal Affairs
The Capitol
Tallahassee, Florida 32304

Michael O. Pearce
Plant General Manager
Turkey Point Nuclear Plant
Florida Power and Light Company
9760 SW. 344th Street
Florida City, FL 33035

Walter Parker
Licensing Manager
Turkey Point Nuclear Plant
9760 SW 344th Street
Florida City, FL 33035

Mark Warner, Vice President
Nuclear Operations Support
Florida Power and Light Company
P.O. Box 14000
Juno Beach, FL 33408-0420

Mr. Rajiv S. Kundalkar
Vice President - Nuclear Engineering
Florida Power & Light Company
P.O. Box 14000
Juno Beach, FL 33408-0420