

June 12, 2006

Mr. Gene F. St. Pierre, Site Vice President
c/o James M. Peschel
Seabrook Station
PO Box 300
Seabrook, NH 03874

SUBJECT: SEABROOK STATION, UNIT NO. 1 - CORRECTION OF AMENDMENT
NO. 108, SIX-MONTH EXTENSION FOR THE CONTAINMENT INTEGRATED
LEAKAGE RATE TEST INTERVAL (TAC NO. MC8549)

Dear Mr. St. Pierre:

On March 24, 2006, the Nuclear Regulatory Commission staff issued the subject amendment in response to your application transmitted by letter dated September 29, 2005. The amendment revised the Seabrook Station, Unit No. 1 (Seabrook) Technical Specifications (TSs). Specifically, the amendment revised the Seabrook TSs to permit a one-time, 6-month, addition to the currently-approved 5-year extension to the 10-year test interval for the containment integrated leak rate test

Subsequent to the issuance, your staff identified an error in the amended TS page. This error resulted from the issuance of another amendment during the review of Amendment No. 108 to Facility Operating License Number NPF-86 which affected the same TS page. The enclosed TS page 6-22 replaces the page included with the issuance of Amendment No. 108. We apologize if this error has caused you any inconvenience.

Sincerely,

/RA/

G. Edward Miller, Project Manager
Plant Licensing Branch I-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-443

Enclosure:
As stated

cc w/encl: See next page

June 12, 2006

Mr. Gene F. St. Pierre, Site Vice President
c/o James M. Peschel
Seabrook Station
PO Box 300
Seabrook, NH 03874

SUBJECT: SEABROOK STATION, UNIT NO. 1 - CORRECTION OF AMENDMENT
NO. 108, SIX-MONTH EXTENSION FOR THE CONTAINMENT INTEGRATED
LEAKAGE RATE TEST INTERVAL (TAC NO. MC8549)

Dear Mr. St. Pierre:

On March 24, 2006, the Nuclear Regulatory Commission staff issued the subject amendment in response to your application transmitted by letter dated September 29, 2005. The amendment revised the Seabrook Station, Unit No. 1 (Seabrook) Technical Specifications (TSs). Specifically, the amendment revised the Seabrook TSs to permit a one-time, 6-month, addition to the currently-approved 5-year extension to the 10-year test interval for the containment integrated leak rate test

Subsequent to the issuance, your staff identified an error in the amended TS page. This error resulted from the issuance of another amendment during the review of Amendment No. 108 to Facility Operating License Number NPF-86 which affected the same TS page. The enclosed TS page 6-22 replaces the page included with the issuance of Amendment No. 108. We apologize if this error has caused you any inconvenience.

Sincerely,

/RA/

G. Edward Miller, Project Manager
Plant Licensing Branch I-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-443

Enclosure:
As stated

cc w/encl: See next page

DISTRIBUTION:

RidsNrrDorlLp1-2
PUBLIC
LPL1-2 R/F
RidsNrrDorl

RidsOgcRp
RidsNrrPMGMiller
RidsNrrLACRaynor
GHill (2)

RidsRgn1MailCenter
RidsAcrsAcnwMailCenter

Package Accession Number: **ML061640077**

Letter Accession Number: **ML061460379**

Tech Spec. Accession Number: **ML06**

OFFICE	LPL1-2/PM	LPL1-2/LA	LPL1-2/BC
NAME	GEMiller	CRaynor	DRoberts
DATE	6/12/06	6/2/06	6/12/06

OFFICIAL RECORD COPY

Seabrook Station, Unit No. 1

cc:

Mr. J. A. Stall
Senior Vice President, Nuclear and
Chief Nuclear Officer
Florida Power & Light Company
P.O. Box 14000
Juno Beach, FL 33408-0420

Mr. Peter Brann
Assistant Attorney General
State House, Station #6
Augusta, ME 04333

Resident Inspector
U.S. Nuclear Regulatory Commission
Seabrook Nuclear Power Station
P.O. Box 1149
Seabrook, NH 03874

Town of Exeter
10 Front Street
Exeter, NH 03823

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Office of the Attorney General
One Ashburton Place, 20th Floor
Boston, MA 02108

Board of Selectmen
Town of Amesbury
Town Hall
Amesbury, MA 01913

Ms. Deborah Bell
Federal Emergency Management Agency
Region I
J.W. McCormack P.O. &
Courthouse Building, Room 401
Boston, MA 02109

Mr. Tom Crimmins
Polestar Applied Technology
One First Street, Suite 4
Los Altos, CA 94019

Mr. Stephen McGrail, Director
ATTN: James Muckerheide
Massachusetts Emergency Management Agency
400 Worcester Road
Framingham, MA 01702-5399

Philip T. McLaughlin, Attorney General
Steven M. Houran, Deputy Attorney
General
33 Capitol Street
Concord, NH 03301

Mr. Bruce Cheney, Director
New Hampshire Office of Emergency
Management
State Office Park South
107 Pleasant Street
Concord, NH 03301

Mr. M. S. Ross, Managing Attorney
Florida Power & Light Company
P.O. Box 14000
Juno Beach, FL 33408-0420

Mr. Rajiv S. Kundalkar
Vice President - Nuclear Engineering
Florida Power & Light Company
P.O. Box 14000
Juno Beach, FL 33408-0420

James M. Peschel
Regulatory Programs Manager
Seabrook Station
FPL Energy Seabrook, LLC
PO Box 300
Seabrook, NH 03874

Marjan Mashhadi
Senior Attorney
Florida Power & Light Company
801 Pennsylvania Ave., NW Suite 220
Washington, DC 20004

Seabrook Station, Unit No. 1

cc:

Mark Warner
Vice President, Nuclear Operations Support
Florida Power & Light Company
P.O. Box 14000
Juno Beach, FL 33408-0420