

**From:** Krzysztof Parczewski  
**To:** DJA1  
**Date:** 05/01/2006 1:50:59 PM  
**Subject:** Question to the applicant

**Mail Envelope Properties** (44564A7A.4C7 : 18 : 34874)

**Subject:** Question to the applicant  
**Creation Date:** 05/01/2006 1:50:50 PM  
**From:** Krzysztof Parczewski

**Created By:** KIP@nrc.gov

**Recipients**

nrc.gov

OWGWPO01.HQGWDO01

DJA1 (DJA1)

**Post Office**

OWGWPO01.HQGWDO01

**Route**

nrc.gov

**Files**

Oyster Creek LR-Q1.wpd

**Size**

2753

**Date & Time**

01 May, 2006 11:56:06 AM

**Options**

**Expiration Date:** None  
**Priority:** Standard  
**Reply Requested:** No  
**Return Notification:** None

**Concealed Subject:** No  
**Security:** Standard

In the response to RAI B.2.3-1 the applicant stated that :

"Stator cooling water conductivity is maintained less than 0.5  $\mu\text{S}/\text{cm}$ . The Generator shall be shutdown immediately if the stator cooling water conductivity reaches 10  $\mu\text{S}/\text{cm}$ ."

The value for the generator shutdown is therefore 20 times higher than the allowable maximum water conductivity . What is the basis for such a large divergence between these two values?

**File: Oyster Creek LR-Q1.wpd**