

**From:** D. Ashley  
**To:** John Hufnagel  
**Date:** 04/13/2006 3:32:04 PM  
**Subject:** request to add to database.

John, George-

Attached are the subject questions from the Audit Team Leader.

He requests that you add to the Q&A Database and include in your next update for ADAMS addition.

=====  
regards,

Donnie Ashley  
NRR/DLR/RLRA  
Oyster Creek  
License Renewal Project Manger  
301-415-3191  
dja1@nrc.gov

**Mail Envelope Properties** (443EA734.9DF : 9 : 10848)

**Subject:** request to add to database.  
**Creation Date:** 04/13/2006 3:32:04 PM  
**From:** D. Ashley

**Created By:** DJA1@nrc.gov

| <b>Recipients</b>   | <b>Action</b> | <b>Date &amp; Time</b> |
|---|---------------|------------------------|
| exeloncorp.com<br>3:32:33 PM<br>john.hufnagel (John Hufnagel) | Transferred   | 13 April, 2006         |

| <b>Post Office</b> | <b>Delivered</b> | <b>Route</b>   |
|--------------------|------------------|----------------|
|                    |                  | exeloncorp.com |

| <b>Files</b>   | <b>Size</b> | <b>Date &amp; Time</b>    |
|--|-------------|---------------------------|
| MESSAGE  | 1204        | 13 April, 2006 3:32:04 PM |
| Flaw EvaluationIf a relevant indication is.wpd<br>2:56:22 PM | 6152        | 13 April, 2006            |
| D. Ashley.vcf  | 232         | 13 April, 2006 3:32:07 PM |

**Options**

**Auto Delete:** No  
**Expiration Date:** None  
**Notify Recipients:** Yes  
**Priority:** Standard  
**Reply Requested:** No  
**Return Notification:** None

**Concealed Subject:** No  
**Security:** Standard

**To Be Delivered:** Immediate  
**Status Tracking:** Delivered & Opened

## Flaw Evaluation

- If a relevant indication is discovered during a Section XI ISI inspection, and the flaw is dispositioned by analysis, a TLAA will be conducted to determine if the flaw will exceed the acceptance criteria during the life of the component.
- If the flaw exceeds the acceptance criteria, and the decision is made to embed the flaw using a weld overlay, the embedded flaw, it results in the creation of a new TLAA.
- **Has Oyster Creek dispositioned any relevant indications by analysis and has Oyster Creek conducted a TLAA for the relevant indication?**
- **Has Oyster Creek used a weld overlay to embed any relevant indications and have they conducted a TLAA for this situation?**